

MEMORANDUM

RECEIVED-FPSC

June 14, 2000

00 JUN 14 AM 10:46

RECORDS AND
REPORTING

TO: DIVISION OF RECORDS AND REPORTING
FROM: DIVISION OF LEGAL SERVICES (ISAAC) *RVE*
RE: DOCKET NO. 000678 - COMPLAINT AGAINST FLORIDA POWER &
LIGHT COMPANY REGARDING PLACEMENT OF POWER POLE AND LINES
BY PABLO ACOSTA

Please add the three e-mails to the docket file for the above-referenced docket.

RNI
Attachment

RGU
SEC
SER
QMH

DOCUMENT NUMBER-DATE

07266 JUN 14 8

FPSC-RECORDS/REPORTING

Carmen Pena

From: Roseanne_Lucas@fpl.com
Sent: Thursday, April 27, 2000 9:27 AM
To: lrasberr@psc.state.fl.us; cpena@psc.state.fl.us
Subject: Reply to Questions on Pedro Acosta Complaint

Good Morning,

Leroy and Carmen, the following are the responses (in red) to the questions we discussed yesterday:

1.) Has this type of installation and type of pole been installed in any other residential areas? If so, indicate area and provide name of streets where installed. (are pole sizes the exact same size?) Are pictures available?

Yes, this type of installation has been installed in various residential neighborhoods in Sweetwater, Miami Beach and Coral Gables. The locations are:

SW 7 Terrace, Sweetwater larger)	(Pole is
Riviera Drive, Coral Gables the same size)	(Pole is
Granada Blvd , Coral Gables the same size)	(Pole is
N Venetian Way, Miami Beach larger)	(Pole is
N Venetian Way, Miami Beach same size)	(Pole is

Pictures are available for the locations and will be available at the Informal Conference.

2.) If this type of installation and type of pole have been installed in other areas, were there any problems? If there were problems, indicate how they were resolved.

These poles have been installed for several years and there were no problems associated with the installation of these poles.

3.) Was this installation done in order to provide service to a mall located in the vicinity, or was it an upgrade? Please explain.

All of the installations were a result of a system upgrade to accommodate for load growth in the area.

Please let me know if you need anything further.

Thanks

Rachael Isaac

From: Roseanne_Lucas@fpl.com
Sent: Thursday, June 01, 2000 11:30 AM
To: risaac@psc.state.fl.us
Subject: Acosta

Rachal,

Per your request for additional information on 5/31, regarding grounding and possible electric discharge, the following is provided:

FPL installs all of its facilities, as per the NESC, using a multi-grounded system. This means that all hardware is intentionally connected to earth through a ground connection or connections of sufficiently low impedance and having sufficient current-carrying capacity to limit the buildup of voltages to levels below that which may result in undue hazard to persons or to connected equipment. Under normal conditions, this will prevent electrical discharges from occurring.

Please let me know if you need anything further.

Rachael Isaac

From: Leroy Rasberry
Sent: Friday, June 09, 2000 12:55 PM
To: Rachael Isaac
Cc: 'Roseanne_Lucas@fpl.com'; Leroy Rasberry
Subject: RE: Pablo Acosta

Thanks Roseanne.

Rachael,

Below is FPL's direct response to you question about using the alley way behind the homes in Pablo Acosta's neighborhood.

-----Original Message-----

From: Roseanne_Lucas@fpl.com [mailto:Roseanne_Lucas@fpl.com]
Sent: Friday, June 09, 2000 10:09 AM
To: lrasberr@psc.state.fl.us
Subject: re: Pablo Acosta

In response to your Voice Mail message last night the following information is being provided:

The reason FPL did not consider using the alley way behind the homes on SW 27 Terrace is because there is not an existing pole line behind the homes, therefore, there are no existing easements.

In addition, the configuration of the homes along SW 27 Terrace and the related side streets would not make this a viable option, even if FPL could have obtained easements from each of the customers.

Please let me know if you have any further concerns or questions.