

AUSLEY & McMULLEN

ATTORNEYS AND COUNSELORS AT LAW

227 SOUTH CALHOUN STREET
P.O. BOX 391 (ZIP 32302)
TALLAHASSEE, FLORIDA 32301
(850) 224-9115 FAX (850) 222-7560

ORIGINAL

August 20, 2002

HAND DELIVERED

Ms. Blanca S. Bayo, Director
Division of Commission Clerk
and Administrative Services
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

RECEIVED FPSC
AUG 20 PM 2:31
COMMISSION
CLERK

020000 - PU

Re: Load Research Sampling Report - Tampa Electric Company


Dear Ms. Bayo:

In compliance with Rule 25-6.0437, enclosed are five copies of Tampa Electric Company's report entitled Load Research Sampling Plan - August 2002.

Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Thank you for your assistance in connection with this matter.

Sincerely,


James D. Beasley

JDB/pp
Enclosures

cc: Angela Llewellyn

AUS _____
CAF _____
CMP _____
COM _____
CTR _____
ECR _____
GCL _____
OPC _____
MMS _____
SEC 1 _____
OTH _____

RECEIVED & FILED
RLM
FPSC-BUREAU OF RECORDS

DOCUMENT NUMBER-DATE

08773 AUG 20 02

FPSC-COMMISSION CLERK

TAMPA ELECTRIC COMPANY
LOAD RESEARCH SAMPLING PLAN
AUGUST 2002

TABLE OF CONTENTS

Applicable Rate Classes 3
Existing Sample Design..... 4
Existing Sample Accuracy..... 6
Proposed Sampling Plan..... 7
Continuous Overlapping Sample 8
Formulas and Definitions 9

APPLICABLE RATE CLASSES

Table 1 lists Tampa Electric Company's rate classes. The third column shows the percent of total annual sales for each rate class and shows that the company is complying with Florida Administrative Code Chapter 25-6.0437, which requires sampling of all rate classes that account for more than one percent of a utility's annual sales. The annual sales reported are for the twelve month period ending December 31, 2001.

TABLE 1
PERCENTAGE OF ANNUAL MWH SALES BY RATE

RATE	ANNUAL SALES (MWH)	PERCENTAGE OF TOTAL SALES
Residential (RS & RST)	7,575,338	44.6
General Service Non-Demand (GS, GST, TS)	962,535	5.7
General Service Demand (GSD & GSDT)	4,661,746	27.5
General Service Large Demand (GSLD, GSLDT, SBFT)	2,006,086	11.8
Interruptible Service (IS-1, IST-1, IS-3, IST-3, SBIT-1, SBIT-3)	1,593,732	9.4
All Other Rate Classes	176,609	1.0
Total	16,976,046	100.0

Each of the rates listed in Table 1 was monitored during 2001 as part of Tampa Electric Company's ongoing load research program. The two overlapping samples for the Residential (RS), General Service Non-Demand (GS), and General Service Demand (GSD) classes were selected in 1999 and 2000 and in most cases the recording equipment was installed prior to December 31 of the year during which the sample was selected. Samples for the General Service Large Demand (GSLD) and Interruptible Service (IS) classes are not necessary since all of the Customers on these rates have recorders installed on their meters for billing purposes. The data collected by these recorders is used for load research purposes. Under this plan the collection of load data for the GSLD and IS classes in this manner will continue.

EXISTING SAMPLE DESIGN

The RS sample was pre-stratified by housing type. The three housing type categories are single family detached, multi-family, and mobile home. The primary reasons for using this stratification were that the load patterns for the three housing types are dissimilar and the percentage of mobile homes in the population changes significantly with the seasons. The percentage of mobile homes ranged from a high of 12.6% in the winter to a low of 11.9% in the summer. The housing type stratification allows corresponding changes to be made in stratum weights (since inter-strata migration is not a concern) on a month-by-month basis when estimating class demands. The estimated demands thus reflect the seasonal changes in the housing type mix.

The sample points were allocated to the strata using Neyman allocation with stratum variances estimated from previous sample results. A minimum sample size of 50 was used in the multi-family and mobile home categories to allow generating more accurate data for these sub-populations. The resulting allocation is shown in Table 2.

TABLE 2

RS SAMPLE

Stratum	Sample Size 1999	Sample Size 2000	Total
Single Family Detached	87	88	175
Multi Family	25	25	50
Mobile Home	25	25	50
Total	137	138	275

The GS class was stratified on the basis of annual kilowatt-hour consumption at the time of sample selection. Two strata were used with the boundary being 15,000 kWh. The sample points were allocated to the strata using Neyman allocation with stratum variances estimated from the previous sample results. The allocation is shown in Table 3.

TABLE 3

GS SAMPLE

Stratum	Sample Size 1999	Sample Size 2000	Total
0 – 14,999 kWh	128	129	257
15,000 – infinity kWh	121	122	243
Total	249	251	500

The GSD class was stratified by several different variables. The first variable was service voltage level; the GSD class contains Customers served at either primary voltage or secondary voltage. Voltage level stratification was used to facilitate analysis required for performing cost of service studies. All Customers served and/or metered at primary voltage were included in the sample. Among secondary Customers an additional 100% sampled stratum was included in the sample design; Customers having demands over 300 kW are included in this stratum. During the course of the data collection for this sample, new Customers meeting the criteria of these 100% sampled strata were added to the sample. The remaining GSD Customers were stratified into two strata on the basis of their highest demand in the twelve-month period prior to sample selection. The stratum boundary used was 200 kW. Sample points were allocated to these two strata using Neyman allocation with variances being estimated from the preceding sample. The allocation shown in Table 4 reflects the sample as of December 2001.

TABLE 4

GSD SAMPLE

Stratum	Sample Size 1999	Sample Size 2000	Total
Primary Metered/Primary Served	72 (100%)		72
Primary Metered/Secondary Served	40 (100%)		40
Secondary under 400 kW			
0 – 199 kW	35	35	70
200 – 399 kW	35	35	70
Secondary over 399 kW	940 (100%)		940
Total	1122	1122	1192

EXISTING SAMPLE ACCURACY

The accuracy achieved for the three sampled classes was calculated for each month's coincident peak for 2001 and for the average of the twelve monthly coincident peaks as well. The accuracy for each class was calculated in the conventional manner for combined ratio analysis. The results are shown in Table 5.

TABLE 5
2001 COINCIDENT PEAK PERCENTAGE ACCURACIES
AT 90% CONFIDENCE LEVEL USING COMBINED
RATIO ESTIMATION

Month	RS	GS	GSD
January	5.5	9.8	6.8
February	7.2	10.2	5.8
March	6.4	7.8	5.5
April	5.1	6.9	4.8
May	5.4	6.1	3.8
June	3.7	7.0	3.3
July	5.1	6.0	3.8
August	3.5	5.9	3.9
September	4.7	5.0	3.6
October	4.5	6.3	3.9
November	6.7	8.2	3.8
December	6.6	6.8	4.7
12 Coincident Peak Average	2.0	3.3	2.5

The 2001 annual system winter peak occurred in January, and the summer peak occurred in August. All three samples achieved better accuracy than the target of $\pm 10\%$ accuracy at the 90% confidence limit for the winter coincident peak, the summer coincident peak and for the 12 coincident peak average.

PROPOSED SAMPLING PLAN

The RS, GS and GSD samples all met the required levels of accuracy for 2001; therefore, no changes in these sample designs are required. Proposed sample allocations for these classes remain the same as filed in the 2000 Load Research Sampling Plan and are shown in the tables below.

TABLE 6

PROPOSED RS SAMPLE

Stratum	Sample Size 2001	Sample Size 2002	Total
Single Family Detached	87	88	175
Multi Family	25	25	50
Mobile Home	25	25	50
Total	137	138	275

TABLE 7

PROPOSED GS SAMPLE

Stratum	Sample Size 2001	Sample Size 2002	Total
0 – 14,999 kWh	128	129	257
15,000 – infinity kWh	121	122	243
Total	249	251	500

TABLE 8
PROPOSED GSD SAMPLE

Stratum	Sample Size 2001	Sample Size 2002	Total
Secondary 0 – 199 kW	35	35	70
Secondary 200 –300 kW	35	35	70
Secondary over 300 kW	940 (100%)		940
Primary Metered/Primary Served	72 (100%)		72
Primary Metered/Secondary Served	40 (100%)		40
Total	1122	1122	1192

CONTINUOUS OVERLAPPING SAMPLES

As outlined in the 2000 Tampa Electric Company Load Research Sampling Plan, we are proposing to continue using the overlapping sampling methodology for all three of the sampled rate classes, RS, GS and GSD.

The half-sized RS, GS, and GSD samples selected and installed in 2000 will be removed and replaced with samples selected and installed prior to December 31, 2002. This follows the schedule of data being collected from each half-sample for twenty-four months. Once the new, independent samples are fully installed and data collection has begun, the oldest previously selected samples will be retired and removed. Thus, for any given month, two independent samples will be available to produce population estimates. For computing annual statistics, in particular the average of the twelve coincident peaks, estimates from two or three independent, overlapping samples will be combined. The sample size for each new sample will be sufficiently large, when used in combination with the existing sample(s), to achieve an expected accuracy of $\pm 10\%$ at the 90% confidence level for the summer and winter coincident peaks and for the average of the twelve monthly coincident peaks.

FORMULAS AND DEFINITIONS

Combined Ratio Estimate

$$\hat{R}_c = \frac{\sum_h W_h \bar{y}_h}{\sum_h W_h \bar{x}_h}$$

Where

\hat{R}_c = combined ratio estimate
 W_h = stratum weight for stratum h
 \bar{y}_h = mean coincident demand for stratum h
 \bar{x}_h = mean billed energy for stratum h

Coincident Peak Estimate

$$\hat{Y}_{rc} = \hat{R}_c X$$

Where

\hat{R}_c = combined ratio estimate
 \hat{Y}_{rc} = estimated class total coincident peak
 X = class total billed energy

Standard Deviation of Sample Residuals

$$s_{dh}^2 = \frac{\sum_{i=1}^{n_h} (y_{hi} - \hat{R}_c x_{hi})^2}{n_h - 1}$$

Where

\hat{R}_c = combined ratio estimate
 n_h = sample size for stratum h
 s_{dh} = standard deviation of sample residuals
 y_{hi} = coincident demand for sample Customer i of stratum h
 x_{hi} = billed energy for Customer i of stratum h

Variance of Coincident Peak Estimate

$$\hat{V}(\hat{Y}_{rc}) = \sum_h \frac{N_h^2 \left(1 - \frac{n_h}{N_h}\right)}{n_h} s_{dh}^2$$

Where

$\hat{V}(\hat{Y}_{rc})$ = variance of coincident estimate
 N_h = population size for stratum h
 n_h = sample size for stratum h
 s_{dh} = standard deviation of sample residuals

Accuracy at 90% Confidence Level

$$A = \frac{1.645 \sqrt{\hat{V}(\hat{Y}_{rc})}}{\hat{Y}_{rc}}$$

Where

\hat{Y}_{rc} = estimated class total coincident peak
 $\hat{V}(\hat{Y}_{rc})$ = variance of coincident estimate
 A = accuracy at 90% confidence level

Sample Size

$$n = \frac{\left(\sum_h W_h s_{dh}\right)^2}{\left(\frac{d}{1.645}\right)^2 \left(\frac{\hat{Y}_{rc}}{N}\right)^2}$$

Where

W_h = stratum weight for stratum h
 \hat{Y}_{rc} = estimated class total coincident peak
 N = population size
 s_{dh} = standard deviation of sample residuals
 n = total sample size
 d = desired relative accuracy

Sample Allocation (Neyman)

$$n_h = n \frac{W_h S_{dh}}{\sum_h W_h S_{dh}}$$

Where

W_h = stratum weight for stratum h
 n_h = sample size for stratum h
 S_{dh} = standard deviation of sample residuals
 n = total sample size

Twelve Coincident Peak Estimate

$$12\hat{CP} = \frac{1}{12} \sum_{m=1}^{12} \hat{Y}_{rcm}$$

Where

\hat{Y}_{rcm} = Coincident Peak Estimate for Month M

Variance Of Twelve Coincident Peak

$$VAR(12\hat{CP}) = \left(\frac{1}{12}\right)^2 \left(\sum_{m=1}^{12} \hat{V}(\hat{Y}_{rcm}) + 2 \sum_{m=1}^{12} \sum_{k < m} \hat{C}(\hat{Y}_{rcm}, \hat{Y}_{rck}) \right)$$

Where

$\hat{V}(\hat{Y}_{rcm})$ = Variance of Coincident Peak Estimate Month m
 $\hat{C}(\hat{Y}_{rcm}, \hat{Y}_{rck})$ = Covariance of Month m and Month k Estimates

Month-To-Month Covariance

$$\hat{C}(\hat{Y}_{rcm}, \hat{Y}_{rck}) = \sum_{h=1}^L \frac{N_{hm} N_{hk}}{\bar{n}_{hmk}} (fpc_{mk}) s_{hdmdk}$$

Where

N_{hm} = Population Size in Month m

N_{hk} = Population Size in Month k

\bar{n}_{hmk} = Average Sample Size in Months m and k

$$fpc_{mk} = 1 - \min\left(\frac{n_m}{N_m}, \frac{n_k}{N_k}\right)$$

$$s_{hdmdk} = \sum_{i=1}^{n_{hmk}} \frac{(y_{hmi} - \hat{R}_m x_{hmi})(y_{hki} - \hat{R}_k x_{hki})}{n'_{hmk} - 1}$$

n'_{hmk} = Sample Size with good data in Month m and k

Combining Estimates From Two Samples

$$\hat{Y}_{rc} = \alpha \hat{Y}_{rcA} + (1 - \alpha) \hat{Y}_{rcB}$$

Where

\hat{Y}_{rcA} = Sample A Estimate

\hat{Y}_{rcB} = Sample B Estimate

α = Weighting factor

Combining Variances From Two Samples

$$\hat{V}(\hat{Y}_{rc}) = \alpha^2 \hat{V}(\hat{Y}_{rcA}) + (1 - \alpha)^2 \hat{V}(\hat{Y}_{rcB})$$

Where

$\hat{V}(\hat{Y}_{rcA})$ = Variance of Sample A Estimate

$\hat{V}(\hat{Y}_{rcB})$ = Variance of Sample B Estimate

α = Weighting factor

Weight To Obtain Minimum Variance

$$\alpha = \frac{\hat{V}(\hat{Y}_{rcA})}{\hat{V}(\hat{Y}_{rcA}) + \hat{V}(\hat{Y}_{rcB})}$$

Where

$\hat{V}(\hat{Y}_{rcA}) = \text{Variance of Sample A Estimate}$

$\hat{V}(\hat{Y}_{rcB}) = \text{Variance of Sample B Estimate}$

$\alpha = \text{Weighting factor}$

Twelve Coincident Peak -- Three Samples Equal / Weighting

$$12\hat{C}P = \left(\frac{1}{24}\right) \left(\sum_{m=1}^l \hat{Y}_{mA} + \sum_{m=1}^{12} \hat{Y}_{mB} + \sum_{m=l+1}^{12} \hat{Y}_{mC} \right)$$

Where

Sample A is in place for the first l months, sample B is in place for all 12 months and sample C is in place for the last $12 - l$ months.

$\hat{Y}_{mA} = \text{Sample A Estimate for Month } m$

$\hat{Y}_{mB} = \text{Sample B Estimate for Month } m$

$\hat{Y}_{mC} = \text{Sample C Estimate for Month } m$

Variance Of Twelve Coincident Peak

$$\begin{aligned} VAR(12\hat{C}P) = & \left(\frac{1}{24}\right)^2 \left\{ \sum_{m=1}^l \hat{V}(\hat{Y}_{rcmA}) + 2 \sum_{m=1}^l \sum_{k=1 < m}^l \hat{C}(\hat{Y}_{rcmA}, \hat{Y}_{rckA}) \right\} \\ & + \left(\frac{1}{24}\right)^2 \left\{ \sum_{m=1}^{12} \hat{V}(\hat{Y}_{rcmB}) + 2 \left(\sum_{m=1}^{12} \sum_{k=1 < m}^{12} \hat{C}(\hat{Y}_{rcmB}, \hat{Y}_{rckB}) \right) \right\} \\ & + \left(\frac{1}{24}\right)^2 \left\{ \sum_{m=l+1}^{12} \hat{V}(\hat{Y}_{rcmC}) + 2 \sum_{m=l+1}^{12} \sum_{k=l+1 < m}^{12} \hat{C}(\hat{Y}_{rcmC}, \hat{Y}_{rcnC}) \right\} \end{aligned}$$