

ORIGINAL



16554 Crossings Boulevard - Suite No. 2  
Clermont, Florida 34711

RECEIVED-FPSC

04 JAN 12 AM 10:15

COMMISSION  
CLERK

January 7, 2004

Ms. Blanca Bayo  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, Florida 32399-0850

640000-Pu

Re: Filing Developer Agreement for Southlake Utilities, Inc.

Dear Ms. Bayo:

Pursuant to Rule 25-30.550, Florida Administrative Code, Southlake Utilities, Inc. ("Southlake"), hereby files with the Florida Public Service Commission ("Commission") the following developer agreement:

Colony Communities, a Florida general partnership by Colony Communities, Inc., a Delaware corporation as a partner

Colony Communities has reserved 82 ERC's or 0.028700 MGD for domestic water capacity and 82 ERC's or 0.024600 MGD for wastewater capacity.

Southlake Water Treatment Plant has a capacity of 2.916 MGD and the current 3 month average daily flow is 1.164 MGD. Southlake Wastewater Treatment Plant has a capacity of 0.600 MGD and the current 3 month average daily flow is 0.520 MGD.

Southlake has filed a replacement tariff with the Commission. Unlike its previous tariff, the new tariff does not include a standard developer agreement in the service availability policy section of the tariff. The enclosed developer agreement is not based upon the old developer agreement, but upon the replacement tariff and the Commission's orders changing Southlake's service availability charges, including changes to plant capacity charges and Allowance for Funds Prudently Invested Charges.

Please call me at (352) 636-8072 if you have any questions.

Sincerely,

  
Randall W. Corbin  
Manager

Copy: Developer File

- AUS \_\_\_\_\_
- CAF \_\_\_\_\_
- CMP \_\_\_\_\_
- COM \_\_\_\_\_
- CTR \_\_\_\_\_
- ECP** \_\_\_\_\_
- GCL \_\_\_\_\_
- OPC \_\_\_\_\_
- MMS \_\_\_\_\_
- SEC   1
- OTH \_\_\_\_\_

SEARCHED INDEXED

81 3 11 21 NOV 2003

DOCUMENT NUMBER-DATE

00450 JAN 12 3

FPSC-COMMISSION CLERK