



Davis Wright Tremaine LLP

ANCHORAGE BELLEVUE LOS ANGELES NEW YORK PORTLAND SAN FRANCISCO SEATTLE SHANGHAI WASHINGTON, D.C.

MARIA BROWNE
 DIRECT (202) 973-4281
 MariaBrowne@dwt.com

SUITE 200
 1919 PENNSYLVANIA AVENUE, N.W.
 WASHINGTON, D.C. 20006-3402

TEL (202) 973-4200
 FAX (202) 973-4499
 www.dwt.com

September 7, 2007

Via Hand Delivery

Ms. Ann Cole
 Commission Clerk
 Florida Public Service Commission
 2540 Shumard Oak Boulevard
 Tallahassee, FL 32399-0850


RECEIVED FPSC
 07 SEP - 7 PM 4: 58
 COMMISSION
 CLERK

Re: **Docket No. 070299-EI**
Review of 2007 Electric Infrastructure Storm Hardening Plan Filed Pursuant To Rule 25-6.0342, Florida Administrative Code, Submitted by Gulf Power Company

Dear Ms. Cole:

Enclosed for filing in the above matter are an original and 15 copies of the Direct Testimony of Michael T. Harrelson on behalf of Florida Cable Telecommunications Association, Inc. Service has been made as indicated on the Certificate of Service. If there are any questions regarding this filing, please contact me at 202-973-4281.

Sincerely,


 Maria T. Browne
 John D. Seiver

Enclosures

- CMP 2
- COM 5
- CTR 1
- ECR
- GCL 2
- OPC
- RCA 1
- SCR
- SGA
- SEC
- OTH

DOCUMENT NUMBER-DATE

08150 SEP-7 5

FPSC-COMMISSION CLERK

CERTIFICATE OF SERVICE

I hereby certify that a true copy of the foregoing *Direct Testimony of Michael T. Harrelson* on behalf of *Florida Cable Telecommunications Association, Inc.* was furnished by regular U.S. mail, on this the 7th day of September, 2007 to the following:

Lorena Holley, Senior Attorney
Keino Young, Esquire
Adam Teitzman, Esquire
Rick Mann, Esquire
Florida Public Service Commission
Division of Legal Services
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399

J.Meza/E.Edenfield/J. Kay/T. Hatch
P.Carver/M.Gurdian
c/o Nancy H. Sims
AT&T Florida
150 South Monroe Street
Suite 400
Tallahassee, FL 32301-1556

John T. Butler
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408-0420

Mr. Bill Walker
Florida Power & Light Company
215 South Monroe Street
Suite 810
Tallahassee, FL 32301-1859

Jeffrey Stone
Russell Badders
S. Griffin
Beggs & Lane Law Firm
P.O. Box 12950
Pensacola, FL 32591

Ms. Susan D. Ritenour
Gulf Power Company
One Energy Place
Pensacola, FL 32520-0780

Mr. Paul Lewis, Jr.
Progress Energy Florida, Inc.
106 East College Avenue, Suite 800
Tallahassee, FL 32301-7740

John T. Burnett
Progress Energy Service Company, LLC
P.O. Box 14042
St. Petersburg, FL 33733-4042

Lee L. Willis
James D. Beasley
Ausley Law Firm
Post Office Box 391
Tallahassee, FL 32302

Tampa Electric Company
Ms. Paula K. Brown
Regulatory Affairs
P.O. Box 111
Tampa, FL 33601-0111

Dulaney L. O'Roark III
Verizon Florida LLC
6 Concourse Parkway
Suite 600
Atlanta, GA 30328

Mr. David Christian
Verizon Florida LLC
106 East College Avenue
Suite 710
Tallahassee, FL 32301-7721

Richard Jackson
City of Panama City Beach and PCB Comm.
Redevelop Agency
110 South Arnold Road
Panama City Beach, FL 32413

Douglas J. Sale
Harrison Law Firm
Post Office Drawer 1579
Panama City, FL 32402-1579

Susan S. Masterton
Embarq Florida, Inc.
Mailstop: FLTLHO0102
1313 Blair Stone Rd.
Tallahassee, FL 32301

Robert Scheffel Wright
John T. LaVia, III
Young van Assenderp, P.A.
225 South Adams Street
Suite 200
Tallahassee, Florida 32301

H. M. Rollins, P.E.
c/o H. M. Rollins Company, Inc.
P.O. Box 3471
Gulfport, MS 39505

Dennis Hayward
North American Wood Pole Council
7017 NE Highway 99, Suite 108
Vancouver, WA 98665

Howard E. Adams
Peter M. Dunbar
Time Warner Telecom of Florida, LP
c/o Pennington Law Firm
P.O. Box 10095
Tallahassee, FL 32302-2095


Hon. Charles Falcone, Mayor
c/o Donald R. Hubbs, Asst. Town
Manager
Town of Jupiter Island
Post Office Box 7
Hobe Sound, FL 33475

Thomas G. Bradford, Deputy Town Mgr
Town of Palm Beach, Florida
360 South County Road
Palm Beach, FL 33480

Colentha Wilson
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Susan D. Ritenour
Gulf Power Company
One Energy Place
Pensacola, Florida 32520-0780

Charles J. Beck, Esquire
Office of Public Counsel
c/o The Florida Legislature
111 West Madison Street, Room 812
Tallahassee, Florida 32399



Maria T. Browne
John D. Seiver
Davis Wright Tremaine LLP
1919 Pennsylvania Ave., NW, Suite 200
Washington, D.C. 20006
Tel: (202) 973-4200
Fax: (202) 973-4499

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

**Review of 2007 Electric Infrastructure
Storm Hardening Plan Filed pursuant to
Rule 25-6.0342, F.A.C., Submitted by Gulf
Power Company.**

Docket No. 070299-EI

**DIRECT TESTIMONY OF MICHAEL T. HARRELSON ON BEHALF OF FLORIDA
CABLE TELECOMMUNICATIONS ASSOCIATION, INC.**

SEPTEMBER 7, 2007

1 **Introductory Issues**

2 Q. Please state your name, title, and business address.

3 A. My name is Michael T. Harrelson. I am a registered professional engineer (Electrical), and an
4 engineering consultant.

5 Q. On whose behalf are you filing this testimony?

6 A. I am appearing on behalf of the Florida Cable Telecommunications Association, Inc.
7 (“FCTA”), an intervenor in this proceeding.

8 Q. Would you please summarize your education, experience and qualifications?

9 A. Certainly. I have Bachelor of Science in Industrial Engineering from Georgia Tech where I
10 was a co-op student while working for Georgia Power Company. I started working at
11 Georgia Power in electric distribution in their co-op program where I also began work toward
12 my B.S. when I was 18, in 1963. I was at Georgia Power in various districts and in various
13 capacities of electric distribution, engineering, construction and maintenance until 1992. In
14 1992 I began a carrier as an Engineering Consultant. I am a registered professional engineer
15 in Georgia and Florida. A more detailed rendering of my work history is included in my CV
16 which is attached as MTH-1.

17 Q. Have you had any experience in working with joint use of electric distribution poles by
18 communications companies?

19 A. Yes. I have had extensive experience in this area.

20 Q. Do you have knowledge of the National Electrical Safety Code (“NESC”)?

21 A. Yes I do. The NESC is the national safety standard for electric supply stations and
22 electric supply and communication lines. The current edition is ANSI C2-2007, ISBN
23 No. 0-7381-4893-8. The purpose of the NESC is the practical safeguarding of persons
24 during the installation, operation, or maintenance of electric supply and communication

1 lines and associated equipment. This code is not intended as a design specification or as a
2 construction manual. The NESC rules contain the basic provisions that are considered
3 necessary for the safety of employees and the public under the specified conditions. If the
4 responsible party wishes to exceed these rules, it may do so for his own purposes, but
5 need not do so for safety purposes. NESC compliance is mandatory in Florida for electric
6 power and communications companies.

7 Q. Do you consider yourself knowledgeable in these areas?

8 A. Yes. I consider myself to be an expert in the NESC and its application..

9 Q. Why is that?

10 A. I worked for Georgia Power Company for a total of 27 years, including during the late
11 1960s and early 1970s when the first cable television systems were built in Georgia, and
12 elsewhere around the country. Because I worked for Georgia Power until 1992, I also
13 witnessed the upgrade and rebuild of improved generations of cable television systems
14 and saw how both cable companies and pole owners, including power companies, work
15 together to complete these system upgrades and rebuilds. Since retiring from Georgia
16 Power I have worked as a consulting engineer and an expert witness to electric companies,
17 cable companies and others.

18 Q. Have you ever been qualified as an expert witness?

19 A. Yes.

20 Q. In what subjects or fields have you been so qualified?

21 A. I have been qualified as an expert in (1) the NESC requirements; (2) electric power
22 distribution design, construction, engineering, operation, and maintenance procedures; (3)
23 joint use of utility poles by power and communications companies; (4) OSHA electric
24 power and communications safety regulation; and (5) the National Electric Code, which
25 applies to electric power utilization systems.

1 Q. On how many occasions have you given testimony as an expert witness in these areas?

2 A. I have testified in deposition or at trial approximately 41 times in the past 18 years. I
3 testified in a pole attachment dispute before the Utah Public Service Commission in a
4 matter closely related to some issues in this proceeding. That dispute involved attachment
5 permitting procedures, engineering guidelines for attachments, and interpretations of the
6 NESC. In addition, in a similar dispute in Arkansas, I submitted written testimony to the
7 Federal Communications Commission (“FCC”) and participated in a mediation session
8 before the FCC. I have also submitted written comments to the Louisiana Public Service
9 Commission in a proceeding to reconsider regulations regarding pole attachment
10 procedures in the state. Moreover, in the spring of last year I gave deposition testimony,
11 submitted direct testimony and testified live on cross examination before the Chief
12 Administrative Law Judge (“ALJ”) at the FCC on behalf of the FCTA and four of its
13 member operators. The issue in that proceeding was whether Gulf Power was entitled to
14 charge pole attachment rates in excess of rates calculated using the FCC formula for cable
15 operator attachments based on, among other things, Gulf Power’s claim that its poles were
16 “full” and that no capacity for further attachments existed. I testified that safe and
17 customary engineering practices, based on my years of experience and the NESC,
18 demonstrated that Gulf Power’s poles had capacity and the Chief ALJ agreed. The matter
19 is now on appeal.

20 I also participated in the Florida Public Service Commission (“FPSC” or the
21 “Commission”) rulemaking proceeding in Dockets Nos. 060172-EU and 060173-EU,
22 through which Rule 25-6.0342, Florida Administrative Code (“F.A.C.”), was developed.
23 Furthermore, I submitted Comments to this Commission in the Storm Preparedness
24 proceeding, Docket No. 060198-EI.

25

1 Q. Do you have additional relevant experience?

2 A. Yes. I have participated in more than 100 pieces of litigation or accident investigations as
3 a consultant.

4 Q. Are there other aspects of your training and background that may be relevant to your
5 testimony?

6 A. Yes. In addition to working in this industry for quite a number of years, I regularly attend
7 conferences on joint use, conduct training sessions and conduct pole-line inspections for
8 pole owners like electric utilities, not unlike the inspections that are, at least in part, at
9 issue in this proceeding. Through these activities I am very familiar not only with
10 standard industry practices as they relate to outside aerial utility plant and joint use, but I
11 am also very familiar with the trends and “state-of-the-art” of utility and communications
12 company practices in this area.

13 Q. Do you have experience with hurricanes in South Florida?

14 A. Yes. I worked in South Florida for an electric cooperative in restoration of service after
15 Hurricanes Jean, Francis, Charlie and Wilma. I personally observed the destruction of
16 trees and buildings and their impact on distribution lines, as well as the poles leaning in
17 softened soil and cascading failures caused by one pole being broken that resulted in
18 several more poles being broken. I saw places where several poles broke and fell in one
19 direction but several adjacent poles in the same line fell in the opposite direction
20 indicating tornado type winds in localized areas. The greatest numbers of power outages
21 were caused by tree limbs and broken wires, not broken poles.

22 Q. Has your work been limited to field work?

23 A. No. I have consulted as a Registered Professional Engineer in joint use contract
24 interpretation and application for 15 years. This includes inspecting joint use facilities,
25 training field engineers and line workers in the NESC, joint use contracts and safe-work

1 rules, and negotiating specific separation, clearance and arrangement requirements (which
2 are additional requirements sometimes imposed by power companies). I have also
3 negotiated procedures, techniques and schedules to complete safety audits, make-ready
4 engineering, make-ready construction and post inspection for joint use projects. I have
5 prepared and conducted numerous workshops or seminars for national joint use
6 conferences and personally conducted several NESC code compliance audits, as well as
7 prepared the make-ready engineering for the power companies and communications
8 companies involved that was necessary to correct violations uncovered in those audits.

9 Q. Anything else?

10 A. Yes. In the past I have been President of local utility coordinating committees in
11 Brunswick and Milledgeville, Georgia and periodically attend national joint use
12 conferences.

13 Q. Please describe your work as President of the local utility coordinating committees.

14 A. These are organizations that are established to foster better communication among the
15 different industries and users that need to use poles and be in the right-of-way. We
16 discuss, design and implement ways to accommodate safe, practical and timely access and
17 use of the limited facilities that all these different companies need to use to provide their
18 services.

19 Q. Are these committees to facilitate joint use of poles?

20 A. Yes, in part. Other issues such as joint trenching, right-of-way restoration, tree-trimming
21 and the like were also considered. But the principal motive for these particular
22 organizations and ones like them is to provide a forum for inter-industry understanding
23 and to find real-world solutions to real-world problems in the joint use area.

24 Q. Are you sponsoring exhibits in this case?

25 A. Yes.

1 MTH-1 (my curriculum vitae and list of testimonies); MTH-2 (Affidavit of Dr. Lawrence
2 M. Slavin Supporting Initial Comments of Verizon Florida Inc. Concerning Proposed
3 Amendments to Rules 25-6.034, 25-6.064, 25-6.078, and 25-6.115, Dockets 060173-EU
4 and 060172-EU (FPSC, filed Aug. 11, 2006) (“Slavin Affidavit”)); and MTH-3 (Process
5 to Engage Third Party Attachers); and MTH-4 (July 24, 2007 Harrelson Letter to Alan
6 McDaniel re Pole Inspections)

7 Q. Could you please explain what your assignment from FCTA was in this proceeding?

8 A. Certainly. My assignment was to evaluate the amended Storm Hardening Plan dated
9 August 14, 2007 (the “Plan”) filed by Gulf Power Company (“Gulf,” “Gulf Power,” or the
10 “Company”) in this docket for the purpose of determining whether the Plan meets the
11 overall objective of the Commission, as set forth in Rule 25-6.0342, F.A.C., of enhancing
12 the reliability of electric transmission and distribution service in a prudent, practical and
13 cost-effective manner. In my testimony, I will address the extent to which the Company
14 has adopted the NESC’s extreme wind loading (EWL) standards for new construction,
15 major planned work and critical infrastructure projects, the deployment strategy the
16 Company will follow to implement those standards, and whether the adopted standards
17 and deployment strategy meet the Commission’s overall objective as set forth in the Rule.
18 I will also address the extent to which the standards and procedures for third party
19 attachments included in the Plan meet or exceed the NESC to assure as far as reasonably
20 practicable that third party attachments do not impair electric service reliability or
21 overload the pole, and are constructed, maintained and operated in accordance with
22 generally accepted engineering practices for the investor-owned utility’s (“IOU”) service
23 territory. Lastly, I will address the extent to which the Company sought and attempted in
24 good faith to accommodate input from attaching entities.

1 Q. How do the provisions of the Company's Plan impact the cable operators who are
2 attached to the Company's poles?

3 A. Cable operators rely on telephone and increasingly power company (who own collectively
4 approximately 80% of the poles statewide) pole infrastructure to distribute video, voice
5 and broadband services to over five million residents throughout the state of Florida.
6 Cable operators are in an intensely competitive industry (competing with satellite
7 operators and telephone companies) and have a fervent interest in ensuring that poles stay
8 up—and their facilities too—to minimize service interruptions, provide access to the
9 Internet, phone service, cable service and important emergency and information services.
10 FCTA and its members also are interested in ensuring that the State's utility poles are safe
11 and reliable and that construction, maintenance and inspection costs are reasonable.
12 Because of quality of service objectives and competitive pressures, cable operators must
13 be sure there are no unreasonable delays in attaching or overlashing existing cables that
14 would delay provisioning of service to customers, and no unreasonable costs imposed that
15 would jeopardize their ability to invest in new and innovative services. Cable operators
16 pay rent based upon the fully allocated cost of the pole space occupied by the cable
17 operator's attachment. Cable operators also directly reimburse utilities for the cost of
18 making the pole ready for their attachments, and pay to make the pole compliant with the
19 NESC when cable operators are responsible for bringing the pole out of compliance. One
20 of my biggest concerns is that all of these costs threaten to go up significantly due to the
21 Company's Plan and cable operators could face additional delays in provisioning service
22 to customers that are not related to pole safety and reliability.

23 I will address these and related issues below in reference to the Company's Plan
24 and the relevant statutory and regulatory requirements. I will also address the testimony
25 filed by witnesses for Gulf Power in this docket, including the Testimony of Alan G.

1 McDaniel dated August 24, 2007 and the Testimony of and Exhibit of Edward J.
2 Battaglia dated August 24, 2007.

3 Q. What is your understanding of what the Company's Plan must do to comply with Rule 25-
4 6.0342, F.A.C.?

5 A. It is my understanding that under that provision the Company's Plan must meet the overall
6 objective of enhancing the reliability of electric transmission and distribution service and
7 reducing restoration costs and outage times in a prudent, practical, and cost-effective
8 manner to the affected parties.

9 Q. Could you please give us details on what the Plan must include and do to meet those
10 requirements?

11 A. Yes. First, the Plan must address the extent to which the Company complies with the
12 NESC. Second, the Plan must address the extent to which it employs the EWL standards
13 specified by Figure 250-2(d) of the 2007 edition of the NESC for new construction, major
14 planned work, and critical infrastructure projects to achieve the objective of enhancing
15 reliability and reducing restoration costs in a prudent, practical and cost effective manner.
16 Third, the Plan must include a detailed description of its deployment strategy, including
17 the facilities affected, the technical design specifications, construction standards, and
18 construction methodologies employed, the communities and areas affected, the extent to
19 which joint use facilities are affected, an estimate of the costs and benefits of the Plan
20 generally, and an estimate of the costs and benefits of the Plan for third party attachers,
21 and explain how the deployment strategy meets the desired objectives of enhancing
22 reliability and reducing storm restoration costs and outage times in a prudent, practical
23 and cost effective manner. Fourth, the Plan must demonstrate that the Company maintains
24 standards and procedures for third party attachments that meet or exceed the NESC so as
25 to assure as far as reasonably practicable that third party attachments do not impair

1 electric service reliability or overload the pole, and are constructed, maintained and
2 operated in accordance with generally accepted engineering practices for the IOU's
3 service territory, and that do not conflict with Title 47, United States Code, Section 224,
4 relating to FCC jurisdiction over pole attachments. Lastly, the Company must show that,
5 in developing its Plan, it sought input from, and attempted in good faith to accommodate
6 concerns raised by, third party attachers.

7 **Company Plan**

8 Q. Have you read the Storm Hardening Plan filed by the Company in the referenced docket?

9 A. Yes I have.

10 Q. Have you reviewed the Testimony and Exhibit of Edward J. Battaglia dated August 24,
11 2007 and Testimony of Alan G. McDaniel dated August 24, 2007 filed in support of the
12 Company's Plan?

13 A. Yes.

14 Q. Have you reviewed the answers to interrogatories and responses to document requests
15 filed by the Company to date in this proceeding?

16 A. Yes.

17 Q. Should the Commission find that the Company's Plan meets the desired objectives of
18 enhancing the reliability of overhead and underground electrical transmission and
19 distribution facilities and reducing restoration costs and outage times in a prudent,
20 practical and cost effective manner?

21 A. No.

22 Q. Why not?

23 A. First, the Company has not adequately explained or justified its change in its plan to
24 "transition to Grade B construction." FCTA does not oppose a transition to Grade B if it
25 is done in a non-discriminatory and practical and cost effective manner. For example, it is

1 not practical or necessary to conduct a detailed loading analysis on a pole when Gulf adds
2 a street light fixture or when a cable operator overlashes a fiber optic cable to existing
3 plant. It is discriminatory when Gulf evaluates overlashing on an existing Grade C pole
4 by Grade B standards and does not do the same when it adds a street light. Such a study
5 may cost in excess of \$200 per pole. More practical means of determining adequate pole
6 strength exist in conventional engineering guidelines. Second, the Company has not has
7 not provided the level of detail for its deployment strategy required by Rule 25-6.0342(4),
8 F.A.C. Third, certain aspects of the Company's deployment strategy are not prudent,
9 practical or cost-effective. Fourth, certain of the third party attachment standards and
10 procedures set forth in the Plan do not relate to storm hardening but instead are rates,
11 terms and conditions regulated by the FCC, and others are not *reasonably practicable* as
12 required by Rule 25-6.0342(5), F.A.C. Lastly, the Company has not fully satisfied its
13 obligation to seek and attempt in good faith to accommodate input from third party
14 attachers.

15 **Wind Loading Standard**

16 Q. Does the Company's Plan address the extent to which, at a minimum, the Plan complies
17 with the current edition of the NESC, ANSI C2-2007, as required by Rule 25-
18 6.0342(3)(a), F.A.C.?

19 A. Rule 25-6.0342, F.A.C., concerns strengthening poles to withstand extreme weather
20 conditions produced by hurricanes—i.e., extreme wind. The relevant NESC rules are
21 those that address loading and the effect of wind on the poles which are located in
22 Sections 24 (Grades of Construction), 25 (Loadings for Grades B and C) and 26 (Strength
23 Requirements) of the NESC. It is my understanding that other provisions of the NESC,
24 including those related to clearances between power facilities and communications
25 facilities, are not at issue in this proceeding. Gulf does not address those requirements,

1 but refers to them, and therefore, I am not expressing an opinion on those provisions
2 except to point out which ones fall outside the scope of this proceeding and therefore
3 should not be approved. With this understanding, yes, the Company's Plan addresses the
4 extent to which it complies with the NESC to the extent required by Rule 25-6.0342(3)(a),
5 F.A.C. See, e.g., Plan at 23.

6 Q. Does the Company's Plan comply, at a minimum, with the relevant provisions of the
7 NESC?

8 A. Yes. The NESC specifies required pole line strengths for distribution lines using grades
9 of construction including Grades B, C and N. The grade of construction depends upon the
10 voltage of the circuits carried on the pole and what the circuits cross over. Grade B design
11 results in an "equivalent wind" load of approximately 116 mph, and is thus "stronger"
12 than Grade C design, which results in an "equivalent wind" load of approximately 86
13 mph. The NESC generally requires Grade C construction for "distribution" poles. Grade
14 B is required for distribution poles crossing over railroad tracks, limited-access highways,
15 and navigable waterways requiring waterway crossing permits. Gulf Power states in its
16 Plan that the Company will exceed the NESC by transitioning to Grade B construction on
17 all new construction, major projects and maintenance work. Plan at 23. Accordingly,
18 Gulf Power's Plan complies at a minimum with the NESC.

19 Q. Does the Company's Plan address the extent to which it is adopting the EWL standards
20 specified by Figure 250-2(d) of the 2007 edition of the NESC?

21 A. Yes. The Company's Plan states that the Company intends to apply the EWL standards to
22 targeted facilities serving critical loads, including critical infrastructure facilities (CIF) and
23 major thoroughfares. Plan at 23-24. It lists the specific CIF and thoroughfares at page 24
24 of its Plan.

1 Q. Is the Company's decision to adopt NESC EWL criteria only for limited targeted facilities
2 prudent, practical and cost effective?

3 A. Yes. First, I agree with Gulf's overall conclusion that EWL is not the right construction
4 criteria to apply throughout its service territory. Second, I agree that it is prudent,
5 practical and cost effective to "move cautiously into the application of the extreme wind
6 loading standards until it is able to determine the cost and outage benefits." Plan at 23.

7 Q. Please explain why you believe EWL is not the right construction criteria to apply
8 throughout Gulf's service territory.

9 A. Gulf has stated it "lacks the data to support the benefits associated with applying extreme
10 wind loading standards to distribution poles." Plan at 23. Gulf's witness, Edward J.
11 Battaglia, states in his pre-filed testimony that it is not cost effective to adopt EWL
12 standards for all of Gulf's existing overhead distribution facilities. Battaglia Test. at 15.
13 He estimates the cost to be approximately \$437.2 million initially plus an additional \$2
14 million annually, and estimates that the possible avoided storm restoration cost would be
15 only \$1.1 million. *Id.* Moreover, he states "Gulf's experience is that wind-blown debris is
16 the predominant cause of damage versus pure wind." *Id.* I agree that the benefits of
17 applying EWL criteria to poles 60 feet and less in height are speculative at best.

18 Q. Please explain.

19 A. Certainly. Rule 250C of the 2007 NESC contains the EWL standard and describes the
20 application of the extreme wind loading required in Rule 250A1 on poles and their
21 supported facilities, including wires, transformers, etc. for purposes of determining the
22 required strength of the pole. The current edition of the NESC exempts from the EWL
23 criteria any structure and its supported facilities that are 60 feet or less above ground. As
24 a clarifying point, only Rule 250C specifies when extreme wind loading is required, not
25 Figure 250-2(d), which is the NESC provision referenced in F.A.C. 25-6.0342. Figure

1 250-2(d) specifies three-second gust wind speeds for Florida, which are then referenced in
2 Rule 250C.

3 The NESC committee responsible for strengths and loadings of overhead electrical
4 systems has considered on numerous occasions whether to apply EWL criteria to
5 distribution lines less than 60 feet high. In fact, during each of the last two code cycles,
6 the NESC committee considered proposed changes that would have required application
7 of EWL to distribution systems of any height. In comments filed in those proceedings, the
8 utility industry resoundingly agreed that most distribution pole failures in extreme weather
9 events are the result of secondary damage effects from trees and debris, not wind alone,
10 and that the system would have failed even if designed to the significantly more expensive
11 EWL criteria. Based largely on this feedback from the field, the NESC committee
12 retained the EWL exemption for structures 60 feet and less in the 2007 Code.

13 Indeed, other companies filing storm hardening plans with the Commission agree
14 that EWL is not the right standard for poles 60 feet and less in height. For example, the
15 Tampa Electric Company (“TECO”) states, “Tampa Electric’s experience continues to
16 show that there is no substantial evidence that building distribution structures to extreme
17 wind construction grades will prevent damage from falling trees, tree limbs and flying
18 debris during major storm events.” TECO Storm Hardening Plan at 15. Jason Cutliffe, on
19 behalf of Progress Energy Florida (PEF) explained “the EWL standard would have no
20 appreciable benefit for PEF’s distribution poles with respect to preventing wind-caused
21 damage” and “other coastal utilities and utilities that experience tornados, [support] the
22 fact that the EWL standard has no appreciable wind damage prevention benefit for their
23 distribution poles.” Cutliffe Test. at 6. Lastly, Mr. Mickey Gunter, who serves as a
24 member of NESC Subcommittee 4 (Overhead Lines-Clearances,) 7 (Underground lines)
25 and the Interpretations committee, also filing testimony on behalf of PEF, stated, “I agree

1 with the 217 others who supported the rejection of eliminating the 60 foot exemption and
2 retaining it in the 2007 NESC edition because eliminating the 60 foot exemption would
3 yield unnecessary costs without significantly improving or increasing safety.” Gunter
4 Test. at 7.

5 Similarly, Dr. Larry Slavin, Chairman of the NESC Subcommittee 5, which is
6 responsible for provisions related to overhead lines strength and loading, filed an affidavit
7 on behalf of Verizon in Dockets 060173-EU and 060172-EU, attached as MTH-2, in
8 which he opined that the application of EWL to distribution poles is not prudent or cost
9 effective. Slavin Aff. § 3.1. Dr. Slavin also pointed out that the use of EWL criteria may
10 have negative unintended consequences including increasing vehicular injuries and deaths
11 resulting from cars hitting a greater number of heavier poles, more downed poles in
12 storms, increased storm restoration delay resulting from more pole failures, harder to
13 replace poles, and a steep learning-curve for engineers not yet trained in these types of
14 applications. *Id.* § 4.2. Dr. Slavin and I are also of like mind that EWL should be applied
15 to distribution poles, if at all, on a limited “trial” or pilot project basis.

16 Based on my experience, the common causes of hurricane related pole failures are
17 falling trees, flying tree limbs, building debris, soft soil made worse by heavy rains, weak
18 guy failure, rotten pole failure, and finally wind force on poles, lines and attachments.
19 Another common cause of wood pole failures is cascading of solid (strong) poles because
20 an adjacent pole breaks in high wind because of flying debris, rot or another defect. These
21 causes will not be remedied by application of EWL criteria.

22 Q. Please explain why you think Gulf’s targeted facilities approach to EWL is prudent,
23 practical and cost effective?

24 A. First, the approach focuses on those feeders which serve critical loads, such as hospitals,
25 major sewage treatment plants, fuel depots, and Interstate crossings. Second, the

1 proposed expenditures for EWL for three years are approximately \$2 million (Plan at
2 28)—this is a reasonable amount when compared to amounts being proposed by other
3 Florida utilities, including FPL, which is proposing to spend close to \$300 million on
4 EWL construction from 2007-2009. Third, a pilot approach will allow Gulf to collect
5 forensic data over the three year period. Gulf plans on installing a total of 19 monitors
6 strategically located at substations nearest to the planned projects for applying the extreme
7 wind loading standards to help determine the effectiveness of the projects.

8 Q. Did the Plan adequately consider using EWL for new construction, major planned work,
9 expansions, rebuilds and relocations of the overhead distribution system?

10 A. Yes, the Plan considered and rejected applying EWL criteria to new construction, major
11 planned work, expansion, rebuilds and relocations of the overhead distribution system.
12 Instead, Gulf states that it will use Grade B criteria in these instances.

13 Q. Does the Company's decision not to use EWL criteria for new construction, planned
14 work, expansions, rebuilds and relocations meet the desired objectives of enhancing
15 reliability and reducing restoration costs and outage times in a prudent, practical and cost-
16 effective manner?

17 A. Yes. As explained above, I am in agreement with the majority of experts that considered
18 and rejected applying EWL criteria to distribution poles in Florida that it is not prudent,
19 practical or cost effective to use EWL for new construction, planned work, expansions,
20 rebuilds and relocations.

21 Q. Do you think the Company's plan to use Grade B criteria for new construction, planned
22 work, expansions, rebuilds and relocations meets the objectives of enhancing reliability
23 and reducing restoration costs and outage times in a prudent, practical and cost-effective
24 manner?

1 A. Yes, except that I have serious reservations about how Gulf intends to deploy Grade B
2 construction criteria. In my opinion, Grade B is more than adequate to strengthen poles
3 against the effects of extreme wind. Compliance with the applicable grade of construction
4 required by the NESC—which is Grade C for poles 60 feet or less in height—will meet
5 the Commission’s objectives as long as other initiatives—such as increased guying,
6 replacing rotten poles, good vegetation management practices, replacing small copper
7 wires with stronger aluminum wires etc—are implemented.

8 In fact, Rule 250B and Table 250-1 requires that in the light loading district, which
9 includes Florida, nine pounds per square foot of wind pressure be applied to the design of
10 all poles 60 feet or less in height. Nine pounds of pressure is equivalent to winds of up to
11 60 miles per hour. The required safety factors are also greater for Grade B and C than
12 EWL thus the even greater equivalent wind speeds for Grades B and C. This standard
13 thus takes into account the higher wind speeds expected to be experienced in Florida. By
14 comparison, the NESC requires that four pounds per square foot of wind pressure be
15 assumed in the medium and heavy loading districts north of Florida. Four pounds per
16 square foot is equivalent to wind speeds of approximately 40 miles per hour.

17 Accordingly, the construction criteria specified by NESC already takes wind speeds into
18 effect and I do not think it is necessary for Gulf to build to Grade B. Also, because Gulf is
19 electing to exceed the NESC requirements, it could develop a targeted approach to apply
20 Grade B in open areas and not risk wasting its resources in areas with heavy tree
21 conditions.

22 That said, it is my opinion based on personal observations that much of Gulf’s
23 plant already is built to Grade B standards. Power lines which have guyed angles, guyed
24 pull off lines, crossing lines or “junction poles” are made stronger by the attachments high
25 on the poles which are under tension. The other wires, cables and guys have excess

1 strength to help resist wind forces. The result is that virtually all of these type poles
2 already exceed Grade B standards even though they are the same class pole required to
3 meet grade C if no other lines or guys are attached. Furthermore, I believe that a slow and
4 orderly transition to Grade B that did not involve changing out sound poles built to Grade
5 C with poles built to Grade B could be prudent, practical and cost effective. However,
6 based upon what I have seen in the Plan, the testimony filed by Gulf's witnesses, and the
7 discovery responses, I do not believe that Gulf intends to follow a reasonably practicable
8 transition to Grade B with respect to third party attachers but rather only with respect to
9 Gulf. I am also concerned that Gulf may use its planned joint use audit to unfairly transfer
10 some of the costs of building to Grade B to third party attachers.

11 While I appreciate the decision of Gulf to adopt Grade B criteria for new
12 construction and major planned work, I have serious concerns, set forth below, about how
13 Gulf plans to deploy those construction standards.

14 **Deployment Strategy**

15 Q. Does the Company's Plan adequately describe the Company's deployment strategy,
16 including the facilities affected, the technical design specifications, construction standards
17 and construction methodologies employed, the communities where electric infrastructure
18 improvements are to be made, the extent to which improvements involve joint use
19 facilities, and the costs and benefits of the proposed Plan as required by Rule 25-
20 06.0342(4), F.A.C.?

21 A. In its current form, I do not believe the Plan adequately *describes* its deployment strategy.
22 Rule 25-06.0342(4), F.A.C., regarding the deployment strategy is quite specific about the
23 level of detail required in the storm hardening plans. The Rule requires each utility to
24 explain the systematic approach it will follow to achieve the desired objectives. The

1 deployment strategy details that must be included in each storm hardening plan are broken
2 down into subsections (a) thru (e).

3 The Company's deployment strategy is set forth in Sections 9.0, 10.0 11.0 and
4 12.0 of the Company's Plan (Plan at 26-34), and Appendices 1-7.

5 Section 9.0 of Gulf's Plan lists the projects, the district locations and estimated
6 number of poles to be impacted by Gulf's CIF and Interstate crossing projects. It also lists
7 the number of joint-use assessments that Gulf will make as part of its Joint Use Pole
8 Attachment Audit, which comprises an integral component of Gulf's Plan. The Joint Use
9 Pole Attachment Audit is set forth in Section 2.2 of the Plan. Plan at 10-12. Section 9.0
10 also provides in Appendix 1 a map of Gulf's entire district service areas to show the
11 "communities and areas affected."

12 Section 10 contains Gulf's estimate of incremental costs and benefits. "Since Gulf
13 has no forensic data from past storms, these estimates are based on using what Gulf has
14 determined to be reasonable assumptions and available data from its Trouble Call
15 Management System." Plan at 28.

16 Section 11 sets forth the impact to collocation facilities. This section doesn't list
17 the specific facilities affected but rather states the general types of storm hardening
18 activities the Company anticipates will impact third party attachers, including increased
19 pole strength and loading engineering calculations, and increased processes for
20 attachment.

21 Lastly, Section 12 sets forth its estimate of the costs and benefits on third parties,
22 and includes Gulf's summary of the various letters and comments submitted by interested
23 third party attachers in this proceeding, including input received from FCTA in Section
24 12.3. I am not sure how relevant the input is given that Gulf has since amended its Plan.
25 Moreover, I am concerned that overall, Gulf makes it seem like FCTA expressed no

1 concerns about its Plan. In fact, in extensive Comments filed in this proceeding on May
2 22, 2007 (which Gulf doesn't list as "input"), FCTA set forth numerous concerns about
3 the Plan. Moreover, Gulf did not capture the following FCTA concerns raised in the
4 letters referenced in Section 12.3: that FCTA objected to Gulf's plan to increase
5 substantially its permitting activities for new attachments and modifications to
6 attachments; that most of the changes outlined in section 11.0 of its Plan dealing with
7 attachment standards and procedures had very little to do with pole line strength problems,
8 the point of this proceeding; that Gulf's advance notice requirement for overlashing, as
9 well as the wind loading analysis requirement, would create significant delays in speed to
10 market for third-party attachers and the wind loading analysis would significantly and
11 unduly increase costs; that all aspects of the 2007 loading analysis should be thoroughly
12 reviewed in order to better focus and improve the pole loading analysis plan; and that Gulf
13 has not determined or quantified what is meant by "overloading."

14 Q. In what way, if any, is the description of the Company's deployment strategy lacking?

15 A. First, the Plan does not include the specific technical design specifications, construction
16 standards and construction methodologies that will be employed by the Company in
17 hardening poles. Second, the Plan does not indicate the joint use poles that will be
18 impacted by storm hardening projects. Third, the Plan does not adequately identify the
19 costs and benefits of its proposed Plan to third party attachers. Lastly, it incorrectly
20 summarizes the input provided by FCTA in this proceeding.

21 Q. Can you provide an assessment of the costs and benefits of the Company's Plan on third
22 party attachers at this time?

23 A. The Company's Plan does not yet include enough information about the costs and benefits
24 of its storm hardening plan to enable me to provide a specific estimate of the costs and
25 benefits that the Company's plan will have on third party attachers. The Company's Plan

1 provides cost estimates for 2007, 2008 and 2009 on a project annual basis. It would be
2 helpful to have more details about these costs including if possible an estimate of the
3 incremental costs per mile and more details about the plant with third party attachments
4 that will impacted by these costs. The Company provided some additional cost
5 information detail in its responses to discovery requests submitted in this Docket. I am
6 currently analyzing this additional information and am not able to assess its usefulness at
7 this time.

8 I can say that the costs that may be recovered from cable operators are tightly
9 prescribed by the FCC. Under the federal scheme, FCTA members pay both make-ready
10 costs—i.e., the cost of making the pole ready for its attachments (including the cost of
11 rearranging existing facilities on the pole, guying the pole to increase strength, or
12 replacing the pole where necessary) and annual rent pursuant to the FCC’s rate formula,
13 which assures that pole owners receive the fully allocated costs of accommodating the
14 attachment. The annual pole attachment rent is determined by multiplying the percentage
15 of the total usable space occupied by the pole attachment by the sum of the operating
16 expenses and actual capital costs of the utility attributable to the entire pole. In addition,
17 depending upon the circumstances, cable operators may incur the cost of transferring their
18 facilities to a new pole.

19 It is clear that cable operators will incur significant additional costs as a result of
20 the Company’s Plan. They will incur costs related to transferring their facilities to poles
21 that are replaced due to storm hardening. In my experience transfer costs can be as little
22 as \$100 for a wood distribution pole but would be significantly more for transferring to a
23 concrete or steel pole, and the costs quickly escalate to the tens of thousands where
24 splicing or new cable runs are required. Annual pole rental rates will increase, possibly
25 significantly. Costs attendant to making the pole ready for third party attachments—

1 including the cost of pre-construction strength —will increase. The number of cable
2 operator attachments on which rents are paid will increase as additional poles are set in
3 existing spans. Cable operators will incur higher costs as a result of constructing to Grade
4 B or EWL. In addition, third party attachers likely will experience significant delays in
5 provisioning service to customers as a result of the new processes and standards the
6 Company is adopting in connection with storm hardening. Given the competitiveness in
7 the communications service markets any delays likely will result in lost customers.

8 From the information I have seen thus far I do not see a corresponding benefit to
9 third party attachers resulting from the majority of the storm hardening activities. I fear
10 that building to EWL may actually increase storm related outages and recovery times. I
11 also do not see a benefit from the Company’s increased emphasis on the strength and
12 loading impact of third party attachments. I strongly believe that limited pilot projects are
13 necessary to better inform the cost benefit analysis. I also believe that more detailed
14 information about the specific design and construction criteria that will be used, and the
15 specific joint use poles that will be impacted, will better enable third party attachers to
16 assess the costs and benefits to their operations.

17 Q. Does the agreed to Process to Engage Third Party Attachers (MTH-3) alleviate your
18 concerns about the level of detail in Gulf’s Plan?

19 A. Yes, that would alleviate my concerns about the details missing from Gulf’s Plan with
20 respect to pilot projects, but details of Gulf’s “transition to Grade B” are still lacking as
21 well as details of its 500 pole analysis of loading. Additionally, Gulf should strike the
22 summary of input provided by third parties in the Plan as I think it is incomplete and
23 therefore could be misleading in light of the agreement.

1 Q. Does the Company's deployment strategy meet the overall objective of enhancing the
2 reliability of the electric distribution and transmission system in a prudent, practical and
3 cost-effective manner?

4 A. In some respects yes, and in others, no.

5 Q. In what ways does Gulf's deployment strategy meet the Commission's overall objective?

6 A. As set forth above, Gulf's three year targeted approach of testing EWL standards on select
7 critical infrastructure facilities and interstate crossings is a prudent, practical and cost
8 effective means of improving reliability and reducing restoration costs. I think the
9 strategy Gulf has laid out for implementing EWL on these targeted projects is satisfactory.

10 I do not believe that Gulf's strategy for deploying Grade B construction is sound.
11 For example, I am very concerned with the way that Gulf plans to implement Grade B
12 construction in its Joint Use Pole Audit, and in general with regard to third party
13 attachments. I am also concerned by the extent to which Gulf is focusing on the loading
14 impact of third party attachments as a significant part of its deployment strategy. It is well
15 known that third party attachments do not create the greatest weight or load burden on the
16 pole.

17 Q. Please explain your concerns about Gulf's deployment of Grade B construction criteria.

18 A. Gulf plans to commence a Pole Strength/Load Assessment in 2007 based on the 2006
19 Joint-Use Field Audit survey. Plan at 12. This will consist of a random sampling of 5%
20 of the Gulf-owned joint-use poles that are at least 20 years old and have three third parties
21 attached. Gulf estimates that this will impact 500 joint-use poles per year during the
22 three-year plan period. Grade B requirements will be applied to these poles which were
23 built to Grade C and the attachments were permitted subject to Grade C criteria. Gulf's
24 decision is contrary to the grandfathering provision of the NESC which was adopted in the
25 storm hardening Rule and applied to power and communications lines. It certainly is not

1 consistent with a reasonably practicable transition to Grade B construction and is
2 discriminatory against third party attachers. Tellingly, this is actually far in excess of the
3 number of poles on which it intends to test EWL criteria—which is less than 500 poles for
4 the entire three year period. It should also be noted that Section 2.9 of Gulf’s storm plan
5 explains its participation in PURCA research. The PURCA committee, including Gulf,
6 did not include overloading by third party attachments as a research priority.

7 Gulf has stated that it will be conducting a complete engineering analysis of these
8 joint use poles, including an analysis of whether the attachments comply with Gulf’s
9 requirements for clearances, which exceed the requirements in the NESC. Gulf has stated
10 that if a pole does not meet Gulf’s clearance requirements, and the pole cannot be
11 rearranged, Gulf will replace the pole with a pole meeting Grade B criteria. The third
12 party that is deemed responsible for the non-compliance will be required to pay the cost of
13 replacing the pole with the stronger class pole. I am very concerned about how Gulf will
14 assign responsibility for non-compliance. Gulf states in response to FCTA Interrogatory
15 Number 21 that it performs “due diligence” to discern who is responsible for the violation
16 based on available information, including, but not limited to, the order of attachment or
17 the most recent modification on the pole.” I am concerned that Gulf will unfairly presume
18 that because it attached to the pole first, it did not bring the pole out of compliance. While
19 they obviously must place the pole first and almost always install the first lines and some
20 facilities, power companies are adding and rearranging facilities and equipment on a daily
21 basis as do the other attachers. The cable systems were initially installed decades ago and
22 thus, almost all of the poles with attachments are likely to have been modified in some
23 way since that time. Additionally both Pensacola and Panama City have experienced
24 severe hurricane damage which was hurriedly placed back in service by out of area
25 emergency repair crews who left many minor violations behind. Holding an attacher

1 accountable for replacing a pole with a stronger class pole creates a huge incentive for
2 Gulf to find non-compliance by a third party.

3 Q. Please explain your concerns about Gulf's inclusion of the loading impact of third party
4 attachments as an integral part of its storm hardening plan.

5 A. Gulf states that it is revising several elements of its approach to third party attachments as
6 part of its storm hardening efforts. Specifically, it states that it will now perform a pole
7 strength and loading calculation before any attachment or overlash is made to any pole,
8 tower or structure. In addition, Gulf states that it is implementing a new pre-notification
9 process for any new additions to the pole including an inspection prior to attachment and
10 after attachment. Gulf's inclusion of this as an integral part of its storm hardening plan is
11 very troubling.

12 Q. Why is it troubling?

13 A. In my experience third party attachments do not significantly increase the wind load on
14 poles. Rather, power lines, hardware for attaching lines to poles and power apparatus
15 such as transformers, fused switches, lightning arrester assemblies, outdoor lights and
16 many other power company attachments usually account for most of the wind load on a
17 pole because they have a larger cross sectional area and are attached to the top part of
18 poles. Wind load is a product of the surface area exposed to the wind multiplied times the
19 force of the assumed wind and also multiplied times the pole height from the fixed point
20 (often the ground line or the lowest guy wire) on the pole.

21 I am also concerned about the factors that Gulf intends to consider in assessing the
22 loading impact of third party attachments on the pole. Gulf plans to use PoleForeman
23 pole loading analysis software to perform its comprehensive pole loading analysis. I am
24 concerned that PoleForeman may not take into account all of the relevant criteria for
25 assessing the true strength of the pole. For example, I do not believe that PoleForeman

1 takes into account the guying effect of lateral lines on the pole without special application
2 procedures by the person using it. Considering that pole loading calculations with
3 computer software, as opposed to using engineering guidelines, tables and charts which
4 have served very well for distribution design for decades, is new to Gulf and many others
5 extra caution should be used to be certain that beneficial as well as detrimental loading
6 effects on poles are included in the sophisticated calculations. Before changing out a pole
7 with a stronger class wood pole or concrete pole, the guying effects of other lateral lines
8 and guy wires on the poles should be taken into consideration.

9 Q. What do you mean by the guying effects of other lateral lines and guy wires on the poles?

10 A. Poles or any tower can be designed to be held upright by as few as three guy wires when
11 nothing else is attached. A guy wire is a strong steel wire which is attached to a pole near
12 the height on the pole where the pole needs additional support. The other end of the guy
13 may be attached to a strong steel anchor in the ground or to another pole in the direction
14 that the pull of the guy is needed. The requirements are that the guys and their anchors
15 must have enough strength to overcome the horizontal force of wind on the structure. The
16 structure must have enough strength to withstand the vertical load, if any, of the guys'
17 downward component of pull on the tower. The horizontal component of the pull of the
18 guys is what must equal or exceed the applied force of the wind.

19 Power lines near the top of the poles create the effect of having two sets of "guys"
20 attached to the poles. These wires are much stronger than the tension at which they are
21 strung from pole to pole. The amount that the strength of each of these wires exceeds the
22 pounds of tension on the wire is available to help strengthen the pole in that direction.
23 This is the same effect on pole strength as guying. The lines are either straight through,
24 turn an angle or stop on each pole. The straight line poles are called tangent structures,
25 the angles are angle structures and the last is called dead end poles.

1 A tangent structure must have enough strength to withstand the force of the
2 assumed speed of the wind for which it is designed. The wind direction must be assumed
3 to be that which results in the most load on the pole. For a tangent pole with no other
4 wires or guys attached the worst direction is perpendicular to the line because of the
5 ability (guying effect) of the line to support the pole in two directions as stated above.
6 The wind force is based on the exposed surface area of the structure and all of its
7 attachments. This strength may be provided by the structure alone or other support such
8 as guy wires and other electric wires and cables attached to the pole. These other
9 attachments leave individual poles in various directions and at different heights. All of
10 these attachments must have greater strength than the tension under which they operate.
11 The operating tensions and strength of various wires and cables generally is known and
12 the tension depends on the distance to the next pole. The amount that the strength of any
13 attachment exceeds its operating tension produces a guying effect on the pole.

14 Angle poles are similar to a tower which is guyed three ways. The line provides
15 guying effects in two directions and the third is provided by a guy and anchor, a horizontal
16 guy wire to another pole or another line leaving the pole and acting as a guy. A dead end
17 pole normally is strengthened in one direction by the power lines and by a guy wire or guy
18 wires in the opposite direction. Dead end poles can be guyed if space is available by two
19 guys whose anchors are spread apart enough to effectively storm guy the pole. The
20 horizontal component of all of these guying effects can and often does make a common
21 diameter pole strong enough to meet EWL standards.

22 Q. Do you have any other concerns about the criteria that Gulf is using for its loading
23 analysis of third party attachments?

24 A. In its response to FCTA First Set of Interrogatories (“FCTA Interrogatory”) No. 17, Gulf
25 states that “all of the attachments on a pole must be modeled and analyzed to determine

1 what impact they have on pole strength.” It will use an “extensive process” that looks at
2 the “size of the conductors attached, the heights of all conductors, the configuration, the
3 span lengths of every conductor, the lead length of all anchors and soil class.” I have
4 serious concerns about how this will be implemented.

5 At earlier stages of this proceeding, I have stated my opinion that Gulf’s plan to
6 determine the extent of overloading, if any, on a 5% sample of its most likely poles to be
7 overloaded is a practical approach to determine the extent of overloading. However, the
8 deployment of this plan has turned out to be unreasonable. Gulf responded to FCTA
9 Interrogatory No.16 that the contractor cost to Gulf to perform the work is confidential
10 and presently Gulf can provide no cost estimate of what the per pole analysis will cost.
11 Gulf unilaterally hired the contractor at an hourly rate without discussing the process to be
12 used with third party attachers. The contractor (which I understand is the same contractor
13 that will perform the work) uses different software from PoleForeman. The findings of
14 the audit will be badly flawed if guying effects of other lines, cables and guys are not
15 included in the loading analysis. FCTA discussions with Gulf took place during the time
16 when Gulf intended to use grade C as its basic standard. Later, at a workshop, Gulf
17 informed me that while Gulf planned to move to Grade B construction, the poles would be
18 assessed using Grade C standards in the audit. Now the plan is to use Grade B.

19 Gulf states in response to FCTA Interrogatory No. 23 regarding the Gulf
20 attachment audit: The contractor makes a “visual inspection for potentially dangerous
21 violations.” In the 500 pole strength assessment whose purpose is to determine if the pole
22 is overloaded Gulf goes completely beyond the responsible procedure it follows in the
23 pole audit. Gulf requires not only a complete NESC audit of spacing requirements which
24 do not affect pole strength but also a time consuming audit of Gulf Power’s many joint
25 use requirements which exceed NESC requirements. Finally, with the effect of likely

1 requiring many more pole replacements, Gulf intends to place blame on the causer of the
2 alleged overload or the irrelevant to strength attachment standards of Gulf.

3 **Third Party Attachment Standards And Procedures**

4 Q. Does the Company maintain standards and procedures for attachments by others that meet
5 or exceed the relevant NESC provisions?

6 A. Yes. Gulf maintains attachment standards and procedures that require compliance with
7 the NESC. Gulf's attachment standards and procedures are outlined in Appendix 3 of its
8 Plan.

9 Q. Do the third party attachment standards and procedures outlined in Appendix 3 comply
10 with the requirements of Rule 25-6.0342(5), F.A.C., i.e., do they meet or exceed the
11 NESC so as to assure as far as reasonably practicable that third party attachments do not
12 impair electric service reliability or overload the pole, and are constructed, maintained and
13 operated in accordance with generally accepted engineering practices in Gulf's service
14 territory?

15 A. No.

16 Q. Why not?

17 A. First, Gulf includes in its outline certain terms and conditions governing third party
18 attachments that are not related to the Commission's overall objective of enhancing
19 reliability or reducing restoration costs i.e., storm hardening, and thus are beyond the
20 scope of this proceeding and should not be approved by this Commission. Only standards
21 and procedures that concern the loading impact of third party attachments on the strength
22 of poles relate to storm hardening and should be in the plans. Second, Gulf's third party
23 attachment standards and procedures that relate to loading and pole strength do not
24 comply with the requirements of Rule 25-6.0342(5) because they do not assure as far as
25 reasonably practicable that third party attachments do no impair electric service reliability,

1 overload the pole or are constructed in accordance with accepted industry standards, and
2 therefore should not be approved.

3 Q. Please provide a summary of the terms and conditions governing third party attachments
4 included in Gulf's Appendix 3 of its Plan that are *not* related to the overall storm
5 hardening objective?

6 A. Gulf's Outline states that its standards and procedures are a combination of its current
7 contracts, its Overlashing Policy (App. 2), its Attachment Permit and Overlashing
8 Notification Procedure (App. 4), and its Joint Use Spec Plates (App. 5). Each of these has
9 elements that fall outside the scope of this proceeding. For example, everything in Gulf's
10 contracts fall outside this proceeding. Gulf's contracts with cable operator third party
11 attachers are comprised of rates, terms and conditions of attachment which are governed
12 by and fall within the jurisdiction of another regulatory body, particularly the FCC, which
13 under statute has exclusive authority to regulate the "rates, terms and conditions for pole
14 attachments to provide that such rates, terms and conditions are just and reasonable" in
15 non-certified states such as Florida. Rule 25-6.0342(8), F.A.C., states "Nothing in this
16 rule is intended to conflict with Title 47, United States Code, Section 224, relating to
17 Federal Communications Commission jurisdiction over pole attachments." Moreover, the
18 FCTA has been in litigation with Gulf for several years concerning Gulf Power's
19 unsuccessful effort to charge pole attachment rates substantially in excess of the rates
20 calculated using the FCC formula for cable operator attachments to Gulf's distribution
21 poles throughout its service area. Gulf's rates, terms and conditions embodied in its
22 contracts cannot be "approved" by the Commission as part of Gulf's hardening plan.
23 Similarly, Gulf's attachment permit and overlashing notification procedure—Section 11
24 of the Plan—refers to the charges it imposes on third party attachers for post-inspections.
25 I do not believe this Commission intended to address issues of cost recovery related to

1 cable operator attachments because, cost recovery for attachments made by cable
2 operators falls within the jurisdiction of the FCC. Gulf also lists “key items” which it
3 states are part of its contracts with third party attachers and will remain part of the
4 attachment process. I do not believe any of these “key items” relate to storm hardening
5 and therefore I am not addressing them here.

6 Q. Is the Gulf litigation you mention above relevant to this proceeding?

7 A. Yes. In that proceeding Gulf disregarded, which is the source of my apprehension here,
8 the actual, dynamic nature of poles in a joint use utility system and gave no consideration
9 to whether and how make-ready work, which must be performed to comply with the
10 NESC and which is an integral part of Gulf’s own pole attachment permitting procedures,
11 could correct safety violations and lead to the availability of space for a new attachment.
12 Similarly, these same techniques may also ensure poles perform safely in hurricane
13 conditions. However, in this docket Gulf appears to be trying to collect some of the
14 rejected rate increase by implementing unreasonable requirements for overlashing and
15 loading and imposing unnecessary inspections, as part of its storm hardening efforts that
16 will do no more than replace safe and strong poles at third-party attachers' expense. In
17 addition, after the FCC proceeding I learned that Gulf was going to be revising its
18 standard joint use pole contracts but I have yet to see the provisions. I expect they will
19 include the permit and overlash provisions they mention in their appendix.

20 Q. Would you please explain what you reviewed and your testimony?

21 A. Sure. I reviewed Gulf Power documents, discovery, testimony and other materials
22 produced and prepared my own expert testimony finding that Gulf’s poles were not “at
23 full capacity” and such poles could, consistent with standard electric industry procedures
24 and Gulf Power’s own practices, safely accommodate further attachments and comply

1 with the NESC. The FCC Chief ALJ hearing the case agreed with me and issued a
2 decision rejecting Gulf's claims

3 Q. Which of Gulf's third party attachment standards and procedures concern the impact of
4 third party attachments on the weight and loading of a pole?

5 A. The provisions that relate to pole strength and loading including the Overlashing Policy
6 set forth in Appendix 2, certain aspects of the Attachment Permit and Overlashing
7 Notification Procedure set forth in Appendix 4, and certain aspects of the Overhead Storm
8 Hardening provisions in Appendix 5.

9 Q. Do Gulf's relevant attachment standards and procedures satisfy the Commission's
10 requirements, as set forth in Rule 25-6.0342(5), F.A.C., of meeting or exceeding the
11 NESC to assure, as far as is reasonably practicable, that electric safety, adequacy, or pole
12 reliability is not impaired, pole loading capacity is not exceeded, and attachments are
13 constructed, installed, maintained, and operated in accordance with generally accepted
14 engineering practices for the utility's service territory?

15 A. No. Gulf's Overlashing Policy requires 30 days advance notice for overlashing, and
16 provides that Gulf or its contractor will perform a pole strength and loading analysis on
17 the attachment. *See also* Gulf's Resp. to FCTA Interrog. No. 15 (stating that Gulf will not
18 allow cable operators to perform any required loading analysis). A 30 day advance notice
19 and approval process is not required for pole safety, adequacy or reliability, and its not a
20 reasonably practicable way to assure that pole loading capacity is not exceeded. As
21 explained by Mr. McDaniel in his testimony, "[i]n the past Gulf has not specifically
22 required third parties to provide advance notice of overlashing." McDaniel Test. at 4.
23 And yet, Gulf produced no records of any pole failing as a result of third party
24 overlashing.

1 Q. Can you further expound on why you think Gulf’s policy concerning overlashing is not
2 necessary or practicable?

3 A. Certainly. Let me begin with a description of overlashing. What a cable operator initially
4 attaches to the pole (i.e., a “new attachment”) is not usually the coaxial or fiber conductor
5 itself, but a steel wire support strand attached to the pole with a clamp and through bolt.
6 The operator then places communications conductors parallel to the strand and secures
7 them by wrapping the strand and the conductor(s) with a thin steel filament called a
8 lashing wire applied by a lashing machine. The cables are not wrapped around the
9 support strand. Through the life of the plant, the cable operator may alter that plant,
10 including by *lashing* additional conductors to the existing strand, i.e., overlashing. For
11 example, growing neighborhoods may be served by lashing additional or rerouted trunk
12 cables to the existing strand, using another filament lashing the new line to the existing
13 strand. More often, in today’s applications, fiber optic sheath is “overlashed” to the
14 coaxial cables in order to increase bandwidth and to provide capacity to offer new
15 services. In addition, operators use overlashing in emergency situations to repair
16 customer outages. Overlashing is used to eliminate amplifiers (which are potential points
17 of failure); to expand channel capacity; and to provide capacity for additional services.

18 Overlashing does not use more pole space, because the same strand remains
19 attached to the same licensed position on the pole. Indeed, it is common for more than
20 one cable to be held in place by lashing it to an already existing and already licensed
21 strand or messenger.

22 In my experience third party attachments do not significantly increase the load on
23 poles, and overlashing has only a very small incremental effect on the already attached
24 strand and cable assembly. Rather, power lines, hardware for attaching lines to poles and
25 power apparatus such as transformers, fused switches, lightning arrester assemblies,

1 outdoor lights and many other power company attachments usually account for most of
2 the wind load on a pole because they have a larger cross sectional area and are attached to
3 the top part of poles. Wind load is a product of the surface area exposed to the wind
4 multiplied times the force of the assumed wind and also multiplied times the pole height
5 from the fixed point (often the ground line or the lowest guy wire) on the pole. As stated
6 above, today's overlashing typically is of fiber optic sheath—a very light weight material
7 that is quite small in diameter. A common fiber optic cable is .59" diameter and weighs
8 .05 pounds per foot. Thus, overlashing will not in the large majority of cases bring a pole
9 out of compliance.

10 Q. In his testimony at page 5, lines 3-5, Mr. McDaniel indicates that the new requirement it is
11 implementing for overlashing is common practice in the state of Florida. Do you agree?

12 A. No. In fact, FPL does not require approval or notice for overlashing that does not result in
13 added weight or increased bundle size. As recognized by FPL, if there is no increased
14 size or weight to an existing attachment—for example, where a cable operator replaces
15 existing conductors or equipment with fiber sheath—no notice should be required. In
16 addition, FPL allows cable operators or third parties hired by cable operators to assess the
17 loading impact of overlashing on the pole, and the loading impact can be assessed on a
18 worst case pole for poles with similar characteristics. In these respects, FPL's practices
19 concerning overlashing are more reasonable than those being proposed by Gulf.

20 Similarly, TECO has allowed cable operator to provide notice after the fact for
21 overlashing in the past. *See* TECO's Resp. to FCTA Interrog. No. 20.

22 Q. What do you propose as a prudent, practical and cost effective solution for overlashing?

23 A. I recommend that cable operators be permitted to overlash existing strand provided that
24 they assess the loading impact on the pole within 30 days of overlashing. To the extent
25 that the loading analysis demonstrates that the overlashing brings the pole out of

1 compliance (or, as is more likely to be the case when poles are found to be overloaded,
2 that the pole was already out of compliance) the operator should notify the pole owner,
3 and make-ready should be planned.

4 Q. Is this ever done?

5 A. Yes, all the time. In fact, other Florida utilities, including TECO, have been doing this in
6 practice for years. Other Florida utilities have not performed any loading analysis on the
7 poles caused by overlashing. Tellingly, of the four utilities that filed storm hardening
8 plans on May 7, 2007, not one has pointed to a single instance in which overlashing has
9 caused a pole failure.

10 Q. Are you suggesting that overlashing should be permitted to bring a pole out of
11 compliance?

12 A. No. First, it is highly unlikely that the incremental wind load caused by overlashing will
13 bring the pole out of compliance. The strand-supported coaxial cable that typically
14 comprises the initial attachment is itself one of the attachments that contributes the least to
15 the wind loading of the pole. The wind load is determined by the diameter and length of
16 wires and cables attached to poles as well as the diameter of the pole and the area of
17 equipment on the pole. The area of each attachment is multiplied times the wind force
18 and its attachment height. The wind load is expressed in foot pounds which causes a
19 mechanical "moment" on the pole at the ground line. The final step in the calculation is to
20 multiply the wind load on each attachment times the height of the attachment above
21 ground i.e., the moment arm.

22 Coaxial cables, used by cable television companies, are smaller and lighter than
23 the common multi-conductor copper communications cables used by telecommunications
24 carriers. Moreover, initial attachment of strand-supported cable plant is handled through
25 the application and make-ready process where the pole strength is evaluated and

1 determined to be adequate. Even lighter than coaxial cables, however, are the fiber optic
2 conductors which are most commonly used for cable television construction today.
3 Indeed, .59-inch fiber optic conductors weigh only 50 pounds per 1000 feet.

4 In contrast, there are typically three power wires attached to the top of poles
5 (primary voltage wires) with the neutral and secondary wires a few feet below the
6 primaries but at least 40 inches above the highest communication cable. These wires
7 frequently weigh more than coaxial cable. Power equipment mounted on poles above
8 communications cables also adds wind load as well as the surface area of the pole itself.
9 All of the power lines and equipment wind loads have to be multiplied times the longer
10 moment arm determined by their higher attachment points above ground.

11 For all of these reasons and more, the loading effect of cable plant is often treated
12 as insignificant in utility practice. The loading effect of overlashing is even less
13 significant. In my experience, I have found no instance in which overlashed fiber was the
14 “straw that broke the camel’s back” by pushing an otherwise compliant pole into violation
15 of applicable loading criteria.

16 Second, any slight non-compliance that might possibly be caused by overlashing
17 could be quickly remedied. Attachers would be required to notify the pole owner within
18 30 days of overlashing and/or would assess the loading on the poles themselves.

19 Q. In your experience does the relative placement of cable operators’ strand and overlap in
20 the communications space on the poles have any beneficial effect on the stability of the
21 pole or ability to withstand wind and other forces?

22 A. Yes it can.

23 Q. Would you please explain?

24 A. Cable plant is deployed similar to power and telephone plant on pole lines. However, due
25 to the needs of each utility the cable television lines often turn or “pull off” the power pole

1 at locations where the power lines do not turn. This pull off must be guyed unless it pulls
2 off in two opposite directions as at some street crossings. These pull off cable lines with
3 their steel messenger wires provide guying effects on the affected poles which strengthen
4 the pole substantially because the pole is supported at 18 to 22 feet high. It is the same
5 effect as storm guying which Gulf supports. *See Gulf's Resp. to Staff Interrog. No. 2;*
6 *Gulf's Resp. FCTA Interrog. No. 2.* This helps keep the poles in a run stable and
7 minimizes cascading as the strand helps keep the lateral poles from pulling down adjacent
8 poles, thus keeping the circuits intact and causing fewer outages, unless of course there is
9 a tree collapse, in which event it is likely no design feature could keep the facilities from
10 being damaged.

11 Q. Is your suggested approach consistent with the NESC?

12 A. Yes. The NESC is a performance standard. The NESC rules provide for what is to be
13 accomplished. The utilities covered by the NESC, including power and communications
14 companies, all have practicable industry practices and reasonable engineering guidelines
15 available to assure compliance with the rules. An exhaustive engineering loading analysis
16 on every pole is not necessary or practicable every time a communication or power
17 attachment is added or modified on a pole. Indeed, given the delays and expense
18 associated with a full engineering loading analysis for overlashing, and the likelihood that
19 the overlash will not be a factor contributing to any overload, any such requirement would
20 not be cost-effective, prudent or practical.

21 Q. Is this consistent with generally accepted engineering practices for the utility's service
22 territory?

23 A. Yes. Several Florida pole owners and pole owners throughout the southeast allow cable
24 operators to overlash existing strand and notify the pole owner after the fact. It is
25 common practice throughout the industry to allow cable operators to notify pole owners

1 after the fact that they have attached to a “drop” pole—i.e., an oftentimes shorter pole
2 used to carry a few service lines to a residence or business.

3 Q. Has Gulf always required prior notice or prior approval for overlashing?

4 A. No, as Gulf explains in its answer to FCTA Interrogatory No. 19, “prior to Gulf’s storm
5 hardening plan, there was no specific protocol for notice if overlashing.” Significantly,
6 Gulf has provided no records of poles failing because of overlashing, stating in its answer
7 to FCTA Interrogatory No. 19, that “Gulf has not previously collected data on the impact
8 of third party overlashing on pole failure.”

9 Q. You have said that the loading impact of most overlashing is *de minimis*. Are there
10 situations in which overlashing could significantly increase the weight or bundle size of
11 the existing attachment?

12 A. Yes. There are situations where overlashing could increase the weight or bundle size in a
13 meaningful way such as when the resulting bundle size is significantly increased.

14 Q. Do you think that even overlashing resulting in significantly increased size bundles should
15 be allowed without prior notice?

16 A. At a minimum, I think there should be some incremental load for overlashing that does
17 not require a full blown loading analysis. New York takes this approach, for example.
18 For incremental loads caused by overlashing existing strand that exceed an agreed upon
19 threshold, I believe that a loading analysis can be performed by the attaching entity with
20 the results provided to the pole owner.

21 Q. What do you think should form the basis of an “agreed upon threshold?”

22 A. The rule adopted by the New York PSC provides that “a predetermined limited amount of
23 overlashing, that is not a substantial increase to existing facilities, shall be allowed,”
24 without notification and allows the attacher itself to make the determination. Specifically,
25 “[a]n Attacher, [sic] whose facility has a pre-existing NESC calculated span tension of no

1 more than 1,750 lbs., shall be allowed to overlash a pre-determined maximum load of not
2 more than 20% to the existing communications facility. Existing facilities with an NESC
3 calculated span tension of less than 1,000 lbs. shall be allowed a pre-determined overlash
4 of up to 40% of such pre-existing facilities.” *Proceeding on Motion of the Commission*
5 *Concerning Certain Pole Attachment Issues*, Order Adopting Policy Statement on Pole
6 Attachment, 2004 N.Y.P.U.C. LEXIS 306, *30 (N.Y.P.U.C. rel. Aug. 6, 2004). If the
7 attacher “determines that the addition of equipment and loading is greater than the pre-
8 determined limits, further assessment of the overlashed facility for its impact on the
9 overall pole loading is required to assure that the pole limits are not exceeded.” *Id.* In
10 those cases, the attacher would be required to “provide the pole Owner with a ‘worst case’
11 pole analysis from the area to be overlashed, to be sure that the additional facilities will
12 not excessively burden the pole structures.” *Id.*

13 Q. Do you have other concerns about Gulf’s requirement of 30 days’ advance notice for
14 overlashing?

15 A. Yes. It is my understanding that such advance notice combined with Gulf’s requirement
16 that it will “require pole strength and loading analysis prior to attachment or overlashing”
17 is a form of “approval” or “permitting.” See Gulf Answer to FCTA Interrogatory No. 14.
18 These requirements, however, are terms and conditions of attachment that is regulated by
19 the FCC and that the FCC has ruled that it is not reasonable for pole owners to require
20 permitting for overlashing or even to require prior approval after a 30 day notice period
21 because this unreasonably delays the provisioning of important services. Rule 25-
22 6.0342(8) provides that “Nothing in this rule is intended to conflict with Title 47, United
23 States Code, Section 224, relating to Federal Communications Commission jurisdiction
24 over pole attachments.”

1 Q. Please explain which relevant provisions in Appendix 5 relating to joint use attachments
2 do not meet or exceed the NESC so as to assure as far as reasonably practicable that third
3 party attachments do not impair pole safety and reliability, do not overload the pole and
4 are constructed, operated and maintained in accordance with accepted standards in the
5 utility's service area?

6 A. The requirements on Gulf Plate A- OZZ-3 are relevant. However, the requirement that
7 guy anchors be placed apart is not an NESC requirement, and it is not always practicable.
8 It should be stated as a preferred standard with some method of gaining exceptions for
9 locations where 4 feet is not available. FPL by comparison specifies 2 feet between
10 anchors.

11 Q. Do you have other concerns about third party attachers?

12 A. Yes. As set forth in part above, I have well founded concerns about how Gulf intends to
13 implement its joint use pole audits, which it includes as an integral component of its
14 overall Plan. I have attached as MTH-4 a copy of an email and attachment to Gulf dated
15 July 24, 2007, expressing these concerns. As expressed there, I am concerned that Gulf
16 will be conducting a complete safety inspection of the attachments on the poles and not
17 just a weight and loading analysis of third party attachments. *See* Gulf's Resp. to FCTA
18 Interrogatory No.27 (objecting to a question directed at this concern). However, there is
19 no mandate in the FPSC Docket No. 060198-EI storm hardening initiative #2 to do a
20 complete NESC safety audit nor a Gulf Power attachment standards audit. FCTA agrees
21 that serious safety violations of the NESC should be reported if found during the field
22 inspections and promptly repaired. However, this is required by NESC 2007 Section 214.

23 As we know from experience, there are many alleged violations of NESC
24 requirements and Gulf attachment standards which exceed the NESC on certain poles in
25 the field. It is frequently difficult or impossible to accurately determine if one or more

1 attachers caused a spacing or separation of communications and power violation or if the
2 power company caused it. These allegations can and should be vigorously disputed
3 because a power company does not have unilateral authority to dictate standards which
4 exceed NESC or decide who caused alleged violations. The NESC requirements are
5 always subject to grandfathering provisions. It is difficult at best to determine when
6 different cable and power facilities were installed and if they violated NESC rules at the
7 time.

8 Moreover, many clear violations of Gulf's standards and even NESC rules do not
9 affect pole strength or employee or public safety. If a complete NESC safety audit is
10 added to the pole strength assessment, it will require much more detailed work in scope of
11 the project. It will also require much more training of the field inspectors. A complete
12 safety inspection would undoubtedly be controversial and detract from the proper focus on
13 pole strength. At a minimum, Gulf should be required to seek input from, and incorporate
14 in good faith concerns raised by, third party attachers concerning any proposed safety
15 audit as well as the strength assessment guidelines.

16 **Third Party Input**

17 Q. In establishing its Plan did the Company seek input from and attempt in good faith to
18 accommodate concerns raised by third party attachers?

19 A. Yes and no. The Company did seek input from third party attachers. It submitted its Plan
20 to the attaching parties and asked for feedback. However, because of the limited
21 information provided by the company in the Plan concerning the incremental costs
22 associated with storm hardening, the joint use poles that would be impacted and the
23 specific design and construction criteria the Company would be using on joint use poles,
24 third party attachers were unable to identify all of their concerns or to provide a
25 cost/benefit assessment of the Plans on third party attachments. The cable operators did

1 provide specific feedback concerning the Company's attachment standards and procedures
2 for third party attachments. Specifically, cable operators pointed out the overly broad
3 scope of the Company's attachment standards and procedures and the ways in which the
4 standards and procedures conflicted with FCC precedent. See Comments of FCTA
5 Regarding Gulf Power Company's 2007 Storm Hardening Plan, Docket No. 070299-EI,
6 filed May 30, 2007, at 16-21. In addition, Gulf amended its Plan on August 14, 2007 at
7 which time it changed it planned grade of construction from Grade C to Grade B. FCTA
8 members have not yet had an opportunity to provide feedback on the amended plan.

9 Q. Has anything changed to affect your conclusion above?

10 A. Yes, the pole owners and FCTA have agreed to a "Process to Engage Third Party
11 Attachers" (MTH-3) that was developed by TECO. This Process is intended to provide a
12 mechanism for giving the level of engineering detail necessary for parties to assess the
13 economic impact of the plan and to provide input as to the specific methodologies being
14 employed, as required by the Rule. This Process, combined with on-site meetings and
15 prior notifications promised by Gulf, should alleviate concerns about the level of required
16 detail that currently is missing from the Plan and the ongoing need for third-party
17 attachers' participation.

18 Q. Does that conclude your testimony?

19 A. Yes.

CURRICULUM VITAE

M. T. (MICKEY) HARRELSON

M. T. (Mickey) Harrelson
P. O. Box 432
McRae, GA 31055

Phone: (912) 568-1504
Cell: (229) 860-1300
Fax: (912) 568-1502

Registered Professional Engineer (Electrical) GA#10724 (1976)
Registered Professional Engineer (Electrical) FL #51788 (1997)

EDUCATION: B.S. Industrial Engineering (Co-op) GA TECH, 1970

WORK EXPERIENCE:

- 1959- Worked part-time with Harrelson Electric Co., owned by my father.
- 1963 W. T. Harrelson, doing residential, commercial, & industrial electrical and repair work in McRae, GA.
- Dec. 1963- Co-op student of Georgia Power Co. in Electric Distribution Operating,
Mar. 1970 McRae, GA, & Commercial Sales, North Atlanta.
- Apr. 1970- Lieutenant in U. S. Army Air Defense, Minneapolis, MINN, & Yong Son,
Jan. 1972 KOREA. Served as Battery Commander, Korea. Military Status:
Inactive, Army Reserves; Rank: Captain.
- Feb. 1972- Operating Engineer, Brunswick, Georgia Power Co.; Designing,
June 1974 operating, and maintaining distribution system and operating transmission system.
- June 1974- Senior Commercial Marketing Engineer, Brunswick. Selling wise use of
Feb. 1976 electricity to new and existing commercial customers in Brunswick area. This included lighting design to I.E.S. standards, and consultations regarding the National Electrical Code.
- Feb. 1976- Operating Engineer, St. Simons Island, Ga. Power; Designing, operating,
June 1978 & maintaining distribution system & operating transmission system.
- June 1978- District Engineer; Supervised engineering and operation of Brunswick
May 1986 District of Ga. Power Co., including Kingsland Operating Headquarters.

- May 1986- Sept. 1989 Area Manager, McRae, Ga. Power Co; Restructure McRae, Eastman, Hazlehurst into area operation, and supervise and coordinate all company activities in the area.
- Sept. 1989- April 1992 District Power Delivery Manager, Milledgeville District; Manager of Engineering, Construction, & Maintenance of the electric distribution system and operation of the transmission & distribution system.

Note: During 28 years with Georgia Power Company, I was involved with claims, damage and accident investigations. From 1978 through 1992, I was in charge of these activities at my location.

- April 1,1992 Resigned from Georgia Power Company, Reason for leaving: Early retirement incentive package gave excellent opportunity to pursue independent consulting engineer goals.
- April 1,1992 to present Electric Utility Consulting Engineer.
Investigated accidents and testified in matters involving the National Electrical Safety Code, OSHA regulations, utility company safety manuals, employee training courses, accepted good work practices, and the National Electrical Code. These cases have involved electrical contact, flash, and burn injuries, collisions with poles and guy wires, falls from poles, etc., hydraulic oil fires, crushing injuries, property losses from fires, stray voltage, etc. The companies involved have been electric, telephone, cable TV, and product manufacturing companies.
- I do management consulting and safety and engineering training for electric cooperatives, engineering consulting companies and private industry
- I do electric power line inspections for electric cooperatives as required by the Rural Utility Service.
- I inspect power lines and communications lines built jointly for National Electrical Safety Code compliance. I teach N.E.S.C. compliance and train field engineers and technicians in joint use compliance. I assist CATV, Power, and Telephone companies in interpreting the NESC and applying its rules to joint use of utility poles.

OTHER COURSES AND SEMINARS:

- 1974 13 weeks Commercial Sales Training by Ga. Power Co., including interior & exterior lighting design, & National Electrical Code.
- 1975 1 week General Electric Outdoor Lighting School, Hendersonville, NC.
- 1976 8 weeks Electric Operations Training by Ga. Power Co.

- 1977 1 week Principles of Leadership Training, Ga. Power Co.
1979 1 week Basic Management Training by Ga. Power Co.
1980-1985 Served as "Leader" of Engineering Dept Quality Circle.
1981 1 week Communications-General Training by Ga. Power Co.
1982 1 week Human Relations Skills Training by Ga. Power Co.
1987 3 days Interpersonal Skills Seminar by Ga. Power Co.
1988 1 week Management Grid School, Mobile, AL, Training by Southern Co.
1988 13 weeks Community Leadership Class sponsored by University of GA
Cooperative Extension Service and Telfair County.
1989 1 week Negotiating Edge Seminar, Athens, GA., Training by Ga. Power
Co. and Susan Wise
1989 Basic Economic Development Course, GA Institute of Technology
1990 3 months- Committee assignment (met bi-weekly) to formulate Ga.
Power Company Guarantee Policy
1991 6 months-Committee assignment (met bi-weekly) to develop "District
Operations Performance Measurement" facilitated by Ernst & Young Co.
1991 3 months-Committee assignment (met bi-weekly) to assess Georgia
Power Company Marketing Dept Readiness for Incentive pay.
1992 1 week advanced Negotiating Skills Seminar, Peachtree City, Training by
Ga. Power Co. & The Executive Speaker, Inc.
1992 1 day IEEE Seminar on 1993 National Electrical Safety Code
1993 2 day NRECA Safety Accreditation Team Training & Testing Seminar
1994 3 day Seminar-The Development & Application of the National Electrical
Safety Code by Allen Clapp
1995 2 day ILCI (International Loss Control Institute, Inc.) Seminar on
accident investigation
1996 1 day IEEE Seminar - "Changes in me 1997 NESC."
1997 3 day Seminar - "Application of 1997 NESC."

MEMBERSHIPS AND AFFILIATIONS:

- 1970-present Member, Georgia Tech Alumni Association
1974-present Member, Georgia & National Society of Professional Engineers
1978-1986 Member, Glynn County GA Electrical Inspection Board
1992-present Member, Telfair Co. Chamber of Commerce
1992-present Member, Institute of Electrical & Electronics Engineers (IEEE)
1993-2002 Board Member, Telfair County Industrial Development Authority

- 1993-2002 Member, Illuminating Engineering Society of North America (IECNA)
- 1993-present Rural Electric Safety Accreditation Program (RESAP) certified accreditation inspector
- 1994-present Member, National Fire Protection Association

TESTIMONY BY MICHAEL T. HARRELSON, P. E.

1. **5-2006 to 8-2007** **Florida Public Service Commission for FCTA**
Michael Gross Attorney Written
comments and Maria Browne, Attorney verbal
comments Beth Keating, Attorney
2. **4-27-06 & 5-1-06** **FCTA, et. al vs. Gulf Power Company Before the FCC**
Testimony

John Seiver
Cole, Raywid & Braverman, L.L.P.
1919 Pennsylvania AVE, NW – Suite 200
Washington, D.C. 20006
3. **3-31-06** **FCTA, et. al vs. Gulf Power Company Before the FCC** Written
Testimony

John Seiver
Cole, Raywid & Braverman, L.L.P.
1919 Pennsylvania AVE, NW – Suite 200
Washington, D.C. 20006
4. **3-16-06 & 3-21-06** **FCTA, et. al vs. Gulf Power Company Before the FCC** Deposition
Testimony

John Seiver
Cole, Raywid & Braverman, L.L.P.
1919 Pennsylvania AVE, NW – Suite 200
Washington, D.C. 20006
5. **3-13-06** **Comcast of Arkansas v. Entergy Arkansas Before the FCC** Deposition
Testimony

John D. Thomas
Hogan & Hartson LLP
555 Thirteenth ST, NW

Washington, D.C. 20004

6. **4-16-05 Louisiana Public Service Commission** Written
Testimony
For LCTA
John D. Thomas
Cole, Raywid & Braverman, L.L.P.
1919 Pennsylvania Ave., NW - Suite 200
Washington, D.C. 34358
7. **2-15-05 CTA Arkansas vs. Entergy** FCC Written
Testimony
John D. Thomas -- *for Plaintiff*
Cole, Raywid & Braverman, L.L.P.
1919 Pennsylvania Ave., NW - Suite 200
Washington, D.C. 34358
8. **1-10-05 Clinton vs. Florida Keys Electrical Cooperative, Inc.** Deposition
& Trial
Sixteenth Judicial Circuit Court in and for Monroe Co., Florida
Eric Peterson -- *For Defendant* H. Clay Roberts -- Plaintiff
Peterson Benard Proenza, Roberts, Hurst, P.A.
P. O. Drawer 15700 2900 W 28th Terrace, Suite
700 West Palm Beach, FL 33416 Miami, Florida 33133
9. **12-03-04 MEAG vs. Goodman** Testified at
Hearing
Mr. Robert Wilmot -- *For Plaintiff*
P. O. Draw 1287
Tifton, GA 31793
MEAG Power Company right-of-way encroachment suit to clear transmission
line
right-of-way of mobile homes.
10. **10-22-04 Caldwell vs. Howard Industries, No. 4:03-cv-198-3**
Deposition
United States District Court, Middle District of Georgia, Columbus
Division
Lester Tate -- *For Plaintiff* William T. Mitchell, Defense
Akin & Tate Crusier & Mitchell, LLP
P. O. Box 878 3500 Parkway Lane
Cartersville, GA 30120 Norcross, GA 30092

11. 6-23-04 Comcast Cable vs. Pacificorp
Deposition

Angela W. Adams -- *For Claimant*
Ballard Spahr Andrews & Ingersoll, LLP
One Utah Center, Suite 600
201 Main Street
Salt Lake City, Utah 84111-2221

12. 6-8-04 Saffold vs. Aldrich Rent-All
Deposition

Heather B. Bush -- *For Defendant*
Peterson Bernard
1550 Southern Boulevard, Suite 300
West Palm Beach, Florida 33416

13. 9-04-03 Perkins v. Georgia Power Company and Altec
Deposition

Attorneys Langston Bass and Hugh McNatt
Defendant
State Court Candler Co., GA

Contractor Lineman contacted 27,000 volts hand-to-band. He was not wearing rubber gloves. He lost both arms. He sued Altec for inadequate bucket truck design and GA Power for inadequate planning and supervising of work. *Settled out of Court.*

14. 5-02-03 McKeown v. CHELCO, et al Deposition
& Trial

Attorney Alan E. Horkey -- *For Defendant*
700 S Palofex Street, Suite 170
Pensacola, Florida 32501
Circuit Court, Walton Co., FL

A teen-aged boy hit power pole with pick-up truck in rain on a curve. He had a severe head injury. He sued electric co-op, claimed they should have moved the pole since it had been hit twice before. Pole location complied with code and DOT guidelines. *Jury verdict gave court cost only to plaintiff.*

15. 11-09-01 Duffie vs. Clay Electric Co-op & Cox Cable et al Deposition &
Arbitration

Attorney Craig Cooley -- *For Defendant*
200 East Robinson Street, Suite 555
Orlando, Florida 32801
Circuit Court Alachua Co., FL

A motorcycle rider hit a power line which fell across a U. S. Highway. A contributing factor was that a Cox Cable anchor had been improperly installed. This allowed a Clay

Electric Co-op pole to break in four pieces. *Settled at arbitration by Clay, Cox and two Cox sub-contractors.*

16. 12-13-00 Darley vs. Amusements of America, Inc.

Deposition

Attorney Robert R. Gunn -- *For Defendant*
P. O. Box 1606
Macon, GA 31202
State Court, Bibb County, GA

A young man got electric shock when he took hold of a metal rail on the platform of an amusement ride. *Settled*

17. 11-21-00 Causey vs. Okefenoke REMC

Deposition

Attorney Mark Barber -- *For Defendant*
136 N Fairground Street, Suite 100
Marietta, GA 30060
Superior Court, Brantley Co., GA

An onlooker was killed by burning transformer oil. He was watching a lineman attempt to stop an oil leak when the explosion and fire occurred. *Settled*

18. 10-18-00 Malin vs. McElmurray & Oellerich Electrical Service Deposition & Trial

Attorney David Bell -- *For Plaintiff*
P.O. Box 1011
Augusta, GA 30903
Superior Court, Richmond Co., GA

A young man was killed while cleaning pipes in a milking barn when he touched a light fixture which was not grounded. *Jury verdict for \$1,000,000.00*

19. 10-04-00 Moses vs. Bill's Dollar Store, et al Deposition
& Trial

Attorney David Bell -- *For Plaintiff*
P.O. Box 1011
Augusta, GA 30903
State Court, Gwinnett Co., GA

A gas company employee was killed when he touched a metal rack which held an air conditioning unit. The unit was not grounded. *Settled*

20. 1-25-00 Byrd vs. Glades Electric Co-op
Deposition

Attorney Robert Swartz -- *For Defendant*

Ft. Lauderdale, Florida
Circuit Court, Glades Co., FL

A flatbed truck crane operator was killed when he put the steel cable into a 7200-volt line. He jumped clear of the truck, then attempted to get in the cab and was electrocuted. *Settled.*

21. 9-10-99 Scruggs vs. Georgia Power Company
Deposition

Attorney Rowland Dye -- *For Defendant*
P. O. Box 2426
Augusta, GA 30903
State Court, Georgia

A truck hit a low power line service which had been previously hit by an over-height load of hay. *Settled.*

22. 3-12-97 Price vs. City of Thomasville Deposition
& Trial

Attorney Hugh McNatt -- *For Defendant*
Vidalia, GA
Federal Court, Albany, GA

A contractor lineman was badly burned and electric shocked when he lost control of a large wire and violated several other safe-work practices. *Settled.*

23. 12-06-96 Dennard vs. Altec
Deposition

Attorney Lester Tate -- *For Plaintiff*
P. O. Box 878
Cartersville, GA 30120

A lineman's hand was crushed when it was caught between the control lever of his bucket truck and the bottom of a transformer. The control levers were poorly designed. *Settled.*

24. 7-17-96 Raulerson vs. Okefenoke REMC
Deposition

Attorney Richard Rumrell -- *For Defendant*
One Hundred BLDG, Suite 250
Jacksonville, FL 32256
Circuit Court, Duval Co., FL

A laborer was killed when the electric meter pole he was setting contacted a 14,400-volt power line. Telephone drop wires and cable television were a factor in making the power line lower. *Settled.*

25. 7-02-96 McCoy vs. Coach & Campers of Atlanta
Deposition

Attorney Nikolai Makarenko, Jr, -- *For Defendant*
100 Galleria Parkway, Suite 1510

Atlanta, GA 30309
State Court, DeKalb Co, GA

A customer separated his shoulder when the RV home shocked him. He was on the ladder on back, touched a grounded chain link fence and fell. The electric circuit to the RV was not grounded. *Settled.*

**26. 6-07-96 Habeishi vs. Greystone Power Corp. Deposition
& Trial**

Attorneys Tisinger, Tisinger, Vance & Greer -- *For Defendant*
P.O. Box 2069
Carrollton, GA 30117
Federal Court, Northern District, GA

The electric power was off to a traffic signal because an electrical connection failed. It had been made improperly by Fulton County Traffic Dept. Two cars collided in the intersection killing both wives of the two drivers. *Jury Verdict \$7,000,000.00!*

**27. 5-16-96 Crossin vs. Central Illinois Light Co.
Deposition**

Attorney Richard Glisson - *For Plaintiff*
837 South Fourth Street
Springfield, Illinois 62705
Circuit Court, Sangamon Co., Illinois

A lineman was electrically shocked when he disconnected a ground wire at the top of a joint transmission and distribution pole. A transformer was connected to the pole ground. The ground was burned open before it connected to the distribution neutral. *Settled.*

**28. 3-16-95 Lockhart vs. TCI Cable & BellSouth Deposition
& Trial**

Attorney M. Francis Stubbs - *For Plaintiff*
P. O. Box 9
Reidsville, GA 30453
Superior Court, Toombs Co., GA

A young man was killed when he struck a TCI guy wire with his neck while riding a motorcycle. The guy wire was abandoned but not maintained in a safe condition. The young man was violating the law by riding off the roadway. *Jury Verdict Defendant's Verdict.*

**29. 9-21-94 Vandevender vs. Klein Tools, Inc. Deposition &
Arbitration**

Attorney Michael Smith - *For Defendant*
240 Third ST
Macon, GA 31201
Federal Court, Middle District, GA

A truck operator was badly shocked and burned when he removed his rubber gloves and touched a bucket truck while a hot 7200-volt line was on the ground nearby. He sued Klein Tool Company claiming the grip used broke the wire allowing it to fall. *Arbitration-Defendant's ruling 2 to 1.*

30. 8-24-94 Underwood vs. Georgia Power Company
Deposition

Attorney Rowland Dye — *For Defendant*
P.O. Box 2426
Augusta, GA 30903
State Court, Emanuel Co., GA

A laborer attempted to use a 20-foot re-bar to unclog a grain bin auger. He contacted a 7200-volt. power line with the metal bar and lost one arm and had serious burns. He claimed the line was too close. The line complied with the NESC. *Settled.*

31. 4-20-93 Buckner vs. Colquitt Electric Co-op
Deposition

Attorney John Austin — *For Defendant*
400 Perimeter Center Terrace, Suite 1050
Atlanta, GA 30346
Superior Court, Colquitt Co, GA

A laborer was shocked and fell from a pecan tree. He was using a 20-foot long aluminum pole to knock pecans from the limbs. *Settled.*

32. 8-05-90 Lockett vs. Georgia Power Company Deposition
& Trial

Attorney Hugh McNatt — *For Defendant*
Vidalia, GA
Superior Court, Telfair Co., GA

Three laborers were raising an aluminum extension ladder under a 7200-volt power line. One was killed, one shocked, one was not hurt. The power line complied with the NESC. *Jury Verdict paid funeral expenses only.*

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Proposed amendments to rules regarding)	Docket No. 060173-EU
overhead electric facilities to allow more)	
stringent construction standards than required)	
by National Electric Safety Code)	
and)	
)	
)	
In re: Proposed rules governing placement of)	Docket No. 060172-EU
new electric distribution facilities underground,)	Filed: August 11, 2006
and conversion of existing overhead)	
distribution facilities to underground facilities,)	
to address effects of extreme weather events)	
_____)	

AFFIDAVIT OF DR. LAWRENCE M. SLAVIN

The undersigned, being duly sworn, states as follows:

1. I am currently Principal of Outside Plant Consulting Services, Inc. Previously, I had an extensive career at Lucent (formerly AT&T), Bell Telephone Laboratories and Telcordia Technologies (formerly Bellcore). My career at Bell Laboratories, at which I was selected to be a Distinguished Member of Technical Staff, spanned more than 28 years (1961-1989), primarily in telecommunications product design and development. During the subsequent 12 years (1990-2001), I was a member of Telcordia's research and professional service organizations, and served as Director of the Network Facilities, Components, and Energy Group, responsible for requirements, testing, and analysis of outside plant media, components, and powering for telecommunications applications, as well as related installation and construction guidelines.

2. I received my Ph.D in mechanical engineering from New York University in 1969, my Master of Science in engineering mechanics from New York University in 1963 and my Bachelor of Science in mechanical engineering from The Cooper Union for the Advancement of Science & Art in 1961.

3. I have been an active member of NESC Subcommittee 5 since 1998, including the development of the 2002 edition of the NESC and the recently issued 2007 edition. Subcommittee 5 (Overhead Lines – Strength & Loading) is directly responsible for specifying the storm loads and associated structural strength requirements referenced by the PSC. I am Chair of Working Group 5.7 (Seminars and Presentations; Subcommittee 5), and have served on Working Group 5.2 (Complete Revision of Sections 25 and 26; Subcommittee 5), and on the immediately relevant Working Group 5.8 (Application of Extreme Wind to All Structures; Subcommittee 5). I have also been Chair of Working Group 4.10 (New Ice Loads and Clearances; Subcommittee 4, Overhead Lines – Clearances), and serve on as the Accredited Standards Committee ASC-O5 (responsible for *ANSI O5.1, Wood Poles, Specifications and Dimensions*).

4. As Chair of WG 5.7, I have been responsible for organizing and coordinating the following industry information sessions, as well as providing some of the associated technical presentations:

- ***Panel Session: Structural Reliability-Based Design of Utility Poles and the National Electrical Safety Code, 2003 IEEE Transmission & Distribution Conference and Exposition, 2003***
- ***Panel Session on National Electrical Safety Code (NESC), 2002 Edition, ANSI C2, 2001 IEEE Transmission & Distribution Conference and Exposition, 2001***


- ***Panel Session on Proposed Changes to Strength & Loading Requirements for the 2002 Edition of the National Electrical Safety Code (NESC), IEEE Power Engineering Society, Towers, Poles & Conductors (TP&C) Subcommittee Meeting, 2000***

I will be chairing a panel session regarding the strength and loading requirements of the 2007 edition of the NESC, and presenting related technical information, at the TP&C Subcommittee Meeting in January 2007.

5. Appendix 1 attached to this Affidavit is a report I have prepared concerning proposed Rule 25-6.034 that is being considered in this proceeding. As I discuss in detail in the report, the proposed rule's requirement that electric utilities be guided by the extreme wind loading standards specified in the 2002 edition of the NESC could result in substantially higher facilities costs and lead to significant unintended consequences. Accordingly, I recommend that this requirement not be included in the proposed rule, or (if this recommendation is not accepted), that certain limitations be adopted.

6. Appendix 2 attached to this Affidavit provides more detailed information concerning my career in the telecommunications and related utility industries, including my activities in relevant professional organizations, such as the Main Committee and several Subcommittees for the NESC.

Further Affiant sayeth naught.


Lawrence M. Slavin

Subscribed and sworn to before me this 10 day of August, 2006.


Notary Public, State of NJ

My commission expires:
May 6, 2009

JENNIFER-L. OSORIO
NOTARY PUBLIC OF NEW JERSEY
MY COMMISSION EXPIRES MAY 6, 2009

APPENDIX 1

Report Concerning Proposed Rule 25-6.034 As It Relates to Extreme Wind Loading Requirements

1. Introduction

This note provides comments regarding the proposed Florida Public Service Commission (PSC) Rule 25-6.034 to require that the extreme wind loading of the 2002 edition of the National Electrical Safety Code (NESC) be reflected in the design of electric utility-owned poles, including those with third-party (telecommunications) attachments. In particular, NESC-2002 Figure 250-2(d), part of NESC Rule 250C, is cited as a guide. The stated objective of the PSC is to "enhance reliability and reduce restoration costs and outage times" due to hurricane events, such as recently experienced during Hurricane Wilma. The present comments discuss the NESC rules (2002 edition), as applicable to the State of Florida, recent relevant discussions and decisions within the NESC Committee, and the impact of adopting the Extreme Wind Loads of Rule 250C throughout Florida.

2. NESC-2002

The NESC is an American National Standards Institute (ANSI) standard based upon a consensus of those substantially concerned with its scope and provisions, including the Institute of Electrical and Electronic Engineers (IEEE), which also acts as the Secretariat. Other members of the NESC Committee include organizations representing providers of electric power or communications service, their suppliers, and other affected or interested parties. The NESC includes various provisions for the safeguarding of persons from hazards from the installation, operation, and maintenance of electric supply and communication lines and equipment. The rules contain the basic provisions that are considered necessary for the safety of employees and the public.

In general, adherence to the NESC is voluntary; however, many commissions throughout the United States routinely adopt the latest edition, or specific editions, for application within their jurisdictions. For example, the Florida PSC has adopted the 2002 edition.

Sections 25 and 26 of the NESC provide the required strengths and loadings of utility poles and other structures. Section 25 specifies the type storm loads that Grade B or C utility lines are required to withstand. ("Grades of Construction" are discussed below.) Section 26 specifies the required strengths of the structures, as subject to the storm loadings specified in Section 25. (Most of Section 26 -- e.g., Rule 261 -- applies to Grade B or C construction.) Two types of storms are specified -- (1) Combined Ice and Wind Loading (Rule 250B) and (2) Extreme Wind Loading (Rule 250C).

2.1 Combined Ice and Wind (Rule 250B)

Rule 250B refers to the Loading District map, NESC Figure 250-1, reproduced below. The three loading districts in the United States (Heavy, Medium and Light) specify the amount of radial ice buildup and a concurrent wind pressure. The Heavy and Medium districts in the north and central portions of the United States are subject to $\frac{1}{2}$ and $\frac{1}{4}$ -

inch radial ice buildup, respectively, on all power and communications wires, cables, and conductors, and a concurrent wind pressure corresponding to 40 m.p.h.. The Light district in the southerly portion of the country, including Florida, is assumed to experience no ice buildup, but a wind pressure corresponding to 60 m.p.h. The latter wind speed, although only 50% greater than that assumed in the rest of the country, corresponds to a wind pressure of more than twice that in the Heavy or Medium districts, due to the strong (non-linear) dependence of the wind force on wind speed.¹ However, the lower pressure in the Heavy or Medium district is applied to a greater "sail area" due to the ice buildup on the wires and conductors. Depending upon the wire or conductor diameters, and the ice buildup levels, the resultant transverse loads in the "Light" district may exceed that in the so-called "Heavy" or "Medium" areas. In addition, the application of Rule 250B requires "overload" factors to be applied to the calculated wind forces to provide a conservative margin of safety when selecting appropriate pole sizes. A factor of 2-to-1 is applied to the common Grade C construction, and a factor of 4-to-1 is applied to Grade B construction, where required.² (See Section 2.3.) This procedure results in a fairly robust design that experience has shown to provide reliable, safe service.

PART 2. SAFETY RULES FOR OVERHEAD LINES




Fig. 250-1
General Loading Map of United States
with Respect to Loading of Overhead Lines

¹ The wind pressure, or force, is proportional to the square of the wind speed.

² The present discussion assumes "tangent" pole lines, without significant corner angles where guys may be required. For such tangent lines, the transverse wind loads typically represent the critical design condition.

Rule 250B applies to all Grade B or C structures, regardless of height, and is typically used by most utilities to determine the strength requirements for distribution poles.

2.2 Extreme Wind (Rule 250C)

NESC Rule 250C refers to various wind maps, of which Figure 250-2(d), including the state of Florida, is reproduced below. The wind speeds³ vary from approximately 95 m.p.h. (interpolated) in the north of the state to as much as 150 m.p.h. at the southern tip. The minimum 95 m.p.h. speed corresponds to a wind pressure of 2½ times that of the 60 m.p.h. wind assumed in the Light loading district. The maximum 150 m.p.h. speed corresponds to a wind pressure of more than six times that due to the 60 m.p.h. wind. However, the corresponding overload factors for Rule 250C are lower than that of Rule 250B, somewhat reducing the wide divergence in pole strength requirements. Nonetheless, if applicable, the impact on pole strength and sizes in Florida, and on utility construction practices and costs, would be major, as discussed in detail in Section 4. For various reasons, as discussed in Section 3.1, the NESC only applies Rule 250C to structures exceeding 60 feet in height above ground. This effectively exempts the vast majority of distribution poles. For cases where both Rule 250B and 250C apply, the larger effective loads would determine the required pole strength.




Fig 250-2(d)
 Eastern Gulf of Mexico and Southeastern US Hurricane Coastline

³ Figure 250-2(d) refers to "3-second gust wind speeds", which is approximately 20% greater than the 1-minute average wind speed used as the basis for categorizing hurricane levels by the Saffir-Simpson Hurricane Scale.

2.3 Grades of Construction

Section 24 of the NESC defines three Grades of Construction intended to distinguish between various situations, requiring varying levels of reliability, as implemented by the overload factors described above. In general, these grades depend upon the combination of voltage levels present in the power and communications conductors supported on the same poles, as well as various details, as specified. Most distribution poles carrying "primary power" (> 750 volts) at the upper portion of the pole, and communications cables below, are in the Grade C category. If the adjacent lines cross railroads tracks or limited access highways, a greater reliability level is required, corresponding to Grade B. Most power utility-owned poles are in the Grade C category.

The third grade of construction is Grade N, and applies if the voltages do not exceed 750 volts, corresponding to the lowest level of reliability.⁴ This includes joint-usage poles supporting only "secondary power" (< 750 volts) or poles supporting only telecommunications cables.

The NESC does not provide specific storm loading or strength requirements for Grade N structures. NESC Section 25 (Loadings for Grades B and C) is not applicable to Grade N, and Section 26 (Rule 263) only states that "[t]he strength of Grade N construction need not be equal to or greater than Grade C" and that "[p]oles used for lines for which neither Grade B nor C is required shall be of initial size or guyed or braced to withstand expected loads, including line personnel working on them." This lack of specificity for Class N poles allows wide variability in application with respect to selecting appropriate pole strengths to withstand storms.

2.4 Required Strength & Pole Class

Based upon the wind pressures corresponding to the storm loads, as applicable, an appropriate strength pole may be selected. Wood pole sizes and strengths are specified in *ANSI O5.1, Wood Poles, Specifications and Dimensions*. ANSI-O5.1 provides a pole classification system based upon the ability of a pole to withstand lateral loads placed near the top of the pole, in a cantilever situation, such as may correspond to transverse wind loads on a pole with attachments. For example, a popular size Class 4 pole would typically (on the average) withstand a lateral load of 2,400 lbs applied 2 feet from the tip of the pole. A Class 3 pole is stronger, and would withstand 3,000 lbs. Within poles of Class 1 - 10, lower class number poles correspond to stronger (*i.e.*, larger diameter) poles. (Poles of strength greater than Class 1, are classified as H1, H2, and so on) with strength increasing with the H-number.)

Thus, a pole may be described as that supporting a specific "grade" of construction, corresponding to a level of required reliability (Grade B or C), or by a "class" size which is selected to match the strength needed to achieve the required reliability level. The strength is determined and calculated based upon the specified loading details (ice buildup and/or wind speed), the number and size (diameter) of the attachments to the pole, the span length between adjacent poles, and the grade of construction (via the overload factors discussed above).

⁴ Grade B applies if the adjacent lines cross railroads tracks or limited access highways.

3. Upcoming and Future Editions of NESC

The 2007 edition of the NESC has recently been issued (August 2006) and is effective as of February 2007. Regarding storm loadings, several significant changes were introduced. Although Rule 250B was left unchanged, a new Rule 250D was added: "Extreme Ice with Concurrent Wind Loading." Similar to Rule 250C, Extreme Wind Loading, Rule 250D would only apply to structures exceeding 60 feet in height, exempting most distribution poles. In any case, this storm load would not have an impact in Florida due to the low associated ice (0-in.) and concurrent wind (30 m.p.h.) loads.

It is particularly interesting that Rule 250C has been modified for the common Grade C construction applications. In previous editions, the overload (design) factors for Grade B and C construction were the same, in spite of the greater implied reliability for the Grade B situations. This inequity was corrected in the 2007 edition by a *reduction* of as much as 25% in the effective design loads for Grade C construction. Thus, in contrast to possibly extending the Extreme Wind Loading to a larger category of structures and applications (e.g., poles \leq 60 feet height) the NESC requirements, where applicable, have been reduced. Nonetheless, there had been extensive effort and discussions regarding the possible extension of Rule 250C to structures of all heights, as described below.

3.1 Extreme Wind Loading -- Discussions

There is a seemingly eternal debate within the NESC Committee to consider eliminating the 60-foot exemption -- so that poles of all heights would then be subject to extreme wind loading. Such a revision was discussed within the NESC Committee with regard to the 2007 edition but, once again, was rejected. In fact, as described above, where applicable -- *i.e.*, poles taller than 60 feet -- the design requirement for Extreme Wind was actually reduced in severity for Grade C construction.

The rationale for rejecting consideration of extreme winds for "distribution" poles (*i.e.*, poles < 60 feet tall) is that the vast majority of industry experiences indicate that almost all damage to such lines is caused by wind-blown debris such as falling branches, and not by the wind forces acting directly on the wires and poles. In that case, little would be gained by attempting to design such poles to withstand the direct hurricane wind forces. The NESC Loading Section (NESC Section 25) does not explicitly use the term "distribution" when referring to these applications, but the 60-foot height threshold was chosen intentionally to exclude the vast majority of such poles. (In contrast, taller structures, such as critical transmission towers, would benefit from such a requirement.) In addition, to the best of my knowledge, the NESC Committee has never discussed extending any of the storm loads of Section 25 of the NESC (*i.e.*, Combined Ice and Wind or Extreme Wind) to Grade N applications, including telecommunications-only poles or joint-use poles with only secondary power (< 750 volts). Thus, the proposal of the PSC to extend Rule 250C to all distribution poles, regardless of height or grade of construction, would appear to be a major departure from present considerations in the NESC Committee, or industry in general. Thus, it would not appear to be "reasonably practical, feasible, and cost-effective" (to quote from proposed Rule 25-6.034(5)) to attempt to apply Rule 250C to Grade N joint-use distribution poles.

Related discussions within the NESC Committee to extend the Extreme Wind loading to structures of all heights (including distribution poles), focused on a particular change proposal, developed within Working Group 5.8, that would limit the impact of such an otherwise potentially dramatic change. In particular, for the Light Loading District portion of the country, which includes Florida, there would be no impact for distribution structures. However, based upon a multitude of industry comments objecting to even this diluted version of an Extreme Wind requirement for distribution poles throughout the country, this proposed change was not incorporated into the 2007 edition. It may be expected that this (rejected) change proposal will serve as a starting point for similar considerations for the 2012 edition of the NESC.

3.2 Future NESC Meetings (2012 Edition)

Although the 2007 edition of NESC is being issued essentially as this report is being written, efforts on the development of the subsequent 2012 edition are already being anticipated by Subcommittee 5. Due to the general interest in the effects of storm loads, such as hurricanes, and the effort required to properly consider the various aspects, Subcommittee 5 typically begins its meetings considerably earlier in the code cycle than most other subcommittees. Thus, initial meetings for development of the 2012 edition probably will begin in 2007. As a precursor, Working Group 5.7 of Subcommittee 5 (chaired by myself) will hold a panel session in January 2007 for the benefit of interested members of the power industry (IEEE Power Engineering Society, TP&C Subcommittee). The panel session will address the changes adopted in the 2007 edition, but will also discuss some of the proposals that were not accepted. The proposed (rejected) changes to Rule 250C, including the proposed extension to distribution structures, will be of particular interest, and will likely generate comments to be considered in the development of the 2012 edition.

4. Impact of Extending Rule 250C

The unlimited application of Rule 250C to all poles would have a major impact on the cost and operations of the utilities and the third party attachers, and would likely significantly affect the system reliability and restoration efforts, as well as public safety -- albeit not necessarily in the manner expected by the PSC.

4.1 System Cost

For electric utility-owned joint-use Grade N, Grade B or Grade C pole applications, the additional pole costs will depend upon the extent to which the proposed Extreme Wind load would exceed "reasonable" (albeit non-mandated) Grade N loads, and the already required Combined Ice and Wind load for Grade B or C applications for poles not exceeding 60 feet in height. Any increased strength requirement leads to stronger (larger diameter) poles, or a correspondingly greater number of poles (resulting in shorter span lengths), both of which would obviously be more expensive.

Figure 1 illustrates the relative pole strength in comparison to that currently required for the common Grade C joint-usage distribution application; e.g., including primary power

(> 750 volts) with telecommunications cables mounted below the power cables.⁵ Assuming the pole does not exceed 60 feet in height (65 feet in length⁶), such a pole must be designed to the present Combined Ice and Wind Loading (NESC Rule 250B, Figure 250-1, Tables 250-1, 253-1 and 261-1A). For present purposes, a tangent line (no corner angles) is assumed, for which the design is based upon the ability to withstand the transverse wind loading. For Florida, located in the NESC Light Loading District (Figure 250-1), this corresponds to a wind speed of approximately 60 m.p.h., but with an additional overload/design factor of approximately 2-to-1 for Grade C, and 4-to-1 for Grade B. For Grade N, a 1-to-1 design factor is conveniently ("reasonably") assumed. For the proposed application of Extreme Wind requirements (NESC Rule 250C), the wind-speed for Florida ranges from less than 100 m.p.h. (assumed to be 95 m.p.h.) in north-central area, to as much as 150 m.p.h. at the southern tip.⁷




Figure 1
 Relative Distribution Pole Strength vs. Typical Grade C Strength Requirements (NESC-2002)

The three solid bars to the left side of Figure 1, labeled "N", "C" and "B", depict the relative magnitude of the present required pole strength for a Grade N, Grade C, or

⁵ Grade B construction would typically be limited to special situations (such as railroad crossings and limited access highways).

⁶ Wood poles are available in 5 foot increments, and are buried at a depth of 10% the length plus 2 feet, with a slightly greater depth for poles shorter than 40 feet; e.g., a 40-foot pole is buried at a depth of 6 feet, resulting in a 32 feet height above ground. (See ANSI-O5.1 wood pole standard.)

⁷ A pole length of 40 feet is assumed. This parameter has only a minor effect on the results.

Grade B application. The seven cross-hatched bars to the right depict the relative magnitude of the required pole strength (which under the proposed rule would be the same for Grade N, C and B poles) due to Extreme Wind loads, at the wind speed indicated, should Rule 250C be directly extended to such applications. The results in Figure 1 thus show that the increased loading for an otherwise Grade C pole may be *increased* by a minimum of 50% (95 m.p.h.) or possibly as much as 300% (150 m.p.h.). In other words, the required strength, or number of poles, would be at least 1½ times -- and possibly as much as four times -- that currently required. For a Grade N pole application, the required strength would be at least three times -- and possibly as much as eight times -- a present reasonable design requirement. For the less common Grade B applications, the impact would not be realized for wind speeds less than 110 m.p.h.. Nonetheless, significant strength increases would be required for wind speeds exceeding 110 m.p.h., which are characteristic of significant portions of Florida, as shown in Figure 250-2(d).

Figure 2 illustrates the corresponding pole class that would be required, assuming a Class 4 pole is necessary for the reference Grade C application, and the same number of poles (or span length) is maintained. Similar to Figure 1, the three solid bars to the left side of Figure 2 depict the representative pole class for a Grade N, Grade C, or Grade B application. The seven cross-hatched bars to the right depict the required class pole corresponding to the PSC proposed application of the Extreme Wind loads (which would be the same for Grade N, C and B poles). A minimum increase of three class sizes (to Class 1) for Grade C would be required for the minimum 95 m.p.h. wind, and as much as eight class sizes (to Class H5) for the 150 m.p.h. case. A Class 7 pole would otherwise suffice for the Grade N construction. As above, the Grade B applications would be affected to a lesser degree, but the increased size would still be significant for wind speeds above 110 m.p.h.

The increased pole material costs, including shipping and storage, are directly related to the number of poles or pole size (class). For larger, stronger poles, increased installation costs for the heavier poles may also be anticipated. Furthermore, the availability of such larger size (diameter) poles may be an issue.

Required Pole Class




Figure 2
 Required Distribution Pole Class vs. Typical Grade C Strength
 Requirements (NESC-2002)

4.2 Unintended Consequences

The imposition of the Extreme Wind requirement may result in unfortunate "unintended consequences," as sometimes occurs when changing long-standing practices that have generally been deemed successful. For example, as discussed above, the increased pole strength requirement would result in significantly stronger (stouter) poles or a larger number of more conventional size poles, corresponding to shorter spans. Such a practice would have a direct and negative impact on vehicular safety, and conflict with the objectives of the U.S. Department of Transportation, and presumably that of the DOTs of many states. The U.S. DOT is attempting to minimize the number of utility poles in order to reduce the incidence and severity of vehicular accidents. A greater number of poles, or stouter poles, would be contrary to such objectives. Thus, an attempt to modify a national safety code (*i.e.*, the NESC) to accomplish one objective may actually compromise public safety.

Other unintended consequences may also result from the introduction of the proposed Extreme Wind loading, due to a possible significant increase in the number of installed distribution poles along a given route. The June 8, 2006 Florida PSC Memorandum (page 5, Rollins) describes the likelihood that the supposedly less loaded individual poles would nonetheless be damaged in a hurricane, caused by the wind-blown debris and branches, resulting in the much more difficult, and time-consuming, recovery process to repair or reinstall many more poles.

Still another negative consequence relates to the engineering support associated with the implementation of the proposed Extreme Wind loads. The determination of the corresponding wind force is considerably more complicated than that of the existing transverse wind force based upon the present required Combined Ice and Wind loading. While such calculations are generally within the capability of experienced transmission engineers, with civil engineering training, they are beyond that of most distribution engineers. Indeed, one of the change proposals submitted for the 2007 edition was an attempt to simplify the engineering implementation of the Extreme Wind loads for even the applicable transmission applications. Although new or available software packages may alleviate the burden, there will be inevitable confusion and delays -- as well as possible errors in implementation -- in the design and installation of new facilities (including Verizon's fiber-optic networks), to the detriment of the consumers.

5. Recommendations

My primary recommendation is that the Commission not alter the manner in which the NESC's extreme wind loading standards are applied. The NESC is a well-respected document that is generally recognized as having served the industry and public well. For this reason, the NESC Committee (e.g., Subcommittee 5, Strength & Loading) generally attempts to introduce significant changes in a gradual, evolutionary manner, in order to avoid or minimize the potential impact, including unintended negative consequences such as described above (Section 4.2). Thus, previous discussions within the NESC Committee (see Section 3.1 above) to extend the Extreme Wind loading to structures less than 60 feet tall (distribution poles), focused on a particular change proposal, developed within Subcommittee 5, that would limit the impact of such an otherwise potentially dramatic change. In particular, for the Light Loading District portion of the country, which includes Florida, the impact would have been insignificant. Nonetheless, based upon a multitude of industry comments objecting to even this diluted version of an Extreme Wind requirement for distribution poles throughout the country, this proposed change was not incorporated into the 2007 edition of the NESC.

Ideally, the Florida PSC should wait until the next code cycle of the NESC (2012 edition) before encouraging or requiring consideration of the NESC Extreme Wind loading. The related discussions within the NESC Committee during the development process would take into account the experiences during Hurricane Wilma, as well as other recent serious storms. Florida Power & Light, in particular, is well-represented on NESC Subcommittee 5. If the Florida PSC decides to change how the NESC's Extreme Wind loading standards are applied, it should be very cautious in the manner in which such a dramatic, controversial change is introduced. At the least, the Commission should attempt to limit the otherwise dramatic impact to as small a category of facilities as possible, or to reduce the magnitude of the impact. Thus, my alternative recommendation, in the event the Commission moves in this direction, is as follows:

- The proposed PSC rule should limit its scope to Grade B or Grade C applications of electric-only or joint-use poles owned by the electric utilities. Thus, Grade N applications -- which include joint-use poles with only secondary power (< 750

volts), as well as several categories of electric-only poles -- should be explicitly excluded from the proposed application of Rule 250C.

- The application of the NESC Extreme Wind load, as presently specified in NESC-2002, Rule 250C, should be modified to limit the quantitative impact to the affected distribution poles. For example, the reduced loads for Grade C construction incorporated into the latest (2007) edition of the NESC should be explicitly cited as consistent with the intent of PSC Rule 25-6034. For Grade C construction, the corresponding wind forces are reduced by as much as 25% compared to NESC-2002. NESC-2007 is being issued in August 2006, and is effective within six months (February 2007).
- The proposed PSC rule, preferably as modified above, should be applied on a trial basis, initially limited to a specified geographic area and a defined period (e.g., 1-2 years), in order to better understand the potential benefits and consequences of such a rule.

Dr. Lawrence M. Slavin
Outside Plant Consulting Services, Inc.
15 Lenape Avenue
Rockaway , NJ 07866
Phone: 1-973-983-0813
fax: 1-973-983-0813
email: lslavin@ieee.org
www.outsideplantconsulting.com

APPENDIX 2
About Outside Plant Consulting Services, Inc. (OPCS)
(Dr. Lawrence M. Slavin)

Outside Plant Consulting Services, Inc. (OPCS) was established in the year 2002 to help meet the needs of the telecommunications and power industries in establishing standards, guidelines and practices for outside plant facilities and products. The OPCS Group provides related support services for field deployment, and product evaluation and analysis. Dr. Lawrence (Larry) M. Slavin, Principal of OPCS, has extensive experience and expertise in such activities, based upon his many years of service at AT&T/Lucent Bell Telephone Laboratories (Distinguished Member of Technical Staff) in telecommunications product design and development, followed by a career at Telcordia Technologies (Bellcore) in its research and professional service organizations.

As Principal Consultant and Manager/Director of the Network Facilities, Components, and Energy Group at Telcordia, Dr. Slavin was responsible for professional services related to the telecommunications industry. These activities included technical leadership in developing installation and construction practices and "generic requirements" documents, introducing new construction methods, and performing analyses on a wide variety of technologies and products (such as poles, duct, wire and cable, electronic equipment cabinets, flywheel energy storage systems and turbine-generators). Throughout his long career, he has had a leading role in the evolution of many telecommunications related fields and disciplines – including aerial and buried plant design and reliability; advanced construction and cable and duct placement techniques; copper pair, coaxial, and fiber-optic technology; flywheel energy storage systems; physical design and development of hardware and electronic and electro-optic systems (such as the "SLC 96" digital loop carrier); cable media and equipment reliability studies; exploratory fiber-optic hardware development; and systems engineering.

Dr. Slavin is a member of several subcommittees of the National Electrical Safety Code Committee, responsible for specifying safety standards for aerial and buried telecommunications and power facilities in the United States. He is also an active member and participant on the Accredited Standards Committee ASC-O5 ("ANSI-O5") for wood poles and products, as well as on several related committees of the American Society of Civil Engineers. In addition, Dr. Slavin is a Charter Member of the North American Society for Trenchless Technology, has been instrumental in the development of directional drilling standards, and directly supports training activities for the directional drilling industry at the Center for Underground Infrastructure and Research and Education (CUIRE) at Michigan State University. Specific present and recent industry activities are listed below.

Industry Activities

- **National Electrical Safety Code Committee**
 - Represents the national telephone industry, via Alliance for Telecommunications Industry Solutions, ATIS
 - Executive Subcommittee
 - Main Committee
 - Subcommittee 4 (Overhead Lines – Clearances)
 - **Subcommittee 5 (Overhead Lines – Strength & Loading)**
 - Subcommittee 7 (Buried Lines)
- **Accredited Standards Committee ASC-O5**
 - ***ANSI O5.1, Wood Poles, Specifications and Dimensions***
 - *ANSI O5.2, Wood Products, Structural Glued Laminated Timber for Utility Structures*
 - *ANSI O5.3, Wood Products, Solid Sawn-Wood Products and Braces*
- **Pole Reliability Based Design (RBD) Committee, ASCE**
 - ***Reliability-Based Design of Utility Pole Structures***
- **Distribution Pole Standard Committee, ASCE**
- **Committee F17 on Plastic Piping Systems, ASTM**
 - Subcommittee F17.67 on Trenchless Plastic Pipeline Technology
 - Task Group Leader for development of HDD Standard ASTM F1962
 - *ASTM F1962, Standard Guide for Use of Maxi-Horizontal Directional Drilling for Placement of Polyethylene Pipe or Conduit Under Obstacles, Including River Crossings*
- **Trenchless Installation of Pipelines (TIPS) Committee, ASCE**
 - *ASCE Manual of Practice for Pipe Bursting Projects*
- **Center for Underground Infrastructure and Research and Education (CUIRE) at Michigan State University**
 - Industry Advisory Board
- **Trenchless Technology Center, Louisiana Tech University**
 - Industry Advisory Board
- **North American Society for Trenchless Technology (NASTT)**
 - Charter Member
 - Chair of Directional Drilling Subcommittee
- **Missouri Western State College**
 - HDD Steering Committee

**PROCESS TO ENGAGE
THIRD PARTY ATTACHERS**

1. The electric utility and third-party attachers will engage in a continuous dialogue on the status of the electric utility's storm hardening plans. A third-party attacher that wishes to be part of this process ("Participant") shall provide notification in writing to the electric utility, providing the name and address of the person designated to receive communications from the electric utility. The electric utility may, no more than once a year, request that Participants confirm that they wish to continue being part of the process and update the name and address of the person designated to receive communication.
2. By September 5 of each year, the electric utility shall provide the Participants with a list of the projects identified in the electric utility's approved storm hardening plan on file with the Commission ("Plan") that the electric utility proposes to undertake in the following calendar year, pending internal budget approval. The electric utility shall provide the Participants with a list of such projects receiving final budget approval promptly as it becomes available.
3. Prior to engineering a job relative to a storm hardening project identified in its Plan, the electric utility shall initiate a meeting with Participants to discuss the electric utility's preliminary ideas for the scope of work ("Pre-Design Meeting"). At the Pre-Design Meeting, the electric utility shall (a)

identify the poles involved; (b) identify whether the electric utility plans to replace poles, change from wood poles to poles of another material (*e.g.*, steel or concrete), place poles in locations different from the existing poles, relocate overhead facilities or underground existing aerial facilities, and; (c) provide the projected commencement date; (d) upon request by a Participant, provide other available information that would enable the Participants to make necessary preparations and evaluate whether to seek dispute resolution pursuant to Rule 25-6.0342(7). During this pre-design phase of a project, the electric utility shall also seek input from Participants as required by Rule 25-6.0342(6).

4. The electric utility shall provide Participants with final engineering plans promptly upon completion. Prior to beginning construction, the electric utility shall initiate a meeting with Participants to discuss coordination of work and a construction schedule.
5. Information submitted to Participants pursuant to section 2, 3 or 4 above regarding projects identified in the electric utility's Plan will not be docketed unless a protest is filed in accordance with Rule 25-6.0342(7), or it is otherwise deemed necessary by the Commission.
6. If the electric utility seeks to amend its Plan by, for example, adding a project not previously identified in its Plan, it shall file a petition with the Commission requesting that the Plan be modified in accordance with Rule 25-6.0342(2).

7. The electric utility will file with the Commission by March 1 each year a status report of its implementation of its Plan. Included in this status report shall be the name of storm hardening projects commenced and/or completed by the electric utility, the routes and circuits affected, and any comments on the project received from third-party attachers.

Keating, Beth

From: Mickey Harrelson [mickeyharrelson@yahoo.com]
Sent: Tuesday, July 24, 2007 3:01 PM
To: AGMCDANI@southernco.com
Cc: Maria Browne; Keating, Beth
Subject: Fwd: Gulf Pole Inspections
Attachments: pat950965966

The FCTA has agreed with Gulf that evaluating loading on a 500 pole sample of poles with three or more cables attached is a good plan for assessing whether or not Gulf's poles are overloaded by communications' cables.

There is no mandate in the FPSC Docket No. 060198-EI storm hardening initiative #2 to do a complete NESC safety audit nor a Gulf Power attachment standards audit.

FCTA agrees that serious safety violations of the NESC should be reported if found during the field inspections and promptly repaired. See Comments filed at 10-30-06 workshop attached.

See NESC 2007 Section 214.

A.2. Inspection

NOTE: It is recognized that inspections may be performed in a separate operation or while performing other duties, as desired.

A.4. Record of defects

Any defects affecting compliance with this Code revealed by inspection or tests, if not promptly corrected, shall be recorded; such records shall be maintained until the defects are corrected.

A.5. Remedying defects

Lines and equipment with recorded defects that could reasonably be expected to endanger life or property shall be promptly repaired, disconnected, or isolated.

As we know from experience, there are many alleged violations of NESC Requirements and Gulf attachment standards which exceed the NESC on certain poles in the field. These allegations can and should be vigorously disputed because a power company does not have unilateral authority to dictate standards which exceed NESC or decide who caused alleged violations. The NESC requirements are always subject to grandfathering provisions. It is difficult at best to determine when different cable and power facilities were installed and if they violated NESC rules at the time.

Many clear violations of NESC rules do not affect pole strength or employee or public safety. It is frequently difficult or impossible to accurately determine if one or more attachers caused a spacing or separation of communications and power violation or if the power company caused it.

If a complete NESC safety audit is added to the pole strength assessment, it will require much more detailed work in scope of the project. It will also require much more training of the field inspectors. A complete safety inspection would undoubtedly be controversial and detract from the proper focus on pole strength.

If Gulf Power determines that a NESC and/or Gulf attachment standards audit is to be included, FCTA requests input into the safety audit as well as the strength assessment guidelines.

Mickey

BEFORE THE PUBLIC SERVICE COMMISSION

In re: Requirement for investor-owned electric utilities to file ongoing storm preparedness plans and implementation cost estimates.

Docket No. 060198-EI

Filed: October 17, 2006

Comments of M. T. (Mickey) Harrelson, Consultant, Submitted on Behalf of the Florida Cable Telecommunications Association, Inc. for the October 30, 2006 Workshop

The initial distribution and transmission pole inspections and audits of the effect of third party attachments on pole strength required those responsible for the inspections and audits to make many assumptions. The attachment procedures and attachment standards in proposed Rule No. 25-6.0342 have not yet been proposed by the power companies. Third party attachers have had no input, and the Commission has not approved the procedures and standards.

Some of the issues to be addressed in the proposed procedures and standards should also be addressed in this workshop.

The comments below pertain to the proposed report lines (A) through (O).

Lines (E) and (F)

The definition(s) of unauthorized attachments should be sufficiently detailed to account for contract and application for permits requirements and past and present actual practices used by the parties in field implementation. For example, an attachment by a cable operator should not be considered to be unauthorized simply because the cable operator cannot produce a copy of a completed attachment permit.

Line (G)

The term strength tested should be defined to indicate if the number reported was the number tested by detailed specific measurements and calculations or some other method.

Lines (N) and (O)

The term apparent NESC violation should be limited to mean apparent NESC violation which affects the strength of the structure and NESC violations which could reasonably be expected to endanger life or property.

It is often difficult or impossible to determine if a violation of NESC spacing requirements between power and communications was caused by one or the other. Even owners of other cable facilities and power employees working on the poles move existing cables into violation. The meaning of the word involving in "involving electric infrastructure" and "involving 3rd party facilities" is not clear.

More useful information will be provided if line (N) states: *Number of apparent NESC violations which involve electric infrastructure only* Line (O) should state: *Number of apparent NESC violations involving 3rd party facilities.*

The intent of the audits was to determine the possible overloading effect of cable attachments on poles supporting power lines. It was not intended to require a complete audit of all NESC requirements.

Previous comments submitted in this docket and Docket Nos. 060172-EU and 060173-EU are attached hereto as:

- Exhibit A - Docket No. 060173-EU, Staff Workshop, July 13, 2006
- Exhibit B - Docket No. 060198-EI, FCTA's Comments on the July 14, 2006 Informal Meeting Regarding Storm Implementation Plans Which the Utilities have Filed in Response to Order No. PSC-06-0351-PAA-EI
- Exhibit C - Docket Nos. 060172-EU and 060173-EU - Excerpts of Posthearing Comments of M.T. (Mickey) Harrelson, Consultant, Submitted on Behalf of the FCTA

Prepared by:

M. T. (Mickey) Harrelson
Professional Engineer
P. O. Box 432
McRae, GA 31055