

**BEFORE THE FLORIDA
PUBLIC SERVICE COMMISSION**

**DOCKET NO. 070301-EI
FLORIDA POWER & LIGHT COMPANY**

**IN RE: FLORIDA POWER & LIGHT COMPANY'S
2007 ELECTRIC INFRASTRUCTURE STORM
HARDENING PLAN FILED PURSUANT TO
RULE 25-6.0342 F.A.C.**

SEPTEMBER 14, 2007

REBUTTAL TESTIMONY OF:

JOHN J. MCEVOY

DOCUMENT NUMBER-DATE

08393 SEP 14 8

FPSC-COMMISSION CLERK

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **FLORIDA POWER & LIGHT COMPANY**

3 **REBUTTAL TESTIMONY OF JOHN J MCEVOY**

4 **DOCKET NO. 070301-EI**

5 **September 14, 2007**

6

7 **Q. Please state your name and business address.**

8 A. My name is John J. McEvoy. My business address is Florida Power & Light
9 Company, 2455 Port West Boulevard, West Palm Beach, Florida, 33407.

10 **Q. By whom are you employed and what is your position?**

11 A. I am employed by Florida Power & Light Company (FPL or the Company) as
12 Manager of Product Support Power Systems Distribution.

13 **Q. Please describe your duties and responsibilities.**

14 A. I am responsible for maintaining the Distribution Construction Standards
15 ("DCS"), Distribution Engineering Reference Manual ("DERM"), and
16 Product Specifications for overhead ("OH") distribution equipment.

17 **Q. Please describe your educational background and professional
18 experience.**

19 A. I have a Bachelor Degree in Electronic Technology from the University of
20 Dayton, Dayton, Ohio. I joined FPL in 1973 and have served in a variety of
21 positions in distribution operations. I have been an Engineering Technician,
22 Industrial Engineering Analyst, Superintendent Meter Test Center, Manager
23 responsible for customer metering and distribution product/standards since

DOCUMENT NUMBER-DATE
1 08393 SEP 14 5
FPSC-COMMISSION CLERK

1 1995. I have been actively involved for the past 15 years with various
2 American National Standard Institute Committees, Edison Electrical Institute
3 Committees, Association of Edison Illuminating Companies (Past Chairmen
4 of Meter & Service Committee). For the past 12 years, I have managed the
5 organization responsible for the DCS and the DERM for FPL.

6 **Q. Please summarize your responsibilities relevant to this proceeding.**

7 A. I am the manager for the engineering team that developed the DERM
8 addendum for Extreme Wind Design and I manage the OH Forensic Team
9 now and during the 2004 and 2005 storm forensic efforts.

10 **Q. Are you familiar with the National Electrical Safety Code (“NESC”)?**

11 A. Yes. The NESC is the national safety code for the practical safeguarding of
12 persons during the installation, operation, or maintenance of electric supply
13 and communication lines and associated equipment. The NESC is not
14 intended as a design specification or as an instruction manual. Rather it is a
15 set of rules that comprise safety standards applicable on a national base. If, as
16 is often the case, a utility has reasons to exceed these minimum standards, it is
17 free to do so.

18 **Q. Do you consider yourself knowledgeable concerning the NESC and its
19 application to electric distribution systems?**

20 A. Yes. Part of my responsibilities for the past 12 years has been to review the
21 NESC rules to insure they are incorporated into our standards.

22 **Q. What is the purpose of your rebuttal testimony?**

1 A. I will respond to the portions of the testimony of Verizon Florida LLC witness
2 Lawrence M. Slavin and Florida Cable Telecommunications Association, Inc.
3 witness Michael T. Harrelson that relate to their objections to FPL's applying
4 extreme wind loading criteria ("EWL") to distribution facilities under the May
5 7, 2007 Electric Infrastructure Storm Hardening Plan (the "Plan") because the
6 NESC does not require FPL to do so.

7 **Q. Dr. Slavin says that the NESC Committee has considered and rejected**
8 **EWL for poles less than 60 feet, because the benefits of EWL are**
9 **projected to be slight in most storms involving extreme wind since**
10 **damage to structures results primarily from falling trees and branches**
11 **and flying debris striking lines rather than the wind pressure imposed on**
12 **the structures and lines themselves. Do you agree that this is a valid**
13 **reason for FPL not to apply EWL to distribution facilities under its Plan?**

14 A. No. I understand Dr. Slavin's and the NESC's position on this issue, as it is
15 the same position that FPL took until Hurricane Wilma struck our service
16 territory in 2005, the seventh storm that had impacted us over a 15-month
17 period. I also understand that any change in a national construction standard,
18 especially a significant change such as adopting EWL standards for
19 distribution facilities nationwide, has to be carefully researched and analyzed
20 before it can be adopted. However, my experience in the forensic effort for
21 Hurricane Wilma and the conclusions of the KEMA report on that effort
22 indicated that "wind only" was the predominant root cause of distribution pole
23 breakage. FPL cannot ignore this direct, relevant data and simply hide behind

1 the general 60 foot exclusion in the minimum national standard reached by the
2 NESC Committee. The implications of this data must be addressed in our
3 Plan.

4
5 The NESC clearly contemplates that utilities may decide to implement design
6 standards that exceed the NESC's minimums. Section 25, 250A-4 of the
7 NESC states that "It is recognized that loadings actually experienced in
8 certain areas in each of the loading districts may be greater, or in some cases,
9 may be less than those specified in these rules. In the absence of a detailed
10 loading analysis, using the same respective statistical methodologies use to
11 develop the maps in Rule 250C or 250D, no reduction in the loadings
12 specified therein shall be made without the approval of the administrative
13 authority."

14 **Q. In response to FPL's Interrogatory No. 6, the FCTA outlined a procedure**
15 **that it claims could be used to reflect the impact on EWL pole-strength**
16 **requirements due to the guying effect of supply wire and**
17 **telecommunications wire/cable. Has the NESC approved the use of the**
18 **procedure outlined by the FCTA?**

19 A. To the best of my knowledge, it has not.

20 **Q. Is FPL aware of any NESC-approved adjustments that can be used to**
21 **reflect the impact on EWL pole-strength requirements due to the guying**
22 **effect of supply wire and telecommunications wire/cable?**

1 A. No. There are currently no load factors that are specified in the NESC that
2 provide for the possible guying affects of supply wire or telecommunications
3 wire. As discussed earlier, the NESC has defined what is needed in order for
4 the NESC to approve a reduction in loading requirements below those
5 specified for EWL. “In the absence of a detailed loading analysis, using the
6 same respective statistical methodologies used to develop the maps in Rule
7 250C or 250D, no reduction in the loadings specified therein shall be made
8 without the approval of the administrative authority.”

9 **Q. Does FPL currently have the necessary information to develop the**
10 **analysis that would be needed to propose such a change in the NESC**
11 **EWL guidelines?**

12 A. No. The idea on its surface has some merit but there are many considerations
13 that must be better understood. For example, when evaluating FPL wires:

- 14 • A span of conductor may have the necessary strength, but this conductor is
15 installed with some amount of sag and at much less tension than its rated
16 breaking strength. To achieve the guying benefit, the pole will deflect
17 until the crossing conductor has been pulled up to tension. At this point
18 the pole may have already broken
- 19 • The method of attaching the conductor to the insulator is much different
20 than attaching a down guy or storm guy. The weak point may be in the
21 method of attachment, the insulator and/or crossarm.
- 22 • Most insulators are attached to the side of the pole. The effect of the
23 torsional load on the pole due to this side attachment is not yet understood.

1 Also, the effect of the torsional load on the insulator mounting bolt is not
2 yet understood.

3 When evaluating telecommunications wires/cables:

4 • How much sag is in the telecommunications wire/cable and how much
5 the pole will deflect before the “guying effect” comes into play must
6 be understood.

7 • How is the telecommunications wires/cables attached? If it is on the
8 side of the pole, then it could induce torsional load on the pole.

9 • If you consider that the point of attachment for the telecommunications
10 wires/cables is fixed, then the moment arm for the supply wires are
11 reduced to that point. However, the diameter of the pole is much less
12 than at ground line and this may now be the weak point of the pole.
13 The pole may have a good chance of breaking above the
14 telecommunication attachment (a condition that was observed during
15 the Hurricane Wilma forensic investigation).

16 Although we have not formally begun an evaluation to look into these
17 questions, we have had discussions both internally and with our design
18 software vendor to better understand them. If these informal investigations
19 indicate there is a possibility of using the guying effects of current wires (even
20 if some design changes are needed) in future installations, we will proceed
21 with a more formal evaluation. FPL is very interested in pursuing any means
22 available to help control the cost of its hardening projects and certainly will
23 take the necessary steps to pursue this issue thoroughly.

1 **Q. Mr. Harrelson suggests that the wind loading effect of fiber optic cable,**
2 **which he states has a 0.59” diameter and a weight of 0.05 pounds per foot,**
3 **does not significantly increase the load on poles. Do you agree with Mr.**
4 **Harrelson?**

5 A. No. Assuming a 0.59” diameter cable (as referenced at pp. 40 & 42 of Mr.
6 Harrelson’s testimony) and a typical span of 200 feet, this means almost 10
7 square feet of additional surface area within a given span, which can catch
8 wind like a sail. For a class 2 wood pole in the 145 mph EWL wind zone, this
9 equates to approximately 10% of the available strength of that pole.

10 **Q. Would you please discuss FPL’s past forensic efforts?**

11 A. After FPL was hit with 3 hurricanes in 2004, I managed an effort to develop a
12 systematic approach for evaluating the root causes of equipment failure during
13 hurricanes. FPL’s previous storm restoration efforts had always focused on
14 using all available resources to restore service after a storm event, without
15 specifically setting aside resources to determine causes of system failures.
16 Since this approach did not generate any specific data to determine causes of
17 failures, FPL had to rely upon high-level indicators of failed equipment (e.g.,
18 number of poles replaced, feet of wire replaced, etc.) and interviews with
19 crews.

20
21 Following the 2004 storm season, FPL recognized that this informal forensics
22 system needed to be improved. The main recommendation of this review was
23 to form a forensic team so that future hurricane damage could be investigated

1 more rigorously. During the later part of 2004 and the beginning of 2005,
2 FPL formed a forensic team comprised of engineers in my group representing
3 over 150 years of cumulative experience with FPL's distribution system.
4 Procedures and process were developed that we subsequently used to perform
5 forensic evaluations of Hurricanes Katrina and Wilma in 2005. Four teams,
6 each comprised of two of my engineers, were deployed immediately after the
7 "all clear" signal was given, in order to gather data prior to restoration crews
8 repairing the damage. As detailed in the KEMA report, a standardized check
9 sheet was used to collect data, pictures were taken at each observation, and
10 notes were made to help determine causes. Our intent was to determine as
11 objectively as possible why equipment failed and to use this data to help us
12 improve system performance and/or restoration time when exposed to future
13 storms.

14 **Q. What did FPL's forensic evaluation conclude when this system was used**
15 **to evaluate storm damage from Hurricane Wilma?**

16 A. Prior to the Hurricane Wilma forensic evaluation, I (and most of my team
17 members) would have agreed with Dr. Slavin and Mr. Harrelson that trees and
18 debris were the major causes of broken poles during a storm. However, as
19 detailed in the KEMA report, we found that wind was the predominant cause
20 for pole breakage during Wilma. I personally was involved in approximately
21 20% of the observations made, and in those cases where I observed broken
22 poles that were categorized as due to "wind only," I am thoroughly convinced
23 that was the cause of their failure.

1 **Q. What caused you to arrive at this conclusion?**

2 A. Multiple factors compelled the conclusion that the force of hurricane winds on
3 the poles caused them to fail:

- 4 • In almost all of the cases, the pole was broken at least one foot above
5 ground level.
- 6 • A significant number of the poles that I observed were relatively new (10
7 – 15 years old).
- 8 • None of these poles had the presence of wood decay.
- 9 • In the majority of the cases, the surrounding terrain was not cluttered,
10 precluding the possibility of something getting into the lines causing
11 damage.
- 12 • The conductors as well as other equipment did not show any signs of
13 damage other than that sustained when it struck the ground.

14 Together, these factors all pointed to the conclusion that the poles had failed
15 because they experienced a wind force greater than their design capability.

16 **Q. What remedy has FPL chosen to reduce the likelihood of poles breaking
17 due to hurricane force wind?**

18 A. The remedy we are using is to design our system to EWL as described in the
19 NESC. I know the NESC does not require this for distribution structures that
20 do not exceed 60 feet above ground or water level, but for our service territory
21 it is apparent that using the “Combined ice and wind loading,” is inadequate
22 and fails to produce a system that is well suited to withstanding hurricane
23 force winds. The “combined ice and wind loading” category is especially ill-

1 suited to Florida because it is in the “light loading” area based on the absence
2 of significant icing risk and therefore applies wind-loading criteria that
3 assume exposure to only relatively modest winds. With Florida’s exposure to
4 storm winds that regularly exceed this assumption, designing to the
5 “combined ice and wind loading” criteria simply does not seem logical.

6
7 EWL requires the designer to address specific wind speeds. The basic wind
8 speed map in the NESC is nominal design 3-second gust wind speeds at 10
9 meters (33 feet) above ground. As is shown in Dr. Slavin’s testimony in
10 Figure 1, combined ice and wind loading Grade B construction is not even as
11 strong as an EWL of 105 mph. This agrees with the conclusions in the
12 KEMA report that, when evaluated against EWL criteria, Grade B Combined
13 ice and wind loading is the equivalent of 104 mph. How can we expect a
14 system designed for only 104 mph winds to perform well, when our
15 experience indicates that winds can far exceed that figure during even
16 moderately strong hurricanes? I should point out that the NESC itself
17 recognizes the potential for strong hurricane force winds in our service
18 territory: it defines the winds for EWL construction to be as high as 150 mph.

19 **Q. Do you agree with Dr. Slavin’s comments that Hurricane Wilma was a**
20 **unique event and “it would not be reasonable to introduce dramatic**
21 **design changes to the distribution plant based on a single storm”?**

22 **A.** No. The force and character of the winds experienced during Hurricane
23 Wilma were typical of what can be expected from a storm of Wilma’s

1 strength. The damage to the distribution system sustained from Wilma was in
2 line with a storm of this magnitude. At its peak, Wilma was categorized as a
3 low-end category 3 storm. Unfortunately, there is considerable historical
4 precedent to anticipate that storms as strong as Wilma will impact FPL's
5 service territory in the future.

6

7 While I agree with Dr. Slavin that performing a forensic analysis is a difficult
8 task and that cautions must be exercised in using conclusions of such a study,
9 the evidence, however, that "wind only" was the predominant cause of pole
10 damage during Hurricane Wilma was overwhelming. There is no reason to
11 believe that our facilities will not be exposed to these type storms in the
12 future, and I do not think one can have a complete plan to address storm
13 outages without designing for these type winds.

14 **Q. Why is FPL using the EWL criteria that apply to Grade B rather than**
15 **Grade C construction?**

16 A. FPL's system has been traditionally designed to Grade B construction, and
17 FPL does not believe it would be consistent to apply the EWL criteria for
18 Grade C construction for a system that is built to Grade B. NESC allows for
19 different load factors for EWL Grade B and Grade C construction. For Grade
20 C, the NESC allows a load factor of 0.87 for winds of 100 mph or less, and an
21 even lower load factor of 0.75 to be used for winds above 100 mph. If the
22 reduced Grade C load factor were used as recommended by Dr. Slavin, then
23 the effective wind speed for the 145 mph zone would be reduced by 13% to

1 only 126 mph. FPL has no data to suggest that designing to these lower wind
2 speeds would be appropriate.

3 **FCTA WITNESS HARRELSON**

4 **Q. Mr. Harrelson states that square concrete poles are more likely to fail**
5 **than round poles in the event of a storm. Do you agree?**

6 A. No. Mr. Harrelson correctly states that the NESC requires the use of a 1.6
7 wind load shape factor for square concrete poles. This value is used to
8 normalize the effect of wind on a square pole to that of a round pole. Using
9 this shape factor results in the proper design strength for EWL when using
10 square concrete poles.

11 **Q. Mr. Harrelson states that the information reported by KEMA does not**
12 **conclusively support improved resilience of hardened distribution**
13 **facilities. Do you agree?**

14 A. No, the KEMA report states on page 80 that, "With the forensic data received
15 and assumptions made as described in this chapter, the following conclusions,
16 based on statistical analysis sufficient to perform root cause analysis and to
17 direct engineering solutions, can be drawn. The sample size was sufficient to
18 guarantee results in a range plus or minus 2.2% with 95% certainty."

19 **Q. Mr. Harrelson states that he does not necessarily agree with the KEMA**
20 **report due in part to "disclaimers" and explanations of assumptions in**
21 **the report. Do those "disclaimers" and explanations affect the validity of**
22 **KEMA's conclusions?**

1 A. No. A review of the “disclaimers” and explanations of assumptions that he
2 discusses shows that they do not affect the validity of KEMA conclusions:

- 3 • Mr. Harrelson quotes the following from page 50 of the KEMA report:
4 “Specific additions to this forensic study and data collection process
5 together with improved accuracy in the pole population data would
6 enable more specific and targeted engineering solutions.” The first
7 sentence in this paragraph, which Mr. Harrelson omits, is “The
8 forensic data as gathered by FPL staff during the restoration of
9 Hurricane Wilma damage was very useful for engineering analysis.”
10 The intent of these two statements was to convey that the Wilma
11 forensic analysis was a good start but that developing specific
12 location/feeder recommendations was not possible due to the wide
13 geographical area surveyed. Also, KEMA observed that FPL did not
14 have a pole population data base with all the specifics of each pole and
15 associated equipment with mounting hardware to use for a detailed
16 root cause analysis. These limitations do not affect the report’s overall
17 conclusions about “wind only” pole failures, but rather cautions that
18 carrying those conclusions to the level of specific location/feeder
19 recommendations would require additional information.
- 20 • The statement quoted from page 58 in Section 7.2.5 states: “FPL
21 verbally confirms that assignment of root causes is a personal
22 judgment call irrespective of the pole ownership.” The intent of this
23 statement was to confirm that KEMA agrees that FPL inspectors

1 investigated pole breakage not considering pole ownership. Thus the
2 team had no bias based on pole ownership.

3
4 The forensic inspectors were charged with assigning cause based on
5 their observation that if a assignable cause was obvious (tree on pole
6 or wire, metal awning rapped around pole, etc.) that cause was
7 documented; if there was no apparent cause, information was
8 documented that was used to determine other probable causes such as
9 presence of deterioration if pole contained some decay or if the pole
10 had multiple circuits or large cable attachments. If there was no
11 apparent reason for the pole failure and the pole broke above ground
12 level this was documented as “wind only.” Given the high level of
13 experience of the investigators making these evaluations, it is a very
14 accurate method to determine failure causes

- 15 • The statement quoted from page 77 in Section 7.4. States: “Design
16 overload is not a major contributor to poles breaking during Hurricane
17 Wilma. Focusing on the 53 FPL owned poles broken with the
18 suspicion of design overload as a contributing factor, most of these
19 were multiple breaks investigated by one inspector.” Mr. Harrelson
20 interprets this as KEMA discrediting the “personal judgment call” of
21 the “one inspector”. This is not the intent of this statement at all, as
22 KEMA further goes on in that paragraph to explain that the reason that
23 design load is not a major contributing factor is that more detailed

1 evaluation of these 53 FPL poles did not yield any one identifiable
2 cause other than the relatively high number of attachments.

- 3 • Mr. Harrelson states that the forensic data is questionable due to more
4 data gathered on feeder poles while FPL has mostly lateral poles.
5 However, in developing the statistic that 52% of the poles were broken
6 by wind only, KEMA normalized the forensic data to more properly
7 reflect the feeder/lateral pole population thus making the forensic data
8 usable for general pole population results.
- 9 • Mr. Harrelson comments that as much as 85% of the broken poles
10 were multiple failures, which is also known as cascading. He further
11 states “that one defective pole or guy wire can allow one pole to break
12 and take down several solid poles which would not have fallen
13 otherwise. Cascading can be started by trees or flying debris hitting
14 facilities on one pole.” He fails to mention that cascading can also
15 start by one pole broken due to the effect of wind only. In the cases of
16 multiple pole failures, the investigator thoroughly looked at the entire
17 set of breakage to try to determine what caused any one of the poles to
18 break. If a cause such as a tree was found, that cause was used for all
19 of the poles in that cascading occurrence. Thus, the assigned causes
20 for multiple pole breakage could have come from any of the categories
21 used. I also would like to point out that stronger facilities can limit the
22 number of poles in a cascade, so EWL poles are more likely to stop a
23 cascading failure once it has started.

- 1 • Mr. Harrelson quotes KEMA at page 77, Section 7.4 of the report: “the
2 counties and areas with highest pole failure rates coincide with the
3 area with the highest wind speeds and are bordering open areas in the
4 path of hurricane Wilma.” Mr. Harrelson then asserts that “This
5 finding validates the well know fact that trees and building shelter
6 lines from winds whereas open areas do not. The trees and flying
7 debris can and do frequently break poles designed to EWL standards.”
8 His conclusion is not supported by any data. Certainly, the KEMA
9 report does not support his conclusion. As mentioned earlier, the
10 NESC states in section 25, 250A, paragraph 3 “In the absence of a
11 detailed loading analysis, using the same respective statistical
12 methodologies used to develop the maps in Rule 250C or 250D, no
13 reduction in the loadings specified therein shall be made without the
14 approval of the administrative authority.” FPL is interested in
15 investigating what changes can be made to reflect the affect of
16 shielding on its distribution lines, but until shielding effects can be
17 documented in accordance with the above guidelines; we cannot
18 arbitrarily change the calculations shown for EWL in the NESC.
- 19 • Mr. Harrelson discusses page 59, Table 7-7 of the KEMA report. He
20 states “that wind only was based upon the personal judgment calls of
21 the inspectors”. As I mentioned earlier, the FPL inspectors had a
22 combined experience of over 150 years with FPL and are engineers in
23 the group responsible for FPL construction standards. They used a

1 process that eliminated as much subjectivity as possible in determining
2 the cause of pole failures. We were interested in collecting valid
3 forensic information to help the distribution system better withstand
4 hurricanes and knew that invalid data would not be helpful. There was
5 no bias or incentive to influence the collection of data toward one
6 cause of failure versus another. Frankly if there had been any bias at
7 all, it would have been *against* concluding that poles failed due to
8 wind only, based on the inspectors' prior experience and expectations.

9
10 In short, FPL's forensic team used a carefully structured forensic
11 process that included multiple reviews of how to do an observation,
12 and what to look for when recording data. Mr. Harrelson has not
13 supplied any forensic data to support the conclusions about pole
14 failures stated in his testimony. It is *his* conclusions, not those of the
15 FPL inspectors, that rely heavily on personal judgment.

- 16 • Mr. Harrelson makes the statement "A better forensic analysis would
17 have sought to determine the cause or causes of the cascading failures
18 which accounted for 85% of the recorded failures." As I discussed in
19 the previous bullet, this is exactly what the forensic team did, assign a
20 cause for both single pole failures and multiple failures.
- 21 • Mr. Harrelson further refers to KEMA Table 7-7 indicating "Table 7-7
22 attributes only 12% of the lateral pole failures to wind only, 33% is
23 attributed to tree and 47% to presence of deterioration. Lateral lines

1 are the smaller lines which serve such area as neighborhoods where
2 more trees and building are common. Significantly, 55% of FPL poles
3 broke during Wilma were lateral poles.” Mr. Harrelson is correct in
4 his statements. The reason the overall percentage of pole breakage due
5 to Wilma is 52% is because, as Table 7-7 indicates, the feeder pole
6 breakage due to “wind only” was 66%. While FPL is concerned with
7 the storm resilience of all its distribution poles, it is especially
8 important to harden the feeder poles because a feeder failure affects
9 many more customers than a lateral failure.

- 10 • Mr. Harrelson cites page 68 of the KEMA report, which “refers to a
11 group of wind only failures where half of them fell to the east and half
12 of them fell to the west.” He goes on to assert that “This is consistent
13 with an embedded tornado-type wind for which EWL would not likely
14 provide adequate protection.” As it so happens, this location was
15 approximately 10 miles from my house. The eye of hurricane Wilma
16 passed directly over my house and this area described. Of course, the
17 wind direction in the leading eye wall is opposite the direction in the
18 following eye wall. I observed these pole breaks, and there was no
19 surrounding area damage that would be consistent with tornado
20 activity. Instead, the phenomenon of some poles falling in one
21 direction while the others fell in the opposite direction resulted from
22 the switch in wind direction after the hurricane’s eye passed over the
23 area in question.

1 • Mr. Harrelson states that “on page 80 KEMA concludes that wind was
2 the predominant root cause of pole breakage in general and tree
3 breakage causing pole breakage in particular.” Mr. Harrelson is not
4 correct; this statement was included in the KEMA report section 7.4
5 “Integral analysis and interpretation” page 78, not in the conclusions
6 section. In section 7.4, KEMA discusses different factors that were
7 used to analyze the data, ruling some factors as usable and some as
8 not. However in the conclusion section 7.5, KEMA states “Wind is
9 the predominant root cause of pole breakage based on analysis of the
10 forensic data collected after Hurricane Wilma.” In fact looking at all
11 FPL wood pole breakage data in the report, 52% was due to “wind
12 only,” while only 20% was due to trees.

13 In summary, Mr. Harrelson has misinterpreted much of the data in the KEMA
14 report. The report accurately reflects the efforts of the forensic team and is
15 the most detailed analysis to date of any hurricane damage to a distribution
16 utility system. I stand by its conclusions.

17 **Q. Does this conclude your rebuttal testimony?**

18 A. Yes.