

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

**NOTICE OF COMMENCEMENT OF PROCEEDINGS FOR DETERMINATION  
OF NEED FOR CONVERSION OF POWER PLANTS**

TO

FLORIDA POWER & LIGHT COMPANY  
DEPARTMENT OF COMMUNITY AFFAIRS  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

AND

ALL OTHER INTERESTED PERSONS

DOCKET NO. 080245-EI: PETITION FOR DETERMINATION OF NEED FOR  
CONVERSION OF RIVIERA PLANT IN PALM BEACH COUNTY  
BY FLORIDA POWER & LIGHT COMPANY.

AND

DOCKET NO. 080246-EI: PETITION FOR DETERMINATION OF NEED FOR  
CONVERSION OF CAPE CANAVERAL PLANT IN BREVARD COUNTY  
BY FLORIDA POWER & LIGHT COMPANY.

ISSUED: May 1, 2008

NOTICE is hereby given pursuant to Rule 25-22.080(3), Florida Administrative Code, that the Florida Public Service Commission has received the petitions of Florida Power & Light Company (FPL) for a determination of need for conversions of power plants in Palm Beach County and power plants in Brevard County.

FPL seeks from the Commission a determination of need for the Riviera Conversion, involving installation of a combined cycle power plant with a summer capacity rating of 1,219 MW and a commercial operation date of June 1, 2014. The Riviera Conversion will replace two operating 280 MW dual-fuel fired steam generating units that entered service in the 1960s and are located at FPL's Riviera plant in Palm Beach County, Florida. The converted plant's primary fuel will be natural gas, and it will have the capability to use light oil as backup fuel.

DOCUMENT NUMBER-DATE

03553 MAY-18

FPSC-COMMISSION CLERK

NOTICE OF NEED DETERMINATION PROCEEDING  
DOCKET NOS. 080245-EI, 080246-EI  
PAGE 2

FPL also seeks from the Commission a determination of need for the Cape Canaveral Conversion, involving installation of a combined cycle power plant with a summer capacity rating of 1,219 MW and a commercial operation date of June 1, 2013. The Cape Canaveral Conversion will replace two operating 400 MW dual-fuel fired steam generating units that entered service in the 1960s and are located at FPL's Cape Canaveral plant in Brevard County, Florida. The converted plant's primary fuel will be natural gas, and it will have the capability to use light oil as backup fuel.

These matters have been assigned Commission Docket No. 080245-EI (Riviera) and Commission Docket No. 080246-EI (Cape Canaveral).

Copies of the petitions and supporting documentation are available for public inspection during normal business hours at the following location:

Florida Public Service Commission  
Office of Commission Clerk  
Room 110, Betty Easley Conference Center  
4075 Esplanade Way  
Tallahassee, Florida

There is a motion pending to consolidate these dockets with Commission Docket No. 080203-EI. The final hearing in these matters has been scheduled for June 23 - 24, 2008.

By DIRECTION of the Florida Public Service Commission this 1st day of May,



---

ANN COLE  
Commission Clerk

( S E A L )

MCB