

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

RECEIVED-PPC
10 MAR 15 AM 8:33
COMMISSION
CLERK

DOCKET NO. 090451-EM,

PETITION FOR DETERMINATION OF NEED FOR THE
THE GAINESVILLE RENEWABLE ENERGY CENTER

SUPPLEMENTAL TESTIMONY OF EDWARD J. REGAN, P.E.

ON BEHALF OF

GAINESVILLE REGIONAL UTILITIES AND

GAINESVILLE RENEWABLE ENERGY CENTER, LLC

6 hard copies filed; CD forwarded to RAD.

COM 5
APA 2 (3.16.10)
ECR 2
GCL 1
RAD 1
SSC 1
ADM 1
OPC 1
CLK 1 (3.16.10)

MARCH 15, 2010

DOCUMENT NUMBER-DATE

01759 MAR 15 2010

FPSC-COMMISSION CLERK

1 BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
2 SUPPLEMENTAL TESTIMONY OF EDWARD J. REGAN
3 ON BEHALF OF
4 GAINESVILLE REGIONAL UTILITIES AND
5 GAINESVILLE RENEWABLE ENERGY CENTER, LLC
6 DOCKET NO. 090451-EM
7 MARCH 15, 2010
8

9 **Q. Please state your name and business address.**

10 A. My name is Ed Regan. My business address is 301 SE 4th Avenue, Gainesville,
11 FL 32601.
12

13 **Q. By whom are you employed and in what capacity?**

14 A. I am employed by Gainesville Regional Utilities (GRU) as Assistant General
15 Manager for Strategic Planning.
16

17 **Q. Have you testified previously in this proceeding?**

18 A. Yes I have.
19

20 **Q. What is the purpose of your supplemental testimony?**

21 A. The purpose of my testimony is to demonstrate that:

- 22 • GREC is the least cost alternative for meeting the Gainesville
23 City Commission's policy objectives while improving GRU's

- 1 electric system reliability and integrity while also mitigating the
2 cost of increasing fossil fuel prices and volatility;
- 3 • GREC's risk adjusted benefits exceed costs by more than 10 to 1
4 under a mid-range probabilistic cost analysis, and benefits exceed
5 costs by a ratio of more than 2 to 1 in an extremely biased worst
6 case probabilistic analysis;
 - 7 • The power purchase agreement between GRU and GREC LLC
8 (PPA) is structured to provide as much as \$88 million (net
9 present value in 2010 dollars) of benefits for GRU's customers in
10 the form of protection from: construction cost over-runs;
11 financing interest rate increases; long term operation and
12 maintenance escalation; unexpected equipment failure and
13 damage; loss of unit efficiency; and failure to perform;
 - 14 • GRU has a number of mechanisms to manage ongoing risks such
15 as the ability to: resell a portion of GREC's output at no less than
16 a fair market price; financially hedge against diesel and labor
17 costs in GREC's fuel contracts; and apply financial tools such as
18 prepayment contracts; and
 - 19 • GREC meets the requirements for a Determination of Need
20 pursuant to Section 403.519, Florida Statutes.
- 21

22 **Q. Have you provided any exhibits to your supplemental testimony?**

23 **A. Yes. My exhibits include the following:**

1 Exhibit No. ____ [EJR-4] Financial Costs Associated With Policy
2 Objectives, Environmental Regulations, Fuel
3 Price Volatility and Adding New Generation
4 Capacity;
5 Exhibit No. ____ [EJR-5] Biased Expected Value Risk Analysis for GREC;
6 Exhibit No. ____ [EJR-6] Gas Price Forecasts are Unstable;
7 Exhibit No. ____ [EJR-7] Mid-Range Expected Value Risk Analysis for
8 GREC;
9 Exhibit No. ____ [EJR-8] Black & Veatch, Biomass Sizing Study, January
10 2007;
11 Exhibit No. ____ [EJR-9] FMPA, Letter to Florida Public Service
12 Commission, February 24, 2010; and
13 Exhibit No. ____ [EJR-10] OUC Letter to GRU General Manager, March 8,
14 2010.

15

16 **GREC Risks and Risk Mitigation**

17 **Q. During the February 9, 2010 Agenda Conference, Chairman Argenziano**
18 **and Commissioner Skop both expressed concern that the GREC project is**
19 **risky, primarily based on a scenario for which a potential ratepayer cost of**
20 **\$100 million dollars (net present value) was identified by staff [TR P6, L4;**
21 **P29, L7; P37, L4]. What is GRU's assessment of the risks that the project**
22 **is designed to mitigate?**

1 A. There are no economic disadvantages to GREC if the benefits in terms of jobs
2 and the \$609 million (net present value in 2010 dollars) of increased regional
3 income as testified to by Mayor Hanrahan are included in the calculations. Even
4 if these benefits are excluded, the biggest risk for GRU ratepayers is to not
5 proceed with the project. GREC is not only the most cost-effective alternative
6 for GRU to obtain the renewable energy needed to meet the City's
7 environmental policy objectives, but it also provides substantial protection
8 against the following risk factors:

- 9 • Fuel supply, price volatility and cost;
- 10 • Reliability and production cost issues associated with an aging
11 generation fleet;
- 12 • Ownership cost over-runs associated with adding new capacity;
- 13 • Potential reductions in unit efficiency through time;
- 14 • Unplanned outages;
- 15 • Renewable portfolio standard (RPS) requirements; and
- 16 • Carbon regulation.

17

18 **Q. Has GRU performed an assessment to address risks?**

19 A. Yes. Two probabilistic risk analyses have been prepared in the form of
20 "Expected Value" analyses. I deliberately biased the first analysis presented
21 against the GREC project; this worst-case analysis indicates a benefit to cost
22 ratio of greater than 2 to 1. In fact, the model used for the risk analysis can be
23 exercised to demonstrate that all three of the following probabilities would have

1 to be assumed to result in the GREC project's benefits being less than its costs
2 (or, more technically, its benefit to cost ratio being less than 1):

- 3 • Carbon legislation – zero probability;
- 4 • RPS – zero probability; and
- 5 • Gas and coal prices exceed current forecasts – zero probability.

6 GRU believes that these hypothetical probabilities are not reasonable, for
7 reasons that will be discussed.

8

9 The second analysis employs mid-range probabilities and found that the benefits
10 of GREC exceeded the potential costs of GREC by a ratio of greater than 10 to
11 1.

12

13 **Q. Please discuss how the Expected Value analysis was performed.**

14 A. The first step in the Expected Value analysis was to quantify the potential
15 financial costs of each risk factor.

16

17 The second step was to quantify the effect that the decision to proceed with
18 GREC with commercial operation by the end of 2013 will have on each risk
19 factor. The resulting cost and benefits (reductions in potential risks) are shown
20 in Exhibit No. __ [EJR-4].

21

22 The third step was to assign a probability to the likelihood of each outcome.

23 The probability was then multiplied by the value of the outcome to obtain the

1 “risk adjusted” value for each outcome as shown in Exhibit No. __ [EJR-5], and
2 Exhibit No. __ [EJR-7].
3

4 The fourth and final step was to sum the risk adjusted values to obtain the
5 overall Expected Value of the decision under analysis, in this case the decision
6 to construct GREC.
7

8 **Q. Why are the costs of meeting the City of Gainesville’s Kyoto Protocol**
9 **objectives as well as U.S. Environmental Protection Agency (EPA) Clean**
10 **Air Interstate Rule (CAIR) and Clean Air Mercury Rule (CAMR)**
11 **objectives included in Exhibit No. __ [EJR-4]?**

12 A. These costs are included in the table to illustrate how much more expensive it
13 would be to meet the City’s Kyoto Protocol policy objectives without GREC
14 and to demonstrate that regulatory changes and the risks associated with them
15 are a normal part of GRU’s business. They were not included in the Expected
16 Value analysis. Since biomass power is the lowest cost form of renewable
17 energy available to the City, failure to obtain a Determination of Need for
18 GREC would result in substantial additional costs to GRU’s customers if the
19 City is to meet its environmental policy goals.
20

21 **Q. What was the result of the biased Expected Value analysis performed?**

22 A. As shown in Exhibit No. __ [EJR-5], the biased analysis results in a benefit to
23 cost ratio of 2.2 to 1 for GREC with a risk adjusted benefit of \$74.1 million (net

1 present value in 2010 dollars), excluding any of the benefits from economic
2 development.

3

4 **Q. Please discuss the probabilities, biased against the GREC project, that were**
5 **assigned by GRU in the Expected Value analysis in Exhibit No. __ [EJR-5].**

6 A. I have assigned a probability of 100 percent to not being able to resell power at
7 contract price and only being able to resell it at market prices as a concession to
8 facilitate discussion.

9

10 I have also assigned a very low probability (10 percent) that some form of
11 carbon regulation will be enacted. I viewed this as an unrealistically low
12 assessment given that the EPA has already made an endangerment finding and
13 has issued a notice of proposed rulemaking.

14

15 I have assigned a low (20 percent) probability to the enactment of an RPS. I
16 believe 20 percent is unrealistically low given that: (1) 35 states have already
17 adopted either a renewable portfolio standard (RPS) or renewable energy goals;
18 (2) legislation is currently proposed to this effect both nationally and for Florida;
19 (3) there is still an outstanding Executive Order for an RPS in Florida; and (4)
20 the most recent report from the Florida Department of Agriculture and
21 Consumer Affairs finds an RPS of 7 percent to be in fact beneficial to Florida's
22 economy as discussed by witness Schroeder (Exhibit No. __RMS-9]).

23

1 Exhibit No. __ [EJR-6] compares average annual wellhead prices for natural gas
2 at Henry Hub from 1997 through 2009 with US Energy Information
3 Administration's Annual Energy Outlook commodity price forecasts for the last
4 seven years. The prices have quadrupled over this period with marked increases
5 in volatility, then collapsed with the overall economic recession. Given that the
6 current commodity fuel prices are the lowest in seven years, and 64 percent of
7 the historical forecast years shown were below the actual natural gas price it is
8 very likely that fuel prices will increase by at least 10 percent. I assigned a low
9 probability of only 1 in 3 chances for this occurring (33 percent) to these factors.

10
11 The remaining factor considered in the Expected Value analysis is ownership
12 risk. The design of the PPA between GRU and GREC LLC has a number of key
13 features that eliminate most of the following risks:

- 14 • Inability to economically dispatch (dispatch costs are less than
15 coal);
- 16 • Efficiency degradation (a guaranteed heat rate);
- 17 • Planned, unplanned, and forced outages (no energy equals no
18 payments by GRU);
- 19 • Construction cost over-runs (30 year fixed price);
- 20 • Operation and Maintenance cost over-runs and escalation (30
21 year fixed price);
- 22 • Equipment renewal, replacement and repair (30 year fixed price);
- 23 • Financing costs (30 year fixed costs); and

- 1 ● Carbon and RPS regulation (GRU owns all environmental
2 attributes produced by GREC).

3 The estimated benefits of the structure of the GREC LLC PPA are conservative
4 in that the analysis did not consider the heat rate guarantee, or liquidated
5 damages for failure to perform. Only reduced risks related to potential
6 construction, operating and maintenance (O&M), and financing cost over-runs
7 were included in the analysis. The probability I assigned to the sum of these
8 PPA benefits is half of what I otherwise would consider realistic.

9
10 **Q. What were the results of the Expected Value analysis performed using mid-**
11 **range probabilities?**

12 A. As shown in Exhibit No. __ [EJR-7], the Expected Value analysis performed to
13 represent a mid-range estimate of probabilities resulted in a benefit to cost ratio
14 for GREC greater than 10 to 1, with an expected value of \$297million (net
15 present value in 2010 dollars). This analysis excluded any of the benefits from
16 economic development.

17
18 **Q. Please briefly discuss the conclusions that you've drawn from the Expected**
19 **Value analysis.**

20 A. In addition to being the least cost way for GRU to meet the City's environmental
21 objectives while improving system reliability, GREC has substantial hedge
22 value. The results of the Expected Value analysis that used probabilities very
23 biased against GREC, indicate that it is hedge with a benefit to cost ratio

1 exceeding 2 to 1 with an expected value of \$74.1 (net present value in 2010
2 dollars). Using mid-range probabilities, GREC has a benefit to cost ratio of
3 greater than 10 to 1 with an expected value of \$297.9 million (net present value
4 in 2010 dollars). The value at risk (approximately \$62 million, on a net present
5 value basis discounted to 2010) is quite small when compared to: a) GRU's
6 alternatives to obtain renewable energy; b) the investment in environmental
7 quality already made by the City; and c) the dramatically greater potential
8 benefits of proceeding with GREC.

9
10 The substantial benefits of increased employment and investment in the local
11 community associated with GREC (over \$600 million net present value in 2010
12 dollars, as discussed in Exhibit No. __ [PH-2] of the supplemental testimony of
13 Mayor Hanrahan) have not been addressed in the Expected Value analysis and
14 add further weight to the City's conclusions that proceeding with GREC is in the
15 best interest of GRU and our customers, and that not proceeding with GREC is a
16 bad option.

17
18 **Q. Please explain why the estimate of \$100 million (net present value)**
19 **downside risk mentioned during the February 9, 2010 Agenda Conference**
20 **differs from the estimate of \$62 million (net present value) previously**
21 **discussed employed in the Expected Value analysis.**

22 **A.** Public Service Commission Staff had requested that GRU model a scenario
23 where the capacity, energy, and environmental attributes of GREC had zero

1 resale value. Notwithstanding GRU's and GREC's belief that such a scenario
2 was highly improbable, the study was performed as requested by PSC Staff, and
3 resulted in a cost of \$100 million (net present value, in 2010 dollars). GRU has
4 since modeled the scenario with more realistic assumptions that, at a minimum,
5 the capacity and energy of the unit had market resale value even if no additional
6 value was extracted from other GRU generating units. This corrected analysis
7 resulted in the \$62 million (net present value, in 2010 dollars) value employed in
8 the Expected Value analysis. The resale value of GREC's output was modeled
9 as the same terms and conditions as the existing firm baseload PPA between
10 GRU and Progress Energy Florida ("PEF") (which is similar to the PPA
11 between Seminole Electric Cooperative and PEF), with no premium for GREC's
12 environmental attributes. This contract has a demand charge and an energy cost
13 as the average of designated PEF baseload units, which is effectively a contract
14 sale indexed to a basket of fuel costs (45 percent natural gas, 35 percent coal, 20
15 percent nuclear).

16
17 Exhibit No. __ [EJR-9] and Exhibit No. __ [EJR-10] from the Florida Municipal
18 Power Agency and the Orlando Utilities Commission affirm their interest and
19 support for the GREC project.

20
21 **Q. Does the estimated cost of \$62 million (net present value in 2010 dollars)**
22 **capture all of the benefits of GREC in the Florida wholesale power market?**

1 A. No. The form of the analysis used to obtain this value does not include the
2 value to be extracted from GRU's generation capacity that GREC will make
3 available. Due to its low incremental cost, GREC will economically dispatch
4 before all of GRU's units except for the 11 MW share of nuclear generation.
5 Accordingly some of GRU's other generating units would become available for
6 off-system sales. The analysis used to develop the \$62 million (net present
7 value in 2010 dollars) cost did not include any consideration of this value. As a
8 result, this scenario greatly penalized GREC's potential economic benefits as
9 well.

10

11 The supplemental testimony of witness Bachmeier includes the results of a
12 power market study performed by The Energy Authority (TEA) (Exhibit No. __
13 [RDB-5]) that specifically addresses the value that GREC could add to GRU
14 from off-system sales. As testified by witness Bachmeier, TEA's modeling
15 resulted in a net benefit to GRU of \$182 million (net present value in 2010
16 dollars) from off-system sales made possible by adding 100 MW of biomass to
17 GRU's fleet. Applying these results instead of the market proxy modeled as
18 PEF's contract structure reduces the cost of \$62 million (net present value in
19 2010 dollars) discussed above by \$19 million (net present value in 2010 dollars)
20 to a lower value of \$43 million (net present value in 2010 dollars).

21

22 The modeling performed by TEA involves large quantities of data processed by
23 a proprietary software system and the results are only presented here as evidence

1 that the cost of \$62 million (net present value in 2010 dollars) is potentially
2 overestimated.

3

4

Cost-Effectiveness Considerations for Municipal Utilities

5 **Q. During the February 9, 2010 Agenda Conference, Commissioner Edgar**
6 **asked how cost-effectiveness considerations might be different for a**
7 **municipal utility than for an investor-owned utility. [TR P13, L19] Are**
8 **there differences that should be considered?**

9 A. Yes. The differences, summarized below, are significant enough to lead to
10 different conclusions based on the same data.

11

12

Cost – Effectiveness Differences Between
Investor-Owned Utilities and GRU

13

14

Perspective/Interest	Investor-Owned Utility	GRU
Fiduciary responsibility	Shareholders & banks	Customers & bond holders
Environmental externalities	No valuation	Value expressed by public
Public welfare	Electrical safety and reliability	Electrical safety and reliability, as well as public health, safety, and welfare
Consumer protection	External agency required	Elected board of directors

15

16 **Q. How can different conclusions based on the same data be drawn?**

17 A. As an example, consider that the tangible property taxes that will be paid by
18 GREC to the City of Gainesville and Alachua County over the next 30 years are
19 estimated to be \$7.2 million per year with a net present value of approximately
20 \$114 million (2010 dollars). Although these are revenues extracted from GRU's
21 customers, they are returned to the community to pay for schools, libraries,
22 police, fire protection, emergency medical transportation, roads, and other

1 municipal and county services. Without this revenue, local taxes would have to
2 be raised to provide the level of service thus afforded. In the Public Service
3 Commission's evaluation of GREC, this \$114 million (net present value) is
4 treated as a cost. From the perspective of the taxpayers of Alachua County, this
5 is seen as a "wash," since without these taxes from GREC, other tax revenues
6 would have to be increased to provide the same level of service. If this \$114
7 million (net present value) were treated in a similar manner by the Public
8 Service Commission, there would not be a single scenario with a negative
9 outcome that would outweigh this benefit.

10
11 **Q. Commissioner Skop expressed his concern that the project has open risks**
12 **that have not been fully mitigated. [TR P37, L10-12] Does GRU have any**
13 **additional policies or resources to mitigate risks that you have not yet**
14 **discussed?**

15 **A.** Yes. GRU staff has developed a number of policies and has identified
16 techniques to mitigate risks that I have not addressed yet. These are summarized
17 as follows:

- 18 • The amount of the electric system general fund transfer has been
19 decoupled from GRU's operating revenue requirements, which
20 include GREC payments.
- 21 • GRU has reviewed the project in detail with Moody's Investment
22 Services and Standard and Poor's bond rating agencies, who have
23 concurred that the GREC LLC PPA does not constitute a capital

1 obligation that would trigger additional debt service reserves or
2 bond coverage requirements.

- 3 • GRU has met with a number of major investment banking firms
4 who are familiar with, and have engaged in, third party
5 prepayment financial structures pursuant to the federal safe
6 harbor provisions for such practices for municipal natural gas and
7 electric power prepayment, and GRU has made certain that the
8 PPA with GREC LLC would allow such provisions. A
9 reasonable estimate of the potential savings from such a structure
10 is roughly 10 percent. No such structure will be contemplated
11 until after the plant commences operation.
- 12 • Experience has shown that the fuel contracts will likely be
13 indexed against diesel fuel and labor costs. Diesel fuel costs are
14 readily hedged with over the counter commodity contracts, and
15 GRU will investigate ways to hedge against labor cost as well.
- 16 • Failure to obtain sufficient fuel would render the facility
17 unavailable. Pursuant to the terms and conditions of PPA
18 between GRU and GREC LLC, under this circumstance, GRU
19 will have no financial liabilities and the clock on liquidated
20 damages for GREC LLC would begin. Furthermore, under
21 Section 3.4.2 of the PPA with GREC LLC, GRU will have the
22 ability to adjust its obligations to reimburse GREC LLC for ad
23 valorem taxes on a pro-rata basis if the unit is unavailable for a

- 1 protracted period. Finally, under Section 4.1 of the PPA with
2 GREC LLC, GRU could take over fuel acquisition.
- 3 • Section 4.7 of the PPA with GREC LLC provides that GRU can
4 continuously monitor fuel costs and ensure that the gain/loss
5 sharing provisions of the PPA are correctly applied. Given the
6 anticipated portfolio of fuel contracts, the scenario presented
7 would only apply to a small portion of the fuel supply. GRU will
8 have the ability to evaluate the effect of this tranche of energy on
9 its overall cost. If this tranche would place some of the output
10 from GREC at an untenable price, GRU has the option to request
11 that the purchase not be made in exchange for dispatching the
12 unit at a slightly lower capacity factor or to obtain its own
13 additional fuel supply. For example, if 90 percent of the fuel is
14 purchased at an economic price, and the next increment of fuel
15 cost is uneconomic, GRU can choose to have GREC LLC not
16 purchase the uneconomic fuel and dispatch GREC at a slightly
17 lower capacity factor.
- 18 • GRU is a member of The Energy Authority (TEA). TEA is a
19 power marketing group managing all of GRU's generation assets
20 in excess of requirements to meet native load on a real time basis
21 and represents GRU in the hourly Florida Cost Based Broker
22 System. TEA is managing over 25,000 MW nationwide, and has
23 a significant market presence. This market presence helps GRU

1 achieve the lowest possible power cost for its native load, and
2 also helps GRU extract the highest possible value from all its
3 generation assets. Thus, to the extent that GRU has surplus
4 generation assets after adding GREC to its generating fleet, TEA
5 will manage all of GRU's assets so as to maximize value to GRU
6 and minimize GRU's customers' rates. Additionally, in the
7 unlikely event that GRU does not contract with other Florida
8 utilities (such as OUC, FMPPA, Lakeland, and Reedy Creek) for
9 the sale of 50 MW of GREC's capacity and energy, GRU expects
10 that it will be able to mitigate rate impacts by asking TEA to
11 market the capacity, energy, renewable attributes, and carbon
12 regulation values of GREC.

13
14 **Q. Commissioner Skop expressed concern whether GRU fully appreciated the**
15 **risks to the ratepayers. [TR P46, L19-24] How would you address**
16 **Commissioner Skop's concerns, and why have biomass fuel supply**
17 **contracts and power purchase agreements for excess capacity not been**
18 **executed as of this date?**

19 **A.** The Expected Value analysis discussed previously clearly illustrates the care and
20 thought that went into managing the risks of GREC, especially through the
21 terms and conditions of the PPA. As discussed in witness Schroeder's
22 testimony, executing fuel contracts prior to regulatory approval would result in a
23 higher cost for the fuel, as the commitment by the suppliers would reduce their

1 options should other purchasers enter the market whereas the certainty of the
2 project is unknown. Negotiating the terms and conditions for off-system
3 wholesale power sales prior to having received all regulatory approvals has the
4 same consideration, compounded by the uncertainty of fuel contract prices and
5 indexing terms and conditions. Knowing that GREC LLC will have to secure its
6 fuel supply prior to obtaining financing, in the interest of obtaining the best PPA
7 terms and conditions for GRU's customers, GRU has decided to not execute
8 these wholesale contracts prior to having regulatory approvals and fuel
9 contracts. Exhibit No. __ [EJR-9] and Exhibit No. __ [EJR-10], which are
10 letters of support for the GREC project from the Florida Municipal Power
11 Agency (FMPA) and the Orlando Utilities Commission (OUC), demonstrate
12 their continuing interest in and support for the project.

13
14 **Optimal Size and Timing of GREC**

15 **Q. During the February 9, 2010 Agenda Conference, Commissioners Edgar**
16 **[TR P17, L5], Klement [TR P64, L20], and Skop [TR P35, L9] each**
17 **questioned the decision to make GREC a 100 MW net unit, whether a**
18 **phased implementation of two smaller units would be cost effective,**
19 **whether the possibility of installing a unit of less than 75 MW had been**
20 **considered, and if the alternative of re-powering Deerhaven 1 with a**
21 **biomass boiler had been considered. Please address these questions for the**
22 **Commissioners.**

1 A. GRU decided to pursue the GREC based on engineering analyses and an
2 evaluation of the alternatives proposed through its competitive solicitation
3 process. GRU never contemplated sizing a facility to circumvent the Public
4 Service Commission's Determination of Need process or the Florida
5 Department of Environmental Protection's Site Certification process.

6
7 GRU has had two studies performed that address the economies of scale
8 inherent in power generation facilities. The first study, performed by ICF
9 Consulting in March 2006 entitled "City of Gainesville Electrical Supply
10 Needs" (included as Exhibit No. __ [RMS-4] to the supplemental testimony of
11 witness Schroeder) compared the cost of various generating units using various
12 fuels for the size range of 75 MW to 800 MW. The second study, performed by
13 Black & Veatch in January of 2007 entitled "Biomass Sizing Study" (Exhibit
14 No. __ [EJR-8]), explicitly compared a number of biomass technologies for 50
15 MW and 100 MW units. Both studies demonstrated substantial economies of
16 scale for larger units (in other words, the cost per unit output decreased with the
17 increase in size of the unit). The results from the Black & Veatch study are
18 directly applicable to the GREC technology and are summarized below. These
19 economies of scale accrue from the improved surface to volume ratio of the
20 boiler and turbine components, and the cost of controls and equipment. Other
21 benefits accrue from the savings in plant operation personnel and improved heat
22 rates. Characterization of the GREC site's high water conditions, foundation
23 conditions, configuration of access roads, and redundant fuel handling systems

1 indicate that the economies of scale associated with GREC are more pronounced
2 than summarized in the table below.

3
4 Comparison of the Economies of Scale Between 50 MW and 100 MW
5 Bubbling Fluidized Bed Biomass Generation Systems
6

Item	Cost Comparison
Capital Cost per Kilowatt	-15%
Fixed Non-Fuel O&M	-40%
Variable Non-Fuel O&M	-24%
Net Plant Heat Rate	-11%

7 Source: "Biomass Sizing Study", pages 1-1 and 4-6
8

9 Phased construction of two smaller units will sacrifice these economies of scale
10 and will also incur the costs of having to mobilize construction twice, and the
11 escalation over time in cost for the second unit will increase costs even further
12 as compared to construction of a 100 MW unit.

13
14 GRU investigated a range of repowering options in a study by Black & Veatch
15 in March 2004 entitled "Supplementary Study of Generating Alternatives for the
16 Deerhaven Generating Station" (included as Exhibit No. __ [RMS-3] to the
17 supplemental testimony of witness Schroeder). The option of repowering
18 Deerhaven 1 would not have resulted in additional capacity to support GRU's
19 long term facility management plan, and the economics of such a repowering
20 would be adversely affected by unit inefficiency due to not having the optimal
21 match of steam temperature and pressure, resulting in a less efficient design.
22

1 **Q. During the February 9, 2010 Agenda Conference, Commissioner Klement**
2 **questioned why GRU is pursuing a biomass resource. [TR P19, L1-2]**
3 **Staff's response was that biomass was chosen for its base load**
4 **characteristics and that municipal solid waste was rejected. [TR P19, L14-**
5 **16] Were there additional reasons why GRU selected biomass?**
6 **A. GRU agrees with Staff that biomass (as opposed to some other forms of**
7 **renewable energy) has the advantage of being suitable to meeting GRU's long**
8 **term needs for base load capacity. The primary decision to write GRU's request**
9 **for proposals (RFP) to solicit proposals for biomass resources was based on the**
10 **policy decision to only add renewable energy generation at a central station, the**
11 **abundance of biomass fuel in the region, and the low cost of biomass generation**
12 **compared to other forms of renewable energy. Under the proposal evaluation**
13 **process developed by the City Commission, municipal solid waste was not ruled**
14 **out but would have been heavily disadvantaged by the factors and their weights.**
15
16 Sufficient study had been conducted by GRU to make it evident that biomass
17 was the least cost alternative for obtaining the substantial amount of renewable
18 energy to meet the City's Kyoto Protocol policy objective. The different types
19 of renewable energy reasonably available to GRU are summarized in the table
20 below, along with their costs and resource potential.
21
22
23

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22

Relative Costs of Renewable Energy Alternatives in Florida

Type	Cost Range (\$ per MWh)	GRU Resource Potential (MW)
Landfill Gas to Energy	75-95	3-6
Biomass	100-135	250
Wind	Not Commercially Proven	Nil
Photovoltaic	320-430 ^a	60-100 ^b

- a. Before tax incentives, \$5.5-\$7.5 per watt, 25 year amortization at 7% interest.
b. Within GRU's service territory

Q. During the February 9, 2010 Agenda Conference, Chairman Argenziano inquired about the timing of GRU's need for GREC, and Staff indicated that the need for GREC for purposes of reserve margin reliability is in 2023. [TR P 21, L9-14] Chairman Argenziano also asked "is there a need for reliability right now?"[TR P49, L7-8] What is GRU's current need for generation capacity to improve system reliability?

A. GRU's near term need is for generating resources to improve system reliability and integrity. Staff was correct with respect to reserve margins, but did not address GRU's immediate need for baseload capacity to improve system reliability and fuel diversity. Prior to GREC coming on line, GRU's existing PPA with PEF provides for 50 MW of baseload capacity intended to back up its low cost coal generation and provide economical power during times of high gas prices. This PPA will terminate at the end of 2013. A more complete discussion of the benefits of GREC on system reliability may be found in the GREC Need for Power Application (Sections 15.3 and 16.2) and is mentioned in Staff's January 28, 2010 recommendation to approve the GRU and GREC LLC joint petition to determine need for GREC (pages 6 through 8, and pages 26 through 27).

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21

Q. During the February 9, 2010 Agenda Conference, concerns were raised about the timing of GRU’s need for capacity. When is GREC needed to meet the need criteria listed in Section 403.519, Florida Statutes?

A. The table summarizes the various need criteria listed in Section 403.519, Florida Statutes, with the date at which GREC would fulfill that need. Delaying the project is not a good option for GRU's customers, in that GRU strongly believes that its customers' rates will be lower, over the long run, with GREC added in December 2013 than under any realistic delay scenario.

GRU’s Need for GREC

Criteria	Date	Comment
Fuel Diversity	2014	Also delivery reliability
System reliability and integrity	2014	Many eggs in one basket- Deerhaven 2
Promoting renewable energy	2014	Multiple policy mandates
Least cost alternative	2014	Among renewable alternatives
Adequate electricity at a reasonable cost	2014	See Expected Value analysis
Meet regulatory requirements	2014	EPA CO ₂ regulation is under development
Reserve margins	2023	Avoids additional capacity through 2032

Biomass Resource Sustainability

Q. During the February 9, 2010 Agenda Conference, Chairman Argenziano asked if during the City Commission’s deliberations and public hearings there was any concern or anyone who was speaking to the sustainability of the biomass resource, especially if other biomass projects were in fact developed within GREC’s fuel catchment area? [TR P21, L21 through P22, L2]. Staff’s response was that there was one who questioned the sustainability of the fuel resource and that there were others who testified

1 **that there was sufficient biomass. [TR P22, L20-23] Does this characterize**
2 **the extent to which this issue was considered by the City Commission?**

3 A. No. This characterization oversimplifies the City Commission's examination of
4 this issue. Resource sustainability came up in many City Commission meetings
5 over the past 5 years, which is why GRU conducted four biomass studies and
6 empowered an ad hoc Forest Stewardship task force to develop minimum
7 standards for the forest derived fuel for GREC. The ad hoc task force was
8 comprised of Florida Division of Forestry staff, as well as local citizens
9 including forestry professionals, growers, and environmental activists. The City
10 Commission also adopted a financial incentive program to encourage growers to
11 participate in third party stewardship certification programs. (See Exhibit No.
12 ___ [RMS-11] to the supplemental testimony of witness Schroeder, which is the
13 Forest Sustainability Fact Sheet).

14
15 **Q. During the February 9, 2010 Agenda Conference, Chairman Argenziano**
16 **expressed concern about how GRU's customers would be impacted if**
17 **GREC were unable to obtain biomass in sufficient quantities to power the**
18 **plant. [TR P24, L15-17] Please address this concern.**

19 A. GRU's customers will not incur any costs for GREC under such a scenario.
20 Failure to obtain sufficient fuel would render the facility unavailable. Pursuant
21 to the terms and conditions of the PPA between GRU and GREC LLC, under
22 this circumstance, GRU will have no financial liabilities and the clock on
23 liquidated damages for GREC LLC would begin. Furthermore, under Section

1 3.4.2 of the PPA with GREC LLC, GRU will have the ability to adjust its
2 obligations to reimburse GREC LLC for ad valorem taxes on a pro-rata basis if
3 the unit is unavailable for a protracted period. Finally, under Section 4.1 of the
4 PPA with GREC LLC, GRU could take over fuel acquisition.

5
6 **Carbon and Renewable Energy Legislation and Regulation**

7 **Q. Chairman Argenziano requested an update on the current status of**
8 **legislation that would impact renewable energy projects. [TR P51, L12-13]**
9 **Can you please provide this update with a discussion of how GRU would be**
10 **affected?**

11 **A.** Please see the summary of the current status of federal and state legislation that I
12 have developed below:

13 **Federal Carbon Cap and Trade**

14 House Bill 2454 (HR 2454), known as the American Clean Energy and Security
15 Act of 2009 (ACES), was adopted by the full House on June 26, 2009. ACES
16 employs a downstream cap and trade program for carbon that has the point of
17 regulation at the electric generator.

18
19 S1733, known, as the Clean Energy Jobs and American Power Act of 2009, was
20 voted out of the Senate Energy and Public Works Committee but was not
21 brought to a floor vote during the 2009 session. S1733 contains carbon cap and
22 trade provisions similar to those of HR 2454. While the caps and timelines are
23 virtually the same, S1733 awards approximately 15 percent fewer “free”

1 allowances to distribution utilities and would result in greater cost to utilities and
2 their customers than HR 2454. Both HR 2454 and S1733 would add
3 significantly to GRU's energy costs. GREC will significantly reduce this
4 liability by offsetting coal and natural gas combustion. Without GREC, under
5 the provisions of HR 2454, GRU will have an allowance shortfall of 28.51
6 million metric tonnes of CO₂ through 2034. With GREC, this shortfall will be
7 reduced 30.7 percent to 19.97 million metric tonnes of CO₂. Based on CO₂
8 allowance costs developed from "EPA Analysis of the American Clean Energy
9 and Security Act of 2009 H.R. 2454 in the 111th Congress 6/23/09", by 2034
10 GREC is estimated to reduce the HR 2454 cap and trade related rate increase for
11 GRU from 36 percent to 25.1 percent in the low cost case and from 115.4
12 percent to 80.6 percent in the high cost case.

13
14 For the above reasons, GRU believes federal legislation regulating carbon
15 emissions or imposing a renewable electricity standard, or both, is a distinct
16 possibility.

17 **Federal Renewable Energy Standards**

18 HB 2454 has a renewable electricity standard (RES) that requires that a utility
19 produce 20 percent of its electric energy from renewable sources by 2020,
20 starting at 6 percent in 2012. This program is under a separate title and adds
21 cost to utility operations beyond the cap and trade program. Up to 25 percent of
22 the RES can be met through energy efficiency projects. These projects can
23 produce energy efficiency credits (EECs) for compliance or sale. Utilities have

1 the compliance option of adding renewable energy resources to their own
2 system or buying renewable energy credits (RECs) or EECs from other entities.
3 In addition, utilities have the ability to make alternate compliance payments
4 (ACPs). The alternate compliance payment starts at \$25 per megawatt hour (in
5 2009 dollars) and increases each year based on inflation. Currently utilities with
6 less than 4,000,000 MWh sales per year are exempt from the RES standard.
7 However, it is likely that smaller utilities (such as GRU) will be able to create
8 RECs that can be sold into the RES market. It is estimated that the cost of RECs
9 will be slightly less than that of the alternate compliance payment. In the event
10 that GRU becomes subject to the RES under HR 2454, GREC should enable
11 GRU to meet the renewable electricity requirements and still have RECs that
12 could be marketed. GRU estimates that through 2034 GREC will produce a
13 surplus of about 3.17 million RECs with a value of \$79 million in 2009 dollars.
14 However, without GREC, the GRU system would have a deficit of 7.2 million
15 RECs by 2030 with a cost of \$180.8 million. Note that only a 7 percent RPS
16 requirement was employed in the Expected Value analysis for GREC that I've
17 discussed previously in my testimony.

18 **More Recent Federal Legislative Proposals**

19 There are two alternative legislative approaches in addition to S1733 that have
20 gained some momentum in the U.S. Senate:

- 21 • S2877, the Carbon Limits and Energy for America's Renewal
22 (CLEAR) Act is a bipartisan bill sponsored by Senator Maria
23 Cantwell (D) of Washington and Senator Susan Collins (R) of

1 Maine. Unlike S1733, the CLEAR Act regulates carbon
2 upstream at the primary source of energy. This would include
3 refineries, coal mines, and natural gas producers. The CLEAR
4 Act is sometimes referred to as a “cap and dividend” bill in that
5 all the carbon allowances are auctioned only to the primary
6 energy sources that are regulated, with 75 percent of the revenue
7 from the auction returned directly (dividend) to American
8 households. Twenty-five percent of the auction revenues are to
9 be used on carbon reduction technologies and energy efficiency
10 innovations. The carbon costs are reflected in fossil fuel prices.
11 The caps and timelines in this proposal are modest in the first few
12 years of the program and increase significantly in later years
13 when carbon control technology is more likely to be available
14 and cost effective.

- 15 • The Kerry Graham Lieberman Energy Bill is a bipartisan bill
16 under development by Senators Kerry, Graham, and Lieberman.
17 Only a general outline of this bill has been released at this time.
18 It is expected this bill will contain both an energy title with an
19 RES and a climate provision, possibly utilizing a cap and trade
20 approach to reduce carbon emissions from fossil fuel-fired
21 electric generation.

22 Implementation of either the CLEAR Act or the Kerry Graham Lieberman
23 Energy Bill would increase the electricity cost of fossil fuel-fired generation,

1 and GREC will therefore enhance GRU's renewable energy position in the
2 energy market, either by reducing GRU's compliance costs or by enabling GRU
3 to benefit economically by selling its RECs, carbon allowances, or other
4 renewable attributes at market prices.

5
6 In addition to the bills discussed previously, Senator Carper has introduced a
7 three pollutant bill to reduce the emissions of SO₂, NO_x and mercury by 90
8 percent. Although this bill does not regulate carbon dioxide, it will significantly
9 increase the cost of coal-fired generation and the GREC project will therefore
10 enhance GRU's renewable energy position in the energy market.

11 **U. S. EPA Regulatory Action**

12 On December 7, 2009, the EPA Administrator signed two distinct findings
13 regarding greenhouse gases under section 202(a) of the Clean Air Act:

- 14 • **Endangerment Finding:** The Administrator determined that the
15 current and projected concentrations of the six key well-mixed
16 greenhouse gases--carbon dioxide (CO₂), methane (CH₄), nitrous
17 oxide (N₂O), hydrofluorocarbons (HFCs), perfluorocarbons
18 (PFCs), and sulfur hexafluoride (SF₆)--in the atmosphere threaten
19 the public health and welfare of current and future generations.
- 20 • **Cause or Contribute Finding:** The Administrator determined
21 that the combined emissions of these well-mixed greenhouse
22 gases from new motor vehicles and new motor vehicle engines

1 contribute to the greenhouse gas pollution which threatens public
2 health and welfare.

3 EPA's Endangerment Finding sets the stage for the regulation of carbon dioxide
4 and other greenhouse gases by EPA under the Clean Air Act. While EPA's
5 initial Endangerment Finding will result in greenhouse gas regulation of the
6 transportation industry, the regulation of large stationary sources such as fossil
7 fuel-fired electric generating units is inevitable. It is uncertain whether EPA
8 regulation of carbon dioxide emissions from electric generating units will be
9 more or less stringent than in currently proposed legislation. However, EPA
10 GHG regulations will increase the cost of fossil fuel-fired generation. As a
11 result, the GREC project will enhance GRU's renewable energy position in the
12 energy market, either by reducing GRU's compliance costs or by enabling GRU
13 to benefit economically by selling its RECs, carbon allowances, or other
14 renewable attributes at market prices.

15 **Federal Council on Environmental Quality**

16 The Council on Environmental Quality (CEQ) recently issued new draft
17 guidelines on evaluating the effects of greenhouse gas emissions on climate
18 change. Under draft guidelines released February 18, 2010, federal agencies
19 will have to consider greenhouse gas emissions and climate change effects when
20 carrying out National Environmental Policy Act reviews. Many expect this to
21 lengthen the licensing process for major energy projects.

22

23

1 **Other Federal Renewable Portfolio Standards**

2 In addition to the renewable electricity standard found in HR 2454, Senate Bill
3 1462, reported out of the Senate Energy and Natural Resources Committee June
4 17, 2009, contains a renewable energy standard (RES). As currently written,
5 S1462 applies to utilities generating greater than 4,000,000 MWh annually. The
6 RES starts at 3 percent of generation in 2011 and increases to 15 percent in
7 2021. This is slightly less stringent than the RES found in HR 2454. ACP costs
8 in S1462 start at \$21/MWh (in 2008 dollars) and increase each year based on
9 inflation. In addition, Senator Graham has released a discussion draft bill
10 entitled the Clean Energy Act of 2009. This bill establishes a clean energy
11 standard (CES) of 13 percent in 2012 increasing to 50 percent by 2050. The
12 CES differs from the RES in that in addition to renewable energy sources, new
13 nuclear generation, coal-fired generation with carbon capture and sequestration
14 (CCS), and certain incremental hydroelectric and geothermal generation can be
15 included for compliance purposes. Qualifying generation sources are treated
16 differently in awarding clean energy standard credits (CESCs). Biomass
17 projects will receive bonus allowances while coal-fired units adding CCS will
18 receive discounted CESCs. The Graham ACP starts at \$50/MWh. This bill may
19 serve as the renewable component of the Kerry Graham Lieberman Energy Bill
20 and would be the most stringent ACP to date. While GRU's generation is less
21 than 4,000,000 MWh annually, this bill would allow for voluntary participation
22 by smaller utilities such as GRU and would provide a market for clean energy

1 credits created by GREC. This provision would add value to the environmental
2 attributes associated with GREC.

3 **Florida 2010 Legislative Session Initiatives**

4 As of the date this testimony was prepared, numerous bills in both the Florida
5 Senate and House of Representatives have been proposed which would increase
6 the economic viability of GREC through different measures. Some of these bills
7 focus on ratifying the rules on the RPS adopted by the Commission, some on
8 allowing renewable energy projects to get cost recovery instead of avoided cost
9 payments, while other bills focus on deleting provisions requiring the
10 Commission to adopt rules on the RPS but allow for exemptions from
11 determination of need requirements for renewable energy facilities. Again, the
12 passage of these bills would enhance the value of the renewable energy output
13 from GREC. The following is a synopsis of the twelve bills presented during
14 the 2010 Florida Legislative Session to date:

15 **2010 Florida Senate Legislation**

16 • **S596 - Relating to Energy (Detert)**

17 S596 introduced by Senator Detert amends Section 366.92,
18 Florida Statutes, to establish a clean energy requirement for
19 electric utilities that requires a clean energy portfolio standard to
20 provide 7 percent of energy sales by 2014 based on 2013 sales.
21 The amount periodically increases to 20 percent of energy sales
22 by 2022 based on 2021 sales. Three classes of clean energy are
23 established: Class I includes wind and solar generation; Class II

1 includes other renewable energy sources including biomass
2 generation; and Class III includes nuclear and coal-fired
3 generation with carbon capture and sequestration technology. The
4 legislation also establishes alternative compliance through the
5 purchase of clean energy credits (CECs). In addition the
6 legislation creates a new section 366.99 that is designed to
7 promote expanded use of natural gas. The legislation also
8 removes solar energy projects from regulation under the Florida
9 Electrical Power Plant Siting Act.

- 10 ● **S774 Relating to Renewable Energy Policy (Constantine)**
11 Ratifies the rules on renewable portfolio standards adopted by the
12 Public Service Commission January 9, 2009.
- 13 ● **S1086 Relating to Renewable Energy (Detert)**
14 Requires that a purchase contract offered to producers of
15 renewable energy contain payment provisions for energy and
16 capacity based upon a public utility's equivalent cost-recovery
17 rate for certain clean energy projects rather than the utility's full
18 avoided costs.
- 19 ● **S1126 Relating to Permitting (Altman)**
20 Clarifies duties of the Office of Tourism, Trade, and Economic
21 Development (OTTED) to approve expedited permitting and
22 comprehensive plan amendments. Revises criteria for businesses
23 submitting permit applications or local comprehensive plan

- 1 amendments. Provides that permit applications and local
2 comprehensive plan amendments for specified biofuel and
3 renewable energy projects are eligible for the expedited
4 permitting process, etc.
- 5 • **S1186 Relating to Renewable Energy (Bennett)**
6 Revises legislative intent regarding the state's renewable energy
7 policy. Deletes provisions requiring that the PSC adopt rules for a
8 renewable portfolio standard. Requires that the commission
9 provide for full cost recovery for certain renewable energy
10 projects. Redefines the term "electrical power plant" for purposes
11 of the Florida Electrical Power Plant Siting Act to exclude solar
12 electrical generating facilities, etc.
 - 13 • **S2346 Relating to Renewable Energy (Altman)**
14 Cites act as the "Florida Farm to Energy Act." Requires investor-
15 owned electric utilities and participating municipal electric
16 utilities and rural electric cooperatives to collect renewable
17 energy fees from retail electric customers. Provides for the
18 deposit and use of such fees. Provides procedures for municipal
19 electric utilities and rural electric cooperatives to participate or
20 terminate their participation, etc.
 - 21 • **S2404 Relating to Renewable Energy (Bennett)**
22 Requires each electric utility in the state to collect from each
23 residential, commercial, and industrial customer a designated

1 monthly systems charge. Requires the electric utilities to deposit
2 collected funds into the Sustainable and Renewable Energy
3 Policy Trust Fund. Creates a direct-support organization for the
4 Florida Energy Office. Revises the expiration date for the Solar
5 Energy System Incentives Program, etc.

6 **2010 Florida House of Representatives Legislation**

7 • **HB 773 - Relating to Expedited Permitting** (Kreegel)

8 Transfers authority over expedited permitting and comprehensive
9 plan amendment process from OTTED to Secretary of
10 Environmental Protection; revises job-creation criteria for
11 businesses to qualify to submit such permit applications and local
12 comprehensive plan amendments; provides for expedited review
13 of specified renewable energy projects; provides for
14 establishment of regional permit action teams through execution
15 of memoranda of agreement developed by permit applicants and
16 secretary; provides for appeal and challenge of expedited permit
17 or comprehensive plan amendment; revises provisions for review
18 of sites proposed for location of facilities eligible for Innovation
19 Incentive Program; specifies expedited review for certain
20 electrical power projects.

21 • **HB 1267 Relating to Renewable Energy** (Rehwinkel Vasilinda)

22 Requires electric utilities to collect monthly systems charge from
23 residential, commercial, & industrial customers; provides for

1 deposit of collected funds into Sustainable and Renewable
2 Energy Policy Trust Fund; creates direct-support organization for
3 Florida Energy Office; requires contract between office and
4 direct-support organization; provides for use of funds; requires
5 annual audit; requires purchase contract offered to producers of
6 renewable energy contain payment provisions for energy and
7 capacity based upon public utility's equivalent cost-recovery rate
8 for certain clean energy projects; extends period of time for
9 which residents are eligible to receive rebates for specified solar
10 energy systems; provides schedule for rebate amounts.

11 • **HB 1371 Relating to Renewable Energy (Randolph)**

12 Requires that purchase contract offered to producers of renewable
13 energy contain payment provisions for energy and capacity based
14 upon public utility's equivalent cost-recovery rate for certain
15 clean energy projects rather than utility's full avoided costs.

16 • **HB 1417 Relating to Renewable Energy (Kriseman)**

17 Deletes provision requiring certain net metering be made
18 available when utility purchases power generated from biogas
19 produced by anaerobic digestions of agricultural waste; ratifies
20 rules on renewable portfolio standards adopted by Public Service
21 Commission.

22

23

1 • **HB 1471 Relating to Renewable Energy (Williams)**
2 Amends section 366.92 to delete provisions requiring the
3 adoption of rules for a renewable portfolio standard by the PSC.
4 The legislation also requires the PSC to provide for full cost
5 recovery including a return of equity of not less than 50 basis
6 points above the last PSC approved rate of return for the utility.
7 The legislation also requires the PSC to approve a total of 700
8 MW of renewable energy projects for years 2010 to 2012. The
9 legislation establishes a finding of the Florida Legislature that
10 there is a need for new Florida renewable resources and that this
11 determination will serve as the need determination required under
12 section 403.519 and also as the commission's agency report
13 under section 403.507 (4) (a). In addition, the legislation requires
14 the commission to vote on the petition for new renewable
15 generation within 90 days of receipt of filing. The legislation
16 also creates an exception for a solar electric generating facility of
17 any capacity under the Florida Electrical Power Plant Siting Act.

18

19 **Summary and Conclusions**

20 **Q. Please summarize your testimony.**

21 A. My testimony may be summarized as follows.

22 • GREC is the least cost alternative for meeting Gainesville's
23 policy objectives, improving GRU's electric system reliability

- 1 and integrity, mitigating the risks of future greenhouse gas and
2 renewable energy regulations, and mitigating the risks of
3 increasing fossil fuel prices and volatility, as well as numerous
4 other risks.
- 5 • GREC will create over 700 permanent jobs in the north central
6 Florida region with an income of \$31 million per year (2010
7 dollars) which is equivalent to a \$608 million net present value
8 (2010 dollars).
 - 9 • When the benefits of economic development are considered,
10 GREC has no downside risk. Excluding economic development
11 benefits, and making biased and unrealistic assumptions against
12 GREC, the expected value of GREC's risk adjusted benefits
13 exceed costs by more than 2 to 1, with a benefit of \$74.1 million
14 (net present value in 2010 dollars). This assumes that
15 unrealistically low probabilities are assigned to carbon regulation
16 (10 percent), renewable energy requirements (20 percent), and
17 the possibility of fossil fuel prices increasing (33 percent).
 - 18 • Under mid-range probabilities, benefits exceed costs by a ratio of
19 greater than 10 to 1 with an expected value \$297.7 million (net
20 present value in 2010 dollars).
 - 21 • To obtain a benefit cost ratio of less than 1, all of the benefits of
22 economic development have to be excluded, the probability of
23 carbon regulation *must be assumed to be zero*, the probability of

1 renewable energy requirements *must be assumed to be zero*, and
2 the possibility of fossil fuel prices increasing *must be assumed to*
3 *be zero*. The implausibility of these outcomes is demonstrated by
4 the initiatives already taken by the U.S. EPA to regulate
5 greenhouse gases and pollutants, the groundswell including 35
6 states with RPS standards or goals and twelve (12) bills
7 introduced to the Florida legislature to promote renewable energy
8 so far this year, and the evidence provided in Exhibit No. __
9 [EJR-6] of the trends in natural gas price compared to forecasts
10 since 2004.

- 11 • The power purchase agreement between GRU and GREC LLC is
12 structured to provide as much as \$88 million (net present value in
13 2010 dollars) of additional benefits for GRU's customers in the
14 form of protection from: construction cost over-runs; financing
15 interest rate increases; long term operation and maintenance
16 escalation; unexpected equipment failure and damage; loss of
17 unit efficiency; and failure to perform.
- 18 • GRU has a number of mechanisms to manage ongoing risks such
19 as the ability to: resell a portion of GREC's output at no less than
20 a fair market price; financially hedge against diesel and labor
21 costs in GREC's fuel contracts; and apply financial tools such as
22 prepayment contracts.

1 In conclusion, GREC will provide substantial reliability, cost savings, and risk
2 mitigation benefits to GRU's customers and the broader Gainesville community,
3 and the Commission should grant the requested determination of need.

4

5 **Q. Does this conclude your testimony?**

6 **A.** Yes it does.

7

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 090451-EM,

PETITION FOR DETERMINATION OF NEED FOR THE
THE GAINESVILLE RENEWABLE ENERGY CENTER

EXHIBITS TO

SUPPLEMENTAL TESTIMONY OF EDWARD J. REGAN, P.E.

ON BEHALF OF

GAINESVILLE REGIONAL UTILITIES AND
GAINESVILLE RENEWABLE ENERGY CENTER, LLC

MARCH 15, 2010

**Financial Costs Associated With Policy Objectives, Environmental Regulations,
Fuel Price Volatility and Adding New Generation Capacity
(\$2010 NPV 30 Years)**

Source of Risk	Potential Cost to GRU Customers	Note	Comment
Policy Goal to Meet Kyoto Targets	100% Solar- net of avoided fuel	-a	Rejected
	Solar @4 MW per year (net)	-b	Adopted
	GREC- with CO2 reg.	c	GREC in 2014
	GREC- Base case	d	GREC in 2014
	GREC- Worst case	d	GREC in 2014
Carbon Cap And Trade	No GREC	-e	
	GREC- market price resale	-	
	Benefit	c	GREC in 2014
Renewable Portfolio Standard	Solar Only	-e	Natural gas additions
	Solar and GREC		With GREC in 2014
	Benefit		
Fossil Fuel 10% Higher	No GREC	-f	
	GREC - market sale	-f	GREC in 2014
	Benefit		
CAIR and CAMR	Market Purchases	g	rejected
	Control Equipment	h	Control equipment
Reliability of Existing Units	Outages	-i	Do Nothing Until 2023
		-	GREC in 2014
	Benefit		
Natural Gas Volatility	Hedging Pgm @.35 \$/mmBtu	-j	Do Nothing
		-k	GREC in 2014
	Benefit		
GREC Ownership Risks	Construction @10%	1.	Structure of PPA
	O&M @ 10%	1.	Structure of PPA
	Financing @ 50 BP	1.	Structure of PPA
	Benefits from PPA		Structure of PPA

a. 788,000 MWh/yr @\$230/MWh

b. Existing FIT Program

c. Scenario from Interrogatory 104 - benefit from avoided carbon costs

d. Scenario from Interrogatory 104

e. HB 2425 CO2 midrange impact

e. HB 2425 RPS impacts without GREC, 7% RPS @\$25/REC

f. Interrogatory 104 scenarios with adjusted fuel prices

g. Evaluation performed based on Nox and SO2 Market in 200

h. Air emission control capital cost plus ongoing O&M

i. 21 days of DH 2 @ \$70/MWh replacement power thru 2032

j. based on GRU's hedging target of .35\$/mmBtu


k. 15% natural gas @ \$8/mmBtu, 12 HR, 15% volatility

k. Based on estimated taxable value of \$375,000,000

Biased Expected Value Risk Analysis for GREC
 (\$2010 Million NPV)

Risk	Cost or Benefit	Biased Probability	Risk Adj. Cost or Benefit
Worst Case Market Resale	-\$61.5	100%	-\$61.5
Carbon Regulation	\$398.9	10%	\$39.9
Renewable Portfolio Standard	\$61.3	20%	\$12.3
Fossil Fuel Price Increase	\$89.1	33%	\$29.4
Gas Hedging Program	\$20.4	50%	\$10.2
Ownership Risk	\$87.6	50%	\$43.8
	Benefit to Cost Ratio		2.20
	Expected value		\$74.1

Figure 1
Gas Price Forecasts Are Unstable



Mid-Range Expected Value Risk Analysis for GREC
(\$2010 NPV)

Risk	Cost or Benefit	Mid-Range Probabilities	Risk Adj. Cost or Benefit
Worst Case Market Resale	-\$61.5	50%	-\$30.8
Carbon Regulation	\$398.9	50%	\$199.5
Renewable Portfolio Standard	\$61.3	50%	\$30.7
Fossil Fuel Price Increase	\$89.1	50%	\$44.6
Gas Hedging Program	\$20.4	50%	\$10.2
Ownership Risk	\$87.6	50%	\$43.8
	Benefit to Cost Ratio		10.69
	Expected value		\$297.9



Gainesville Regional Utilities

Biomass Sizing Study

FINAL REPORT

B&V Project Number 145639

B&V File Number 40.0000

January 2007

Black & Veatch Corporation
11401 Lamar
Overland Park, Kansas 66211
Tel: (913) 458-2000 www.bv.com



BLACK & VEATCH
building a **world** of difference™

ENERGY WATER INFORMATION GOVERNMENT

Principal Investigators:

Jack Miller, Project Manager
Jim Easterly
Bill Crean
Keith Cummer
Ryan Pletka
Boyd Pro

Table of Contents

1.0 Executive Summary	1-1
1.1 Identification of Technologies to be Considered	1-1
1.2 Development of Preliminary Technology Characteristics	1-1
1.2.1 Boiler Vendor Surveys.....	1-2
1.2.2 Air Permitting	1-3
1.2.3 Performance Modeling.....	1-3
1.2.4 Cost and Operating Data.....	1-4
1.3 Impacts Resulting from the Incorporation of Fuel Flexibility	1-4
2.0 Introduction.....	2-1
2.1 Background.....	2-1
2.2 Objective	2-1
3.0 Identification of Technologies to be Considered	3-1
3.1 Biomass Feedstock Considerations.....	3-1
3.2 Conversion Technology Options	3-1
3.2.1 Direct Combustion Technologies	3-2
3.2.2 Gasification	3-9
3.2.3 Pyrolysis.....	3-18
3.3 Recommended Technologies for Further Consideration	3-20
4.0 Development of Preliminary Technology Characteristics	4-1
4.1 Boiler Vendor Surveys.....	4-1
4.1.1 Findings of the Vendor Survey	4-2
4.1.2 Recommendations for the Biomass-Fired System.....	4-4
4.2 Air Permitting	4-4
4.2.1 Project Description.....	4-4
4.2.2 PSD Applicability	4-5
4.2.3 Additional Regulatory Review	4-9
4.2.4 Summary	4-11
4.3 Performance Modeling.....	4-11
4.3.1 Model Assumptions and Results.....	4-11
4.3.2 Biomass Fuel Consumption Rates	4-12
4.3.3 Feasibility of Reheat Systems.....	4-14
4.4 Cost and Operations Data	4-15
4.4.1 Capital Cost Estimates and Cash Flow during Construction.....	4-15

4.4.2 Operating and Maintenance Parameters and Cost Estimates.....	4-21
5.0 Impacts Resulting from the Incorporation of Fuel Flexibility	5-1
5.1 Opinions from Boiler Vendors.....	5-1
5.2 Permitting Implications of Cofiring.....	5-2
5.3 Impacted Systems and Estimated Costs.....	5-3

Appendices

Appendix A. Heat Balance for 50 MW Stoker System

Appendix B. Heat Balance for 100 MW CFB System

Appendix C. Heat Balance for 100 MW CFB (Reheat) System

List of Tables

Table 1-1. Summary of System Performance Modeling. ^a	1-5
Table 1-2. Summary of Key Cost and Operational Data for BFB Systems.	1-6
Table 1-3. Increase in Capital Cost of 100 MW CFB (30% Coal Cofiring).	1-7
Table 3-1. General Comparison of Stoker and Fluidized Bed Technologies.	3-9
Table 4-1. List of Contacted Biomass Boiler Vendors.	4-1
Table 4-2. Maximum Steam Flow Rates and Conditions by Vendor.	4-4
Table 4-3. PSD Significant Emission Rates.	4-6
Table 4-4. Assumptions for Biomass-Fired Unit Emission Calculations.	4-6
Table 4-5. Emission Limits of a 50 MW CFB Located in New Hampshire.	4-8
Table 4-6. Emission Limits of a Biomass-Fired Stoker Located in Washington.	4-9
Table 4-7. Summary of System Performance Modeling. ^a	4-13
Table 4-8. Owner's "Soft" Costs.	4-17
Table 4-9. Capital Cost Estimate—50 MW BFB (2006 Overnight Costs)*	4-18
Table 4-10. Capital Cost Estimate—100 MW BFB (2006 Overnight Costs)*	4-19
Table 4-11. Cash Flow during Construction of Biomass-Fired Unit.	4-20
Table 4-12. Expected Unit Availability.	4-21
Table 4-13. Unit Outage Schedule.	4-21
Table 4-14. Non-fuel O&M Cost Estimate.	4-22
Table 5-1. Increase in Capital Cost of 100 MW CFB (30% Coal Cofiring).	5-3
Table A-1. Preliminary Heat Balance—Biomass-Fired 50 MW Stoker, 100% Load.	A-3
Table A-2. Preliminary Heat Balance—Biomass-Fired 50 MW Stoker, 75% Load.	A-5
Table A-3. Preliminary Heat Balance—Biomass-Fired 50 MW Stoker, 50% Load.	A-7
Table B-1. Preliminary Heat Balance—Biomass-Fired 100 MW CFB, 100% Load.	B-3
Table B-2. Preliminary Heat Balance—Biomass-Fired 100 MW CFB, 75% Load.	B-5
Table B-3. Preliminary Heat Balance—Biomass-Fired 100 MW CFB, 50% Load.	B-7
Table C-1. Preliminary Heat Balance—Biomass-Fired 100 MW CFB (with Reheat), 100% Load.	C-3
Table C-2. Preliminary Heat Balance—Biomass-Fired 100 MW CFB (with Reheat), 75% Load.	C-5
Table C-3. Preliminary Heat Balance—Biomass-Fired 100 MW CFB (with Reheat), 50% Load.	C-7

List of Figures

Figure 3-1. Vibrating Grate Stoker (Source: Riley Power).	3-4
---	-----

Figure 3-2. Typical Bubbling Fluidized Bed (source: Energy Products of Idaho).....	3-5
Figure 3-3. Alholmens Kraft Multi-Fuel CFB (Source: Kvaerner).....	3-7
Figure 3-4. Gas Flare from an Experimental 5 TPD Biomass Gasifier.....	3-11
Figure 3-5. General Gasification Process Flow Options.	3-14
Figure 3-6. Gasification for Biomass Cofiring with Fossil Fuels.....	3-14
Figure 3-7. General Pyrolysis Process Flow Options.	3-19
Figure 3-8. Bio-oil Produced from Pyrolysis (Source: Iowa State University).....	3-20
Figure 4-1. Partial Load Net Plant Heat Rate.	4-14
Figure A-1. Preliminary Steam Cycle Diagram—Biomass-Fired 50 MW Stoker.	A-2
Figure B-1. Preliminary Steam Cycle Diagram—Biomass-Fired 100 MW CFB.	B-2
Figure C-1. Preliminary Steam Cycle Diagram—Biomass-Fired 100 MW CFB (with Reheat).....	C-2

1.0 Executive Summary

Gainesville Regional Utilities (GRU) has retained Black & Veatch to determine the optimal technology for the production of biomass-fired electrical generation at Deerhaven Generating Station. Three tasks were formulated as follows:

- Task 1—Identification of Technologies to be Considered
- Task 2—Development of Preliminary Technology Characteristics for Various Technologies and Unit Sizes
- Task 3—Estimation of Impacts Resulting from Incorporating Fuel Flexibility

This report summarizes the findings of Task 1, Task 2 and Task 3, including the relevant technology characteristics for biomass combustion technologies capable of providing between 50 and 100 MW of electrical generation.

1.1 Identification of Technologies to be Considered

Black & Veatch identified potential biomass-fired technologies that could be used for this application, focusing on those that are considered commercially available in the size range being considered. In evaluating suitable technologies, key criteria include cost effectiveness (on a life cycle basis), proven technology, reliability, tolerance to fuel variability, and ease of operation.

Black & Veatch reviewed both combustion and gasification technologies to determine their potential for a biomass-fired power generation facility. Details of this review are provided in Section 3.0 of this report. Based on proven performance in prior biomass power applications, Black & Veatch recommends three direct combustion technologies for further consideration. These technologies included:

- Stoker grate boilers
- Bubbling Fluidized Bed (BFB) boilers
- Circulating Fluidized Bed (CFB) boilers

These three technologies were the focus of Task 2 and Task 3.

1.2 Development of Preliminary Technology Characteristics

Following the identification of likely biomass-fired generation technologies, the defining characteristics of the appropriate generation system were determined through discussions with biomass boiler vendors, review of applicable environmental regulations,

performance modeling of steam cycle and cost estimation of the likely system components.

1.2.1 Boiler Vendor Surveys

Biomass combustion equipment vendors were contacted to determine the current state of the art of the selected biomass combustion technologies and to identify the relevant operational parameters of the technologies. The vendors contacted during this survey included the following:

- Babcock & Wilcox
- Foster Wheeler
- Alstom
- Energy Products of Idaho
- Kvaerner
- McBurney
- PowerDyne (Detroit Stoker)
- Wellons Boiler

The information provided by vendors during the biomass boiler survey is presented in Section 4.1 of this report. The most significant findings of the survey include:

- Vendors capable of providing all three biomass combustion technologies (i.e., Babcock & Wilcox and Foster Wheeler) independently stated that BFBs are the best choice for units up to 70 MW in size. Babcock & Wilcox recommended the use of BFBs across the entire size range of 50 to 100 MW, while Foster Wheeler recommended the use of CFBs for units in the size range of 70 to 100 MW (above 650,000 lb/hr of steam).
- At the lower end of the size range (approximately 50 MW), the vendors recommended BFBs in favor of stokers due to the high moisture content of the biomass and low alkali content of woody biomass.
- At the higher end of the size range, Babcock & Wilcox recommended BFBs in the favor of CFBs due to the higher capital costs of CFBs.
- All vendors are capable of firing fuels with moisture contents in the range of 35 to 50 percent.
- All vendors claimed to be able to meet expected emission requirements for the biomass-only case. All vendors felt that SNCR would be necessary to comply with NO_x limits, but little to no sulfur control would be required for the combustion of 100 percent biomass.

Based on the information regarding biomass-fired systems provided by the vendors, Black & Veatch recommends the following:

- A bubbling fluidized bed (BFB) boiler is recommended to provide steam for an electrical generation system fired by 100 percent biomass.
- The electrical generation capacity of the system will be determined by the availability of biomass fuel rather than any technical characteristic or limitation of the boiler system. Therefore, a detailed biomass resource assessment is recommended to identify potential biomass suppliers, to better establish the likely cost of the fuel, and to determine the optimal size of the system.
- Specific fuel characterization (fuel analyses) should be done as part of the resources assessment.

1.2.2 Air Permitting

Unless netting can be used to avoid PSD applicability, it is expected that the installation of a new wood-fired boiler at the Deerhaven facility would be considered a major modification to the facility under PSD regulations for a number of pollutants. If PSD is triggered, it will require installation of emission controls that are deemed to be BACT, and an AAQIA would be needed as part of the permit application. In general, a PSD permitting effort from start of application preparation to receiving an Agency permit is typically estimated to take 12 to 24 months. Another consideration when proposing to install additional electric utility steam generating units in Florida is whether the installation will be subject to the Florida Power Plant Siting Act. Going through the siting act approval process can add complexity and time to the overall permitting process. It is expected that, at a minimum, the installation of a new generating unit at Deerhaven would require a modification to the plant's Site Certification.

1.2.3 Performance Modeling

To quantify performance of the system and determine certain operating parameters, a model of the steam cycle was prepared, and heat and mass balances were developed for three operational scenarios. These scenarios include:

- 50 MW (net) Steam Cycle (steam provided by a Stoker boiler)
- 100 MW (net) Steam Cycle (steam provided by a CFB boiler)
- 100 MW (net) Steam Cycle, with Reheat (steam provided by a CFB boiler)

The results of thermal performance modeling are summarized in Table 1-1. The complete heat balances for the 50 MW scenario, the 100 MW CFB scenario and the 100 MW CFB with reheat scenario are provided in Appendix A, Appendix B and Appendix C, respectively.

The performance results for the 100 MW BFB case are based on the results for the 100 MW CFB case. Because the steam cycle parameters are identical for the BFB and CFB systems, the steam flows and conditions for these two cases are also identical. Furthermore, the differences in auxiliary power requirements for these two systems were assumed to be negligible, as the increased pressure drops through the CFB system are mitigated to some extent by the increased excess air requirements of the BFB. However, the boiler efficiency of the BFB was assumed to be approximately 3 percentage points lower for the BFB relative to the CFB due to increased excess air requirements and greater unburned carbon losses for the BFB. The lower boiler efficiency results in a slightly higher net plant heat rate and greater fuel requirements for the BFB relative to the CFB system, as shown in Table 1-1.

1.2.4 Cost and Operating Data

Cost estimates and operational parameters have been gathered for biomass-fired units based on similar projects. These estimates and operational parameters have been gathered for both a 50 MW BFB system and a 100 MW BFB system, and they include capital costs (EPC contracting basis), operating and maintenance (O&M) costs, cash flow during construction, maintenance schedules and availability assumptions. The complete data set is presented in Section 4.4. Key parameters for these systems are summarized in Table 1-2.

1.3 Impacts Resulting from the Incorporation of Fuel Flexibility

While the generation systems described in the previous sections have been assumed to utilize only biomass fuels, there may be fuel supply situations in which the ability to fire coal in the selected system would be advantageous. Black & Veatch consulted with boiler vendors, reviewed relevant permitting regulations and identified the required system modifications and associated costs to determine the extent to which the selected biomass systems may be capable of utilizing coal as a fuel.

If it is determined that the limited availability of biomass resources requires the combustion of coal at a more significant level (i.e., the unit's standard operating procedure includes the cofiring of coal at more than 20 percent of the heat input to the boiler), it is recommended that a CFB boiler rather than a BFB boiler be employed to generate steam, as CFBs are more capable of simultaneously combusting varied fuels.

Discussions with Babcock & Wilcox and Foster Wheeler indicated that capital costs of CFBs are roughly 10 percent to 15 percent greater than those of BFBs. As in the case of coal cofiring in a BFB, control systems would be required to limit the emission of sulfur dioxide. These systems would likely be composed of limestone injection equipment and downstream polishing reactors.

Table 1-1. Summary of System Performance Modeling. ^a

	50 MW Stoker	100 MW BFB ^b	100 MW CFB	100 MW CFB (Reheat)
Full Load System Parameters				
Turbine Gross Output (100% Load), kW	57,465	115,053	115,053	114,977
Turbine Heat Rate (100% Load), Btu/kWh	8,657	8,259	8,259	7,924
Total Auxiliary Power (100% Load), kW	7,470	15,000	15,000	15,000
Total Auxiliary Power (100% Load), %	13.0	13.0	13.0	13.0
Net Plant Output (100% Load), kW	50,000	100,050	100,050	99,980
Heat to Steam from Boiler (100% Load), MBtu/hr	497.9	951.2	951.2	913.4
Boiler Efficiency (HHV)	80.0	77.0	80.0	80.0
Boiler Heat Input (100% Load), MBtu/hr (HHV)	622.4	1,235.3	1,189.0	1,141.7
Biomass Fuel Requirement ^c , tons/day	1,464	2,907	2,798	2,686
Number of Heaters	4	5	5	5
Part Load Heat Rate Calculations				
Net Plant Heat Rate (100% Load), Btu/kWh (HHV)	12,448	12,347	11,884	11,420
Net Plant Heat Rate (75% Load), Btu/kWh (HHV)	13,017	12,826	12,345	11,779
Net Plant Heat Rate (50% Load), Btu/kWh (HHV)	14,177	13,979	13,455	12,705

Notes:

- ^a Performance is preliminary and for information only. Not to be used for detailed design.
Auxiliary power is assumed to be 13% of base load (100% load).
Water cooling with mechanical draft cooling tower is used.
Average ambient conditions of 59°F dry bulb temperature and 50% relative humidity are used.
Boiler efficiency is assumed to be 80% for all cases except the 100 MW BFB case.
- ^b The thermal performance for the 100 MW BFB case was estimated from the modeling of the 100 MW CFB case. It was assumed that auxiliary power requirements would be roughly equivalent for the two systems, but boiler efficiency would be slightly lower for the BFB relative to the CFB because of the increased excess air requirements and greater unburned carbon losses for the BFB.
- ^c Biomass fuel requirement, in tons per day, was calculated based on the boiler heat input and an assumed heating value of biomass of 5100 Btu/lb. This heating value assumes a biomass moisture content of 40%.

Table 1-2. Summary of Key Cost and Operational Data for BFB Systems.

	50 MW BFB System	100 MW BFB System
Total Project Capital Cost (EPC)*, \$ (2006\$)	142,290,957	242,907,204
Non-fuel O&M Cost**		
Fixed Non-fuel O&M, \$/kW-yr (2006\$)	91.04	55.65
Variable Non-fuel O&M, \$/MWh (2006\$)	4.13	3.13
Equivalent Availability Factor, %	88 to 90	88 to 90
Forced Outage Rate, %	5 to 8	5 to 8
Steam Generator Outages		
Duration, weeks	3	3
Frequency, years/outage	2 to 3	2 to 3
Steam Turbine Outages		
Duration, weeks	6	6
Frequency, years/outage	6 to 8	6 to 8

Notes:

* Total Project Cost is an estimate of overnight cost and does not include Owner's Costs such as Interest During Construction (IDC), Escalation or Permitting.

** Non-fuel O&M costs assume net generation of 50 MW and 100 MW, respectively.

The increase in capital costs for a 100 MW CFB unit with the capability to cofire 30 percent coal is shown in Table 1-3. Other costs may increase relative to the 100 MW biomass-fired BFB system, but these costs are not expected to be as significant as the costs identified in Table 1-3. Furthermore, Black & Veatch does not expect the change from a biomass-only BFB system to a cofired CFB system to alter the expected cash flow during construction, unit availability or outage schedule.

Table 1-3. Increase in Capital Cost of 100 MW CFB (30% Coal Cofiring).

Equipment	Cost (2006\$)
Fluidized Bed*	4,713,000
Sulfur Dioxide Control**	11,483,000
Total	16,169,000

Notes:

- * Increase in capital cost of a 100 MW CFB unit designed to fire a 70/30 biomass/coal fuel mixture relative to the cost of a 100 MW BFB designed to fire 100% biomass. Incremental cost assumed to be 10% of the equipment cost of a 100 MW BFB (as listed in Table 4-10).
- ** Capital cost of sulfur dioxide control equipment necessary to reduce SO₂ emissions from a 100 MW CFB to permitted levels assuming a 70/30 biomass/coal fuel mixture. This estimate assumes a dry lime system coupled with an existing ESP for sorbent capture.

2.0 Introduction

Gainesville Regional Utilities (GRU) has retained Black & Veatch to determine the optimal technology for the production of biomass-fired electrical generation at Deerhaven Generating Station. The work was subdivided into the following three tasks:

- Task 1—Identification of Technologies to be Considered
- Task 2—Development of Preliminary Technology Characteristics for Various Technologies and Unit Sizes
- Task 3—Estimation of Impacts Resulting from Incorporating Fuel Flexibility

This report summarizes the findings of Task 1, Task 2 and Task 3, including the relevant technology characteristics for biomass combustion technologies capable of providing between 50 and 100 MW of electrical generation.

2.1 Background

GRU has received direction from the City Commission to pursue specific methods for meeting the City of Gainesville's future additional electric energy needs, one of which involves generation utilizing biomass fuel. Accordingly, GRU is investigating the feasibility of biomass-fired generation, which is to be located at the Deerhaven Generating Station. The selected biomass technology should be capable of burning 100 percent biomass and should have the ability to provide up to 100 MW of generation.

2.2 Objective

GRU intends to develop a production cost model to simulate the economic performance of the biomass concept. To provide the appropriate inputs to the economic model, Black & Veatch has been requested to estimate the optimum size for such a facility within the range of 50 MW to 100 MW, and the corresponding cost and performance characteristics for input to GRU's model.

The objective of Task 1 is to identify the most promising biomass-fired technologies for near-term energy production. The objective of Task 2 is to characterize performance and cost parameters of the selected technology concepts. These parameters are to be determined for the 100 percent biomass case and include capital costs, operation and maintenance costs, net capacity, auxiliary power consumption, biomass burn rate and net plant heat rate. The objective of Task 3 is to determine the extent to which the systems developed in Task 2 would be capable of firing coal, considering technical, regulatory and economic perspectives.

3.0 Identification of Technologies to be Considered

Black & Veatch reviewed a variety of potential biomass-fired technologies that could be used to provide 50 MW to 100 MW of electrical generation, including both direct combustion and gasification schemes. This investigation focused on those technologies that are considered commercially available in the size range being considered. In evaluating suitable technologies, key criteria include cost effectiveness (on a life cycle basis), proven technology, reliability, tolerance to fuel variability, and ease of operation. A discussion of the relevant characteristics of biomass technologies is presented in the following subsections.

3.1 Biomass Feedstock Considerations

Wood is the most common type of biomass currently used as fuel for electric power production, and considered to be the most likely choice for fueling a biomass power plant at Deerhaven. Other biomass fuels that can be used for power production include agricultural residues such as bagasse (sugar cane residues), dedicated fuel crops such as fast growing grasses and eucalyptus trees, dried manure and sewage sludge, and "black liquor" residues from pulp mills.

Biomass plants have typically had electric generating capacities of less than 50 MW because of the transportation costs inherent in the dispersed nature of the feedstock and the lower energy density of the fuel per unit volume, thus requiring larger volumes of fuel per megawatt-hour of production. As a result of the smaller scale of the plants and lower energy density of the fuels per unit of volume, biomass plants are commonly less efficient than modern fossil fuel plants. In addition to being less efficient, power production from biomass has typically been more expensive than conventional fossil fuels on a \$/MBtu basis because of added transportation costs alluded to above. These factors have typically limited the use of biomass for electric power production to inexpensive waste biomass sources; however the rise in fossil fuel prices that has occurred over the last few years has created an economic environment in which a wider variety of biomass sources can be competitive.

3.2 Conversion Technology Options

The objective of Task 1 is to identify commercial technologies that could be attractive for a GRU-owned biomass-fueled power plant. For power generation from biomass fuels, direct combustion has long been the preferred technology. Almost all of the nearly 10,000 MW of biomass and waste fired power plants in the U.S. rely on direct combustion technology.

Biomass gasification is an emerging alternative that can be used in advanced power cycles such as integrated gasification combined cycle (IGCC). Further, by converting solid fuel to a combustible gas, gasification expands the end use options for biomass. Gasification allows the use of cleaner and more efficient power conversion processes such as gas turbines and fuel cells to produce power, and/or chemical synthesis to produce ethanol and other value added products.

Pyrolysis and anaerobic digestion are two other options for producing electric power from biomass. Pyrolysis offers similar promise to gasification. However, most pyrolysis processes are in the early stages of commercialization and focused on production of value added chemicals rather than steam or power. Finally, anaerobic digestion is suitable for niche applications where waste stabilization is a primary concern. Examples of appropriate fuels include dairy manure, hog manure, slaughterhouse waste, and food waste. Energy yield from anaerobic digestion systems is typically lower than combustion and gasification systems.

The remainder of this section reviews combustion, gasification, pyrolysis, and anaerobic digestion processes. Of these, combustion and gasification have greater promise and are explored in more detail. Anaerobic digestion and pyrolysis are included for completeness.

3.2.1 Direct Combustion Technologies

There are several proven direct combustion systems for burning biomass fuels. These include the following:

- Stoker grate boilers (dumping grate, traveling grate, vibrating grate, etc.);
- Bubbling fluidized bed boilers;
- Circulating fluidized bed boilers; and
- Pulverized fuel suspension fired boilers.

Except for pulverized fuel suspension fired boilers, which are generally only suitable for very dry, small size biomass fuels (e.g., rice husks), the various combustion devices are described further in this section.

3.2.1.1 Stoker Grate Boilers

Stoker combustion is a proven technology that has been successfully used with biomass fuels (primarily wood) for many years. In the stoker boiler, fuel feeders ("stokers") regulate the flow of fuel down chutes that penetrate the front wall of the boiler above a grate. Mechanical devices or jets of high-pressure air throw the fuel out into the furnace section and onto the grate. Because biomass fuel readily devolatilizes,

much of the biomass burns in suspension. Therefore, a significant portion of the total combustion air is introduced as overfire air. The unburned char settles on the grate surface and char burnout is completed by preheated primary air introduced below the grate. The speed of the feeders is modulated to maintain output with changing fuel conditions or to respond to load changes.

The grate must be designed to support efficient combustion of the biomass char and allow removal of the ash. There are several types of grates used with stokers:

- **Dumping grates** – Relatively old technology for high ash fuels
- **Pin-hole grates** – Stationary grate design for low ash fuels such as sugar cane bagasse
- **Traveling grates** – Well-proven air-cooled conveying grate design suitable for most biomass fuels
- **Vibrating grates** – Water-cooled sloping grate that periodically vibrates to remove ash from the grate surface.

One of the most commonly used grates in new applications is the vibrating grate, which is shown in Figure 3-1. Compared to traveling grate stokers, vibrating grates have virtually no maintenance and have low excess air requirements which improve boiler efficiency and emissions. In a vibrating grate stoker, vibration of the grate causes ash to move toward the discharge end of the grate where it falls into the bottom ash collection and conveying system. The vibration of the grate is not continuous. The frequency, duration, and intensity of the grate vibrations are adjustable. This allows for optimization of the ash layer depth on the grate. About 40 percent of the ash will leave the boiler as bottom ash, and 60 percent will be fly ash.

The stoker boiler requires the biomass fuel to be sized. Depending on the manufacturer, the top size of the fuel may range from 3 to 6 inches. Black & Veatch recommends that fuel specifications require a top size of 3 inches. However, the stoker boiler has some flexibility to handle larger pieces. It is likely the stoker will be able to handle up to 5 percent of the total fuel feed as strips or stringers up to 12 inches in length. On the other hand, small fuel tends to burn more completely in suspension, and its contribution to the overall fuel mix also needs to be limited. The ash from small fuel particles leaves the furnace as fly ash instead of settling on the grate and forming a protective thermal layer. Generally, for full load operation, no more than 25 percent of the total fuel stream should be less than 1/4 inch, and no more than 6 percent should be less than 1/8 inch.




Figure 3-1. Vibrating Grate Stoker (Source: Riley Power).

Nitrogen oxide emissions from a new stoker boiler burning biomass waste can vary significantly with the type of biomass being burned, the moisture content of the biomass, temperature on the grate, and quantity of primary air. Although some plants report lower emissions, NO_x emissions from biomass-fired stoker boilers typically range from 0.2 to 0.4 lb/MBtu. Selective non-catalytic reduction (SNCR) systems have been used in stoker boilers to reduce NO_x emissions. In a SNCR system, a reagent (ammonia or urea) is injected into the flue gas to reduce NO_x emissions levels by approximately 50 to 60 percent. Some facilities have reported higher reductions.

3.2.1.2 Bubbling Fluidized Bed Combustion

Combustion of biomass in fluidized bed boilers has been practiced for more than thirty years. In bubbling fluidized bed boilers, fuel feeders discharge either to chutes that drop the fuel into the bed or to fuel conveyors that distribute the fuel to feed points around the boiler. The speed of the feeders is modulated to maintain output when fuel conditions or loads change. The fluidized bed consists of fuel, ash from the fuel, inert material (e.g., sand), and possibly a sorbent (e.g., limestone) to reduce sulfur emissions. In most biomass fired applications, the fuel typically has no or very little sulfur, thus limestone sorbent is not required and a sand bed is typically utilized. (There are some cases where biomass fuels can have higher sulfur content; for example, the sulfur content

for wet cake and syrup residues from ethanol plants are somewhat higher, which may necessitate sorbent injection to control emissions).

The fluidized state of the bed is maintained by hot primary air flowing upward through the bed, as shown in Figure 3-2. The air is introduced through a grid to evenly distribute the air. The amount of air is just sufficient to cause the bed material to lift and separate. In this state, circulation patterns occur causing fuel discharged on top of the bed to mix throughout the bed. Because of the turbulent mixing, heat transfer rates are very high and combustion efficiency is good. Consequently, combustion temperatures can be kept low compared to other conventional fossil fuel burning boilers. The bed may also be operated in a sub-stoichiometric mode with additional air added in the freeboard to complete combustion. Low bed temperatures and air staging reduces NO_x formation. Low temperature is also an advantage with biomass fuels because they may have relatively low ash fusion temperatures. Low ash fusion temperatures can lead to excessive boiler slagging.




Figure 3-2. Typical Bubbling Fluidized Bed (source: Energy Products of Idaho).

In a bubbling bed boiler, the unit is generally designed to have flue gas velocities through the bed of less than 10 feet per second. This low velocity minimizes the amount of large solid material entrained in the flue gas stream. Management of tramp material and agglomerates in the bed is very important for long term reliable operation. For example, in the Energy Products of Idaho (EPI) bubbling fluidized bed boiler, there is a bed recycle system that withdraws material from the bottom of the fluidized bed. The removed bed material is screened to separate the tramp materials (dirt, and other noncombustibles) from the inert bed material, and the reclaimed inert material is recycled back to the bed.

As with a stoker boiler, the wood waste fuel rapidly devolatilizes. This results in 55 to 60 percent of the combustion occurring in the bed and 40 to 45 percent occurring above the bed. Overfire air is required to ensure complete combustion of the fuel.

The bubbling fluidized bed boiler requires sized fuel. For the EPI fluidized bed combustor, the top size of fuel should be 4 inches. Furthermore, while the stoker boiler has some flexibility to handle longer pieces, a three dimensional sizing criteria may be required for the fluidized bed boiler. This may require more screening and sizing operations to ensure that no dimension of the fuel exceeds the recommended upper limit.

Bubbling fluidized beds are fuel flexible and are technically capable of burning a wide variety of biomass fuels as well as coal. A disadvantage of bubbling fluidized beds compared to stokers is the large auxiliary power requirement for the fluidizing air fan. Further, they are typically more expensive than stokers.

Because of the low combustion temperatures, NO_x emissions from a bubbling fluidized bed boiler burning biomass will be generally less than 0.20 lb/MBtu. In addition, the operating temperature of a bubbling fluidized bed is usually within the temperature range that allows a SNCR system to be effective. Another advantage with this type of system is that it has the potential to accommodate a wider range of fuel heating value and moisture content than the stoker boiler.

3.2.1.3 Circulating Fluidized Bed Combustion

As with bubbling fluidized bed boilers, circulating fluidized bed (CFB) units also offer a high degree of fuel flexibility and would be a suitable technology for burning biomass. As discussed earlier, with bubbling bed designs, gas velocities through the bed are typically less than 10 feet per second. In a circulating bed, fluidizing air velocity is maintained at 13 to 20 feet per second to prevent a dense bed from forming and to encourage carryover of solids from the bed. A solids separator (such as a cyclone) is used to recirculate the particles carried over from the furnace. Fuel is fed pneumatically into the combustor near the bottom of the unit and/or in the solids return leg.

Circulating fluidized beds share many of the same advantages as bubbling fluidized beds with regards to fuel flexibility, combustion efficiency, and emissions. The technology is better suited for larger sizes than stoker and bubbling fluidized bed combustion. The reason is that injection of fuel and limestone into the circulating media is much easier than evenly spreading the feed across a large grate or bubbling bed. While early circulating fluidized bed units were in the size range appropriate for most biomass plants (10-50 MW), present use of CFB technology is focused primarily on large fossil fueled units of 200 to 300 MW. Although manufacturers quote small CFBs, these units

generally cost more than other combustion technologies, making them difficult to justify for smaller biomass plants.

Large CFBs are ideally suited to burn a broad mix of fossil and biomass fuels. Some CFBs have been designed to burn up to 100 percent biomass or 100 percent coal in the same unit. An example of a successful multi-fuel unit is the 240 MW CFB owned by Alholmens Kraft Oy in Finland. This plant burns a mix of wood, peat and lignite. This unit, shown in Figure 3-3, was supplied by Kvaerner Pulping and was commissioned in 2001. This is the largest biomass fired power plant in the world. At this scale, the technology is able to maximize economies and efficiencies of scale, similar to conventional coal plants.



Figure 3-3. Alholmens Kraft Multi-Fuel CFB (Source: Kvaerner).

3.2.1.4 Combustion Technology Summary Observations

This section (3.2.1) reviewed stoker grate boilers, bubbling fluidized bed combustion, and circulating fluidized bed combustion. The selection of combustion technology for a given application is influenced by the size of the unit, the characteristics of the biomass fuel, required emissions levels, and the amount and type of maintenance effort the owner will accept.

Although stoker boilers are the most widely used combustion technology for biomass, they are not always the most appropriate technical choice. For example, rice husks are most easily fired in fluidized beds or gasifiers because the lower operation temperatures reduce the risk of slagging. Stokers may also be used, but precautions should be taken to minimize the slagging potential. Fluidized beds are good choices in general because they can tolerate wide variations in fuel moisture content and size. Their lower operating temperatures also minimize concerns related to slagging and fouling. This allows fluidized beds to take advantage of low quality opportunity fuels that stokers might not be able to fire (such as wood from storm damaged trees in Florida that can have significant amounts of sand and dirt contamination). An additional advantage of fluidized beds is their inherently lower emissions and the ability to easily add sorbent to the bed to allow capture of sulfur. The turbulent action of the bed results in high combustion efficiency for fluidized beds; however, overall plant efficiency of fluidized bed units is usually slightly lower than stokers, due to the high auxiliary power consumption of the fluidizing air fans.

Considering economics, the choice of technology to use is somewhat related to size, as the capital costs of the different technologies scale differently. For units with a steam output equivalent of 25 MW of electrical generation and smaller, it is likely that the cost effective combustion technologies will be stoker and bubbling fluidized beds (BFBs). Stokers have lower capital costs (10 to 20 percent less than BFBs) and also have lower operations and maintenance costs. Although a single stoker can be designed to provide steam for systems as large as 100 MW, stokers are typically not cost competitive above 50 MW.

At sizes above 25 MW, circulating fluidized bed (CFB) combustion technology enters the mix of cost effective proven technologies. BFBs and CFBs are the most cost effective option for very large biomass plants (>70 MW). Ensuring consistent and even injection of fuel and limestone to the boiler is much easier for larger CFBs than stokers and BFBs. The fuel flexibility of a large CFB could allow it to utilize multiple fuel sources, including biomass and fossil fuels.

Table 3-1 compares the features of stoker and fluidized bed (bubbling and circulating) biomass boilers.

Table 3-1. General Comparison of Stoker and Fluidized Bed Technologies.

	Stoker Technologies	BFB and CFB Technologies
Efficiency Issues		
Boiler Efficiency	65-85	65-85
Auxiliary Power Consumption	7-12%	8-14%
Cost Issues		
Typical Total Plant Capital Cost	\$2,500-\$3,000/kW	\$2,750-\$3,500/kW
Operating and Maintenance Cost	\$15-20/MWh	\$16-22/MWh
Fuel Issues		
Fuel Flexibility	Good	Very Good
Ability to Handle High Moisture	Good	Very good
Slagging and Fouling Potential*	Fair with proper design	Good
Uncontrolled Emissions		
NOx Emissions	0.2 to 0.4 lb/Mbtu	Less than 0.2 lb/MBtu
SOx Emissions	Fuel dependent	Fuel dependent, but controllable with sorbent
CO Emissions	0.30 lb/MBtu	0.15 lb/MBtu
* Highly fuel dependent.		

3.2.2 Gasification

Similar to coal gasification, biomass gasification is a thermal process to convert solid biomass into a gaseous fuel. This is accomplished by heating the biomass in an environment low in oxygen ("fuel rich"). Gasification is a promising process for biomass conversion. By converting solid fuel to a combustible gas, gasification offers the potential of using more advanced, efficient and environmentally benign energy conversion processes such as gas turbines and fuel cells to produce power, and chemical synthesis to produce ethanol and other value added products. Provided it is clean enough, the syngas created from gasification could also be used to displace natural gas currently used in gas-fired boilers, dryers, and other applications.

This section provides a brief history of biomass gasification, followed by a description of gasification fundamentals and a discussion of gas quality issues. The section also describes the various gasifier technology options, including gas conversion options and biomass integrated gasification combined cycle.

3.2.2.1 Gasification History

The history of gasification has been sporadic. Near the beginning of the twentieth century, over 12,000 large gasifiers were installed in North America in a period of just 30 years. These large systems provided gas to light city streets and heat various processes. Moreover, by the end of World War II, over one million small gasifiers had been used worldwide to produce fuel gas for automobiles. However, at the end of the war, the need for this emergency fuel disappeared; automobiles were reconverted to gasoline, and the arrival of large interstate natural gas pipelines put many municipal "gasworks" out of business. With the loss of equipment went the majority of the gasification artists – those who operated their generators with practical experience and intuition. In some cases, scientists and developers still struggle to reproduce with "state-of-the-art" technology what was routine operation half a century ago.

3.2.2.2 Gasification Fundamentals

Gasification is typically thought of as incomplete combustion of a fuel to produce a fuel gas with a low to medium heating value. Heat from partial combustion of the fuel is also generated, although this is not considered the primary useable product. Gasification lies between the extremes of combustion and pyrolysis (no oxygen) and occurs as the amount of oxygen supplied to the burning biomass is decreased. Biomass gasification can be described by the simple equation



Gasification occurs as the amount of oxygen, expressed in the equivalence ratio, is decreased. The equivalence ratio is defined as the ratio of the actual air-fuel ratio to the stoichiometric air-fuel ratio. Thus at an equivalence ratio of one, complete combustion theoretically occurs; at an equivalence ratio of zero, no oxygen is present and fuel pyrolysis occurs. Gasification occurs between the two extremes and is a combination of combustion and pyrolysis.

A formal definition of gasification might be the process that stores the maximum chemical energy in the gaseous portion of the products. Depending on the fuel and the reactor, the equivalence ratio for this condition can range between 0.25 and 0.35. An equivalence ratio of 0.25 represents the oxidation of one-fourth of the fuel. In most gasifiers, the heat released by burning this portion of the fuel pyrolyzes the remainder and produces a low heating value fuel gas. Below an equivalence ratio of 0.25, char (mostly solid carbon) begins to be substantially produced, and the gas production begins to taper off.

3.2.2.3 Gas Quality

The primary product of air-blown gasification is a low heating value fuel gas, typically 15 to 20 percent (150-200 Btu/ft³) of the heating value of natural gas (1,000 Btu/ft³). Gasifier fuel gas is alternatively known as syngas and producer gas. Combustible components of the gas include carbon monoxide, hydrogen, methane, and higher hydrocarbons such as ethane and propane. Inert components include nitrogen, carbon dioxide, water vapor, and trace pollutants and contaminants. The combustion of producer gas is illustrated in Figure 3-4.



Figure 3-4. Gas Flare from an Experimental 5 TPD Biomass Gasifier.

The relatively poor quality of syngas from biomass gasification is a barrier for many applications. Most gasifiers use air to partially oxidize the fuel. Nitrogen, which comprises nearly half the volume of typical air-blown fuel gas, is inert and substantially decreases the heating value of the gas. Nitrogen can not be easily removed from the syngas using post-gasification processes; other approaches must be taken. The heating value of the fuel gas may be increased by using oxygen or steam instead of air to gasify the fuel or by indirectly heating the reactor. Either option removes most of the nitrogen from the fuel gas. Large coal gasification plants typically use pure oxygen as the oxidant and are able to achieve substantially increased gas heating values. However, the cost of building a separate oxygen plant is not justified for biomass facilities, which are typically

less than 50 MW. Some alternative or indirectly-heated designs are promising, but these technologies are just now entering commercialization.

3.2.2.4 Gasifier Technology Options

There is a huge variety of gasification technologies including updraft, downdraft, fixed grate, entrained flow, fluidized bed, and molten metal baths. Unlike combustion technologies discussed previously, it is difficult to generally group and categorize gasification technologies because of the wide variety of process variables that differentiate designs. These include:

- **Reactor type** – Many of the same technologies that have been developed for combustion can be adapted for gasification. These include grate systems and bubbling and circulating fluidized beds. Some of these technologies can alternately operate between combustion and gasification modes simply by varying the balance and distribution of air and fuel in the reactor. Named for the direction of gas flow in the reactor, small updraft and downdraft gasifiers are more traditional designs and have been widely studied and used. Because they minimize tar production, downdraft gasifiers have been employed in small engine systems. Updraft gasifiers (such as the Primenergy gasifier) are more tolerant of high moisture fuels, but produce much more tar than downdraft gasifiers. For this reason, updraft gasifiers are usually operated close-coupled to burners. In addition to these types, there are a large number of other potential gasifier reactor designs including entrained flow (common for coal gasification) and molten metal baths.
- **Oxygen, steam, or air-blown** – Air blown gasification produces a fuel gas with a low heating value, typically 15 to 20 percent (150-200 Btu/scf) of the heating value of natural gas. The heating value of the gas may be increased by using oxygen or steam to gasify the fuel. Either option removes most of the inert nitrogen from the fuel gas, raising the gas heating value to near 500 Btu/scf. High heating value gas can be more readily used in combustion turbines and for chemical synthesis.
- **Heating method** – Air-blown gasification partially combusts biomass to provide the heat necessary to drive the gasification reactions. Instead of directly burning part of the fuel, indirect heating can be used to increase the gas heating value. Many methods have been devised to supply this energy. Some experimenters have simply heated the reactors externally with natural gas or electrical resistance heaters. These approaches have only been done on the research scale because they are not very efficient at supplying heat to the

reactor. More novel approaches for providing the heat include gasification in a molten metal bath, combustion of a portion of the fuel gas in immersed fire-tubes (MTCI), and dual circulating fluidized beds which circulate solids to transfer heat (FERCO).

- **Pressure** – Gasification systems can either be near atmospheric pressure or pressurized. Pressurized systems are preferred for applications that require the syngas be compressed (such as Fischer-Tropsch synthesis or gas turbines). However, pressurization complicates material feed and other aspects of the design.
- **Fuel gas conversion options** – There are many potential options for converting gasifier fuel gas to useful energy, as described further in the next section.

3.2.2.5 Gasification Fuel Gas Conversion Options

The primary advantage of gasification over combustion is the versatility of the gasification product. Gasification expands the use of solid fuel to include practically all the uses of natural gas and petroleum. Beyond higher efficiency power generation available through advanced processes, the gaseous product (specifically CO and H₂) can be used for chemical synthesis of methanol, ammonia, ethanol, and other chemicals. Gasification is also better suited than combustion for providing precise process heat control (e.g., for drying or glass-making).

The various fuel gas conversion options are illustrated in Figure 3-5. These options include:

- **Close-Coupled Boilers** – Fuel gas from gasifiers has been traditionally fired in close-coupled boilers for power generation via a standard steam power cycle, as shown in Figure 3-6. The fuel gas is combusted in a traditional oil or natural gas boiler to generate steam. The steam then drives a turbine to produce power. This setup provides the most conventional method of generating power but also one of the least efficient, with efficiencies comparable to direct combustion processes (20 to 25 percent). A potential advantage of this approach compared to direct combustion is that separate gasification allows one to remove ash material prior to the combustion stage. This can benefit downstream gas combustion devices by reducing particulate loading, emissions, and boiler corrosion and slagging caused by alkali material in the biomass. The fuel gas can also be cofired in existing fossil fuel boilers with little modification required to the boiler (see figure). This is a potentially attractive option for fossil fuel plant owners looking to add

renewable fuel to their portfolio, without having to build a new greenfield plant. It is also attractive for industrial boilers looking to repower with biomass due to rising gas or coal costs. Compared to a greenfield biomass plant, the costs for a cofiring retrofit are much smaller.




Figure 3-5. General Gasification Process Flow Options.




Figure 3-6. Gasification for Biomass Cofiring with Fossil Fuels.

- **Gas Engines and Turbines** – Gasifier fuel gas can also be fired in a reciprocating gas engine or gas turbine. Use of fuel gas in gas engines has been demonstrated, particularly for smaller system sizes. Derivatives of jet engine technology, gas turbines are more suited for larger sizes and are the centerpiece of integrated gasification combined cycle (IGCC) power plants, see further discussion below.
- **Fuel Cells** – Fuel cells electrochemically convert fuel gas and air into power. In general, fuel cells are not expected to be commercially available for a few years. Gasification is best suited for higher temperature fuel cells designs such as molten carbonate and solid oxide. Because fuel cells extract energy directly from fuel gases, they are very efficient throughout their size range. Integrated gasification fuel cell (IGFC) plants are not a commercial reality at this point because of high capital costs and developmental issues related to the extensive fuel gas conditioning and clean-up that is required.
- **Chemical Synthesis (including ethanol)** – The components of syngas, particularly carbon monoxide and hydrogen, can be used as “building blocks” for a large variety of chemicals, fuels, fertilizers, and other products. One of the more promising pathways is production of ultra-clean liquid fuels (such as methanol, ethanol, and diesel) through Fischer-Tropsch synthesis. Chemical synthesis using biomass gasification typically requires clean syngas and is largely in the demonstration phase. Gasification is heavily promoted as one of the key building blocks in the Department of Energy’s “thermochemical platform” for the production of high value products, like ethanol, from biomass. Although ethanol synthesis via gasification is not yet a proven technology, gasification projects could be phased to demonstrate the technology incrementally (natural gas displacement followed by ethanol synthesis). Such an approach is being explored by Chippewa Valley Ethanol, near Benson, MN.
- **Stirling Engines** – Although not shown in the diagram, Stirling engines are another technology that can be used to convert the energy of the biomass syngas (or hot combustion gases) into electricity. A Stirling engine converts heat into useable mechanical energy by heating (expanding) and cooling (contracting) a captive gas such as helium or hydrogen. Unlike an internal combustion engine, where combustion occurs within the device, the Stirling engine is an external combustion device. Combustion takes place in another chamber and heat is transferred to the engine through a heat exchanger. The advantage is that the syngas or combustion gases do not need to be cleaned

prior to utilization. Stirling engines are typically small (< 100 kW) and are still in the research and development stage.

3.2.2.6 Biomass Integrated Gasification Combined Cycle

Up until the most recent focus on chemical synthesis applications, one of the principal focus areas for biomass gasification technology developers has been biomass integrated gasification combined cycle (IGCC). IGCC power plants are suitable for larger scale biomass conversion. Such plants consist of a gasifier or pyrolyzer that provides fuel gas to a standard gas turbine. The gas turbine burns the fuel and generates power. Sensible energy in the hot exhaust of the turbine can be recovered in a heat recovery steam generator (HRSG). Steam generated by the HRSG can be used for cogeneration and/or to power a steam turbine.

Commercial-scale IGCC coal-fired power plants are considered to be the most efficient solid-fuel technologies in operation today. Further development of this technology for biomass would benefit from improved gas clean-up. The most difficult part of the process is providing a clean gas to the gas turbine. Research in this area, specifically hot gas clean-up, is intensive. Biomass gasification systems should be lower cost than similar size coal IGCC plants because (1) the high reactivity (volatility) of biomass reduces gasifier costs, and (2) the low sulfur content of biomass reduces gas clean-up system costs. However, as with other biomass energy systems, gasification economics are hurt by difficulty reaching very large scales due to fuel supply constraints. Net conversion to electricity is projected to be approximately 35 percent for biomass IGCC plants, compared to 20 to 25 percent for conventional biomass combustion plants.

The potentially significant increase in efficiency has made biomass IGCC attractive to many developers and governments. Unfortunately, biomass IGCC projects around the globe have struggled to reach commercialization:

- **ARBRE, UK Project** – The 8 MW ARBRE IGCC project located near Eggborough in the United Kingdom was designed to use a TPS atmospheric circulating fluidized bed gasifier. The project included gas clean-up and a 5 MW Typhoon gas turbine. The project was to be fueled with locally grown wood. The project, originally estimated to cost over \$40 million, was declared bankrupt after failing to achieve commercial operation. It was recently bought for around \$4 million. Future status is unclear.
- **FERCO, Vermont Gasification Project** – The Vermont biomass gasification project, developed by Battelle/DOE and Future Energy Resources Corporation (FERCO), was only partially more successful. The project was sized to gasify up to 200 tpd of wood chips. Although FERCO did announce some

successful extended gasification trials, the project was never advanced to the IGCC stage (the syngas had been cofired in the adjacent wood stoker boiler). FERCO declared bankruptcy in 2002 after investing \$10 million of its own money into the project (in addition to more than \$30 million U.S. government funds). However, FERCO has now reorganized, and is actively seeking to sell gasification equipment again.

- **Hawaii Gasification Project** – The Hawaii gasification demonstration project was a pressurized air/oxygen gasifier designed to process up to 100 tpd of bagasse. The gasifier was designed by the Gas Technology Institute (GTI). The project was to include hot gas clean-up to allow the syngas to be fired in a gas turbine. The project had operated for about 500 hours but was halted due to ongoing problems with material handling and cessation of DOE funding. Carbona (formerly known as Tampella) has licensed the GTI gasifier design and is seeking to develop new projects with the technology.
- **Värnamo, Sweden** – The only large-scale IGCC project that has run for any appreciable length of time is the project in Värnamo, Sweden. The gasifier ran for more than 7,000 hours between 1993 and 1999. The demonstration project produced 6 MW of electricity and thermal energy. It was developed by Sydkraft AB and Foster Wheeler. The gasifier was a pressurized, air-blown circulating fluidized bed designed to gasify wood and wood waste. The project included warm gas clean-up and firing in a combustion turbine provided by European Gas Turbines. The project was not designed to be a full-scale commercial facility, and was closed in 1999 after completing demonstration trials.¹

3.2.2.7 Making Advanced Gasification Projects Successful

The recent attempts to demonstrate IGCC have frustrated the biomass industry. Difficulties have been related not so much to the gasification process itself, but to supporting ancillary equipment, such as fuel handling and gas cleanup. Project budgets have generally not included enough contingency funding to overcome these issues. Given enough time, expertise, and capital, there are engineering solutions to these problems.

There are several suppliers of commercial gasification equipment, including Foster Wheeler, Energy Products of Idaho, and Primenergy. There are also numerous

¹ UC Davis, "Technology Assessment for Biomass Power Generation," October 2004, available at http://biomass.ucdavis.edu/pages/reports/UCD_SMUD_DRAFT_FINAL.pdf.

emerging vendors of advanced technologies that offer significant benefits (FERCO, Clean Energy / Pearson, and Frontline Bioenergy). Close cooperation with these suppliers and proper attention to ancillary systems will be necessary to make advanced biomass gasification projects successful. However, until there are proven, operating reference plants to visit, investors and lenders will remain skeptical of the technology.

Despite the recent problems with technology demonstration, the promise of (1) higher efficiency power production offered by IGCC or (2) the potential for lower cost ethanol production via a chemical synthesis platform remains attractive. One possible method to overcome the risks associated with advanced gasification processes is to develop a phased commercial project. In this approach, the various elements of the process would be built and proven sequentially prior to the next phase being implemented. For example, a project could be developed by building and proving the gasifier in a close-coupled boiler application first, prior to adding gas cleanup and advanced gas conversion processes. The economics and permitting of the project would be facilitated if an existing fossil fuel boiler could be identified to host the project.

The potential for advanced applications of gasification technology make the technology promising and worthy of further consideration for some applications. However, unlike combustion systems, for which there are commercial suppliers of proven technology, gasification is a more developmental technology. Although the first full-scale commercial systems for IGCC or chemical synthesis applications may be operational within five years, it will likely take 5 to 10 years before commercial systems are widely offered. This makes the technology less attractive to investors with shorter payback timeframes. On the other hand, investors who are more receptive to the risks and rewards associated with new technologies may find gasification to be an attractive approach.

3.2.3 Pyrolysis

Pyrolysis is the thermal decomposition of material in the absence of oxygen to produce a wide variety of products. It is an emerging biomass conversion process. To trace the word back to its Latin roots, pyrolysis is the breaking down (*lysis*) of a material with heat (*pyro*). Pyrolysis is performed with very little or no oxygen, and has been termed as "anaerobic combustion." Pyrolysis produces a variety of products, as described in the simple equation below:



There are different types of pyrolysis, and the differences affect the end products of the process. Slow pyrolysis is the most conventional approach. The term “slow” is derived from the low fuel heating rates (less than 20°F/s). Additionally, temperatures are relatively low (less than 1,000°F), and char and oil/tar are the primary products. Fast pyrolysis, on the other hand, involves quick heat-up rates (20-200,000°F/s), and high temperatures (above 1,100°F). Rapid processing of the fuel freezes chemical reactions and allows for greater gas production at the expense of char, oil, and tar. Another classification, flash pyrolysis, is similar to fast pyrolysis in heat-up rates but occurs at lower temperatures (750-1,100°F). Flash pyrolysis focuses on the production of liquid tar and oil at the expense of gas and char. A general flow diagram for a typical pyrolysis system is included in Figure 3-7.




Figure 3-7. General Pyrolysis Process Flow Options.

Perhaps the most promising product from pyrolysis is bio-oil (see Figure 3-8). Bio-oil has potential applications as a replacement fuel for petroleum in boilers (and possibly heavy duty industrial gas turbines) or as a precursor for the creation of high

value specialty chemicals (e.g., levoglucosan). Most pyrolysis processes are in the research, development and demonstration phase, and are not explored further in this study.




Figure 3-8. Bio-oil Produced from Pyrolysis (Source: Iowa State University).

3.3 Recommended Technologies for Further Consideration

Based on the observations provided above regarding the range of potential technologies that can be used for biomass-fired electric power production, three direct combustion technologies are recommended for further consideration for the biomass-fired unit at Deerhaven:

- Stoker grate boilers;
- Bubbling fluidized bed boilers; and
- Circulating fluidized bed boilers.

These technologies have demonstrated successful and reliable performance in prior biomass power applications and are considered fully commercial technologies. A variety of gasification and pyrolysis technologies offer promise for future biomass power applications, and some of these appear ready for early “pioneer” demonstration projects. However, a substantial amount of risk will be incurred with these initial demonstrations, and are likely to entail research “fixes” (and related costs) for debugging problems that are more palatable when undertaken with significant government cost-sharing for the project. GRU has indicated a preference for commercially proven technologies rather than demonstration-stage technologies. Therefore, it is recommended that gasification or pyrolysis technologies be dropped from further consideration for this project.

4.0 Development of Preliminary Technology Characteristics

Following the identification of likely biomass-fired generation technologies, the defining characteristics of the appropriate generation system were determined through discussions with biomass boiler vendors, review of applicable environmental regulations, performance modeling of steam cycle and cost estimation of the likely system components. The findings are summarized in this section.

4.1 Boiler Vendor Surveys

Following the preliminary screening of technologies completed in Task 1, biomass combustion equipment vendors were contacted to determine the current state of the art of the selected biomass combustion technologies and to identify the relevant operational parameters of the technologies. To provide a basis for discussion, vendors were asked to identify the optimal equipment for the combustion of woody biomass fuels with moisture contents of 40 percent or greater. These systems were to be of sufficient size to supply steam to a steam turbine generator providing 50 to 100 MW of electrical generation. The vendors contacted during this survey are listed in Table 4-1.

Table 4-1. List of Contacted Biomass Boiler Vendors.

Vendor	Technologies Offered	Sales Representative	Phone
Babcock & Wilcox	Stoker, BFB, CFB	Michael Nickey	(281) 591-0139
Foster Wheeler	Stoker, BFB, CFB	Jim Utt	(719) 685-1986
Alstom ^a	Stoker, BFB, CFB	Vince Pacello	(913) 681-1616
Energy Products of Idaho	BFB	Patrick Travis	(208) 765-1611
Kvaerner	BFB	Hank Sherrod	(214) 783-5803
McBurney	Stoker	Greg Imig	(770) 925-7100
PowerDyne (Detroit Stoker) ^b	Stoker	Bryce Wilson	(816) 741-9779
Wellons Boiler	Biomass Boiler ^c	Bob Van Wassen	(412) 856-9745
Notes:			
^a Alstom declined to participate in discussions as the project size was deemed to be too large for their industrial group and too small for their utility group.			
^b Attempts were made to directly contact Detroit Stoker were attempted, but the inquiries were directed to PowerDyne, LLC, the regional distributor of Detroit Stoker equipment.			
^c The Wellons Boiler design is similar to modern stoker boilers, but contains features that are not found in typical stokers.			

Prior to this survey, Black & Veatch anticipated that stoker boilers would be the preferred technology for units near 50 MW in size and that circulating fluidized bed boilers would be the preferred technology for units 75 MW in size and larger. However,

as discussed below, through our vendor discussions, we found a strong case for the use of bubbling fluidized bed boiler technology throughout the 50 to 100 MW size range.

4.1.1 Findings of the Vendor Survey

Vendors capable of providing all three biomass combustion technologies under consideration were contacted first to determine which technology they currently recommend for biomass combustion in the defined size range. Key findings of the vendor survey include:

- Vendors capable of providing all three biomass combustion technologies under consideration (i.e., Babcock & Wilcox and Foster Wheeler) independently stated that BFBs would be the best choice for units up to 70 MW in size. Babcock & Wilcox recommended the use of BFBs across the entire size range, while Foster Wheeler recommended the use of CFBs for units in the size range of 70 to 100 MW (above 650,000 lb/hr of steam).
- At the lower end of the size range (approximately 50 MW), the vendors recommended BFBs in lieu of stokers because of the high moisture content of the biomass and low alkali content of woody biomass.
 - Stoker boilers would be an appropriate choice for fuels with moisture contents lower than 30 percent at the lower end of the size range. Foster Wheeler stated that a stoker boiler may also be appropriate if alkali contents were high, but the company declined to define the alkali level that would be considered “high” and recommended that a fuel analysis be completed prior to the final technology selection.
 - The operation of BFB is actually enhanced by fuels with moisture contents of approximately 40 to 50 percent; the presence of moisture in the fuel moderates the temperature of the fluidized bed and maintains an operating regime in which combustion is complete and NOx emissions are relatively low.
 - For optimal operation of a BFB, Babcock & Wilcox recommended that fuel moisture content be held within a 15 percentage point window (i.e., fuel moisture content be maintained in a range of 40% to 55% or another similarly sized range). This will allow the BFB to be designed for optimal performance for the selected fuel and reduce process upsets.
 - Since BFBs are considered a more modern technology, permitting of a BFB may be easier than permitting of a stoker system.

- Due to the lower operating temperature of BFBs and the use of flue gas recirculation (FGR), there is very little thermal NO_x produced during BFB combustion of biomass. Virtually all of the NO_x produced is believed to be fuel-derived. Uncontrolled NO_x emissions for a BFB are in the ballpark of 0.15-0.20 lb/MBtu; utilization of an SNCR system may reduce this rate by 25%.
- The design of the boiler (waterwalls, superheater and backpasses) is very similar for the stoker and BFB-fired units. In fact, stokers have been modified to operate as BFBs. Due to the similarity in design, capital costs for similarly sized stokers and BFBs are roughly equivalent.
- At the higher end of the size range, Babcock & Wilcox recommended BFBs in lieu of CFBs due to the higher capital costs of CFBs.
 - According to Babcock & Wilcox, the capital costs of CFBs are approximately 10% to 15% higher than those of BFBs.
 - Operational costs for CFBs are also higher (Babcock & Wilcox did not quantify the difference) than BFBs. This is due to the higher auxiliary load of CFBs (due to higher pressure drops through the system, a CFB requires a higher horsepower blower) and higher costs associated with dust collection systems and other downstream equipment.

Following discussions with Babcock & Wilcox and Foster Wheeler, the other vendors listed in Table 4-1 were contacted. Pertinent notes from those discussions include:

- With the exception of Kvaerner, all of the remaining vendors would be limited to supplying units near 50 MW in size. Wellons Boiler would be required to provide two units to produce the requisite steam for a 50 MW system. The maximum steam flow rates and conditions of each of these vendor's systems are shown in Table 4-2.
- All vendors are capable of firing fuels with moisture contents in the range of 35 to 50 percent.
- All vendors claimed to be able to meet expected emission requirements for the biomass-only case. All vendors felt that SNCR would be necessary to comply with NO_x limits, but little to no sulfur control would be required for the combustion of 100 percent biomass.

Table 4-2. Maximum Steam Flow Rates and Conditions by Vendor.

Vendor	Technology Offered	Steam Flow (lb/hr)	Steam Conditions (psig/°F)
Energy Products of Idaho	BFB	420,000	650/650
Kvaerner	BFB	920,000	1500/1005
McBurney	Stoker	500,000	Unspecified
PowerDyne (Detroit Stoker)	Stoker	500,000	Unspecified
Wellons Boiler	Biomass Boiler	500,000*	825/825

Notes:

* Wellons Boiler would require two 250,000 lb/hr units to provide 500,000 lb/hr.

4.1.2 Recommendations for the Biomass-Fired System

Based on the information provided by the vendors during the survey, Black & Veatch recommends the following:

- A bubbling fluidized bed (BFB) boiler is recommended to provide steam for an electrical generation system fired by 100 percent biomass.
- The electrical generation capacity of the system will be determined by the availability of biomass fuel rather than any technical characteristic or limitation of the boiler system. A detailed biomass resource assessment is recommended to identify potential biomass suppliers, to better establish the likely cost of the fuel, and to determine the optimal size of the system.
- Specific fuel characterization (fuel analyses) should be done as part of the resources assessment.

4.2 Air Permitting

The following is a high-level assessment of air permitting considerations associated with the possible installation of a biomass-fired stoker boiler or biomass-fired fluidized bed boiler at the Gainesville Regional Utility (GRU) Deerhaven Generating Station (hereinafter referred to as facility). A primary focus of this assessment is new source review (NSR) applicability and requirements. Other permitting issues, such as new source performance standard (NSPS) applicability, are also addressed.

4.2.1 Project Description

Based on information provided in the facility Title V permit, the facility currently consists of one 960 MBtu/hr fuel oil or natural gas fired boiler, one 2,428 MBtu/hr coal

fired boiler, and one nominal 74 MW (990.6 MBtu/hr) simple cycle combustion turbine. GRU is considering installation of 50 to 100 MW of biomass-fired generation at Deerhaven. For the purposes of this assessment only emissions from the new boiler are considered and emissions from auxiliary project equipment including wood material handling and preparation processes are not discussed.

4.2.2 PSD Applicability

The prevention of significant deterioration (PSD) NSR regulations are the regulations of concern for facilities located in areas designated attainment or unclassifiable for all criteria pollutants. For areas classified nonattainment for a criteria pollutant, the nonattainment NSR regulations would be the regulations of concern for those pollutants designated nonattainment. Based on a review of information in the United States Environmental Protection Agency (USEPA) Green Book internet data base, Alachua County Florida is not classified nonattainment for any criteria pollutants. As such, PSD regulations would govern for the Deerhaven Facility.

The facility is one of 28 named source categories with a 100 ton per year (tpy) PSD major source threshold level. Because the existing facility has potential emissions greater than 100 tpy of at least one PSD pollutant, it is considered an existing major PSD source. The installation of a new emissions unit at an existing PSD major source is considered a modification to that major source. If the emissions increase and the net emissions increase associated with the installation of the new emissions unit are greater than the PSD significant emission rates (SERs), the modification is considered a major modification and is subject to PSD permitting. An emissions increase analysis must be conducted to determine the potential annual emissions for each PSD pollutant and determine PSD applicability for each pollutant. This entails a pollutant-by-pollutant emissions increase comparison with the PSD SERs. Table 4-3 below shows the SERs for the pollutants commonly associated with installation of a new boiler.

As an initial step in determining project PSD applicability, the Project potential to emit for each pollutant is compared to the respective SER for that pollutant to determine PSD applicability for that pollutant. Projected operating data and emission rates for each type of new boiler considered for the Project are shown in Table 4-4 below. Comparing the Table 4-4 estimated annual emissions with the SERs given in Table 4-3, it is seen that with all three units considered for the project, the potential emission increases are greater than the PSD SERs for NO_x, CO, PM/PM₁₀ and SO₂. As such, unless it can be demonstrated that the project net emissions increase on a pollutant-by-pollutant basis are less than the respective SERs, the project would be subject to PSD for each of these pollutants. Note that the potential tpy emissions presented in Table 4-4 are based on

unlimited full-load year round operation (8,760 hours per year operation at 100 percent load). Although one method to try to avoid PSD permitting is to accept a limit on the annual operation of a new emissions unit, it is seen by the level of emissions shown in Table 4-4 that a relatively significant limit on operations would be needed to avoid PSD permitting, and that approach is not discussed further in this assessment.

Table 4-3. PSD Significant Emission Rates.

PSD Pollutant	Significant Emission Rates (tons per year)
NO _x	40
SO ₂	40
CO	100
VOC	40
PM	25
PM ₁₀	15
Sulfuric acid mist	7
Lead	0.6

Table 4-4. Assumptions for Biomass-Fired Unit Emission Calculations.

	50 MW Stoker Boiler	Smaller-Scale (75 MW) CFB Boiler	Larger-Scale (100 MW) CFB Boiler
Net Power Output (MW)	50.0	75.0	100.0
Est. Auxiliary Load (MW)	7.5	8.3	11.0
Gross Power Output (MW)	57.5	83.3	111.0
Net Plant Heat Rate (Btu/kWh)	13,500	12,000	12,000
Est. Biomass Input (MBtu/hr)	675	900	1200
Emission Rates			
NO _x (lb/MBtu)	0.150	0.075	0.075
CO (lb/MBtu)	0.300	0.100	0.100
VOC (lb/MBtu)	0.050	0.005	0.005
PM ₁₀ (lb/MBtu)	0.025	0.020	0.020
SO ₂ (lb/MBtu)	0.100	0.040	0.040

The determination of whether there is a net emissions increase is typically referred to as a netting analysis. A netting analysis only provides a favorable result if there have been or will be emission reductions at the facility during what is termed the netting contemporaneous period. The netting contemporaneous period covers the period beginning five years prior to commencing construction on the new project and ending when emission increases from the new project are first realized. Typical facility changes that may have or will result in emission decreases and thus be useful in considering whether a netting analysis would be beneficial are shutdown of existing emission units or the addition of controls to existing emission units, such as controls added to reduce NO_x or SO₂ emissions as part of a clean air interstate rule (CAIR) compliance strategy. With the netting analysis all contemporaneous emission decreases and increases, including the project emission increases are summed to determine if there is a net emission increase greater than the respective SER for each pollutant. Again, the netting analysis is done on a pollutant-by-pollutant basis to determine PSD applicability for each pollutant for which the project itself results in an emissions increase greater than the SER.

Note that the basis for this discussion is this installation of a new unit at an existing PSD major source (Deerhaven). If the new unit were to be located at a greenfield site, the initial determination of whether PSD would apply to the installation would be based on whether potential emissions of any single PSD pollutant were greater than the major source threshold level. As discussed previously, the major source threshold level for 28 listed source categories is 100 tpy, while all other facilities would have a major source threshold level of 250 tpy. The 100 tpy threshold source category that may be applicable to a new unit of the type considered in this analysis would be the category fossil fuel-fired steam electric plants of more than 250 MBtu/hr heat input. If the type of unit proposed for the Deerhaven facility were to be located at a Greenfield site a closer look at the design fuel for the unit would be needed to determine if it constituted a fossil-fuel fired unit and as such a 100 tpy source. Whether a 100 tpy or 250 tpy source, PSD applicability for a Greenfield site construction is first based on whether potential emissions of any single PSD pollutant exceed the applicable major source threshold level (either 100 tpy or 250 tpy). If so, then potential emissions of all other pollutants are compared to the SERs to determine PSD applicability. Therefore, in terms of PSD applicability, the advantage of locating at a Greenfield site is only gained if one can limit emissions of each PSD pollutant to less than the appropriate PSD major source threshold level.

Several requirements associated with PSD permitting can add complexity, costs, and increased permitting time to a project. PSD permitting includes the requirement to use best available control technology (BACT) and the requirement to conduct an ambient

air quality impact analysis (AAQIA). Both the BACT requirement and the AAQIA will add complexity to the permit application preparation and processing of the permit by the permitting agency. This in turn results in an increase in the amount of time needed to obtain an air construction permit, which is needed before a facility can commence construction on a project. For these reasons, if the PSD permitting process can reasonably be avoided for a project, it is typically preferred to obtain a minor source construction permit. However, unless a netting analysis can be used to net out of PSD, it is typical for the installation of a new generating unit at a power plant to go through PSD permitting.

The following is a brief emissions control discussion. If the Project can avoid PSD applicability, an official best available control technology (BACT) analysis will not be required. However, without a netting analysis, it is expected that the proposed unit would be a PSD major modification and would need to go through a PSD BACT analysis. A good place to start in determining emission controls on similar units is to look at permit limits for similar projects. A preliminary review of the USEPA BACT/RACT/LAER Clearinghouse shows a limited listing of new biomass boilers over the last five years. Two of those listings are summarized here. The most recent listing for a CFB wood boiler with greater than 250 MBtu/hr heat input was for a 50 MW unit in New Hampshire with an October 25, 2004 permit issue date. The emission limits of this unit are shown in Table 4-5. A waste wood spreader stoker boiler was permitted in the state of Washington in 2002; the emission limits for this unit are shown in Table 4-6.

Table 4-5. Emission Limits of a 50 MW CFB Located in New Hampshire.

Pollutant	Units	Permitted Limit	Comments
NO _x	lb/MBtu	0.075	BACT—PSD
SO ₂	lb/MBtu	0.020	
CO	lb/MBtu	0.100	
VOC	lb/MBtu	0.005	
PM ₁₀	lb/MBtu	0.025	
Hg	lb/MBtu	3 x 10 ⁻⁶	MACT
Sulfuric acid mist	lb/MBtu	0.020	MACT
NH ₃	ppm	10	@ 7% O ₂

Table 4-6. Emission Limits of a Biomass-Fired Stoker Located in Washington.

Pollutant	Units	Permitted Limit	Comments
NO _x	lb/MBtu	0.150	
CO	lb/MBtu	0.350	
PM	lb/MBtu	0.020	

4.2.3 Additional Regulatory Review

4.2.3.1 NSPS Applicability

A separate regulatory program that will likely be applicable to the Project wood fired boiler is the New Source Performance Standards (NSPS). The NSPS regulations are found in Part 60 of Volume 40 of the Code of Federal Regulations (CFR). NSPS Subparts D, Da, Db, and Dc apply to boilers, depending on the size of the boiler, the date of construction, reconstruction or modification of the boiler and the types of fuel fired in the boiler.

Preliminary NSPS applicability:

40 CFR 60 Subpart Da – *Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978* – is applicable to electric utility steam generating fossil fuel fired units of the designated size. Per 40 CFR 60.40Da, Subpart Da is applicable to each electric utility steam generating unit that is capable of combusting more than 250 MBtu/hr heat input of fossil fuel (either alone or in combination with any another fuel) and for which construction, reconstruction or modification commenced after September 18, 1978. Because wood is not considered a fossil fuel, applicability of Subpart Da to a wood boiler would be dependent on the extent, if any, that fossil fuels would also be used in the boiler. While a detailed review of Subpart Da is required to determine applicability and requirements, the following is a general listing of the PM, NO_x, and SO₂ standards applicable to a newly constructed unit subject to Subpart Da:

- PM standard of 0.015 lb/MBtu
- NO_x standard of 1.0 lb/MWh
- SO₂ standard of 1.4 lb/MWh

40 CFR 60 Subpart Db – *Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units* – is applicability to new facilities that have a heat

input capacity greater than 29 MW (100 million Btu/hr). Units subject to NSPS Subpart Da are not subject to Subpart Db. Since Subpart Db applicability is not limited to fossil fuel fired units, the new wood boiler would be subject to Subpart Db unless it is determined that Subpart Da is applicable. The Subpart Db standard for NO_x is a function of the fuel types used in the boiler and the capacity factor for use of the various fuel types. The following is a general listing of the PM, NO_x, and SO₂ standards for a new unit subject to Subpart Db:

- PM standard of 0.03 lb/MBtu
- NO_x standard of 0.2 lb/MBtu if the unit fires coal, oil, or natural gas or a mixture of these fuels, or with any other fuels, unless the facility has a federally enforceable requirement that limits operation of the unit to an annual capacity factor of 10 percent or less for coal, oil, and natural gas.
- SO₂ standard of 0.2 lb/MBtu

4.2.3.2 MACT Standard Applicability

The National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters is found at 40 CFR Part 63, Subpart DDDDD. These types of standards are commonly referred to as MACT (maximum achievable control technology) standards and this specific standard is commonly referred to as the industrial boiler MACT. A fossil-fuel fired electric utility steam generating unit of more than 25 megawatts that produces electricity for sale is not subject to the industrial boiler MACT. However, wood is not considered a fossil-fuel. If only wood is fired in the new unit, it appears that the proposed new unit would not meet this exemption and would be subject to the industrial boiler MACT. However, if wood is to be co-fired with a fossil fuel or a fossil fuel may be used as an alternative fuel source in the boiler, a more detailed analysis would be needed to determine whether the new unit would be subject to the industrial boiler MACT. Also, only affected units at major sources of hazardous air pollutants (HAPs) are subject to this MACT standard. Based on information provided in the Deerhaven facility Title V permit, the facility is an existing major source of HAPs.

4.2.3.3 CAIR Applicability

The Clean Air Interstate Rule (CAIR) includes a cap and trade program for NO_x and SO₂ emissions. A fossil-fuel fired boiler serving a generator with a nameplate capacity greater than 25 MWe producing electricity for sale is subject to CAIR. According to the definitions given in the CAIR regulations a fossil fuel fired unit is a unit

that fires any amount of fossil fuel in a calendar year. As such, if fossil fuel is used in the new unit it may be subject to the CAIR cap and trade program.

4.2.3.4 Florida Power Plant Siting Act

The Florida Power Plant Siting Act provides procedures for obtaining all needed permits and approvals for a new electric utility facility or unit. The appropriate air construction permit application is one part of the overall siting act application. Going through the siting act approval process can add complexity and time to the overall permitting process. The GRU Deerhaven facility has gone through the Florida Power Plant Site Certification Act and as such has conditions of certification for the facility. It is expected that, at a minimum, the installation of a new generating unit at Deerhaven would require a modification to the plant's Site Certification.

4.2.4 Summary

In summary, unless netting can be used to avoid PSD applicability, it is expected that the installation of a new wood-fired boiler at the Deerhaven facility would be considered a major modification to the facility under PSD regulations for a number of pollutants. If PSD is triggered, it will require the need to install BACT level controls and an AAQIA would be needed as part of the permit application. In general, a PSD permitting effort from start of application preparation to receiving an Agency permit is typically estimated to take 12 to 24 months. Another consideration when proposing to install additional electric utility steam generating units in Florida is whether the installation will be subject to the Florida Power Plant Siting Act. It is expected that, at a minimum, the installation of a new generating unit at Deerhaven would require a modification to the plant's Site Certification.

4.3 Performance Modeling

To quantify performance of the system and determine certain operating parameters, a model of the steam cycle was constructed, and heat and mass balances were developed for three operational scenarios. These scenarios include:

- 50 MW (net) Steam Cycle
- 100 MW (net) Steam Cycle
- 100 MW (net) Steam Cycle, with Reheat

4.3.1 Model Assumptions and Results

Key assumptions of the thermal performance modeling include:

- Average ambient dry bulb temperature is assumed to be 59°F, and average relative humidity is assumed to be 50 percent.
- Boiler efficiency is assumed to be 80 percent.
- Steam temperature and pressure at the boiler outlet are assumed to be 955°F and 1528 psig for the 50 MW scenario. Steam temperature and pressure at the boiler outlet are assumed to be 955°F and 1815 psig for the 100 MW scenarios.
- A wet cooling system with a mechanical draft cooling tower is employed to condense steam.

The results of thermal performance modeling are summarized in Table 4-7. The complete results for the 50 MW scenario, the 100 MW scenario and the 100 MW with reheat scenario are provided in Appendix A, Appendix B and Appendix C, respectively.

The performance results for the 100 MW BFB case are based on the results for the 100 MW CFB case. Because the steam cycle parameters are identical for the BFB and CFB systems, the steam flows and conditions for these two cases are also identical. Furthermore, the differences in auxiliary power requirements for these two systems were assumed to be negligible, as the increased pressure drops through the CFB system are mitigated to some extent by the increased excess air requirements of the BFB. However, the boiler efficiency of the BFB was assumed to be approximately 3 percentage points lower for the BFB relative to the CFB due to increased excess air requirements and greater unburned carbon losses for the BFB. The lower boiler efficiency results in a slightly higher net plant heat rate and greater fuel requirements for the BFB relative to the CFB system, as shown in Table 4-7.

Partial load performance data was obtained by consideration of the operation of all scenarios at full (100 percent) load, 75 percent load and 50 percent load. Net plant heat rates at partial loads are illustrated in Figure 4-1.

4.3.2 Biomass Fuel Consumption Rates

The biomass fuel consumption of the facilities was estimated for each of the scenarios. This calculation assumed a higher heating value of 8500 Btu/lb for dry biomass and a moisture content of 40 percent for as-received biomass fuel. Thus, the higher heating value of the as-received biomass fuel was assumed to be 5100 Btu/lb. Given this heating value, the biomass fuel consumption of the 50 MW facility would be roughly 1460 tons per day (tpd). The biomass fuel consumption of the 100 MW facility without reheat would be approximately 2800 tpd, while the biomass fuel consumption of the 100 MW facility with reheat would be approximately 2690 tpd.

Table 4-7. Summary of System Performance Modeling.^a

	50 MW Stoker	100 MW BFB ^b	100 MW CFB	100 MW CFB (Reheat)
Full Load System Parameters				
Turbine Gross Output (100% Load), kW	57,465	115,053	115,053	114,977
Turbine Heat Rate (100% Load), Btu/kWh	8,657	8,259	8,259	7,924
Total Auxiliary Power (100% Load), kW	7,470	15,000	15,000	15,000
Total Auxiliary Power (100% Load), %	13.0	13.0	13.0	13.0
Net Plant Output (100% Load), kW	50,000	100,050	100,050	99,980
Heat to Steam from Boiler (100% Load), MBtu/hr	497.9	951.2	951.2	913.4
Boiler Efficiency (HHV)	80.0	77.0	80.0	80.0
Boiler Heat Input (100% Load), MBtu/hr (HHV)	622.4	1,235.3	1,189.0	1,141.7
Biomass Fuel Requirement ^c , tons/day	1,464	2,907	2,798	2,686
Number of Heaters	4	5	5	5
Part Load Heat Rate Calculations				
Net Plant Heat Rate (100% Load), Btu/kWh (HHV)	12,448	12,347	11,884	11,420
Net Plant Heat Rate (75% Load), Btu/kWh (HHV)	13,017	12,826	12,345	11,779
Net Plant Heat Rate (50% Load), Btu/kWh (HHV)	14,177	13,979	13,455	12,705
Notes: ^a Performance is preliminary and for information only. Not to be used for detailed design. Auxiliary power is assumed to be 13% of base load (100% load). Water cooling with mechanical draft cooling tower is used. Average ambient conditions of 59°F dry bulb temperature and 50% relative humidity are used. Boiler efficiency is assumed to be 80% for all cases except the 100 MW BFB case. ^b The thermal performance for the 100 MW BFB case was estimated from the modeling of the 100 MW CFB case. It was assumed that auxiliary power requirements would be roughly equivalent for the two systems, but boiler efficiency would be slightly lower for the BFB relative to the CFB because of the increased excess air requirements and greater unburned carbon losses for the BFB. ^c Biomass fuel requirement, in tons per day, was calculated based on the boiler heat input and an assumed heating value of biomass of 5100 Btu/lb. This heating value assumes a biomass moisture content of 40%.				




Figure 4-1. Partial Load Net Plant Heat Rate.

4.3.3 Feasibility of Reheat Systems

As indicated in Figure 4-1, the inclusion of reheat systems into the design of the 100 MW unit lowers the net plant heat rate from 11,900 Btu/kWh to 11,400 Btu/kWh, or approximately 4 percent. Based on the calculated biomass fuel consumption rates, this improved efficiency results in a reduction of fuel consumption by 34,000 tons per year. Assuming a biomass cost of \$15 per ton, the inclusion of a reheat system results in fuel cost savings of roughly \$500,000 per year.

As a general guideline, Black & Veatch assumed that the reheat system would have to pay for itself within ten years to be considered economically viable. Therefore, considering the estimated fuel cost savings, the addition of the reheat system must increase the required capital investment by less than \$5,000,000. Black & Veatch estimates that the inclusion of a reheat system would increase the total capital investment required for the 100 MW system by roughly \$15,000,000 to \$20,000,000. Therefore, the reheat system does not appear to be economically viable. It should be noted that this conclusion is consistent with the opinions of boiler vendors expressed during the vendor survey discussed in Section 4.1. The consensus among vendors was that reheat systems are not economically viable unless the generation system size is significantly larger than 100 MW.

4.4 Cost and Operations Data

Cost estimates and operational parameters have been gathered for biomass-fired units based on similar projects. These estimates and operational parameters include capital costs (EPC contracting basis), operating and maintenance (O&M) costs, cash flow during construction, maintenance schedules and availability assumptions. This information is presented in the following subsections.

4.4.1 Capital Cost Estimates and Cash Flow during Construction

Cost estimates have been developed for both a 50 MW biomass-fired BFB system and a 100 MW biomass-fired BFB system. The cost estimates have been determined on an EPC-contracted basis. Assumptions of the cost estimates include:

- The plant site is the existing Deerhaven site, which is reasonably level and clear with no wetlands. Demolition of any existing structures is not included in this cost estimate. Sufficient space exists for the new boiler and steam turbine and for additional biomass storage. The site has sufficient area available to accommodate construction activities including, but not limited to, offices, laydown, and staging. The cost of piles under all major equipment is included.
- Wood chips will serve as fuel for the unit and will be delivered to the plant "ready to burn". No on-site processing is included. The 50 MW plant will require 1460 tons per day of biomass, and the 100 MW plant will require 2800 tons per day.
- The plant configuration consists of one bubbling fluidized bed (BFB) boiler with a Rankine steam cycle. All steam is sent to a condensing steam turbine. The 50 MW system will require 480,000 lb/hr of steam, and the 100 MW system will require 940,000 lb/hr of steam.
- Heat rejection from the main cycle is accomplished using a mechanical draft, evaporative cooling tower.
- Standard redundancy has been assumed for boiler feed pumps, feedwater heaters and condensate pumps.
- Air quality control is accomplished through the use of a Selective Noncatalytic Reduction (SNCR) system for NOx. A baghouse is included for particulate control. No SO2 control systems or equipment are included.

Direct cost assumptions include:

- All direct costs are expressed in 2006 US dollars.

- Direct costs include those associated with the purchase of equipment, erection, and contractors' services. Service contracts and construction indirects are included and cover all heavy equipment use such as turbine and transformer unloading equipment, cranes, hoists and earth moving equipment. This category also includes all performance testing during construction (welds, concrete, etc.), subcontractor profit and site services such as cleanup during construction and sanitary services and water. Field office expenses are included in this category.
- These costs are "overnight" costs excluding Owner's costs, escalation and interest-during-construction.
- Equipment shipping is included in the cost estimate.

Indirect cost assumptions include:

- General indirect costs include relay checkouts and testing; instrumentation and control equipment calibration and testing; systems and plant startup including services of an operating crew during testing and the initial operation period; operating crew training; and the electricity, water, and fuel used by contractors during construction. All standard insurances are included. An allowance is included for spare parts during startup.
- Engineering and related services include architectural and engineering (A/E) services, and other related costs.
- Field construction management services include field management staff and supporting staff personnel; field contract administration, field inspection, and quality assurance; project control; technical direction and management of startup and testing; cleanup expense for the portion not included in the direct-cost construction contracts; safety and medical services; guards and other security services; insurance premiums; and other required labor-related insurance. Telephone and other utility bills associated with construction are included.
- A contingency allowance is also included.

The cost estimates exclude Owner's "soft" costs. Potential costs that are typically classified as Owner's costs are listed in Table 4-8. Based on Black & Veatch experience, total Owner's costs can range between 35 to 65 percent of the EPC cost. The magnitude of Owner's costs is dependent upon the site specific requirements of each project.

Based on the assumptions identified above, cost estimates were developed for both the 50 MW and 100 MW biomass-fired BFB systems. The estimates are listed in Table 4-9 and Table 4-10, respectively.

The cash flow during construction is assumed to follow a general S-curve for both scenarios considered in the capital cost estimates. The monthly cash flows are listed in Table 4-11.

Table 4-8. Owner's "Soft" Costs.

Project Development:	Plant Start-up / Construction Support:
Site selection study	Owner's site mobilization
Land purchase / options / rezoning	O&M staff training
Transmission / gas pipeline rights of way	Initial test fluids and lubricants
Road modifications / upgrades	Initial inventory of chemicals / reagents
Demolition (if brownfield)	Consumables
Environmental permitting / offsets	Cost of fuel not recovered in power sales
Public relations / community development	Auxiliary power purchase
Site specific feasibility study	Construction risk insurance
Utility Interconnections:	Taxes / Advisory Fees / Legal:
Natural gas service (if applicable)	Taxes
Gas system upgrades (if applicable)	Market and environmental consultants
Electrical transmission	Owner's legal expenses:
Supply water	PPA
Waste water / sewer (if applicable)	Interconnect agreements
Spare Parts and Plant Equipment:	Contract-procurement and construction
AQCS materials, supplies, and parts	Property transfer
Boiler materials, supplies, and parts	Financing:
Steam turbine materials, supplies, and parts	Financial advisor, lender's legal, market analyst, and engineer
BOP equipment / tools	Interest during construction
Rolling stock	Loan administration and commitment fees
Plant furnishings and supplies	Debt service reserve fund
Owners Project Management:	Owner's Contingency:
Provide project management	Unidentified project scope increases
Perform engineering due diligence	Unidentified project requirements
Provide personnel for site construction management	Costs pending final agreement (e.g., interconnection contract) costs)

Table 4-9. Capital Cost Estimate—50 MW BFB (2006 Overnight Costs)*.

	Description	Total Cost (2006\$)
Purchase Contracts		
61.0000	Civil/Structural	9,807,024
62.0000	Mechanical	
	Steam Generator	24,130,000
	Turbine Generator	7,200,000
	Balance of Plant	10,779,926
63.0000	Electrical	4,003,334
64.0000	Control	1,129,511
65.0000	Chemical	1,465,000
	Subtotal Purchase Contracts:	\$58,514,795
Construction Contracts		
71.0000	Civil/Structural Construction	12,521,121
72.0000	Mechanical/Chemical Construction	14,589,584
73.0000	Electrical/Control Construction	4,409,935
78.0000	Service Contracts & Construction Indirects	8,277,990
	Subtotal Construction Contracts:	\$39,798,630
	Total Direct Costs:	\$98,313,425
Indirect Costs		
99.1100	Engineering Costs	10,530,000
99.1200	Construction Management	6,111,531
99.1300	Start-up Spare Parts	400,000
99.1400	Construction Utilities(Power & Water)	500,000
99.1500	Project Insurance	1,557,000
99.1600	Bonds	1,020,000
99.2200	Other Indirect Costs	23,859,000
	Total Indirect Costs:	\$43,977,531
	Total Project Cost**:	\$142,290,957

Notes:

* EPC Contracting basis.

** Total Project Cost does not include Owner's Costs such as Interest During Construction (IDC), Escalation or Permitting.

Table 4-10. Capital Cost Estimate—100 MW BFB (2006 Overnight Costs)*.

	Description	Total Cost (2006\$)
Purchase Contracts		
61.0000	Civil/Structural	15,439,150
62.0000	Mechanical	
	Steam Generator	47,130,000
	Turbine Generator	14,000,000
	Balance of Plant	18,789,345
63.0000	Electrical	7,062,131
64.0000	Control	2,049,511
65.0000	Chemical	1,625,000
	Subtotal Purchase Contracts:	\$106,095,137
Construction Contracts		
71.0000	Civil/Structural Construction	19,521,401
72.0000	Mechanical/Chemical Construction	24,180,692
73.0000	Electrical/Control Construction	7,832,178
78.0000	Service Contracts & Construction Indirects	11,950,577
	Subtotal Construction Contracts:	\$63,484,847
	Total Direct Costs:	\$169,579,984
Indirect Costs		
99.1100	Engineering Costs	15,795,000
99.1200	Construction Management	6,790,220
99.1300	Start-up Spare Parts	500,000
99.1400	Construction Utilities(Power & Water)	750,000
99.1500	Project Insurance	3,114,000
99.1600	Bonds	1,725,000
99.2200	Other Indirect Costs	44,653,000
	Total Indirect Costs:	\$73,327,220
	Total Project Cost**:	\$242,907,204

Notes:

* EPC Contracting basis.

** Total Project Cost does not include Owner's Costs such as Interest During Construction (IDC), Escalation or Permitting.

Table 4-11. Cash Flow during Construction of Biomass-Fired Unit.

Month	Incremental	Cumulative
-9	0.22%	0.22%
-8	0.29%	0.51%
-7	0.39%	0.89%
-6	0.50%	1.40%
-5	0.65%	2.05%
-4	0.82%	2.87%
-3	1.03%	3.90%
-2	1.27%	5.17%
-1	1.54%	6.71%
1	1.84%	8.54%
2	2.17%	10.71%
3	2.51%	13.22%
4	2.87%	16.10%
5	3.24%	19.33%
6	3.591%	22.92%
7	3.926%	26.85%
8	4.229%	31.08%
9	4.488%	35.57%
10	4.693%	40.26%
11	4.835%	45.09%
12	4.907%	50.00%
13	4.907%	54.91%
14	4.835%	59.74%
15	4.693%	64.43%
16	4.488%	68.92%
17	4.229%	73.15%
18	3.926%	77.08%
19	3.591%	80.67%
20	3.236%	83.90%
21	2.873%	86.78%
22	2.513%	89.29%
23	2.166%	91.46%
24	1.839%	93.29%
25	1.538%	94.83%
26	1.268%	96.10%
27	1.030%	97.13%
28	0.824%	97.95%
29	0.649%	98.60%
30	0.504%	99.11%
31	0.386%	99.49%
32	0.291%	99.78%
33	0.216%	100.00%

4.4.2 Operating and Maintenance Parameters and Cost Estimates

Unit availability should be similar to other units currently in operation at Deerhaven. Typical availability assumptions for fluidized bed technologies are shown in Table 4-12.

Table 4-12. Expected Unit Availability.					
	Availability Factor (%)	Equivalent Availability Factor (%)	Scheduled Outage Factor (%)	Forced Outage Factor (%)	Forced Outage Rate (%)
Range of Values	90 to 92	88 to 90	4 to 6	4 to 6	5 to 8
Suggested Values	91	89	4	5	6

System outages should be similar to other generation units. Expected duration and frequency of system outages is shown in Table 4-13.

Table 4-13. Unit Outage Schedule.		
	Outage Duration (Weeks)	Outage Frequency (Years/Outage)
Steam Generator	3	2 to 3
Steam Turbine	6	6 to 8

Operating and maintenance (O&M) costs are defined as all production related expenses associated with the generation of steam and electric power. O&M costs typically include production and maintenance labor, chemical costs, water costs, ash disposal costs, maintenance parts and materials, and various other expenses associated with plant operation and maintenance. Not included in O&M costs are items such as fixed charges on capital investment which consist of return on investment, depreciation, and income taxes. Also not included are general utility office expenditures related to power generation and transmission. Operating and maintenance costs are typically split into fixed and variable components:

- **Fixed Operating and Maintenance Costs**—O&M costs that do not vary with the output of the facility. Such costs typically include staffing, insurance, property taxes, etc. Fixed O&M estimates were determined based on staff and labor cost estimates and an allowance for other fixed costs.
- **Variable Operating and Maintenance Costs**—O&M costs that vary with the output of the plant. These costs include consumables such as urea and

limestone as well as spare equipment parts and materials. Estimates for the variable O&M for the project were obtained from a cost build-up based upon Black & Veatch's experience with similar types and sizes of systems.

The O&M cost estimates for both the 50 MW and 100 MW facilities are shown in Table 4-14. Among other assumptions, the O&M costs calculations are based on the following key inputs:

- The 50 MW facility will require an operating and maintenance staff of 38 employees for 50 MW. The 100 MW facility will require an operating and maintenance staff of 44 employees.
- The capacity factor of the facility is assumed to be 85 percent, which is typical for biomass-fired generation facilities in this size range.
- Due to the uncertainty of fuel costs for the biomass facility, no assumption has been made for delivered fuel costs. Therefore, the O&M costs presented below are non-fuel O&M costs.

Table 4-14. Non-fuel O&M Cost Estimate.				
	Fixed O&M Cost		Variable O&M Cost	
	(\$000/yr)	(\$/kW-yr)	(\$000/yr)	(\$/MWh)
50 MW Facility	4,552	91.04	1,541	4.13
100 MW Facility	5,562	55.65	2,335	3.13

5.0 Impacts Resulting from the Incorporation of Fuel Flexibility

While the generation systems described in the previous sections have been assumed to utilize only biomass fuels, there may be fuel supply situations in which the ability to fire coal in the selected system would be advantageous. Black & Veatch consulted with boiler vendors, reviewed relevant permitting regulations and identified the required system modifications and associated costs to determine the extent to which the selected biomass systems may be capable of utilizing coal as a fuel. The findings from these activities are summarized in the following subsections.

5.1 Opinions from Boiler Vendors

Boiler equipment vendors were contacted to discuss the possibility of firing coal in combustion equipment designed to fire biomass. The contacted vendors consisted of the vendors contacted to discuss the initial biomass system design, as shown in Table 4-1. Key findings obtained during discussions with vendor representatives include:

- Following discussions with their own technical experts, Babcock & Wilcox believed that it would be possible to cofire up to 20 percent coal in a BFB designed to combust biomass. Babcock & Wilcox stressed that this was “only an educated guess.”
- Foster Wheeler stated that BFBs may be able to burn up to 30 percent coal and CFBs could be able to burn up to 70 percent coal in a unit designed to burn 100 percent biomass. Foster Wheeler also stated that it may be technically possible to burn 100 percent coal in a CFB designed for biomass combustion, but a detailed investigation would be required to confirm this belief. Foster Wheeler did not provide any indication of the effects on emissions when burning coal in unit designed for biomass combustion, other than to say it is likely that NO_x and SO_x would increase when combusting coal.
- EPI expressed concern developing BFB systems with extensive fuel flexibility, and the company identified the following issues with fuel-flexible units:
 - **Permitting:** Permitting would be complicated by the possibility of cofiring coal, as SO_x would certainly increase significantly and other emissions would likely increase as well. To remain within permit limits, systems unnecessary for biomass combustion such as FGD would likely be required when cofiring, which would substantially increase capital costs associated with the project.

- **Heat Release:** The heat released during combustion of biomass is split evenly between the fluidized bed and the vapor space above the bed, while the heat released during combustion of coal is released almost completely within the bed. The combustion of coal would require additional heat transfer surface within the bed, which EPI does not typically include in their designs and would increase the cost of the system. B&W had mentioned this requirement as well.
- **Fan Size:** Combustion of coal requires more excess air than combustion of biomass. The system would either be fan-limited during combustion of coal or the fan would have to be oversized for biomass combustion to provide fuel flexibility.
- **Capital Cost:** EPI estimated that the extent of coal cofiring would be limited to roughly 10 percent to 20 percent from a technical feasibility perspective, but the company stated that the increased cost requirements of this fuel flexibility would likely limit the cofiring of coal to a much smaller percentage.
- Kvaerner has investigated the utilization of more traditional fuels in its biomass BFBs. Based on the results of these trials, Kvaerner limits the utilization of "hot fuels" such as coal, tire derived fuel (TDF), and pet coke to 20 percent of the heat input to the unit. Kvaerner recommended the use of a CFB if it was desired to cofire higher levels of coal on a regular basis.
- McBurney, Wellons Boiler and Detroit Stoker all limited coal utilization to 10 percent or less in their biomass stoker boilers, as the combustion of coal raised temperatures within the boiler and increased the production of pollutants.

5.2 Permitting Implications of Cofiring

The use of coal in the CFB will likely not affect whether the proposed new unit at the Deerhaven unit would have to go through PSD permitting, since it is likely that PSD will be triggered regardless of the type of fuel used. The type of fuel used in the units will likely be a factor when determining the case-by-case BACT requirements for the new units. The BACT requirements will likely be affected by whether the facility proposes that the permit allows the use of 100 percent coal in the new unit or whether it would simply allow for a small amount of coal cofiring to augment the primary (biomass) fuel. NSPS and other rule applicability, such as CAIR and the Clean Air Mercury Rule (CAMR) will also likely be affected by the use of coal in the proposed new unit.

5.3 Impacted Systems and Estimated Costs

The consensus among boiler vendors was that the cofiring of coal in BFBs would be limited to a relatively minor level of 10 percent to 20 percent of the heat input to the boiler. The utilization of coal above this level in BFBs would require additional in-bed heat transfer surface and downstream emissions control systems that would likely be cost-prohibitive, particularly if the coal was only sporadically added to the fuel mix.

If it is determined that the limited availability of biomass resources regularly requires the combustion of coal at a more significant level (i.e., more than 20 percent of the heat input to the boiler on a continuous basis), it is recommended that a CFB boiler rather than a BFB boiler be employed to generate steam, as CFBs are more capable of simultaneously combusting varied fuels. Discussions with Babcock & Wilcox and Foster Wheeler indicated that capital costs of CFBs are roughly 10 percent to 15 percent greater than those of BFBs. As in the case of coal cofiring in a BFB, emission control systems would be required to limit the emission of sulfur dioxide. These systems would likely be composed of limestone injection equipment and downstream polishing reactors.


The increase in capital costs for a 100 MW CFB unit with the capability to cofire 30 percent coal is shown in Table 5-1. Other costs may increase relative to the 100 MW biomass-fired BFB system, but these costs are not expected to be as significant as the costs identified in Table 5-1. Furthermore, Black & Veatch does not expect the change from a biomass-only BFB system to a cofired CFB system to alter the expected cash flow during construction, unit availability or outage schedule.

Table 5-1. Increase in Capital Cost of 100 MW CFB (30% Coal Cofiring).

Equipment	Cost (2006\$)
Fluidized Bed*	4,713,000
Sulfur Dioxide Control**	11,483,000
Total	16,169,000
Notes:	
* Increase in capital cost of a 100 MW CFB unit designed to fire a 70/30 biomass/coal fuel mixture relative to the cost of a 100 MW BFB designed to fire 100% biomass. Incremental cost assumed to be 10% of the equipment cost of a 100 MW BFB (as listed in Table 4-10).	
** Capital cost of sulfur dioxide control equipment necessary to reduce SO ₂ emissions from a 100 MW CFB to permitted levels assuming a 70/30 biomass/coal fuel mixture. This estimate assumes a dry lime system coupled with an existing ESP for sorbent capture.	

Appendix A. Heat Balance for 50 MW Stoker System

GRU Biomass Preliminary Cycle Diagram - 50 MW
Black & Veatch Project 145639



Date: 12/08/2006
Preparer: XWX
Reviewer: DAC

GRU Biomass-50 MW Stoker

Black & Veatch STEAM MASTER 16.0 1579 2008-12-05 15:47:44 Steam Properties: IAPWS-IF97
FILE: C:\Documents and Settings\user4372\My Documents\PROJECTS\Biomass\GRU Biomass-50 MW Stoker.STM Cycle:
1 CONDENSER & COOLING TOWERS
p[psia], T[F], m[lb/s], h[BTU/lb]

Figure A-1. Preliminary Steam Cycle Diagram—Biomass-Fired 50 MW Stoker.

Table A-1. Preliminary Heat Balance—Biomass-Fired 50 MW Stoker, 100% Load.

System Parameters				
Turbine Gross Output, kW	57,465			
Turbine Heat Rate, Btu/kWh	8,657			
Total Auxiliary Power, kW	7,470			
Total Auxiliary Power, %	13.0			
Net Plant Output, kW	50,000			
Heat to Steam from Boiler, MBtu/hr	497.9			
Boiler Efficiency (HHV)	80.0			
Boiler Heat Input, MBtu/hr (HHV)	622.4			
Net Plant Heat Rate, Btu/kWh (HHV)	12,448			
Number of Heaters	4			
STEAM MASTER Streams				
	P (psia)	T (°F)	h (Btu/lb)	m (kpph)
1 Feedwater into boiler		450.1	431.0	482.72
17 Steam leaving superheater	1528.0	955.0	1462.5	482.72
53 HPT inlet, before stop valves	1466.9	950.1	1461.6	482.72
67 ST group 2 addition / extraction	477.5	678.0	1346.0	-43.58
70 ST group 3 addition / extraction	167.0	458.4	1250.1	-39.33
73 ST group 4 addition / extraction	50.8	281.9	1161.9	-13.02
76 ST group 5 addition / extraction	9.7	192.0	1062.1	-32.21
79 ST group 6 addition / extraction	0.9	96.6	955.8	335.93
119 FW into condensate pump		96.6	64.7	399.81
130 FWH1A heating steam	9.1	188.6	1061.1	32.21
132 FWH1A feedwater inlet		96.9	65.5	399.81
133 FWH1A feedwater exit		183.6	152.1	399.81
134 FWH1A drain	9.1	107.0	75.0	63.23
135 FWH2A heating steam	47.2	277.4	1160.9	13.02
137 FWH2A feedwater inlet		183.6	152.1	399.81
138 FWH2A feedwater exit		272.4	241.7	399.81
139 FWH2A drain	47.2	193.6	161.8	30.88
140 FWH3A heating steam	155.3	453.9	1249.1	39.33
142 FWH3A feedwater inlet		272.5	241.7	399.81
144 FWH3A drain	155.3	361.2	333.6	482.72
145 FWH4A heating steam	444.0	672.5	1345.0	43.58
147 FWH4A feedwater inlet		366.4	341.2	482.72
148 FWH4A feedwater outlet		450.1	431.0	482.72
149 FWH4A drain	444.0	376.4	350.1	43.58

Notes:

- ^a Performance is preliminary and for information only. Not to be used for detailed design.
- ^b Auxiliary power is assumed to be 13% of base load.
- ^c Water cooling with mechanical draft cooling tower is used.
- ^d Average ambient conditions of 59°F dry bulb temperature and 50% relative humidity are used.
- ^e Boiler efficiency is assumed to be 80%.

Table A-2. Preliminary Heat Balance—Biomass-Fired 50 MW Stoker, 75% Load.

System Parameters				
Turbine Gross Output, kW	43,291			
Turbine Heat Rate, Btu/kWh	8,829			
Total Auxiliary Power, kW	6,550			
Total Auxiliary Power, %	15.1			
Net Plant Output, kW	36,740			
Heat to Steam from Boiler, MBtu/hr	382.6			
Boiler Efficiency (HHV)	80.0			
Boiler Heat Input, MBtu/hr (HHV)	478.2			
Net Plant Heat Rate, Btu/kWh (HHV)	13,017			
Number of Heaters	4			
STEAM MASTER Streams				
	P (psia)	T (°F)	h (Btu/lb)	m (kpph)
1 Feedwater into boiler		427.1	405.8	362.06
17 Steam leaving superheater	1501.6	953.5	1462.5	362.06
53 HPT inlet, before stop valves	1466.9	950.1	1461.6	362.03
67 ST group 2 addition / extraction	361.8	666.2	1346.7	-29.91
70 ST group 3 addition / extraction	127.6	451.5	1251.3	-27.06
73 ST group 4 addition / extraction	38.7	265.3	1162.9	-8.51
76 ST group 5 addition / extraction	7.5	179.6	1063.7	-23.97
79 ST group 6 addition / extraction	0.7	88.4	957.9	258.21
119 FW into condensate pump		88.4	56.4	305.10
130 FWH1A heating steam	7.0	176.6	1062.7	23.97
132 FWH1A feedwater inlet		88.9	57.4	305.10
133 FWH1A feedwater exit		173.6	141.9	305.10
134 FWH1A drain	7.0	96.5	64.6	46.23
135 FWH2A heating steam	36.8	262.2	1161.9	8.510
137 FWH2A feedwater inlet		173.6	141.9	305.10
138 FWH2A feedwater exit		259.5	228.5	305.10
139 FWH2A drain	36.8	180.9	149.0	22.27
140 FWH3A heating steam	120.4	447.9	1250.3	27.06
142 FWH3A feedwater inlet		259.5	228.5	305.10
144 FWH3A drain	120.4	341.5	312.9	362.06
145 FWH4A heating steam	341.0	661.9	1345.7	29.91
147 FWH4A feedwater inlet		347.6	321.5	362.06
148 FWH4A feedwater outlet		427.1	405.8	362.06
149 FWH4A drain	341.0	353.5	325.7	29.91

Notes:

- ^a Performance is preliminary and for information only. Not to be used for detailed design.
- ^b Auxiliary power is assumed to be 13% of base load.
- ^c Water cooling with mechanical draft cooling tower is used.
- ^d Average ambient conditions of 59°F dry bulb temperature and 50% relative humidity are used.
- ^e Boiler efficiency is assumed to be 80%.

Table A-3. Preliminary Heat Balance—Biomass-Fired 50 MW Stoker, 50% Load.

System Parameters				
Turbine Gross Output, kW	28,863			
Turbine Heat Rate, Btu/kWh	9,120			
Total Auxiliary Power, kW	5,610			
Total Auxiliary Power, %	19.4			
Net Plant Output, kW	23,250			
Heat to Steam from Boiler, MBtu/hr	263.7			
Boiler Efficiency (HHV)	80.0			
Boiler Heat Input, MBtu/hr (HHV)	329.6			
Net Plant Heat Rate, Btu/kWh (HHV)	14,177			
Number of Heaters	4			
STEAM MASTER Streams				
	P (psia)	T (°F)	h (Btu/lb)	m (kpph)
1 Feedwater into boiler		394.6	370.9	241.57
17 Steam leaving superheater	1482.4	952.5	1462.5	241.57
53 HPT inlet, before stop valves	1466.9	950.1	1461.6	241.35
67 ST group 2 addition / extraction	244.5	654.4	1347.8	-17.26
70 ST group 3 addition / extraction	87.0	444.9	1252.8	-16.13
73 ST group 4 addition / extraction	26.4	248.4	1164.4	-4.28
76 ST group 5 addition / extraction	5.1	163.2	1065.7	-15.18
79 ST group 6 addition / extraction	0.5	78.8	962.1	178.41
119 FW into condensate pump		78.8	46.8	208.17
130 FWH1A heating steam	4.8	160.9	1064.7	15.18
132 FWH1A feedwater inlet		79.8	48.1	208.17
133 FWH1A feedwater exit		159	127.2	208.17
134 FWH1A drain	4.8	84.5	52.6	29.11
135 FWH2A heating steam	25.7	246	1163.4	4.28
137 FWH2A feedwater inlet		159	127.2	208.17
138 FWH2A feedwater exit		240.6	209.2	208.17
139 FWH2A drain	25.7	163.1	131.2	13.94
140 FWH3A heating steam	83.3	442.1	1251.8	16.13
142 FWH3A feedwater inlet		240.6	209.2	208.17
144 FWH3A drain	83.3	314.8	285.1	241.57
145 FWH4A heating steam	234.3	651.2	1346.8	17.26
147 FWH4A feedwater inlet		322.7	295.8	241.57
148 FWH4A feedwater outlet		394.6	370.9	241.57
149 FWH4A drain	234.3	325.4	296.2	17.26

Notes:

- ^a Performance is preliminary and for information only. Not to be used for detailed design.
- ^b Auxiliary power is assumed to be 13% of base load.
- ^c Water cooling with mechanical draft cooling tower is used.
- ^d Average ambient conditions of 59°F dry bulb temperature and 50% relative humidity are used.
- ^e Boiler efficiency is assumed to be 80%.

Appendix B. Heat Balance for 100 MW CFB System




Figure B-1. Preliminary Steam Cycle Diagram—Biomass-Fired 100 MW CFB.

Table B-1. Preliminary Heat Balance—Biomass-Fired 100 MW CFB, 100% Load.

System Parameters				
Turbine Gross Output, kW	115,053			
Turbine Heat Rate, Btu/kWh	8,259			
Total Auxiliary Power, kW	15,000			
Total Auxiliary Power, %	13.0			
Net Plant Output, kW	100,050			
Heat to Steam from Boiler, MBtu/hr	951.2			
Boiler Efficiency (HHV)	80.0			
Boiler Heat Input, MBtu/hr (HHV)	1,189.0			
Net Plant Heat Rate, Btu/kWh (HHV)	11,884			
Number of Heaters	5			
STEAM MASTER Streams				
	P (psia)	T (°F)	h (Btu/lb)	m (kpph)
1 Feedwater into boiler		455.9	437.7	937.54
17 Steam leaving superheater	1815.0	955	1452.3	937.54
53 HPT inlet, before stop valves	1742.4	949.4	1451.3	937.44
67 ST group 2 addition / extraction	486.5	637.7	1322.2	-76.16
70 ST group 3 addition / extraction	224.3	475.6	1252.6	-61.58
73 ST group 4 addition / extraction	82.8	314.4	1176.8	-58.28
76 ST group 5 addition / extraction	29.6	249.5	1115.9	-55.40
79 ST group 6 addition / extraction	7.0	176.8	1033.8	-51.16
81 ST group 7 addition / extraction	0.9	96.6	936.9	633.20
119 FW into condensate pump		96.6	64.6	741.43
130 FWH1A heating steam	6.5	173.6	1032.8	51.16
132 FWH1A feedwater inlet		96.8	65.1	741.53
133 FWH1A feedwater exit		168.5	136.8	741.53
134 FWH1A drain	6.5	105.6	73.6	106.56
135 FWH2A heating steam	27.5	245.4	1114.9	55.40
137 FWH2A feedwater inlet		168.5	136.8	741.53
138 FWH2A feedwater exit		240.5	209.1	741.53
139 FWH2A drain	27.5	178.5	146.6	55.40
140 FWH3A heating steam	80.3	312.3	1175.8	58.28
142 FWH3A feedwater inlet		240.5	209.1	741.53
144 FWH3A drain	80.3	312.3	282.5	937.54
145 FWH4A heating steam	213.1	471.4	1251.6	61.58
147 FWH4A feedwater inlet		318.4	292.2	937.54
148 FWH4A feedwater outlet		384.1	360.4	937.54
149 FWH4A drain	213.1	328.4	299.4	137.74

150 FWH5A heating steam	462.2	633	1321.2	76.16
152 FWH5A feedwater inlet		384.1	360.4	937.54
153 FWH5A feedwater outlet		455.9	437.7	937.54
154 FWH5A drain	462.2	394.2	369.0	76.16

Notes:

- ^a Performance is preliminary and for information only. Not to be used for detailed design.
- ^b Auxiliary power is assumed to be 13% of base load.
- ^c Water cooling with mechanical draft cooling tower is used.
- ^d Average ambient conditions of 59°F dry bulb temperature and 50% relative humidity are used.
- ^e Boiler efficiency is assumed to be 80%.

Table B-2. Preliminary Heat Balance—Biomass-Fired 100 MW CFB, 75% Load.

System Parameters				
Turbine Gross Output, kW	88,591			
Turbine Heat Rate, Btu/kWh	8,301			
Total Auxiliary Power, kW	13,280			
Total Auxiliary Power, %	15.0			
Net Plant Output, kW	75,310			
Heat to Steam from Boiler, MBtu/hr	743.8			
Boiler Efficiency (HHV)	80.0			
Boiler Heat Input, MBtu/hr (HHV)	929.7			
Net Plant Heat Rate, Btu/kWh (HHV)	12,345			
Number of Heaters	5			
STEAM MASTER Streams				
	P (psia)	T (°F)	h (Btu/lb)	m (kpph)
1 Feedwater into boiler		431.1	410.5	676.74
17 Steam leaving superheater	1783.6	953.3	1452.3	703.39
53 HPT inlet, before stop valves	1742.4	949.4	1451.3	703.08
67 ST group 2 addition / extraction	364.8	599.2	1309.3	-50.07
70 ST group 3 addition / extraction	169.5	444.7	1242.2	-41.49
73 ST group 4 addition / extraction	63.1	296.0	1168.7	-41.28
76 ST group 5 addition / extraction	22.7	234.7	1109.3	-40.31
79 ST group 6 addition / extraction	5.4	165.2	1028.8	-38.87
81 ST group 7 addition / extraction	0.7	88.2	933.5	489.76
119 FW into condensate pump		88.1	56.2	570.61
130 FWH1A heating steam	5.0	162.3	1027.8	38.87
132 FWH1A feedwater inlet		88.5	56.8	570.54
133 FWH1A feedwater exit		159.4	127.6	570.54
134 FWH1A drain	5.0	95.1	63.1	79.18
135 FWH2A heating steam	21.3	231.2	1108.3	40.31
137 FWH2A feedwater inlet		159.4	127.6	570.54
138 FWH2A feedwater exit		227.9	196.4	570.54
139 FWH2A drain	21.3	166.6	134.6	40.31
140 FWH3A heating steam	61.5	294.3	1167.7	41.28
142 FWH3A feedwater inlet		228.0	196.4	570.54
144 FWH3A drain	61.5	294.4	263.9	703.39
145 FWH4A heating steam	163.0	441.3	1241.2	41.49
147 FWH4A feedwater inlet		301.9	275.0	676.74
148 FWH4A feedwater outlet		363.9	339.0	676.74
149 FWH4A drain	163.0	307.0	277.1	91.57

150 FWH5A heating steam	351.3	595.6	1308.3	50.07
152 FWH5A feedwater inlet		363.9	339.0	676.74
153 FWH5A feedwater outlet		431.1	410.5	676.74
154 FWH5A drain	351.3	369.5	342.6	50.07

Notes:

- ^a Performance is preliminary and for information only. Not to be used for detailed design.
- ^b Auxiliary power is assumed to be 13% of base load.
- ^c Water cooling with mechanical draft cooling tower is used.
- ^d Average ambient conditions of 59°F dry bulb temperature and 50% relative humidity are used.
- ^e Boiler efficiency is assumed to be 80%.

Table B-3. Preliminary Heat Balance—Biomass-Fired 100 MW CFB, 50% Load.

System Parameters				
Turbine Gross Output, kW	59,910			
Turbine Heat Rate, Btu/kWh	8,515			
Total Auxiliary Power, kW	11,410			
Total Auxiliary Power, %	19.0			
Net Plant Output, kW	48,500			
Heat to Steam from Boiler, MBtu/hr	522.1			
Boiler Efficiency (HHV)	80.0			
Boiler Heat Input, MBtu/hr (HHV)	652.6			
Net Plant Heat Rate, Btu/kWh (HHV)	13,455			
Number of Heaters	5			
STEAM MASTER Streams				
	P (psia)	T (°F)	h (Btu/lb)	m (kpph)
1 Feedwater into boiler		397.1	373.8	427.51
17 Steam leaving superheater	1760.8	952.0	1452.3	469.49
53 HPT inlet, before stop valves	1742.4	949.4	1451.3	468.72
67 ST group 2 addition / extraction	245.5	570.7	1303.2	-27.52
70 ST group 3 addition / extraction	115.4	423.0	1237.8	-22.83
73 ST group 4 addition / extraction	43.2	272.0	1165.7	-25.02
76 ST group 5 addition / extraction	15.6	214.9	1107.7	-25.98
79 ST group 6 addition / extraction	3.7	149.9	1028.4	-25.16
81 ST group 7 addition / extraction	0.5	78.7	936.3	341.31
119 FW into condensate pump		78.6	46.7	394.13
130 FWH1A heating steam	3.5	147.6	1027.4	25.16
132 FWH1A feedwater inlet		79.3	47.5	394.12
133 FWH1A feedwater exit		146.1	114.3	394.12
134 FWH1A drain	3.5	83.3	51.4	51.15
135 FWH2A heating steam	14.8	212.2	1106.7	25.98
137 FWH2A feedwater inlet		146.1	114.3	394.12
138 FWH2A feedwater exit		211.1	179.4	394.12
139 FWH2A drain	14.8	150.8	118.8	25.98
140 FWH3A heating steam	42.4	270.8	1164.7	25.02
142 FWH3A feedwater inlet		211.2	179.4	394.12
144 FWH3A drain	42.4	270.8	239.8	469.49
145 FWH4A heating steam	112.5	420.4	1236.8	22.83
147 FWH4A feedwater inlet		281.0	253.6	427.51
148 FWH4A feedwater outlet		336.0	309.9	427.51
149 FWH4A drain	112.5	283.0	252.4	50.35


150 FWH5A heating steam	239.5	567.9	1302.2	27.52
152 FWH5A feedwater inlet		336.0	309.9	427.51
153 FWH5A feedwater outlet		397.1	373.8	427.51
154 FWH5A drain	239.5	338.0	309.4	27.52

Notes:

- ^a Performance is preliminary and for information only. Not to be used for detailed design.
- ^b Auxiliary power is assumed to be 13% of base load.
- ^c Water cooling with mechanical draft cooling tower is used.
- ^d Average ambient conditions of 59°F dry bulb temperature and 50% relative humidity are used.
- ^e Boiler efficiency is assumed to be 80%.

Appendix C. Heat Balance for 100 MW CFB (Reheat) System

GRU Biomass Preliminary Cycle Diagram - 100 MW CFB Reheat Steam Turbine
Black & Veatch Project 145639



Date: 12/08/2006
Preparer: XWX
Reviewer: DAC

GRU Biomass-100MW CFB RH ST

Black & Veatch STEAM MASTER 16.0 1579 2006-12-05 16:47:19 Steam Properties: IAPWS-IF97
FILE: C:\Documents and Settings\user43724\My Documents\PROJECTS\Biomass\GRU biomass\GRU Biomass-100 MW CFB-RH ST-100% k
1 CONDENSER 4 COOLING TOWERS
p[psia], T[F], m[lb/s], h[BTU/lb]

Figure C-1. Preliminary Steam Cycle Diagram—Biomass-Fired 100 MW CFB (with Reheat).

Table C-1. Preliminary Heat Balance—Biomass-Fired 100 MW CFB (with Reheat), 100% Load.

System Parameters				
Turbine Gross Output, kW	114,977			
Turbine Heat Rate, Btu/kWh	7,924			
Total Auxiliary Power, kW	15,000			
Total Auxiliary Power, %	13.0			
Net Plant Output, kW	99,980			
Heat to Steam from Boiler, MBtu/hr	913.4			
Boiler Efficiency (HHV)	80.0			
Boiler Heat Input, MBtu/hr (HHV)	1,141.7			
Net Plant Heat Rate, Btu/kWh (HHV)	11,420			
Number of Heaters	5			
STEAM MASTER Streams				
	P (psia)	T (°F)	h (Btu/lb)	m (kpph)
1 Feedwater into boiler		455.8	437.5	773.45
17 Steam leaving superheater	1815.0	955.0	1452.3	773.45
53 HPT inlet, before stop valves	457.4	618.2	1313.0	697.20
67 ST group 2 addition / extraction	431.5	952.3	1497.3	697.20
70 ST group 3 addition / extraction	1742.4	949.4	1451.3	773.31
73 ST group 4 addition / extraction	425.1	950.0	1496.3	697.20
76 ST group 5 addition / extraction	100.1	607.4	1333.1	625.26
79 ST group 6 addition / extraction	462.0	620.5	1314.0	-56.07
81 ST group 7 addition / extraction	232.2	799.9	1424.1	-41.33
119 FW into condensate pump	100.1	607.6	1333.2	-47.62
130 FWH1A heating steam	32.5	386.9	1231.2	-46.01
132 FWH1A feedwater inlet	6.8	175.8	1121.6	-36.29
133 FWH1A feedwater exit	0.9	96.7	1007.4	542.97
134 FWH1A drain		96.7	64.7	627.90
135 FWH2A heating steam	6.4	172.6	1120.6	36.29
137 FWH2A feedwater inlet		97.9	66.3	628.44
138 FWH2A feedwater exit		167.4	135.7	628.44
139 FWH2A drain	6.4	107.8	75.9	83.62
140 FWH3A heating steam	30.2	384.2	1230.3	46.01
142 FWH3A feedwater inlet		167.4	135.7	628.44
144 FWH3A drain		246.4	215.2	628.44
145 FWH4A heating steam	30.2	177.5	145.6	46.01
147 FWH4A feedwater inlet	97.1	605.1	1332.2	47.62
148 FWH4A feedwater outlet		246.5	215.2	628.44

**Gainesville Regional Utilities
Biomass Sizing Study**

**Appendix C. Heat Balance for 100 MW
CFB (Reheat) System**

149 FWH4A drain	97.1	325.7	296.3	773.45
150 FWH5A heating steam	220.6	797.0	1423.1	41.33
152 FWH5A feedwater inlet		331.7	305.7	773.45
153 FWH5A feedwater outlet		393.1	369.8	773.45
154 FWH5A drain	220.6	341.7	313.2	97.38

Notes:

- ^a Performance is preliminary and for information only. Not to be used for detailed design.
- ^b Auxiliary power is assumed to be 13% of base load.
- ^c Water cooling with mechanical draft cooling tower is used.
- ^d Average ambient conditions of 59°F dry bulb temperature and 50% relative humidity are used.
- ^e Boiler efficiency is assumed to be 80%.

**Table C-2. Preliminary Heat Balance—Biomass-Fired 100 MW CFB (with Reheat),
75% Load.**

System Parameters				
Turbine Gross Output, kW	89,273			
Turbine Heat Rate, Btu/kWh	7,930			
Total Auxiliary Power, kW	13,320			
Total Auxiliary Power, %	14.9			
Net Plant Output, kW	75,950			
Heat to Steam from Boiler, MBtu/hr	715.7			
Boiler Efficiency (HHV)	80.0			
Boiler Heat Input, MBtu/hr (HHV)	894.6			
Net Plant Heat Rate, Btu/kWh (HHV)	11,779			
Number of Heaters	5			
STEAM MASTER Streams				
	P (psia)	T (°F)	h (Btu/lb)	m (kpph)
1 Feedwater into boiler		432.1	411.5	558.71
17 Steam leaving superheater	1783.6	953.3	1452.3	579.94
53 HPT inlet, before stop valves	346.6	577.4	1298.4	528.13
67 ST group 2 addition / extraction	327.1	939.9	1494.0	528.13
70 ST group 3 addition / extraction	1742.4	949.4	1451.3	579.96
73 ST group 4 addition / extraction	322.2	937.7	1493.0	528.13
76 ST group 5 addition / extraction	76.6	600.3	1331.2	479.18
79 ST group 6 addition / extraction	349.9	579.7	1299.4	-36.08
81 ST group 7 addition / extraction	176.8	789.9	1421.4	-28.88
119 FW into condensate pump	76.6	600.7	1331.4	-33.49
130 FWH1A heating steam	25.0	382.1	1230.0	-33.28
132 FWH1A feedwater inlet	5.2	164.2	1120.8	-27.31
133 FWH1A feedwater exit	0.7	88.4	1008.0	418.58
134 FWH1A drain		88.4	56.5	481.51
135 FWH2A heating steam	4.9	161.3	1119.8	27.31
137 FWH2A feedwater inlet		90.1	58.4	481.49
138 FWH2A feedwater exit		158.2	126.4	481.49
139 FWH2A drain	4.9	97.1	65.2	61.89
140 FWH3A heating steam	23.4	379.5	1229.0	33.28
142 FWH3A feedwater inlet		158.2	126.4	481.49
144 FWH3A drain		233.6	202.1	481.49
145 FWH4A heating steam	23.4	165.5	133.5	33.28
147 FWH4A feedwater inlet	74.7	598.4	1330.4	33.49
148 FWH4A feedwater outlet		233.6	202.1	481.49

149 FWH4A drain	74.7	307.3	277.3	579.94
150 FWH5A heating steam	169.4	787.4	1420.4	28.88
152 FWH5A feedwater inlet		314.7	288.1	558.71
153 FWH5A feedwater outlet		374.9	350.5	558.71
154 FWH5A drain	169.4	321.1	291.7	64.96

Notes:

- ^a Performance is preliminary and for information only. Not to be used for detailed design.
- ^b Auxiliary power is assumed to be 13% of base load.
- ^c Water cooling with mechanical draft cooling tower is used.
- ^d Average ambient conditions of 59°F dry bulb temperature and 50% relative humidity are used.
- ^e Boiler efficiency is assumed to be 80%.

Table C-3. Preliminary Heat Balance—Biomass-Fired 100 MW CFB (with Reheat), 50% Load.

System Parameters				
Turbine Gross Output, kW	60,834			
Turbine Heat Rate, Btu/kWh	8,081			
Total Auxiliary Power, kW	11,470			
Total Auxiliary Power, %	18.9			
Net Plant Output, kW	49,360			
Heat to Steam from Boiler, MBtu/hr	501.7			
Boiler Efficiency (HHV)	80.0			
Boiler Heat Input, MBtu/hr (HHV)	627.1			
Net Plant Heat Rate, Btu/kWh (HHV)	12,705			
Number of Heaters	5			
STEAM MASTER Streams				
	P (psia)	T (°F)	h (Btu/lb)	m (kpph)
1 Feedwater into boiler		399.2	376.0	352.93
17 Steam leaving superheater	1760.8	952.0	1452.3	386.66
53 HPT inlet, before stop valves	235.5	550.6	1293.2	356.06
67 ST group 2 addition / extraction	222.3	940.8	1497.8	356.06
70 ST group 3 addition / extraction	1742.4	949.4	1451.3	386.64
73 ST group 4 addition / extraction	219.1	938.7	1496.8	356.06
76 ST group 5 addition / extraction	52.9	605.2	1335.3	329.09
79 ST group 6 addition / extraction	237.8	552.9	1294.2	-19.20
81 ST group 7 addition / extraction	121.1	793.1	1425.4	-16.48
119 FW into condensate pump	52.9	605.7	1335.5	-20.27
130 FWH1A heating steam	17.3	387.3	1233.6	-21.28
132 FWH1A feedwater inlet	3.6	148.7	1123.2	-17.67
133 FWH1A feedwater exit	0.5	78.9	1014.3	290.14
134 FWH1A drain		78.9	47.0	330.69
135 FWH2A heating steam	3.4	146.4	1122.2	17.67
137 FWH2A feedwater inlet		81.5	49.7	330.71
138 FWH2A feedwater exit		145.0	113.1	330.71
139 FWH2A drain	3.4	85.8	53.9	39.52
140 FWH3A heating steam	16.4	384.9	1232.6	21.28
142 FWH3A feedwater inlet		145.0	113.2	330.71
144 FWH3A drain		216.5	184.9	330.71
145 FWH4A heating steam	16.4	149.8	117.8	21.28
147 FWH4A feedwater inlet	51.8	603.6	1334.5	20.27
148 FWH4A feedwater outlet		216.6	184.9	330.71

149 FWH4A drain	51.8	283.3	252.6	386.66
150 FWH5A heating steam	117.6	790.8	1424.4	16.48
152 FWH5A feedwater inlet		293.2	266.0	352.93
153 FWH5A feedwater outlet		348.9	323.3	352.93
154 FWH5A drain	117.6	295.7	265.4	35.68

Notes:

- ^a Performance is preliminary and for information only. Not to be used for detailed design.
- ^b Auxiliary power is assumed to be 13% of base load.
- ^c Water cooling with mechanical draft cooling tower is used.
- ^d Average ambient conditions of 59°F dry bulb temperature and 50% relative humidity are used.
- ^e Boiler efficiency is assumed to be 80%.



Florida Municipal Power Agency

Docket No. 090451-EI
2-24-10 FMPA Letter to PSC
Exhibit _____ EJR-9
(Page 1 of 2)

Nicholas P. Guarriello
General Manager and CEO

February 24, 2010

Florida Public Service Commission
c/o Chair Nancy Argenziano
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850

Subject: Gainesville Regional Utilities 100 MW proposed Biomass Power Plant Need
Determination Request

The Florida Municipal Power Agency (FMPA) is a wholesale power agency owned by municipal electric utilities. FMPA provides the entire wholesale power supply needs for 14 municipal electric utilities throughout the state through our All-Requirements Project (the ARP), and we are committed to securing electric generation capacity to meet our member's needs. Together, the ARP members serve approximately 261,000 residential, commercial and industrial customers throughout the state.

Since the ARP is interested in identifying cost effective renewable energy options, and because of the potential regulatory issues associated with conventionally fueled electric generation, we continue to investigate options to incorporate cost-effective renewable forms of energy into our generation mix. The renewable energy programs implemented on behalf of the ARP members to date have primarily focused on solar photovoltaic power projects. However, we have also been evaluating several landfill gas and biomass options.

FMPA is one of the entities in Florida that has entered into a confidentiality agreement with American Renewables d/b/a Gainesville Renewable Energy Center LLC. We entered into this agreement in order to examine the terms and conditions behind Gainesville Regional Utilities offer to resell up to 50 MW of the capacity and energy from the unit for up to ten years. This offer included all the environmental attributes of the capacity (assuming biomass is considered carbon neutral in any Renewable Portfolio Standard or carbon regulations) as well as renewable energy credits. In addition to its renewable aspects, this project is a potential source of firm, base load power.

8553 Commodity Circle | Orlando, FL 32819-9002
T. (407) 355-7767 | Toll Free (888) 774-7606
F. (407) 355-5794 | www.fmpa.com
nick.guarriello@fmpa.com

Florida Public Service Commission
February 24, 2010
Page 2

Other favorable aspects of the offer from GRU include only paying for available power, the fixed aspects of the prices over the next ten years, and the opportunity to diversify the fuel mix for the ARP. The open question for us is the premium, if any, the ARP members may be willing to pay over conventional sources of power for the environmental attributes of the project.


We understand that GRU has taken the position that they are not going enter into contract negotiations with potential off-takers until all certifications and permits are received, and after the fuels contracts that will be required by American Renewables' financiers have been executed. Having these issues resolved will assist us in our deliberations.

Respectfully


Nicholas P. Guarriello
General Manager and CEO

NPG/su

REC'D MAR 01 2010



March 8, 2010

Mr. Robert E. Hunzinger
Gainesville Regional Utilities
P.O. Box 147117 (A134)
Gainesville, FL 32614-7117

**RE: Gainesville Regional Utilities 100 MW Proposed Biomass Power Plant
Need Determination Request**

Dear Bob,

The Orlando Utilities Commission (OUC) is the sixteenth largest municipal electric and water utility in the U.S., serving over 250,000 customer accounts in the City of Orlando and City of St. Cloud, as well as unincorporated Orange and Osceola Counties. Established in 1923, OUC has a long history of providing our customers with affordable rates, reliable power and environmental stewardship. Our power plants have been built with the best available environmental control technology at the time of construction, and we have a diversified generation fuel mix that we evaluate against changes in market and regulatory conditions

With this corporate strategy, OUC was one of the first utilities in the State in 1997 to make a substantial investment in renewable energy by co-firing landfill gas from the nearby Orange County Landfill in our Stanton Energy Center coal fired power plant.

Since that time, we have actively evaluated the addition of renewable generation to our portfolio and sought projects that meet our three guiding principles. To date, the renewables that we are pursuing or have deployed include landfill gas, solar, biomass, hybrid solar/biomass and municipal solid waste-to-energy.

OUC is one of the municipal electric utilities in Florida that has expressed interest in the purchase power possibilities from the Gainesville Renewable Energy Center LLC. In addition to its renewable aspects, biomass energy offers a potential source of firm, base load generation that, though not competitive against traditional forms of generation, competes very well against other forms of renewable energy such as solar photovoltaic.

ORLANDO UTILITIES COMMISSION

Mr. Robert E. Hunzinger
March 8, 2010
Page Two

Ultimately, the extent of OUC's commitment to this project will depend on several factors, including cost, OUC's need for additional renewable generation, and the outcome of GRU's proceedings before the Florida Public Service Commission.

Please let me know if you need any additional information.

Sincerely,



Kenneth P. Ksionek
General Manager & CEO

KPK/emm

cc: Jan Aspuru, Vice President, Power Resources