

State of Florida



Public Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD
TALLAHASSEE, FLORIDA 32399-0850

RECEIVED-FPSC
10 OCT 4 AM 10:59

-M-E-M-O-R-A-N-D-U-M-

COMMISSION
CLERK

DATE: October 1, 2010
TO: Ann Cole, Commission Clerk, Office of Commission Clerk
FROM: Connie S. Kummer, Chief of Certification & Tariffs, Division of Economic Regulation
RE: Filing by Progress Energy Florida, dated September 30, 2010

Please file this document in Docket No. 100000, for undocketed filings. It appears the document came directly to me, rather than through the Clerk's office. Investor-owned electric utilities are required by Rule 25-6.078, F.A.C., to file information concerning the cost of undergrounding distribution facilities no later than October 15 each year. The report is informational in nature and does not require a separate docket. Thank you.

DOCUMENT NUMBER DATE

08282 OCT-4 2

FPSC-COMMISSION CLERK



September 30, 2010

Ms. Connie S. Kummer
Chief, Bureau of Certification, Economics & Tariffs
Florida Public Service Commission
250 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

FLORIDA PUBLIC SERVICE
COMMISSION
BUREAU OF
ECONOMIC REGULATION

10 SEP 31 AM 8:33

FLORIDA PUBLIC SERVICE
COMMISSION
BUREAU OF
ECONOMIC REGULATION

Dear Ms. Kummer:

In accordance with FPSC Rule 25-6.078, please find enclosed FORM PSC/EAG 13, Schedules 1-3, which utilize current material and labor costs for residential overhead and underground low density subdivision designs. This form demonstrates that the per lot differential for the low density subdivision (including the net present value of the lifecycle costs) is currently \$691. PEF's currently approved per lot differential for the low density subdivision is \$646. This is an increase of \$45 per lot, or 7%. In accordance with the 10% threshold established in Rule 25-6.078, the Company will not be obligated to file additional data in April 2011, and will file the complete long form filing on or before October 1, 2011.

Please feel free to contact me at (727) 820-5481 if you have any questions.

Respectfully,

Nancy Holdstein
Principal Regulatory Specialist
Regulatory Planning - Florida

Enclosures

DOCUMENT NUMBER DATE

08282 OCT-4 09

FPSC-COMMISSION CLERK

**PROGRESS ENERGY FLORIDA
OVERHEAD/UNDERGROUND RESIDENTIAL COST ESTIMATE**

OVERHEAD vs. UNDERGROUND SUMMARY SHEET

SCHEDULE NO. 1

***LOW DENSITY 210 LOT SUBDIVISION
COST PER SERVICE LATERALS***

9/1/2010

ITEM	OVERHEAD	UNDERGROUND	DIFFERENTIAL
Labor	409	757	348
Material	419	622	203
Fleet	51	109	58
SUB TOTAL	879	1,488	609
NPV of Life Cycle Operational Cost Including Storm Restoration and Pole Attachment Revenue			82
Total including NPV of Life Cycle Cost			691

**PROGRESS ENERGY FLORIDA
OVERHEAD/UNDERGROUND RESIDENTIAL COST DATA**

COST PER SERVICE LATERAL OVERHEAD MATERIAL AND LABOR

SCHEDULE NO. 2

LOW DENSITY 210 LOT SUBDIVISION

ITEM	MATERIAL	LABOR	TOTAL
Service(2)	74.68	54.86	129.54
Primary	71.83	102.80	174.63
Secondary	45.96	18.01	63.97
Initial Tree Trim	0.00	0.00	0.00
Poles	52.16	23.79	75.95
Transformers	154.03	18.22	172.25
Sub-Total(1)	398.66	217.68	616.34
Stores Handling(3)	20.10	0.00	20.10
Sub-Total	418.76	217.68	636.44
Engineering(4)	0.00	190.93	190.93
TOTAL	418.76	408.61	827.37

1-Includes Sales Tax.

2-Includes Meter.

3-9.0% of all material:	excluding transformers with a cost of:	139.37
	and meters with a cost of:	36.00

4-30% of all matl. and labor:

**PROGRESS ENERGY FLORIDA
OVERHEAD/UNDERGROUND RESIDENTIAL COST DATA**

COST PER SERVICE LATERAL UNDERGROUND MATERIAL AND LABOR

SCHEDULE NO. 3

LOW DENSITY 210 LOT SUBDIVISION

ITEM	MATERIAL	LABOR	TOTAL
Service (2)	102.67	90.25	192.92
Primary	110.39	52.12	162.51
Secondary	163.39	41.68	205.07
Transformers	213.90	32.78	246.68
TRENCHING:			
Prim. & Secondary	0.00	138.39	138.39
Service	0.00	83.79	83.79
Sub-Total(1)	590.35	439.01	1029.36
Stores Handling(3)	31.90	0.00	31.90
Sub-Total	622.25	439.01	1061.26
Engineering(4)	0.00	318.38	318.38
TOTAL	622.25	757.39	1379.64

1-Includes Sales Tax.

2-Includes Meter.

3-9.0% of all material: excluding transformers with a cost of: 199.90
and meters with a cost of: 36.00

4-30% of all matl. and labor:

Progress Energy Florida
Actuals for 5 Year Period of 2005-2009
Summary of NPV Life Cycle Costs per mile for Overhead and Underground Distribution
Including Storm Costs and Pole Attachment Revenues

	Including Storm	Excluding Storm	Storm
5 year average OH Unit Costs in 2010 Dollars - Annual	\$ 3,650	\$ 3,057	\$ 593
5 year average UG Unit Costs in 2010 Dollars - Annual	\$ 4,215	\$ 4,018	\$ 197
Differential in 2010 Dollars - OH more (less) than UG	\$ (565)	\$ (961)	\$ 396

NPV of 34 Year Life Cycle - Costs per mile

Overhead	\$ 63,630	\$53,292	\$10,338
Underground	\$ 73,479	\$70,045	\$3,434
Differential - OH more (less) than UG	\$ (9,850)	\$ (16,753)	\$ 6,903

NPV Life Cycle Costs - Per Lot Differentials

	OHD	UG			
Low Density					
Feet of Line	19,272	17,920			
Miles of Line	3.65	3.39			
Number of Lots	210	210			
Per Lot - OHD			\$ 1,106	\$ 926	\$ 180
Per Lot - UG			\$ 1,188	\$ 1,132	\$ 56
Per Lot - Differential			\$ 82	\$ 206	\$ (124)

DISTRIBUTION CONSTRUCTION COSTS

Progress Energy Florida
LOW DENSITY OVERHEAD SUBDIVISION - 210 LOTSDATE: 9/21/2010
PAGE: 1

ITEM	QTY	DESCRIPTION	MATERIAL	LABOR	TOTAL
-----	---	-----	-----	-----	-----
*** OH Services					
S302 M	165	SVC L/CBL, TRI, NO POLE ATT DEV#2 AL	6.79	6.91	13.70
S301 M	36	SVC L/CBL, W/O POLE ATT DEV, 1/0 AL	4.76	1.51	6.27
S300 M	9	SVC L/CBL, W/O POLE ATT DEV, 4/0 AL	1.24	0.38	1.62
EN	116	EYE NUT 5/8"	0.99	0.24	1.23
KC12	276	COMPRESSION CONN 1/0 STR AL-2 STR AL	0.32	4.05	4.36
KC11	286	COMPRESSION CONN 1/0 STR AL-1/0 STR AL	0.69	4.19	4.89
KC01	66	COMPRESSION CONN 4/0 STR AL-1/0 STR AL	0.16	0.97	1.13
KC00	18	COMPRESSION CONN 4/0 STR AL-4/0 STR AL	0.04	0.26	0.30
KC02	186	COMPRESSION CONN 4/0 STR AL-2 STR AL	0.50	2.73	3.22
KC52	28	WEDGE CONN 500 MCM AL 2 STR AL	2.13	0.41	2.54
KC00	18	COMPRESSION CONN 4/0 STR AL-4/0 STR AL	0.04	0.26	0.30
C30S	360	AERIAL CABLE SVC 3W 4/0 AL 600V	2.11	0.75	2.86
S31	1440	SERVICE WIRE, 3 WIRE, #1/0AL	4.46	3.02	7.47
S32	6600	SERVICE CABLE, 3 WIRE #2 AL	14.46	13.83	28.29
USER-INPUT:MTR	210	METER	36.00	15.34	51.34
			-----	-----	-----
			74.68	54.86	129.54
*** OH Primary					
WR1	15015	WIRE, #1/0 AAAC AL, ON 700 LB. REEL	12.87	31.46	44.33
V101 M	26	VERT 1PH 0 TO 5 DEG, 1/0 AAAC	2.97	1.25	4.22
V111 M	11	VERT 1PH 6 TO 15 DEG, 1/0AAAC	2.75	0.53	3.28
V121 M	11	VERTICAL 1PH 16 TO 59 DEG 1/0 AAAC	1.51	0.53	2.04
V141 M	24	VERTICAL 1 PH DEADEND 1/0 & #4 AAAC	2.64	1.16	3.80
V151 M	4	VERT 1PH SLACKSPAN, 1/0AAAC	0.35	0.16	0.51
V201 M	2	VERT 2PH, 0 TO 5 DEG, 1/0AAAC	0.46	0.19	0.65
V221 M	3	VERT. 2 PH 16 TO 59 DEG. 1/0 AAAC	0.82	0.29	1.11
V241 M	2	VERT 2PH DEADEND #1/0 & #4 AAAC	0.44	0.19	0.63
V251 M	5	VERTICAL 2PH SLACK SPAN1/0 AAAC	0.88	0.40	1.28
N101 M	35	NEUTRAL 1 WIRE NO POLE ATTCH DEV 1/0AL	1.62	0.73	2.36
N1E1 M	7	NEUTRAL 1 WIRE EYEBOLT 1/0 AAAC AUTO DE	0.41	0.29	0.71
N1S1 M	1	NEUTRAL, 1 WIRE, W/SPOOL & BOLT 1/0 AAAC	0.04	0.05	0.08
N1S1S M	8	NEUTRAL 1 WIRE SPOOL&BOLT1/0AAAC SLCKSPN	0.29	0.32	0.61

DISTRIBUTION CONSTRUCTION COSTS

Progress Energy Florida
 LOW DENSITY OVERHEAD SUBDIVISION - 210 LOTS

DATE: 9/21/2010
 PAGE: 2

ITEM	QTY	DESCRIPTION	MATERIAL	LABOR	TOTAL
N1R1 M	3	NEUTRAL 1 WIRE RACK W/SPOOL 1/0 DE GRIP	0.09	0.12	0.21
C3C0 M	12	SEC CBL 3W MESSENGER CLAMP 4/0 AL	0.77	0.25	1.02
C3E0 M	48	SEC CBL TRIPX W/EYEBOLT4/0AL	2.82	2.01	4.83
C3E0S M	34	SEC CBL TRIPLEX W/EYEBOLT 4/0AL SLCKSPN	2.78	1.42	4.20
C300 M	1	SECCBL TRIPX NO POLE ATTACH DEV 4/0AL	0.05	0.02	0.07
C300S M	2	SECCBL TRIPX NO POLE ATTACH 4/0SLCKSPN	0.14	0.04	0.18
C3E1 M	13	SEC CBL TRIPX W/EYEBOLTDE 1/0AL	0.76	0.54	1.31
C3E1S M	55	SEC CBL TRIPLEX W/EYEBOLT 1/0AL SLCKSPN	4.32	2.30	6.63
C301 M	3	SECCBL TRIPX NO POLE ATTACH 1/0AL	0.14	0.06	0.20
C301S M	4	SECCBL TRIPX NO POLE ATTACH 1/0AL SLCK	0.26	0.08	0.35
EN	38	EYE NUT 5/8"	0.32	0.08	0.40
SUPW	9	SETUP PILOT WINDER	0.00	1.89	1.89
SUTT	9	SETUP TENSIONER, TUGGER	0.00	7.54	7.54
GA111 M	44	GUY ASSY 1PH 1/0AAAC PH 5/16&N 5/16-10"	19.23	10.01	29.24
GA211 M	4	GUYASY 2PH 1/0AAACUP5/16LO5/16-10N5/16-8	2.64	1.44	4.08
FL7	48	FIBERGLASS LINK 78", 15M	3.27	0.50	3.78
GAS11 M	5	GUY ASSY SEC 1/0 OR 4/0 OPTION 1	1.18	0.72	1.89
GS75 M	1	GUY SPAN, W/78" LINK, 5/16" GUY	0.18	0.09	0.28
CP M	3	CUTOUT 15 KV POLE MTD "L" BRKT	0.77	9.94	10.71
MSC11	2	MID-SPAN CLAMP 1/0 AAAC TO 1/0 AAAC	0.27	0.10	0.38
CBF	2	CLAMP (BUTTERFLY) MIDSPAN	0.05	0.10	0.16
WORKLOC	128	Work Location for Framme	0.00	21.46	21.46
KC11	125	COMPRESSION CONN 1/0 STR AL-1/0 STR AL	0.30	1.83	2.14
KC01	69	COMPRESSION CONN 4/0 STR AL-1/0 STR AL	0.17	1.01	1.18
KC00	72	COMPRESSION CONN 4/0 STR AL-4/0 STR AL	0.16	1.06	1.21
KC50	14	WEDGE CONN 500 MCM AL 4/0 STR AL	1.05	0.21	1.26
KC51	23	WEDGE CONN 500 MCM AL 1/0 STR AL	1.68	0.34	2.02
KC71	3	WEDGE CONN 795 MCM AL 1/0 STR AL	0.37	0.04	0.41
			71.83	102.80	174.63
*** OH Secondary					
C31	2360	AERIAL CABLE, 3 WIRE, #1/0AL	9.44	4.94	14.38
C30	6235	AERIAL CABLE, 3 WIRE, 4/0 AL	36.52	13.06	49.58
			45.96	18.01	63.97

DISTRIBUTION CONSTRUCTION COSTS

Progress Energy Florida
 LOW DENSITY OVERHEAD SUBDIVISION - 210 LOTS

DATE: 9/21/2010
 PAGE: 3

ITEM	QTY	DESCRIPTION	MATERIAL	LABOR	TOTAL
-----	---	-----	-----	-----	-----
*** OH Poles					
P30	53	POLE WOOD 30' CL 6	19.43	10.01	29.44
P35	64	POLE WOOD 35' CL 5	26.15	12.08	38.23
P40	9	POLE WOOD 40' CL 5	6.58	1.70	8.28
			-----	-----	-----
			52.16	23.79	75.95
*** OH Transformers					
TA1S25 M	1	XFMRASSY 1PH120/240V 7200Y 1B/C 25KVA	3.46	0.36	3.83
TA1S50 M	17	XFMR ASSY 1PH 120/240V 1 BUSHC 50KVA	91.02	8.16	99.17
TA1D75T M	7	XFMRASSY 1PH120/240V 2B/C75KVA TAPS	54.49	3.83	58.32
GO	25	GROUND, OVERHEAD	4.65	5.24	9.89
KSP1	25	COMPRESSION STIRRUP, 1/0 STR AL	0.41	0.63	1.04
			-----	-----	-----
			154.03	18.22	172.25

MATERIAL DOES NOT INCLUDE STORES CHARGES. LABOR ADJUSTED BY COMPANY BENEFITS LOADING AND PRODUCTIVITY.
 LABOR = (RATE X 1.684) / 1

DISTRIBUTION CONSTRUCTION COSTS

Progress Energy Florida
LOW DENSITY UNDERGROUND SUBDIVISION - 210 LOTSDATE: 9/21/2010
PAGE: 4

ITEM	QTY	DESCRIPTION	MATERIAL	LABOR	TOTAL
-----	---	-----	-----	-----	-----
*** UG Services					
US320	8745	SEC CABLE D/B 2/0-2/0-#2 AL	35.81	11.82	47.63
US340	1430	4/0-4/0-2/0 AL D/B TRIPLEX SERVICE CABLE	8.10	1.93	10.04
US33	1375	UG D/B SERVICE CABLE 350-350-4/0 AL	12.18	1.86	14.04
MBR25	25	METER BASE RISER 2 1/2"	2.93	3.92	6.84
MBR2	185	METER BASE RISER 2"	7.65	28.97	36.62
USER-INPUT:MTR	210	METER	36.00	15.34	51.34
PMU	210	PREBEND, INSTALL AND MAKEUP IN CAN	0.00	19.37	19.37
TSC	210	TAP-UP SECONDARY AND CODE	0.00	7.04	7.04
			-----	-----	-----
			102.67	90.25	192.92
*** UG Primary					
UP11	17989	PRI CABLE 15 KV, 1PH, 1/0AL	97.65	18.14	115.79
TMP21 M	2	TERMINAL POLE RISER, 2 PH1/0 SOLID AL	2.43	3.86	6.29
TMP11 M	2	TERMINAL POLE RISER, 1 PH1/0 SOLID AL	1.29	3.26	4.55
CA2T M	2	CUTOUT/ARR 2 EA W/TRIPLE BRKT TERM POLE	2.53	0.60	3.13
CA1T M	2	CUTOUT AND ARR. W "T" BRKT TERM POLE	0.94	0.35	1.29
IP	4	INSULATOR, POST 15KV	0.32	0.11	0.43
KSP7	4	WEDGE STIRRUP 795 MCM AL	0.69	0.06	0.75
CHP	3	TEST HI POT OR PH PRI CBL FOR SETUP	0.00	0.57	0.57
GO	4	GROUND, OVERHEAD	0.74	0.84	1.58
AE1L M	3	ARR. ELBOW ASSY 1 PH LOOP DEADFRONT	2.60	0.58	3.17
B4932	44	BEND, SCH. 40, 90 DEG. 36" RAD 2" PVC	1.07	1.42	2.48
CCP2	88	CONDUIT CAP PLASTIC 2"	0.12	0.57	0.68
WORKLOC	130	Work Location for Framme	0.00	21.79	21.79
			-----	-----	-----
			110.39	52.12	162.51
*** UG Secondary					
UC320	3169	2/0 UG DIRECT BURIAL TRIPLEX CABLE	12.98	3.20	16.17
UC340	6500	4/0 UG D/ B TRIPLEX 4/0-4/0-2/0 AL	36.83	8.78	45.62
UC33	8094	SEC CABLE D/B 3/C 350-350-4/0 AL	71.69	10.94	82.63

DISTRIBUTION CONSTRUCTION COSTS

Progress Energy Florida
LOW DENSITY UNDERGROUND SUBDIVISION - 210 LOTS

DATE: 9/21/2010
PAGE: 5

ITEM	QTY	DESCRIPTION	MATERIAL	LABOR	TOTAL
-----	---	-----	-----	-----	-----
K034W	87	CONNECTOR PED 3 WAY 4/0 WATERPROOF	3.35	1.90	5.25
K040	111	CONNECTOR PEDESTAL 4 WAY 4/0 STR	1.95	2.42	4.37
K065	78	CONNECTOR PEDESTAL 6 WAY 500 MCM	2.96	1.70	4.66
K060W	33	CONNECTOR PEDESTAL 6 COND350 WATERPROOF	2.01	0.72	2.73
PED0	11	PED SEC 12X20	5.58	0.57	6.14
PED7	29	PED SEC FLUSH 9X14	4.39	3.57	7.96
PED4	63	PED SEC 9X14	21.66	3.26	24.91
TSC	138	TAP-UP SECONDARY AND CODE	0.00	4.63	4.63
			-----	-----	-----
			163.39	41.68	205.07
*** UG Transformers					
TA1L25 M	3	XFMR ASSY 120/240V PDMT DF LOOP 25KVA	21.13	2.79	23.91
TA1L50 M	19	XFMR ASSY 120/240V PDMT DF LP 50KVA	184.78	17.64	202.42
K580	36	CONNECTOR XFMR 5/8" STUD 8 WAY 4/0 STR	1.28	0.79	2.07
K585	30	CONNECTOR XFMR 5/8" STUD 8 WAY 500 MCM	1.26	0.65	1.91
TE1	44	TERMNR LDBRK 200 A, LDBRKELBOW	5.45	10.91	16.36
			-----	-----	-----
			213.90	32.78	246.68
*** UG Primary/Secondary Trenching					
TRM	17920	TRENCH W/TRCHNG MACH P/FTINCL BKFILLNG	0.00	138.39	138.39
			-----	-----	-----
			0.00	138.39	138.39
*** UG Service Trenching					
TRH	2100	TRENCH BY HAND PER FT, INC BACKFILLNG	0.00	35.14	35.14
TRM	6300	TRENCH W/TRCHNG MACH P/FTINCL BKFILLNG	0.00	48.65	48.65
			-----	-----	-----
			0.00	83.79	83.79

MATERIAL DOES NOT INCLUDE STORES CHARGES. LABOR ADJUSTED BY COMPANY BENEFITS LOADING AND PRODUCTIVITY.
LABOR = (RATE X 1.684) / 1

DISTRIBUTION CONSTRUCTION COSTS

Progress Energy Florida
TRANSFORMERS ONLY - LOW DENSITY SUB

DATE: 9/21/2010

PAGE: 6

ITEM	QTY	DESCRIPTION	MATERIAL	LABOR	TOTAL
-----	---	-----	-----	-----	-----
*** OH Transformers Only					
T1S25	1	XFMR 120/240 7200/12470Y 1BC 25KVA	3.16	0.21	3.37
T1S50	17	XFMR 120/240 7200/12470Y 1BC 50KVA	85.74	5.45	91.19
T1D75T	7	XFMR 120/240V 7200/12470Y2B/C 75KVAW/TP	50.46	2.24	52.71
			-----	-----	-----
			139.37	7.90	147.27
*** UG Transformers Only					
T1L25	3	XFMR 1PH 120/240V PM DF LOOP, 25KVA	20.31	0.79	21.09
T1L50	19	XFMR 1PH 120/240V PM DF LOOP, 50KVA	179.59	4.98	184.57
			-----	-----	-----
			199.90	5.76	205.66

MATERIAL DOES NOT INCLUDE STORES CHARGES. LABOR ADJUSTED BY COMPANY BENEFITS LOADING AND PRODUCTIVITY.
LABOR = (RATE X 1.684) / 1