



RECEIVED-FPSC

12 JUN 20 PM 2:40

COMMISSION  
CLERK

**John T. Butler**  
Assistant General Counsel – Regulatory  
Florida Power & Light Company  
700 Universe Boulevard  
Juno Beach, FL 33408-0420  
(561) 304-5639  
(561) 691-7135 (Facsimile)  
E-mail: [john.butler@fpl.com](mailto:john.butler@fpl.com)

June 20, 2012

Ms. Ann Cole  
Commission Clerk  
Florida Public Service Commission  
2540 Shumard Oak Blvd.  
Tallahassee, FL 32399-0850

**Re: Docket No. 120001-EI**

Dear Ms. Cole:

As requested by the Commission Staff, Florida Power & Light Company hereby files the original and ten (10) copies of the GPIF Actual Unit Performance Data Schedules covering the month of May 2012. These schedules are being filed at the same time but separately from its monthly filing of the A Schedules.

If there are any questions regarding this transmittal, please contact me at 561-304-5639.

|     |       |
|-----|-------|
| COM | _____ |
| APA | _____ |
| ECR | _____ |
| GCL | _____ |
| RAD | _____ |
| SRC | _____ |
| ADM | _____ |
| OPC | _____ |
| CLK | _____ |

Sincerely,

John T. Butler

Copy to: All parties of record

FPSC-REGISTRY

04057 JUN 20 12

FPSC-COMMISSION CLERK

**CERTIFICATE OF SERVICE**  
**Docket No. 120001-EI**

**I HEREBY CERTIFY** that a true and correct copy of the foregoing has been furnished by hand delivery (\*) or United States mail this 20<sup>th</sup> day of June 2012, to the following:

|   |   |
|---|---|
| <p>Martha F. Barrera, Esq.*<br/>         Division of Legal Services<br/>         Florida Public Service Commission<br/>         2540 Shumard Oak Blvd<br/>         Tallahassee, Florida 32399-0850</p>  | <p>Lisa Bennett, Esq.*<br/>         Division of Legal Services<br/>         Florida Public Service Commission<br/>         2540 Shumard Oak Blvd<br/>         Tallahassee, Florida 32399-0850</p>   |
| <p>James D. Beasley, Esq<br/>         J. Jeffrey Wahlen, Esq.<br/>         Ausley &amp; McMullen<br/>         Attorneys for Tampa Electric<br/>         P.O. Box 391<br/>         Tallahassee, Florida 32302</p>  | <p>John T. Burnett, Esq.<br/>         Dianne M. Triplett, Esq.<br/>         Attorneys for PEF<br/>         P.O. Box 14042<br/>         St. Petersburg, Florida 33733-4042</p>   |
| <p>Samuel Miller, Capt., USAF<br/>         USAF/AFLOA/JACL/ULFSC<br/>         139 Barnes Drive, Suite 1<br/>         Tyndall AFB, FL 32403-5319<br/>         Attorney for the Federal Executive Agencies</p>  | <p>Beth Keating, Esq.<br/>         Gunster Law Firm<br/>         Attorneys for FPUC<br/>         215 So. Monroe St., Suite 601<br/>         Tallahassee, Florida 32301- 1804</p>  |
| <p>Jeffrey A. Stone, Esq.<br/>         Russell A. Badders, Esq.<br/>         Beggs &amp; Lane<br/>         Attorneys for Gulf Power<br/>         P.O. Box 12950<br/>         Pensacola, FL 32591-2950</p>   | <p>James W. Brew, Esq / F. Alvin Taylor, Esq.<br/>         Attorney for White Springs<br/>         Brickfield, Burchette, Ritts &amp; Stone, P.C<br/>         1025 Thomas Jefferson Street, NW<br/>         Eighth Floor, West Tower<br/>         Washington, DC 20007-5201</p> |
| <p>Robert Scheffel Wright, Esq.<br/>         Gardner, Bist, Wiener, et al., P.A.<br/>         Attorneys for Florida Retail Federation<br/>         1300 Thomaswood Drive<br/>         Tallahassee, FL 32308</p>   | <p>Jon C. Moyle, Esq. and Vicki Kaufman, Esq.<br/>         Moyle Law Firm, P.A.<br/>         118 N. Gadsden St.<br/>         Tallahassee, FL 32301<br/>         Counsel for FIPUG</p>   |
| <p>J. R. Kelly, Esq.<br/>         Patricia Christensen, Esq.<br/>         Charles Rehwinkel, Esq.<br/>         Office of Public Counsel<br/>         c/o The Florida Legislature<br/>         111 West Madison Street, Room 812<br/>         Tallahassee, Florida 32399</p> | <p>Michael Barrett<br/>         Division of Economic Regulation<br/>         Florida Public Service Commission<br/>         2540 Shumard Oak Blvd<br/>         Tallahassee, Florida 32399-0850</p>  |

By:   
 John T. Butler  
 Fla. Bar No. 283479

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2012 TO: Dec-2012**

|     |                 | PLANT / UNIT: FORT MYERS 02 |         |         |         |         |     |     |     |     |     |     | PFM 02 |          |
|-----|-----------------|-----------------------------|---------|---------|---------|---------|-----|-----|-----|-----|-----|-----|--------|----------|
|     |                 | Jan                         | Feb     | Mar     | Apr     | May     | Jun | Jul | Aug | Sep | Oct | Nov | Dec    | Ytd      |
| 1.  | EAF (%)         | 94.8                        | 95.7    | 95.1    | 79.9    | 96.4    | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 92.2     |
| 2.  | PH              | 744                         | 696     | 743     | 720     | 744     | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 3647     |
| 3.  | SH              | 744                         | 696     | 743     | 573.17  | 744     | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 3500.17  |
| 4.  | RSH             | 0                           | 0       | 0       | 5.55    | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 5.55     |
| 5.  | UH              | 0                           | 0       | 0       | 141.28  | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 141.28   |
| 6.  | POH             | 0                           | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 7.  | FOH             | 0                           | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 8.  | MOH             | 0                           | 0       | 0       | 141.28  | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 141.28   |
| 9.  | PPOH            | 0                           | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 10. | LR PP (MW)      | 0                           | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 0        |
| 11. | PFOH            | 0                           | 11.15   | 76.52   | 0       | 5.35    | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 93.02    |
| 12. | LR PF (MW)      | 0                           | 221.83  | 221.83  | 0       | 221.83  | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 221.83   |
| 13. | PMOH            | 230.5                       | 168.72  | 142.85  | 12.22   | 199.12  | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 763.4    |
| 14. | LR PM (MW)      | 221.83                      | 221.83  | 221.83  | 362.35  | 221.83  | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 224.11   |
| 15. | NSC             | 1330                        | 1330    | 1330    | 1330    | 1330    | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1330     |
| 16. | OPER BTU (MBTU) | 5383667                     | 5265122 | 5900613 | 4563755 | 6024408 | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 27137565 |
| 17. | NET GEN         | 737780                      | 724985  | 814439  | 619447  | 836281  | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 3732932  |
| 18. | ANOHR (BTU/KWH) | 7297                        | 7262    | 7245    | 7367    | 7204    | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 7270     |
| 19. | NOF (%)         | 74.6                        | 78.3    | 82.4    | 81.3    | 84.5    | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 80.2     |
| 20. | NPC (MW)        | 1426                        | 1426    | 1426    | 1432    | 1432    | 0   | 0   | 0   | 0   | 0   | 0   | 0      | 1428     |

|     |                |  |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0            B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2012 TO: Dec-2012**

|     |                 | PLANT / UNIT: MANATEE UNIT 3 CC 03 |         |         |         |         |     |     |     |     |     | PM3 03 |     |          |
|-----|-----------------|------------------------------------|---------|---------|---------|---------|-----|-----|-----|-----|-----|--------|-----|----------|
|     |                 | Jan                                | Feb     | Mar     | Apr     | May     | Jun | Jul | Aug | Sep | Oct | Nov    | Dec | Ytd      |
| 1.  | EAFF (%)        | 84.5                               | 99.9    | 98.6    | 98      | 98.9    | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 95.9     |
| 2.  | PH              | 744                                | 696     | 743     | 720     | 744     | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 3647     |
| 3.  | SH              | 640.42                             | 696     | 743     | 720     | 744     | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 3543.42  |
| 4.  | RSH             | 8.8                                | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 8.8      |
| 5.  | UH              | 94.78                              | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 94.78    |
| 6.  | POH             | 0                                  | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 7.  | FOH             | 0                                  | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 8.  | MOH             | 94.78                              | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 94.78    |
| 9.  | PPOH            | 0                                  | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 10. | LR PP (MW)      | 0                                  | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 11. | PFOH            | 0                                  | 2.88    | 0       | 0       | 0.83    | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 3.72     |
| 12. | LR PF (MW)      | 0                                  | 244.14  | 0       | 0       | 260.25  | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 247.75   |
| 13. | PMOH            | 62.75                              | 0       | 40.3    | 57.92   | 31.37   | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 182.33   |
| 14. | LR PM (MW)      | 405.01                             | 0       | 260.25  | 260.25  | 260.25  | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 302.13   |
| 15. | NSC             | 1041                               | 1041    | 1041    | 1041    | 1041    | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 1041     |
| 16. | OPER BTU (MBTU) | 3276652                            | 3713441 | 4161810 | 4473362 | 4800753 | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 20226018 |
| 17. | NET GEN         | 471026                             | 538351  | 597868  | 650674  | 664201  | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 2922120  |
| 18. | ANOHR (BTU/KWH) | 6956                               | 6898    | 6961    | 6875    | 6927    | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 6922     |
| 19. | NOF (%)         | 70.7                               | 74.3    | 77.3    | 86.8    | 85.8    | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 79.2     |
| 20. | NPC (MW)        | 1113                               | 1113    | 1113    | 1111    | 1111    | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 1112     |

|     |                |  |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0            B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2012 TO: Dec-2012**

|     |                 | PLANT / UNIT: MARTIN-UNIT 8 08 |         |         |         |         |     | PM8 08 |     |     |     |     |     |          |
|-----|-----------------|--------------------------------|---------|---------|---------|---------|-----|--------|-----|-----|-----|-----|-----|----------|
|     |                 | Jan                            | Feb     | Mar     | Apr     | May     | Jun | Jul    | Aug | Sep | Oct | Nov | Dec | Ytd      |
| 1.  | EAJ (%)         | 94.3                           | 81.4    | 99.6    | 90.6    | 95.2    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 92.4     |
| 2.  | PH              | 744                            | 696     | 743     | 720     | 744     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 3647     |
| 3.  | SH              | 719.88                         | 641.6   | 743     | 720     | 744     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 3588.48  |
| 4.  | RSH             | 0                              | 0       | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 5.  | UH              | 24.12                          | 54.4    | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 78.52    |
| 6.  | POH             | 0                              | 0       | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 7.  | FOH             | 0                              | 0       | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 8.  | MOH             | 24.12                          | 54.4    | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 78.52    |
| 9.  | PPOH            | 0                              | 0       | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 10. | LR PP (MW)      | 0                              | 0       | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 11. | PFOH            | 10                             | 10.2    | 14.55   | 5.83    | 22.5    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 63.08    |
| 12. | LR PF (MW)      | 285.33                         | 264.25  | 264.25  | 264.25  | 264.25  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 264.42   |
| 13. | PMOH            | 61.95                          | 277.07  | 0       | 264.37  | 113.8   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 717.18   |
| 14. | LR PM (MW)      | 272.74                         | 276.53  | 0       | 264.25  | 278.38  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 271.97   |
| 15. | NSC             | 1057                           | 1057    | 1057    | 1057    | 1057    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 1057     |
| 16. | OPER BTU (MBTU) | 3850795                        | 3333478 | 4537377 | 4171466 | 4422835 | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 20115951 |
| 17. | NET GEN         | 517695                         | 471112  | 680772  | 613616  | 640658  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 2903853  |
| 18. | ANOHR (BTU/KWH) | 7052                           | 7076    | 6867    | 6798    | 6904    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 6927     |
| 19. | NOF (%)         | 68                             | 69.5    | 84.1    | 80.6    | 81.5    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 77       |
| 20. | NPC (MW)        | 1119                           | 1119    | 1119    | 1132    | 1132    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 1124     |

|     |                |  |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0            B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2012 TO: Dec-2012**

|     |                 | PLANT / UNIT: TURKEY POINT #5 05 |         |         |         |         |     | TP6 05 |     |     |     |     |     |          |
|-----|-----------------|----------------------------------|---------|---------|---------|---------|-----|--------|-----|-----|-----|-----|-----|----------|
|     |                 | Jan                              | Feb     | Mar     | Apr     | May     | Jun | Jul    | Aug | Sep | Oct | Nov | Dec | Ytd      |
| 1.  | EAFF (%)        | 94.1                             | 95.2    | 99.8    | 97.9    | 95.5    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 96.5     |
| 2.  | PH              | 744                              | 698     | 743     | 720     | 744     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 3647     |
| 3.  | SH              | 744                              | 670.33  | 743     | 720     | 744     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 3621.33  |
| 4.  | RSH             | 0                                | 25.67   | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 25.67    |
| 5.  | UH              | 0                                | 0       | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 6.  | POH             | 0                                | 0       | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 7.  | FOH             | 0                                | 0       | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 8.  | MOH             | 0                                | 0       | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 9.  | PPOH            | 0                                | 0       | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 10. | LR PP (MW)      | 0                                | 0       | 0       | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 11. | PFOH            | 0.08                             | 0       | 6.8     | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 6.88     |
| 12. | LR PF (MW)      | 259                              | 0       | 259     | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 259      |
| 13. | PMOH            | 171.23                           | 48.25   | 0       | 60.52   | 134.73  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 414.73   |
| 14. | LR PM (MW)      | 265.93                           | 724.48  | 0       | 259     | 259     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 316.02   |
| 15. | NSC             | 1036                             | 1036    | 1036    | 1036    | 1036    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 1036     |
| 16. | OPER BTU (MBTU) | 3684389                          | 3630206 | 4341789 | 4488183 | 4434342 | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 20578910 |
| 17. | NET GEN         | 515399                           | 507136  | 609936  | 637939  | 624259  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 2894669  |
| 18. | ANOHR (BTU/KWH) | 7149                             | 7158    | 7118    | 7035    | 7103    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 7109     |
| 19. | NOF (%)         | 66.9                             | 73      | 79.2    | 85.5    | 81      | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 77.2     |
| 20. | NPC (MW)        | 1113                             | 1113    | 1113    | 1148    | 1148    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 1127     |

|     |                |  |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0      B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

ISSUED BY: FLORIDA POWER & LIGHT CO.

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2012 TO: Dec-2012**

|     |                 | PLANT / UNIT: SCHERER 04 |         |        |     |         |     | PSG 04 |     |     |     |     |     |          |
|-----|-----------------|--------------------------|---------|--------|-----|---------|-----|--------|-----|-----|-----|-----|-----|----------|
|     |                 | Jan                      | Feb     | Mar    | Apr | May     | Jun | Jul    | Aug | Sep | Oct | Nov | Dec | Ytd      |
| 1.  | EAF (%)         | 100                      | 100     | 4.7    | 0   | 70.2    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 64.8     |
| 2.  | PH              | 744                      | 696     | 743    | 720 | 744     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 3647     |
| 3.  | SH              | 744                      | 696     | 34.7   | 0   | 522.73  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 1997.43  |
| 4.  | RSH             | 0                        | 0       | 0      | 0   | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 5.  | UH              | 0                        | 0       | 708.3  | 720 | 221.27  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 1649.67  |
| 6.  | POH             | 0                        | 0       | 708.3  | 720 | 221.27  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 1649.67  |
| 7.  | FOH             | 0                        | 0       | 0      | 0   | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 8.  | MOH             | 0                        | 0       | 0      | 0   | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 9.  | PPOH            | 0                        | 0       | 0      | 0   | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 10. | LR PP (MW)      | 0                        | 0       | 0      | 0   | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 11. | PFOH            | 0                        | 0       | 0      | 0   | 0.37    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0.37     |
| 12. | LR PF (MW)      | 0                        | 0       | 0      | 0   | 843.32  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 843.32   |
| 13. | PMOH            | 0                        | 0       | 0      | 0   | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 14. | LR PM (MW)      | 0                        | 0       | 0      | 0   | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 15. | NSC             | 881                      | 881     | 881    | 881 | 881     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 881      |
| 16. | OPER BTU (MBTU) | 4099616                  | 3769377 | 253638 | 0   | 3374854 | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 11497484 |
| 17. | NET GEN         | 395936                   | 388960  | 28291  | 0   | 324010  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 1117197  |
| 18. | ANOHR (BTU/KWH) | 10354                    | 10216   | 8965   | 0   | 10416   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 10291    |
| 19. | NOF (%)         | 60.4                     | 60.2    | 92.5   | 0   | 70.4    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 63.5     |
| 20. | NPC (MW)        | 888                      | 888     | 888    | 880 | 880     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 885      |

|     |                |  |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0            B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2012 TO: Dec-2012**

|     |                 | PLANT / UNIT: ST LUCIE 01 |     |     |        |         |     | PSL 01 |     |     |     |     |     |         |
|-----|-----------------|---------------------------|-----|-----|--------|---------|-----|--------|-----|-----|-----|-----|-----|---------|
|     |                 | Jan                       | Feb | Mar | Apr    | May     | Jun | Jul    | Aug | Sep | Oct | Nov | Dec | Ytd     |
| 1.  | EAF (%)         | 0                         | 0   | 0   | 8      | 53.3    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 12.4    |
| 2.  | PH              | 744                       | 698 | 743 | 720    | 744     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 3647    |
| 3.  | SH              | 0                         | 0   | 0   | 205.65 | 744     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 949.65  |
| 4.  | RSH             | 0                         | 0   | 0   | 0      | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0       |
| 5.  | UH              | 744                       | 698 | 743 | 514.35 | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 2697.35 |
| 6.  | POH             | 744                       | 698 | 743 | 494.97 | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 2677.97 |
| 7.  | FOH             | 0                         | 0   | 0   | 19.38  | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 19.38   |
| 8.  | MOH             | 0                         | 0   | 0   | 0      | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0       |
| 9.  | PPOH            | 0                         | 0   | 0   | 205.65 | 644     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 849.65  |
| 10. | LR PP (MW)      | 0                         | 0   | 0   | 604.45 | 453.06  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 489.71  |
| 11. | PFOH            | 0                         | 0   | 0   | 0      | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0       |
| 12. | LR PF (MW)      | 0                         | 0   | 0   | 0      | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0       |
| 13. | PMOH            | 0                         | 0   | 0   | 0      | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0       |
| 14. | LR PM (MW)      | 0                         | 0   | 0   | 0      | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0       |
| 15. | NSC             | 839                       | 839 | 839 | 839    | 839     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 839     |
| 16. | OPER BTU (MBTU) | 0                         | 0   | 0   | 556710 | 3648029 | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 4204739 |
| 17. | NET GEN         | 0                         | 0   | 0   | 31158  | 289487  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 320645  |
| 18. | ANOHR (BTU/KWH) | 0                         | 0   | 0   | 17867  | 12602   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 13113   |
| 19. | NOF (%)         | 0                         | 0   | 0   | 18.1   | 46.4    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 40.2    |
| 20. | NPC (MW)        | 839                       | 839 | 839 | 839    | 839     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 839     |

|     |                |  |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0      B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2012 TO: Dec-2012**

|     |                 | PLANT / UNIT: ST LUCIE 02 |        |        |         |         |     | PSL 02 |     |     |     |     |     |          |
|-----|-----------------|---------------------------|--------|--------|---------|---------|-----|--------|-----|-----|-----|-----|-----|----------|
|     |                 | Jan                       | Feb    | Mar    | Apr     | May     | Jun | Jul    | Aug | Sep | Oct | Nov | Dec | Ytd      |
| 1.  | EAF (%)         | 99.8                      | 100    | 100    | 99.9    | 92.7    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 98.4     |
| 2.  | PH              | 744                       | 696    | 743    | 720     | 744     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 3647     |
| 3.  | SH              | 744                       | 696    | 743    | 720     | 696.3   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 3599.3   |
| 4.  | RSH             | 0                         | 0      | 0      | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 5.  | UH              | 0                         | 0      | 0      | 0       | 47.7    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 47.7     |
| 6.  | POH             | 0                         | 0      | 0      | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 7.  | FOH             | 0                         | 0      | 0      | 0       | 47.7    | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 47.7     |
| 8.  | MOH             | 0                         | 0      | 0      | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 9.  | PPOH            | 0                         | 0      | 0      | 7.35    | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 7.35     |
| 10. | LR PP (MW)      | 0                         | 0      | 0      | 46.8    | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 46.8     |
| 11. | PFOH            | 32.75                     | 0      | 0      | 0       | 16.05   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 48.8     |
| 12. | LR PF (MW)      | 68.66                     | 0      | 0      | 0       | 358.6   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 164.02   |
| 13. | PMOH            | 0                         | 0      | 0      | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 14. | LR PM (MW)      | 0                         | 0      | 0      | 0       | 0       | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0        |
| 15. | NSC             | 839                       | 839    | 839    | 839     | 839     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 839      |
| 16. | OPER BTU (MBTU) | 0                         | 0      | 0      | 6619391 | 6339554 | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 12958944 |
| 17. | NET GEN         | 663824                    | 622813 | 661286 | 639713  | 603729  | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 3191365  |
| 18. | ANOHR (BTU/KWH) | 0                         | 0      | 0      | 10347   | 10501   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 4061     |
| 19. | NOF (%)         | 106.3                     | 106.7  | 106.1  | 105.9   | 103.3   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 105.7    |
| 20. | NPC (MW)        | 745                       | 745    | 745    | 745     | 745     | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 745      |

|     |                |  |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0                  B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2012 TO: Dec-2012**

|     |                 | PLANT / UNIT: TURKEY POINT 03 |         |     |     |        |     |     |     |     |     | PTN 03 |     |          |
|-----|-----------------|-------------------------------|---------|-----|-----|--------|-----|-----|-----|-----|-----|--------|-----|----------|
|     |                 | Jan                           | Feb     | Mar | Apr | May    | Jun | Jul | Aug | Sep | Oct | Nov    | Dec | Ytd      |
| 1.  | EAF (%)         | 100                           | 80.6    | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 35.8     |
| 2.  | PH              | 744                           | 696     | 743 | 720 | 744    | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 3647     |
| 3.  | SH              | 744                           | 600.05  | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 1344.05  |
| 4.  | RSH             | 0                             | 0       | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 5.  | UH              | 0                             | 95.95   | 743 | 720 | 744    | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 2302.95  |
| 6.  | POH             | 0                             | 95.95   | 743 | 720 | 744    | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 2302.95  |
| 7.  | FOH             | 0                             | 0       | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 8.  | MOH             | 0                             | 0       | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 9.  | PPOH            | 0                             | 346.03  | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 346.03   |
| 10. | LR PP (MW)      | 0                             | 78.17   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 78.17    |
| 11. | PFOH            | 0                             | 0       | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 12. | LR PF (MW)      | 0                             | 0       | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 13. | PMOH            | 0                             | 0       | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 14. | LR PM (MW)      | 0                             | 0       | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 15. | NSC             | 693                           | 693     | 693 | 693 | 693    | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 693      |
| 16. | OPER BTU (MBTU) | 5825442                       | 4336931 | 0   | 0   | 188398 | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 10350771 |
| 17. | NET GEN         | 538558                        | 393047  | 0   | -39 | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 931567   |
| 18. | ANOHR (BTU/KWH) | 10817                         | 11034   | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 11111    |
| 19. | NOF (%)         | 104.5                         | 94.5    | 0   | 0   | 0      | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 100      |
| 20. | NPC (MW)        | 693                           | 693     | 693 | 693 | 693    | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 693      |

|     |                |   |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | $\text{ANOHR} = A + B \text{ (N.O.F.)}$ $A = 0 \quad B = 0$ |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|---|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2012 TO: Dec-2012**

|     |                 | PLANT / UNIT: TURKEY POINT 04 |         |         |         |         |     |     |     |     |     | PTN 04 |     |          |
|-----|-----------------|-------------------------------|---------|---------|---------|---------|-----|-----|-----|-----|-----|--------|-----|----------|
|     |                 | Jan                           | Feb     | Mar     | Apr     | May     | Jun | Jul | Aug | Sep | Oct | Nov    | Dec | Ytd      |
| 1.  | EAFF (%)        | 100                           | 100     | 100     | 100     | 97.9    | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 99.8     |
| 2.  | PH              | 744                           | 696     | 743     | 720     | 744     | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 3647     |
| 3.  | SH              | 744                           | 696     | 743     | 720     | 744     | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 3647     |
| 4.  | RSH             | 0                             | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 5.  | UH              | 0                             | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 6.  | POH             | 0                             | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 7.  | FOH             | 0                             | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 8.  | MOH             | 0                             | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 9.  | PPOH            | 0                             | 0       | 0       | 0       | 31.98   | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 31.98    |
| 10. | LR PP (MW)      | 0                             | 0       | 0       | 0       | 337.04  | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 337.04   |
| 11. | PFOH            | 0                             | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 12. | LR PF (MW)      | 0                             | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 13. | PMOH            | 0                             | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 14. | LR PM (MW)      | 0                             | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 0        |
| 15. | NSC             | 693                           | 693     | 693     | 693     | 693     | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 693      |
| 16. | OPER BTU (MBTU) | 5831584                       | 5456032 | 5822689 | 5644147 | 5716171 | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 28470624 |
| 17. | NET GEN         | 538698                        | 501421  | 534308  | 516620  | 515783  | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 2606829  |
| 18. | ANOHR (BTU/KWH) | 10825                         | 10881   | 10898   | 10925   | 11083   | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 10922    |
| 19. | NOF (%)         | 104.5                         | 104     | 103.8   | 103.5   | 100     | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 103.1    |
| 20. | NPC (MW)        | 693                           | 693     | 693     | 693     | 693     | 0   | 0   | 0   | 0   | 0   | 0      | 0   | 693      |

|     |                |  |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|
| 21. | ANOHR EQUATION | ANOHR = A + B (N.O.F.)<br>A = 0      B = 0 |  |  |  |  |  |  |  |  |  |  |  |
|-----|----------------|--|--|--|--|--|--|--|--|--|--|--|--|

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**FROM: Jan-2012 TO: Dec-2012**

**PLANT / UNIT: SANFORD 4 & 5 CC 04 PSR 04**

|                     | Jan  | Feb     | Mar     | Apr     | May     | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Ytd      |
|---------------------|--|---------|---------|---------|---------|-----|-----|-----|-----|-----|-----|-----|----------|
| 1. EAF (%)          | 93.4                                       | 94.8    | 99.2    | 96.7    | 99.1    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 96.7     |
| 2. PH               | 744  | 698     | 743     | 720     | 744     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 3647     |
| 3. SH               | 744  | 698     | 743     | 720     | 744     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 3647     |
| 4. RSH              | 0  | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 5. UH               | 0  | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 6. POH              | 0  | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 7. FOH              | 0  | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 8. MOH              | 0  | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 9. PPOH             | 0  | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 10. LR PP (MW)      | 0  | 0       | 0       | 0       | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0        |
| 11. PFOH            | 11.2                                       | 0.92    | 1.02    | 2.85    | 27.8    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 43.78    |
| 12. LR PF (MW)      | 223.42                                     | 224.25  | 224.25  | 224.25  | 221.03  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 221.99   |
| 13. PMOH            | 182.95                                     | 78.05   | 22      | 73.58   | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 356.58   |
| 14. LR PM (MW)      | 227.89                                     | 411.82  | 224.25  | 278.14  | 0       | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 278.29   |
| 15. NSC             | 897  | 897     | 897     | 897     | 897     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 897      |
| 16. OPER BTU (MBTU) | 3166929                                    | 3014230 | 3970887 | 3874352 | 4128259 | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 18154657 |
| 17. NET GEN         | 420755                                     | 395935  | 542613  | 533183  | 566774  | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 2459260  |
| 18. ANOHR (BTU/KWH) | 7527                                       | 7613    | 7318    | 7266    | 7284    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 7382     |
| 19. NOF (%)         | 63   | 63.4    | 81.4    | 82.6    | 84.9    | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 75.2     |
| 20. NPC (MW)        | 955  | 955     | 955     | 958     | 958     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 956      |
| 21. ANOHR EQUATION  | ANOHR = A + B (N.O.F.)<br>A = 0      B = 0 |         |         |         |         |     |     |     |     |     |     |     |          |

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

ISSUED BY: FLORIDA POWER & LIGHT CO.

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 From: Jan-2012 To: Dec-2012

PLANT / UNIT: FORT MYERS 02 PFM 02

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION   |
|------------|----------------|-------|---------------|---|
| 01/05/2012 | FMO            | 14.4  | 143           | 2F CT MOF   |
| 01/05/2012 | PMO            | 14.4  | 69.31         | Impact loss due to curtailment on 2F                        |
| 01/05/2012 | PMO            | 14.4  | 9.52          | Impact loss due to curtailment on 2F                        |
| 01/10/2012 | FMO            | 115.3 | 143           | 2CCT generator H2 seal replacement                          |
| 01/10/2012 | PMO            | 115.3 | 69.31         | Impact loss due to curtailment on 2C                        |
| 01/10/2012 | PMO            | 115.3 | 9.52          | Impact loss due to curtailment on 2C                        |
| 01/24/2012 | FMO            | 23.4  | 143           | 2A CT MOF   |
| 01/24/2012 | PMO            | 23.4  | 9.52          | Impact loss due to curtailment on 2A                        |
| 01/24/2012 | PMO            | 23.4  | 69.31         | Impact loss due to curtailment on 2A                        |
| 01/25/2012 | FMO            | 63.1  | 143           | 2B CT MOF   |
| 01/25/2012 | PMO            | 63.1  | 69.31         | Impact loss due to curtailment on 2B                        |
| 01/25/2012 | PMO            | 63.1  | 9.52          | Impact loss due to curtailment on 2B                        |
| 01/30/2012 | FMO            | 14.2  | 143           | Gas flange leak   |
| 01/30/2012 | PMO            | 14.2  | 69.31         | Impact loss due to curtailment on 2C                        |
| 01/30/2012 | PMO            | 14.2  | 9.52          | Impact loss due to curtailment on 2C                        |
| 02/05/2012 | FMO            | 19.4  | 143           | 2E CT MOF Replace Exhaust Frame Blower                      |
| 02/05/2012 | PMO            | 19.4  | 69.31         | Impact loss due to curtailment on 2E                        |
| 02/05/2012 | PMO            | 19.4  | 9.52          | Impact loss due to curtailment on 2E                        |
| 02/08/2012 | FMO            | 61.3  | 143           | 2D CT MOF Compressor inspection                             |
| 02/08/2012 | PMO            | 61.3  | 69.31         | Impact loss due to curtailment on 2D                        |
| 02/08/2012 | PMO            | 61.3  | 9.52          | Impact loss due to curtailment on 2D                        |
| 02/14/2012 | FMO            | 88.0  | 143           | 2F CT MOF Mainsteam Isolation valve seal ring repair outage |
| 02/14/2012 | PMO            | 88.0  | 9.52          | Impact loss due to curtailment on 2F                        |
| 02/14/2012 | PMO            | 88.0  | 69.31         | Impact loss due to curtailment on 2F                        |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 From: Jan-2012 To: Dec-2012  
 PLANT / UNIT: FORT MYERS 02 PFM 02

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION   |
|------------|----------------|-------|---------------|---|
| 02/22/2012 | FFO            | 11.2  | 143           | 2F Exciter Failure                                      |
| 02/22/2012 | PFO            | 11.2  | 69.31         | Impact loss due to curtailment on 2F                    |
| 02/22/2012 | PFO            | 11.2  | 9.52          | Impact loss due to curtailment on 2F                    |
| 03/05/2012 | FMO            | 17.2  | 143           | 2D CT BORESCOPE INSPECTION                              |
| 03/05/2012 | PMO            | 17.2  | 9.52          | Impact loss due to curtailment on 2D                    |
| 03/05/2012 | PMO            | 17.2  | 69.31         | Impact loss due to curtailment on 2D                    |
| 03/06/2012 | FMO            | 42.7  | 143           | 2E CT HYD oil pump                                      |
| 03/06/2012 | PMO            | 42.7  | 9.52          | Impact loss due to curtailment on 2E                    |
| 03/06/2012 | PMO            | 42.7  | 69.31         | Impact loss due to curtailment on 2E                    |
| 03/16/2012 | FMO            | 14.1  | 143           | Repair Exhaust Frame Blower                             |
| 03/16/2012 | PMO            | 14.1  | 69.31         | Impact loss due to curtailment on 2C                    |
| 03/16/2012 | PMO            | 14.1  | 9.52          | Impact loss due to curtailment on 2C                    |
| 03/25/2012 | FMO            | 68.9  | 143           | 2D CT R-2 inspection/ HRSG tube leak maintenance outage |
| 03/25/2012 | PMO            | 68.9  | 69.31         | Impact loss due to curtailment on 2D                    |
| 03/25/2012 | PMO            | 68.9  | 9.52          | Impact loss due to curtailment on 2D                    |
| 03/28/2012 | FFO            | 76.5  | 143           | 2ACT Equalizing Line ASGJ-BV-27ED Failure               |
| 03/28/2012 | PFO            | 76.5  | 69.31         | Impact loss due to curtailment on 2A                    |
| 03/28/2012 | PFO            | 76.5  | 9.52          | Impact loss due to curtailment on 2A                    |
| 04/13/2012 | PMO            | 6.0   | 9.52          | Impact loss due to curtailment on 2B                    |
| 04/13/2012 | PMO            | 7.8   | 69.31         | Impact loss due to curtailment on 2B                    |
| 04/13/2012 | FMO            | 149.1 | 143           | 2BCT-ST2 Balance shot outage                            |
| 04/13/2012 | PMO            | 4.4   | 9.52          | Impact loss due to curtailment on 2E                    |
| 04/13/2012 | PMO            | 6.2   | 69.31         | Impact loss due to curtailment on 2E                    |
| 04/13/2012 | FMO            | 147.5 | 143           | 2ECT-ST2 balance shot outage                            |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 From: Jan-2012 To: Dec-2012

PLANT / UNIT: FORT MYERS 02 PFM 02

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION                           |
|------------|----------------|-------|---------------|---------------------------------------|
| 04/13/2012 | FMO            | 143.1 | 57            | ST1 - ST2 Balance shot Outage         |
| 04/14/2012 | FMO            | 141.3 | 415           | ST2 - ST2 Balance Shot Outage         |
| 04/14/2012 | FMO            | 141.3 | 143           | 2CCT - ST2 Balance Shot Outage        |
| 04/14/2012 | FMO            | 141.3 | 143           | 2ACT-ST2 Balance Shot Outage          |
| 04/14/2012 | FMO            | 142.3 | 143           | 2FCT- ST2 Balance Shot Outage         |
| 04/14/2012 | FMO            | 142.3 | 143           | 2DCT- ST2 Balance Shot Outage         |
| 04/19/2012 | PMO            | 1.0   | 69.31         | Impact loss due to curtailment on 2F  |
| 04/19/2012 | PMO            | 1.0   | 69.31         | Impact loss due to curtailment on 2D  |
| 04/19/2012 | PMO            | 1.0   | 9.52          | Impact loss due to curtailment on 2F  |
| 04/19/2012 | PMO            | 1.0   | 9.52          | Impact loss due to curtailment on 2D  |
| 04/25/2012 | FMO            | 3.4   | 57            | ST1 - ST2 Steam Seal Regulator repair |
| 04/25/2012 | FMO            | 1.5   | 415           | ST2 - Steam Seal Regulator Repair     |
| 05/06/2012 | FFO            | 5.4   | 143           | 2F CT Drum Level Trip                 |
| 05/06/2012 | PFO            | 5.4   | 69.31         | Impact loss due to curtailment on 2F  |
| 05/06/2012 | PFO            | 5.4   | 9.52          | Impact loss due to curtailment on 2F  |
| 05/10/2012 | FMO            | 72.4  | 143           | 2F CT Outage                          |
| 05/10/2012 | PMO            | 72.4  | 69.31         | Impact loss due to curtailment on 2F  |
| 05/10/2012 | PMO            | 72.4  | 9.52          | Impact loss due to curtailment on 2F  |
| 05/18/2012 | FMO            | 54.8  | 143           | 2C CT maintenance outage              |
| 05/18/2012 | PMO            | 54.8  | 69.31         | Impact loss due to curtailment on 2C  |
| 05/18/2012 | PMO            | 54.8  | 9.52          | Impact loss due to curtailment on 2C  |
| 05/28/2012 | FMO            | 72.0  | 143           | 2FCT Tube leak repair                 |
| 05/28/2012 | PMO            | 72.0  | 69.31         | Impact loss due to curtailment on 2F  |
| 05/28/2012 | PMO            | 72.0  | 9.52          | Impact loss due to curtailment on 2F  |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 From: Jan-2012 To: Dec-2012  
 PLANT / UNIT: SCHERER 04 PSG 04

| DATE       | OUTAGE TYPE(1) | HOURS  | (MW) AFFECTED | DESCRIPTION                                   |
|------------|----------------|--------|---------------|---|
| 03/02/2012 | FPO            | 1630.6 | 881           | Scherer 4 Boiler Outage                       |
| 05/11/2012 | FPO            | 19.0   | 881           | Temporary Stop Valve Steam Strainers Cleaning |
| 05/14/2012 | PFO            | 0.4    | 851           | Configuration of Master Fuel Trip (MFT) Input |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2012

To: Dec-2012

PLANT / UNIT: ST LUCIE

01

PSL 01

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION  |
|------------|----------------|-------|---------------|--|
| 01/01/2012 | FPO            | 744.0 | 839           | U1 PEL SL1-24 Refueling/Uprate Outage 010112             |
| 02/01/2012 | FPO            | 696.0 | 839           | U1 PEL SL1-24 Refueling/Uprate Outage 020112             |
| 03/01/2012 | FPO            | 743.0 | 839           | U1 PEL SL1-24 Refueling/Uprate Outage 030112             |
| 04/01/2012 | FPO            | 495.0 | 839           | U1 PEL SL1-24 Refueling/Uprate Outage 040112             |
| 04/21/2012 | PPO            | 0.1   | 699.2         | U1 PEL SL1-24 Breaker Close/Power Ascension Part 1 04211 |
| 04/21/2012 | FFO            | 19.4  | 839           | U1 UEL Main Generator Breaker Failure 042112             |
| 04/22/2012 | PPO            | 205.5 | 604.4         | U1 PEL SL1-24 Power Ascension part 2 042212              |
| 05/01/2012 | PPO            | 432.5 | 585.52        | U1 PEL SL1-24 Power Ascension May 050112                 |
| 05/19/2012 | PPO            | 211.5 | 223.15        | U1 PEL SL1-24 Power Ascension Extension 051912           |

(1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:

ISSUED BY: FLORIDA POWER &amp; LIGHT CO.

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**From: Jan-2012 To: Dec-2012**

**PLANT / UNIT: ST LUCIE 02 PSL 02**

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION  |
|------------|----------------|-------|---------------|--|
| 01/01/2012 | PFO            | 32.8  | 68.66         | U2 UEL 2B2 Circ Water Pump Repair 010112                 |
| 04/02/2012 | PPO            | 7.4   | 46.8          | U2 PEL Turbine Valve Test 040212                         |
| 05/11/2012 | FFO            | 47.7  | 839           | U2 UEL Feedwater Control Valve FCV-9011 Forced Outage 05 |
| 05/13/2012 | PFO            | 16.1  | 358.6         | U2 UEL Feedwater Control Valve FCV-9011 Uppower 051312   |

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2012

To: Dec-2012

PLANT / UNIT: TURKEY POINT

03

PTN 03

| DATE       | OUTAGE TYPE(1) | HOURS  | (MW) AFFECTED | DESCRIPTION                      |
|------------|----------------|--------|---------------|----------------------------------|
| 02/11/2012 | PPO            | 309.1  | 49            | Unit 3 Cycle 26 T-Ave coastdown  |
| 02/24/2012 | PPO            | 37.0   | 322           | Unit 3 Cycle 26 Downpower        |
| 02/26/2012 | FPO            | 2303.0 | 693           | Unit 3 Cycle 26 Refueling outage |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

ISSUED BY: FLORIDA POWER &amp; LIGHT CO.

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**From: Jan-2012 To: Dec-2012**  
**PLANT / UNIT: TURKEY POINT 04 PTN 04**

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION  |
|------------|----------------|-------|---------------|--|
| 05/18/2012 | PPO            | 32.0  | 337           | Unit 4 planned power reduction for Turbine Valve Testing |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 From: Jan-2012 To: Dec-2012  
 PLANT / UNIT: TURKEY POINT #6 05 TP5 05

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION                               |
|------------|----------------|-------|---------------|---|
| 01/04/2012 | FFO            | 0.1   | 145.47        | 5D Liquid Fuel Swap Trip                  |
| 01/04/2012 | PFO            | 0.1   | 113.53        | Impact loss due to curtailment on 5D      |
| 01/07/2012 | FMO            | 20.8  | 145.47        | 5B BFP Recirc Regulator Repair            |
| 01/07/2012 | PMO            | 20.8  | 113.53        | Impact loss due to curtailment on 5B      |
| 01/08/2012 | FMO            | 79.5  | 145.47        | 5A 1st Quarter Rainbow Inspection         |
| 01/08/2012 | PMO            | 79.5  | 113.53        | Impact loss due to curtailment on 5A      |
| 01/12/2012 | FMO            | 75.6  | 145.47        | 5C 1st Quarter Rainbow Inspection         |
| 01/12/2012 | PMO            | 75.6  | 113.53        | Impact loss due to curtailment on 5C      |
| 02/17/2012 | FMO            | 27.9  | 145.47        | 5B HP Manual Iso SNOW                     |
| 02/17/2012 | PMO            | 27.9  | 113.53        | Impact loss due to curtailment on 5B      |
| 02/17/2012 | FMO            | 29.0  | 145.47        | 5C HP Manual Iso SNOW                     |
| 02/17/2012 | PMO            | 29.0  | 113.53        | Impact loss due to curtailment on 5C      |
| 02/18/2012 | FMO            | 32.1  | 145.47        | 5D HP Manual Isolation SNOW               |
| 02/18/2012 | PMO            | 32.1  | 113.53        | Impact loss due to curtailment on 5D      |
| 02/18/2012 | FMO            | 34.0  | 145.47        | 5A HP Manual Iso SNOW                     |
| 02/18/2012 | PMO            | 34.0  | 113.53        | Impact loss due to curtailment on 5A      |
| 02/23/2012 | FMO            | 12.0  | 145.47        | 5B Liquid Fuel Flange O-ring Replacement  |
| 02/23/2012 | PMO            | 12.0  | 113.53        | Impact loss due to curtailment on 5B      |
| 03/01/2012 | FFO            | 6.8   | 145.47        | 5B BFP Lead Box Failure                   |
| 03/01/2012 | PFO            | 6.8   | 113.53        | Impact loss due to curtailment on 5B      |
| 04/23/2012 | FMO            | 30.6  | 145.47        | 5A SNOW - Replace corroded drain lines    |
| 04/23/2012 | PMO            | 30.6  | 113.53        | Impact loss due to curtailment on 5A      |
| 04/27/2012 | FMO            | 30.0  | 145.47        | 5B SNOW - Corroded Drain line replacement |
| 04/27/2012 | PMO            | 30.0  | 113.53        | Impact loss due to curtailment on 5B      |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

**ACTUAL PERFORMANCE DATA**  
**COMPANY: FLORIDA POWER AND LIGHT**  
**From: Jan-2012 To: Dec-2012**

**PLANT / UNIT: TURKEY POINT #6 05 TP5 05**

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION                                |
|------------|----------------|-------|---------------|--|
| 05/21/2012 | FMO            | 85.7  | 145.47        | 5D Maintenance Outage - CT GCV replacement |
| 05/21/2012 | PMO            | 85.7  | 113.53        | Impact loss due to curtailment on 5D       |
| 05/29/2012 | FMO            | 49.0  | 145.47        | 5C - OLWW and Boroscope inspection         |
| 05/29/2012 | PMO            | 49.0  | 113.53        | Impact loss due to curtailment on 5C       |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 From: Jan-2012 To: Dec-2012  
 PLANT / UNIT: MANATEE UNIT 3 CC 03 PM3 03

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION                          |
|------------|----------------|-------|---------------|--------------------------------------|
| 01/06/2012 | FMO            | 10.0  | 151.37        | ignitor replacement                  |
| 01/06/2012 | PMO            | 10.0  | 92.77         | Impact loss due to curtailment on 3A |
| 01/15/2012 | PMO            | 26.1  | 92.77         | Impact loss due to curtailment on 3C |
| 01/15/2012 | FMO            | 130.6 | 151.37        | valve repair                         |
| 01/16/2012 | FMO            | 109.1 | 151.37        | Valve Repair                         |
| 01/16/2012 | PMO            | 0.5   | 92.77         | Impact loss due to curtailment on 3D |
| 01/16/2012 | PMO            | 0.1   | 92.77         | Impact loss due to curtailment on 3B |
| 01/16/2012 | FMO            | 103.7 | 151.37        | Valve Repair                         |
| 01/16/2012 | FMO            | 108.7 | 435.52        | Valve repair                         |
| 01/17/2012 | FMO            | 102.7 | 151.37        | Valve Repair                         |
| 01/21/2012 | PMO            | 2.8   | 92.77         | Impact loss due to curtailment on 3A |
| 02/10/2012 | FFO            | 2.9   | 151.37        | PMT3C CT Runback                     |
| 02/10/2012 | PFO            | 2.9   | 92.77         | Impact loss due to curtailment on 3C |
| 03/16/2012 | FMO            | 40.3  | 151.37        | COMBUSTOR INSPECTION                 |
| 03/16/2012 | PMO            | 40.3  | 108.88        | Impact loss due to curtailment on 3B |
| 04/06/2012 | FMO            | 28.5  | 151.37        | Off line waterwash                   |
| 04/06/2012 | PMO            | 28.5  | 108.88        | Impact loss due to curtailment on 3D |
| 04/13/2012 | FMO            | 29.4  | 151.37        | OFFLINE WATER WASH PMT 3A            |
| 04/13/2012 | PMO            | 29.4  | 108.88        | Impact loss due to curtailment on 3A |
| 05/14/2012 | FMO            | 31.4  | 151.37        | 89ND switch replacement              |
| 05/14/2012 | PMO            | 31.4  | 108.88        | Impact loss due to curtailment on 3C |
| 05/15/2012 | FFO            | 0.8   | 151.37        | PMT 3D Trip                          |
| 05/15/2012 | PFO            | 0.8   | 108.88        | Impact loss due to curtailment on 3D |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2012

To: Dec-2012

PLANT / UNIT: MARTIN-UNIT 8 08

PM8 08

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION   |
|------------|----------------|-------|---------------|---|
| 01/05/2012 | FMO            | 47.0  | 152.85        | 8A Event MOF (LO HX leak)                               |
| 01/05/2012 | PMO            | 47.0  | 111.4         | Impact loss due to curtailment on 8A                    |
| 01/18/2012 | FFO            | 1.5   | 445.6         | UNIT 8 STEAM TURBINE LOW VACUUM TRIP                    |
| 01/18/2012 | PFO            | 0.2   | 112.85        | 8D Runback due to high Reheat Temperatures              |
| 01/19/2012 | FFO            | 6.3   | 152.85        | 8C CT HIGH EXHAUST SPREAD TRIP                          |
| 01/19/2012 | PFO            | 6.3   | 111.4         | Impact loss due to curtailment on 8C                    |
| 01/23/2012 | PFO            | 0.3   | 95.85         | 8B CTG Runback to FSNL due to Exhaust Frame Blower Trou |
| 01/30/2012 | PFO            | 1.9   | 45.6          | Impact loss due to curtailment on 8D                    |
| 01/30/2012 | PFO            | 1.9   | 101.85        | 8D EFOR Main Steam Stop Check Stuck                     |
| 01/30/2012 | FMO            | 309.0 | 152.85        | 8D EVENT MOF FOR MS STOP CHECK VLV                      |
| 01/30/2012 | PMO            | 223.7 | 111.4         | Impact loss due to curtailment on 8D                    |
| 01/30/2012 | FMO            | 85.3  | 445.6         | 8ST Event MOF for main steam stop check repairs         |
| 01/30/2012 | FMO            | 79.7  | 152.85        | 8C Event MOF Main Steam Stop Check Sticking             |
| 01/30/2012 | FMO            | 86.7  | 152.85        | 8B Event MOF Main steam stop check valve sticking       |
| 01/30/2012 | FMO            | 78.5  | 152.85        | 8A Event MOF Main steam stop check stuck                |
| 02/03/2012 | PMO            | 2.0   | 111.4         | Impact loss due to curtailment on 8B                    |
| 02/10/2012 | FFO            | 3.9   | 152.85        | 8A CTG Exhaust Thermocouple Trouble                     |
| 02/10/2012 | PFO            | 3.9   | 111.4         | Impact loss due to curtailment on 8A                    |
| 02/16/2012 | FFO            | 6.3   | 152.85        | 8B EXHAUST SPREAD TRIP                                  |
| 02/16/2012 | PFO            | 6.3   | 111.4         | Impact loss due to curtailment on 8B                    |
| 02/23/2012 | FMO            | 61.5  | 152.85        | 8A EVENT MOF (Repair Solar isolation valve)             |
| 02/23/2012 | PMO            | 61.5  | 111.4         | Impact loss due to curtailment on 8A                    |
| 03/19/2012 | FFO            | 3.1   | 152.85        | 8C CBV soleniod failure and hyd switch failure          |
| 03/19/2012 | PFO            | 3.1   | 111.4         | Impact loss due to curtailment on 8C                    |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER &amp; LIGHT CO.

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 From: Jan-2012 To: Dec-2012  
 PLANT / UNIT: MARTIN-UNIT 8 08 PM8 08

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION   |
|------------|----------------|-------|---------------|---|
| 03/20/2012 | FFO            | 3.8   | 152.85        | 8C CT TRIP AT 38 MWS                                      |
| 03/20/2012 | PFO            | 3.8   | 111.4         | Impact loss due to curtailment on 8C                      |
| 03/24/2012 | FFO            | 7.7   | 152.85        | 8A CT TRIP - CBV FAULT                                    |
| 03/24/2012 | PFO            | 7.7   | 111.4         | Impact loss due to curtailment on 8A                      |
| 04/10/2012 | FMO            | 105.3 | 152.85        | 8B Solar CRH Tie In (Task MOF)                            |
| 04/10/2012 | PMO            | 105.3 | 111.4         | Impact loss due to curtailment on 8B                      |
| 04/15/2012 | FFO            | 1.6   | 152.85        | 8B Liquid Fuel Testing Trip (EFOR)                        |
| 04/15/2012 | PFO            | 1.6   | 111.4         | Impact loss due to curtailment on 8B                      |
| 04/21/2012 | FMO            | 97.1  | 152.85        | 8C CT SOLAR COLD REHEAT TIE-IN SNOW (TMOF)                |
| 04/21/2012 | PMO            | 97.1  | 111.4         | Impact loss due to curtailment on 8C                      |
| 04/26/2012 | FMO            | 62.0  | 152.85        | 8D CTG Cycle to replace Water Injection Manifold TMOF     |
| 04/26/2012 | PMO            | 62.0  | 111.4         | Impact loss due to curtailment on 8D                      |
| 04/26/2012 | FFO            | 4.2   | 152.85        | 8B EFOR (IP FW regulator ACV-SGA-2110 failure)            |
| 04/26/2012 | PFO            | 4.2   | 111.4         | Impact loss due to curtailment on 8B                      |
| 05/01/2012 | FMO            | 29.1  | 152.85        | 8CCT Event MOF (Repair solar MOV)                         |
| 05/01/2012 | PMO            | 29.1  | 111.4         | Impact loss due to curtailment on 8C                      |
| 05/02/2012 | FMO            | 37.8  | 152.85        | 8ACT Event MOF (reheater bypass valve)                    |
| 05/02/2012 | PMO            | 37.8  | 111.4         | Impact loss due to curtailment on 8A                      |
| 05/04/2012 | FFO            | 0.1   | 152.85        | 8A CT BREAKER TRIP/ (CBV FAULT)                           |
| 05/04/2012 | PFO            | 0.1   | 111.4         | Impact loss due to curtailment on 8A                      |
| 05/07/2012 | FFO            | 5.4   | 152.85        | 8B CT Trip During Lighting Storm / S/U Generator Lock Out |
| 05/07/2012 | PFO            | 5.4   | 111.4         | Impact loss due to curtailment on 8B                      |
| 05/13/2012 | FFO            | 2.1   | 152.85        | 8C CT COMPRESSOR BLEED VALVE RUNBACK TO FSNL              |
| 05/13/2012 | PFO            | 2.1   | 111.4         | Impact loss due to curtailment on 8C                      |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 From: Jan-2012 To: Dec-2012  
 PLANT / UNIT: MARTIN-UNIT 8 08 PM8 08

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION  |
|------------|----------------|-------|---------------|--|
| 05/14/2012 | FFO            | 2.7   | 152.85        | 8C CT TRIP (FSNL) COMPRESSOR BLEED VALVE POSITIC         |
| 05/14/2012 | PFO            | 2.7   | 111.4         | Impact loss due to curtailment on 8C                     |
| 05/15/2012 | FFO            | 3.3   | 152.85        | 8D CT COMPRESSOR BLEED VALVE #3 & #4 POSITION FA         |
| 05/15/2012 | PFO            | 3.3   | 111.4         | Impact loss due to curtailment on 8D                     |
| 05/15/2012 | FMO            | 53.0  | 152.85        | 8BCT Event MOF (Gas heater gasket leak)                  |
| 05/15/2012 | PMO            | 53.0  | 111.4         | Impact loss due to curtailment on 8B                     |
| 05/16/2012 | FFO            | 2.8   | 152.85        | 8A Runback to FSNL from Base, due to Compressor Bleed VI |
| 05/16/2012 | PFO            | 2.8   | 111.4         | Impact loss due to curtailment on 8A                     |
| 05/22/2012 | FFO            | 6.2   | 152.85        | 8B CT 86RE LOR TRIPPED prevented GB from closing during  |
| 05/22/2012 | PFO            | 6.2   | 111.4         | Impact loss due to curtailment on 8B                     |
| 05/22/2012 | FFO            | 0.1   | 152.85        | 8D EFOR LOSS OF FEED PUMP (MIN FLOW)                     |
| 05/22/2012 | PFO            | 0.1   | 111.4         | Impact loss due to curtailment on 8D                     |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2012

To: Dec-2012

PLANT / UNIT: SANFORD 4 &amp; 5 CC 04

PSR 04

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION   |
|------------|----------------|-------|---------------|---|
| 01/05/2012 | PFO            | 0.3   | 78.1          | Impact loss due to curtailment on 4A                      |
| 01/05/2012 | PFO            | 0.3   | 115.15        | 4A CT runback due to IP Drum FW Blk. Vlv. failed to open. |
| 01/07/2012 | FFO            | 7.9   | 146.15        | 4B HP Bypass Failure (SGG-ACV-3)                          |
| 01/07/2012 | PFO            | 7.9   | 78.1          | Impact loss due to curtailment on 4B                      |
| 01/12/2012 | FMO            | 54.8  | 146.15        | PSR 41 OFF FOR PIPING LEAK REPAIR                         |
| 01/12/2012 | PMO            | 54.8  | 78.1          | Impact loss due to curtailment on 4A                      |
| 01/14/2012 | FFO            | 3.0   | 146.15        | 4A late for RFC due to failure of CO2 purge regulator     |
| 01/14/2012 | PFO            | 3.0   | 78.1          | Impact loss due to curtailment on 4A                      |
| 01/23/2012 | FMO            | 49.8  | 146.15        | 4B #3 Exhaust Thermocouple Repair                         |
| 01/23/2012 | PMO            | 49.8  | 78.1          | Impact loss due to curtailment on 4B                      |
| 01/25/2012 | FMO            | 44.2  | 146.15        | PSR 4C OFF BEARING TUNNEL WORK                            |
| 01/25/2012 | PMO            | 44.2  | 78.1          | Impact loss due to curtailment on 4C                      |
| 01/28/2012 | FMO            | 37.1  | 146.15        | PSR 4B OFF TO REPAIR EXHAUST FRAME SEAL                   |
| 01/28/2012 | PMO            | 37.1  | 78.1          | Impact loss due to curtailment on 4B                      |
| 02/09/2012 | FMO            | 9.8   | 146.15        | PSR 4C OFF FOR TRANSFORMER MAINTENANCE                    |
| 02/09/2012 | PMO            | 9.8   | 78.1          | Impact loss due to curtailment on 4C                      |
| 02/10/2012 | FFO            | 0.9   | 146.15        | 4C missed RFC due to starting unit late                   |
| 02/10/2012 | PFO            | 0.9   | 78.1          | Impact loss due to curtailment on 4C                      |
| 02/24/2012 | FMO            | 31.3  | 146.15        | PSR 4D OFF FOR CONDENSER TUBE CLEANING                    |
| 02/24/2012 | PMO            | 31.3  | 78.1          | Impact loss due to curtailment on 4D                      |
| 02/25/2012 | FMO            | 31.2  | 146.15        | PSR 4C OFF FOR CONDENSER CLEANING                         |
| 02/25/2012 | PMO            | 31.2  | 78.1          | Impact loss due to curtailment on 4C                      |
| 02/26/2012 | FMO            | 36.0  | 146.15        | PSR 4B OFF TO SUPPORT CONDENSER TUBE CLEANING             |
| 02/26/2012 | PMO            | 36.0  | 78.1          | Impact loss due to curtailment on 4B                      |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER &amp; LIGHT CO.

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 From: Jan-2012 To: Dec-2012

PLANT / UNIT: SANFORD 4 & 5 CC 04

PSR 04

| DATE       | OUTAGE TYPE(1) | HOURS | (MW) AFFECTED | DESCRIPTION                                   |
|------------|----------------|-------|---------------|---|
| 02/26/2012 | FMO            | 35.1  | 146.15        | PSR 4A OFF TO SUPPORT CONDENSER TUBE CLEANING |
| 02/26/2012 | PMO            | 35.1  | 78.1          | Impact loss due to curtailment on 4A          |
| 03/18/2012 | FMO            | 22.0  | 146.15        | 4D CT Replace Failed "A" LO Pump Motor        |
| 03/18/2012 | PMO            | 22.0  | 78.1          | Impact loss due to curtailment on 4D          |
| 03/27/2012 | FFO            | 1.0   | 146.15        | 4D 89ss switch failed to open during startup  |
| 03/27/2012 | PFO            | 1.0   | 78.1          | Impact loss due to curtailment on 4D          |
| 04/07/2012 | FMO            | 40.9  | 146.15        | PSR 4A OFF FOR BLADE INSPECTIONS              |
| 04/07/2012 | PMO            | 40.9  | 78.1          | Impact loss due to curtailment on 4A          |
| 04/08/2012 | FMO            | 17.7  | 146.15        | PSR 4C OFF FOR OFFLINE COMPRESSOR WASH        |
| 04/08/2012 | PMO            | 17.7  | 78.1          | Impact loss due to curtailment on 4C          |
| 04/17/2012 | FFO            | 2.9   | 146.15        | 4C CT LATE FOR RFC OFF TURNING GEAR           |
| 04/17/2012 | PFO            | 2.9   | 78.1          | Impact loss due to curtailment on 4C          |
| 04/21/2012 | FMO            | 32.7  | 146.15        | PSR 4D OFF FOR COMPRESSOR WASH                |
| 04/21/2012 | PMO            | 32.7  | 78.1          | Impact loss due to curtailment on 4D          |
| 05/11/2012 | FFO            | 14.3  | 146.15        | PSR - 4C - VCMI card failure                  |
| 05/11/2012 | PFO            | 14.3  | 78.1          | Impact loss due to curtailment on 4C          |
| 05/12/2012 | FFO            | 9.0   | 146.15        | PSR 4C could not start due to R core          |
| 05/12/2012 | PFO            | 9.0   | 78.1          | Impact loss due to curtailment on 4C          |
| 05/15/2012 | FFO            | 3.9   | 146.15        | 4A CT Trip-Cardox Zone 1 release - Heavy Rain |
| 05/15/2012 | PFO            | 3.9   | 78.1          | Impact loss due to curtailment on 4A          |
| 05/24/2012 | PFO            | 0.6   | 78.1          | Impact loss due to curtailment on 4B          |
| 05/24/2012 | PFO            | 0.6   | 1             | 4B Missed RFC missed stop vlv alarm           |

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

**GPIF Units**  
**Actual Performance Data (ACRONYMS) for 2012**

| ACRONYMS       | DESCRIPTION   |
|----------------|---|
| "R"            | Mark VI "R" Processor   |
| 1A2            | Unit 1 Pump A2  |
| 1B             | Unit 1 Pump B   |
| 2B1            | Unit 2 Pump B1  |
| 2A             | Unit 2 Combustion Turbine (sub unit A)  |
| 2A CT - 2A 230 | Combustion Turbine (sub unit A) - 2A Collector Bus                                    |
| 2A HDP         | 2 Alpha High Differential Pressure  |
| 2B             | Unit 2 Combustion Turbine (sub unit B)  |
| 2B CT - 2A 230 | Combustion Turbine (sub unit B) - 2A Collector Bus                                    |
| 2B MSR         | 2 Bravo Moisture Separator Reheater   |
| 2C             | Unit 2 Combustion Turbine (sub unit C)  |
| 2C CT - 2A 230 | Combustion Turbine (sub unit C) - 2A Collector Bus                                    |
| 2D             | Unit 2 Combustion Turbine (sub unit D)  |
| 2E             | Unit 2 Combustion Turbine (sub unit E)  |
| 2F             | Unit 2 Combustion Turbine (sub unit F)  |
| 3 CTB          | Unit 3 Combustion Turbine (sub unit B)  |
| 3A             | Unit 3 Combustion Turbine (sub unit A)  |
| 3B             | Unit 3 Combustion Turbine (sub unit B)  |
| 3C             | Unit 3 Combustion Turbine (sub unit C)  |
| 3D             | Unit 3 Combustion Turbine (sub unit D)  |
| 3ST            | Unit 3 Steam Turbine  |
| 41AC-1         | Breaker 1 for Power Supply to Exciter   |
| 41AC-2         | Breaker 2 for Power Supply to Exciter   |
| 4A             | Unit 4 Combustion Turbine (sub unit A)  |
| 4A SGFP        | 4A Steam Generator Feedwater Pump   |
| 4B             | Unit 4 Combustion Turbine (sub unit B)  |
| 4C             | Unit 4 Combustion Turbine (sub unit C)  |
| 4D             | Unit 4 Combustion Turbine (sub unit D)  |
| 4KV            | 4 Thousand Volts  |
| 5A             | Unit 5 Combustion Turbine (sub unit A)  |
| 5B             | Unit 5 Combustion Turbine (sub unit B)  |
| 5C             | Unit 5 Combustion Turbine (sub unit C)  |
| 5D             | Unit 5 Combustion Turbine (sub unit D)  |
| 5ST            | Unit 5 Steam Turbine  |
| 8A             | Unit 8 Combustion Turbine (sub unit A)  |
| 8B             | Unit 8 Combustion Turbine (sub unit B)  |
| 8C             | Unit 8 Combustion Turbine (sub unit C)  |
| 8D             | Unit 8 Combustion Turbine (sub unit D)  |
| 8X             | Unit 8 Steam Turbine  |
| 89SS           | Static Start Switch   |
| 89ND           |   |
| ABV            | Air Block Valve   |
| ACV-3          | Automatic Control Valve # 3   |
| ACV-408        | Air Control Valve Tag 408   |
| ASGJ-BV-27ED   | A (unit 2A) SGJ (hot reheat to condenser) BV ( block valve) 27 (#) ED ( valve bypass) |
| AUX            | Auxiliary   |
| BFP            | Boiler Feed Pump  |
| BFPT           | Boiler Feed Pump Turbine  |
| BRG            | Bearing   |
| BRK            | Breaker   |
| BSGG           | Unit B, main steam section of HRSG  |

**GPIF Units  
Actual Performance Data (ACRONYMS) for 2012**

| ACRONYMS     | DESCRIPTION  |
|--------------|--|
| CBV          | Compressor Bleed Valve                               |
| CEA          | Control Element Assembly                             |
| CEA 38       | Control Element Assembly Number 38                   |
| CEA 65       | Control Element Assembly Number 65                   |
| CEDM         | Control Element Drive Mechanism                      |
| Circ         | Circulating (water pump)                             |
| com          | Communication  |
| comm         | Communication  |
| CRH          | Cold Reheat  |
| CT           | Combustion Turbine                                   |
| CT C         | Combustion Turbine (sub unit C)                      |
| CTG SRV      | Speed Ratio Valve on Combustion Turbine (gas system) |
| CV-4-1510    | Control Valve Number 4-1510                          |
| CW           | Circulating Water                                    |
| CWP          | Circulating Water Pump                               |
| DFS          | Debris Filtration System                             |
| diff         | Differential   |
| DLN          | Dry Low Nox  |
| DWATT XDUCER | Megawatt transducer                                  |
| DX           | DeXcitation  |
| EFOR         | Equivalent Forced Outage Rate                        |
| EHC          | Hydraulic  |
| EOC          | End of cycle   |
| ESGA         | System code for Ft. Myers 2E HRSG                    |
| EXP          | Expansion  |
| Fa           | Failed   |
| FGT          | Florida Gas Transmission                             |
| FME          | Foreign Material Exclusion                           |
| FPI          | Fluorescent penetrant inspection                     |
| FSGJ         | F is the unit (2F) SGJ is the system designator      |
| FSNL         | Full Speed No Load                                   |
| FRV          | Feedwater Regulating Valve                           |
| FW           | Feedwater  |
| GCV          | Gas Control Valve                                    |
| GE           | General Electric                                     |
| GSU          | Generator Step Up                                    |
| Haz          | Hazardous  |
| HI           | High   |
| HMI          | Human Machine Interface                              |
| HP           | High Pressure  |
| HRH          | Hot Reheat   |
| HRSG         | Heat Recovery Steam Generator                        |
| HTF          | Heat Transfer Fluid                                  |
| I/O          | Input / Output                                       |
| IBH          | Inlet Bleed Heat Valve                               |
| ID           | Induced Draft  |
| Instr.       | Instrumentation                                      |
| IP           | Intermediate Pressure                                |
| ISO          | Isolation  |
| LCI          | Load Commutating Inverter                            |
| LL           | Low Low  |

**GPIF Units  
Actual Performance Data (ACRONYMS) for 2012**

| ACRONYMS    | DESCRIPTION   |
|-------------|---|
| LO          | Low   |
| LP          | Low Pressure  |
| MFIV        | Main Feed Isolation Valve                           |
| MF PP       | Main Feed Pump                                      |
| MG          | Motor Generator                                     |
| MOF         | Maintenance Outage Factor                           |
| mof         | maintenance outage factor                           |
| MOF/AA      | Maintenance Outage Factor / Atomizing Air           |
| MOV         | Motorized Operating Valve                           |
| MSR         | Moisture Separator Reheater                         |
| MSSV        | Main Steam Safety Valve                             |
| MW          | Megawatt  |
| MUV         | Motor actuated <u>U</u> nidirectional <u>V</u> alve |
| NO          | No  |
| O/H         | Overhaul  |
| OLWW        | Off-Line Water Wash                                 |
| OMC         | Outside Management Control                          |
| POF         | Planned Outage Factor                               |
| PEL         | Planned Energy Loss                                 |
| PFM         | Ft. Myers   |
| PM1         | Gas Valve Number 1                                  |
| PM3         | Gas Valve Number 3                                  |
| MAJOR       | Major Overhaul                                      |
| PM320102662 | Manatee Unit 3 GADS #20102662                       |
| PMG         | Martin  |
| MS          | Main Steam  |
| PMT         | Manatee   |
| ND          | Neurtal Disconnect                                  |
| Pmp         | Pump  |
| PSL         | St Lucie  |
| PSR         | Sanford   |
| PT          | Potential transformer                               |
| PWR         | Power   |
| R           | Repair  |
| R0          | Row 0 blades on steam turbine                       |
| R1          | Row 1 blades on steam turbine                       |
| RCP         | Reactor Coolant Pump                                |
| RFC         | Ready For Control                                   |
| RFO         | Refueling Outage                                    |
| RPS         | Reactor Protection System                           |
| RSD         | Reserve Shutdown                                    |
| RSV         | Reheat Stop Valve                                   |
| RSV1        | Reheat Stop Valve Number 1                          |
| RV          | Release Valve                                       |
| S/U         | Startup   |
| SGFP        | Steam Generator Feed Pump                           |
| SGG         | Main Steam - High Pressure                          |
| SGJ-ACV-10  | System Designator Air Control Valve                 |
| SL1-23      | St Lucie Unit 1 cycle 23 refueling outage           |
| SL2-19      | St Lucie Unit 2 cycle 19 refueling outage           |
| SNO         | Short Notice Outage                                 |

**GPIF Units  
Actual Performance Data (ACRONYMS) for 2012**

| ACRONYMS   | DESCRIPTION   |
|------------|---|
| SNOW       | Short Notice Outage                                     |
| SRV        | Speed Ratio Valve                                       |
| STARS      | Strategic Anti Rotation Stall Surge testing             |
| ST         | Steam Turbine   |
| ST1        | Steam Turbine Number 1                                  |
| ST2        | Steam Turbine Number 2                                  |
| STG or SG  | Steam Generator   |
| STM 1      | Steam Turbine Number 1                                  |
| STM 2      | Steam Turbine Number 2                                  |
| T-Ave      | Temperature Average                                     |
| TC or T/Cs | Thermal/Couples   |
| TCW HX     | Turbine Cooling Water Heat Exchanger                    |
| TMOF       | Task MOF  |
| U1         | Unit 1  |
| U2         | Unit 2  |
| UEL        | Unplanned Energy Loss                                   |
| VCM1       | Communication interface board for Mark 6 ovation system |
| Vi         | Roman Numeral 6   |
| VLV        | Valve   |
| WO         | Work  |
| WW         | Water wash  |
| XFMR       | Transformer   |