FILED AUG 22, 2013 DOCUMENT NO. 04926-13 FPSC - COMMISSION CLERK

DOCKET NO. 130225-EQ

# BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Florida Power & Light Company's Petition for Approval of Modification to Standard Interconnection Agreements Contained in Tariffs

Docket No. 13-\_\_\_\_

Filed: August 22, 2013

# **Petition for Approval of Modification to Standard Interconnection Agreements**

Florida Power & Light Company ("FPL"), pursuant to Rule 25-9.001(3), F.A.C., respectfully petitions the Florida Public Service Commission (the "Commission") for approval of modifications to the Standard Interconnection Agreements for Tier 1, Tier 2, and Tier 3 Customer-Owned Renewable Generation Systems (the "Standard Interconnection Agreements") contained in FPL's approved tariff. To promote and improve customer usage of Renewable Energy Systems, FPL requests authority to: (1) modify the indemnity and insurance provisions in order to eliminate conflicts with statutory limitations on governmental liability; (2) include the "Gross Power Rating" definition in the Standard Interconnection Agreement to make the definition readily accessible to customers and reduce the errors in the application process; (3) eliminate the manual disconnect switch requirement on U.L. 1741 systems for inverter-based customer-owned renewable generation systems and add clarity regarding the requirements for non-inverter based renewable generation systems in order to improve customer safety and reduce costs; and (4) add to Tier 1 the provision already set forth in Tiers 2 and 3, which specifies the customer's responsibility for disconnecting the customer-owned renewable generation systems.

Because each modification benefits customers and promotes the use of renewable energy, the Commission should approve the requested modifications to the modifications to the Standard Interconnection Agreements.

# I. Introduction and Background

1. The Petitioner's name and address:

Florida Power & Light Company 700 Universe Boulevard Juno Beach, FL 33408

2. Any pleading, motion, notice, order, or other document required to be served upon FPL or filed by any party to this proceeding should be served upon the following individuals:

Kenneth A. Hoffman Vice President, Regulatory Affairs ken.hoffman@fpl.com Florida Power & Light Company 215 S. Monroe Street, Suite 810 Tallahassee, FL 32301 (850) 521-3919 (850) 521-3939 (fax) Maria J. Moncada Principal Attorney maria.moncada@fpl.com Florida Power & Light Company 700 Universe Boulevard Juno Beach, FL 33408 (561) 304-5795 (561) 691-7135 (fax)

- 3. Pursuant to Rule 25-9.001(3), Florida Administrative Code ("F.A.C."), FPL seeks approval of modifications to the Standard Interconnection Agreements contained in its tariffs.
- 4. The purpose of Rule 25-6.065 is to encourage renewable energy generation. Rule 25-6.065(3), F.A.C. required each investor-owned utility (IOU) to file for Commission approval within 30 days of the Rule's enactment a Standard Interconnection Agreement for expedited interconnection of customer-owned renewable generation up to two megawatts.
- 5. By Order No. PSC-08-0624-TRF-EI, issued September 24, 2008, in Docket No. 080265-EI, *In re: Petition for approval of net metering tariff and standard interconnection agreements, by Florida Power & Light Company*, the Commission approved tariffs incorporating the Standard Interconnection Agreements submitted by FPL. In Order No. PSC-08-0625-TRF-EI, the Commission recognized that the requirements of Rule 25-6.065, F.A.C., represented a new process, and that IOUs can request tariff revisions as they gain experience.

6. The experience FPL has gained administering its Standard Interconnection Agreements has revealed that certain modifications are necessary to further the goal of encouraging renewable energy generation. FPL requests modifications to the Standard Interconnection Agreements to (1) modify the indemnity and insurance provisions; (2) include a definition of "Gross Power Rating"; (3) remove the requirement for a manual disconnect switch on U.L. 1741 systems for inverter-based customer-owned renewable generation systems and provide flexibility as to the location placement of manual disconnect switches for non-inverter based systems; and (4) add to Tier 1 the provision already set forth in Tiers 2 and 3, which specifies the customer's responsibility for disconnecting the customer-owned renewable generation systems. As will be demonstrated below, the requested modifications benefit customers by facilitating increased customer participation, improving customer safety or information accessibility, or reducing customer costs. Accordingly, the modifications detailed herein should be approved.

# **II.** Modification of Indemnity and Insurance Provisions

- 7. Indemnity Provision. Rule 25-6.065(5), F.A.C., lists the minimum contents of a Standard Interconnection Agreement. Subsection (d) of the Rule requires "[a] provision that the customer shall hold harmless and indemnify the investor-owned utility from all loss to third parties resulting from the operation of the customer-owned renewable generation, except when the loss occurs due to the negligent actions of the investor-owned utility."
- 8. FPL's Standard Interconnection Agreements for Tier 2 (Section 8.1) and Tier 3 (Section 10.1) systems, as contained in FPL's tariff, currently state: "Customer shall indemnify, hold harmless and defend FPL from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property (including the Customer-

owned renewable generation system), fines and penalties, costs and expenses arising out of or resulting from the operation of the Customer-owned renewable generation system, except in those instances where such loss is due to the negligent action or inactions of FPL."

- 9. *Insurance provision*. Rule 25-6.065(5)(e), F.A.C., sets forth "[a] requirement for general liability insurance for personal and property damage, or sufficient guarantee and proof of self-insurance, in the amount of no more than \$1 million for Tier 2, and no more than \$2 million for Tier 3." Accordingly, FPL's Standard Interconnection Agreement for Tiers 2 and 3 contain insurance provisions.
- 10. The existing Tier 2 insurance provision states: "The Customer agrees to provide and maintain general liability insurance for personal and property damage, or sufficient guarantee and proof of self-insurance, in the amount of not less than **\$1 million** during the entire period of this Interconnection Agreement. Initial proof of insurance shall be in the form of a copy of the policy attached to this Interconnection Agreement evidencing the Homeowner's or other insurance policy in effect at the time of interconnection." (emphasis added).
- 11. The existing Tier 3 insurance provision states: "The Customer agrees to provide and maintain general liability insurance for personal and property damage, or sufficient guarantee and proof of self-insurance, in the amount of not less than **\$2 million** during the entire period of this Interconnection Agreement. Initial proof of insurance shall be in the form of a copy of the policy attached to this Interconnection Agreement evidencing the Homeowner's or other insurance policy in effect at the time of interconnection." (emphasis added).
- 12. State Sovereign Immunity. State and government agencies that are FPL customers seek to install customer-owned renewable generation systems. These state and government agencies assert that they are barred by law, however, from agreeing to the indemnity and

insurance provisions contained in FPL's Standard Interconnection Agreements. Section 768.28, Florida Statutes (2013), provides a limited waiver of sovereign immunity for state agencies. Specifically, Section 768.28(5) states that "[n]either the state nor its agencies or subdivisions shall be liable to pay a claim or a judgment by any one person which **exceeds the sum of \$200,000** or any claim or judgment, or portions thereof, which, when totaled with all other claims or judgments paid by the state or its agencies or subdivisions arising out of the same incident or occurrence, **exceeds the sum of \$300,000**." (emphases added).

13. Pursuant to this statute, state and government agencies are self-insured only up to the limits permitted by Section 768.28(5), and as a statutory matter they cannot agree to the insurance or indemnity provisions contained in FPL's existing Standard Interconnection Agreement. To address these limitations, FPL requests that the indemnity provisions of its Standard Interconnection Agreement for Tiers 1, 2 and 3 be modified to add the following language denoted in <u>underlined</u> type face:

# Indemnity. \*\*\*

Customer, to the extent permitted by law without waiving or limiting any defense of sovereign immunity, shall indemnify, hold harmless and defend FPL from and against any and all judgments, losses, damages, claims relating to injury or to death of any person or damage to property (including the Customer-owned renewable generation system), fines and penalties, costs and expenses arising out of or resulting from the operation of the Customer-owned renewable generation system, except in those instances where such loss is due to the negligent action or inactions of FPL. Nothing herein shall be intended to serve as a waiver or limitation of the Customer's sovereign immunity defense as allowed by law. <sup>1</sup>

14. Similarly, regarding the insurance provisions, FPL requests that each Tier limit the requirements "to the extent permitted by law." Thus, FPL requests that the insurance

<sup>&</sup>lt;sup>1</sup> For Tiers 1 and 2, this provision is located at Section 8.1. For Tier 3, this provision is located at Section 10.1.

provisions of its Standard Interconnection Agreement for Tiers 1, 2 and 3 be modified to add the following language denoted in <u>underlined</u> type face:

#### Tier 1

11.1 FPL recommends that the Customer maintain Liability Insurance for Personal Injury and Property damage in amount of not less than \$100,000 during the entire term of this Interconnection Agreement to the extent permitted by law. For government entities, the policy coverage shall not exceed the entity's maximum liability established by law.

# Tier 2

11.1 The Customer agrees to provide and maintain general liability insurance for personal and property damage, or sufficient guarantee and proof of self-insurance, in the amount of not less than \$1 million during the entire period of this Interconnection Agreement, to the extent permitted by law. Initial proof of insurance shall be in the form of a copy of the policy or certificate of insurance attached to this Interconnection Agreement evidencing the Homeowner's or other insurance policy in effect at the time of interconnection. For government entities, the policy coverage shall not exceed the entity's maximum liability established by law. Proof of self-insurance consistent with law shall satisfy this requirement.

# Tier 3

- 13.1. The Customer agrees to provide and maintain general liability insurance for personal and property damage, or sufficient guarantee and proof of self-insurance, in the amount of not less than \$2 million during the entire period of this Interconnection Agreement, to the extent permitted by law. Initial proof of insurance shall be in the form of a copy of the policy or certificate of insurance attached to this Interconnection Agreement evidencing the Homeowner's or other insurance policy in effect at the time of interconnection. For government entities, the policy coverage shall not exceed the entity's maximum liability established by law. Proof of self-insurance consistent with law shall satisfy this requirement.
- 15. These tariff modifications will allow state and government agencies that are FPL customers to enter into FPL's Standard Interconnection Agreements, thus promoting the goal of encouraging renewable generation. In addition, the requested tariff modifications will improve

administrative efficiency for FPL to execute its Standard Interconnection Agreements with state agencies by eliminating the need to obtain waivers from the Commission each time a state agency seeks to install a customer-owned generation system. In this, way, the tariff modifications also will reduce the regulatory burdens on the state agencies.

16. The Commission approved a substantially similar request by Progress Energy Florida in Docket No. 120228-EQ, Order Nos. PSC-12-0538-PAA-EQ and PSC-12-0602-CO-EQ (dated Nov. 5, 2012). The same rationale underlying the Commission's approval in that docket applies here. Accordingly, the Commission should approve FPL's request to modify the indemnity and insurance provisions for Tiers 1, 2 and 3 in order to eliminate any conflict with statutory liability limitations.

# **III.** Definition of Gross Power Rating

- 17. Rule 25-6.065(2)(b), F.A.C. defines "Gross Power Rating" as "the total manufacturer's AC nameplate generating capacity of an on-site customer-owned renewable generation system that will be interconnected to and operate in parallel with the investor-owned utility's distribution facilities. For inverter-based systems, the AC nameplate generating capacity shall be calculated by multiplying the total installed DC nameplate generating capacity by .85 in order to account for losses during the conversion from DC to AC."
- 18. FPL's Standard Interconnection Agreement requires customers to provide information related to the Gross Power Rating of their proposed renewable generation system. In FPL's experience administering the Standard Interconnection Agreements, many customer applications contain errors related to the Gross Power Rating calculation information. Thus, FPL

believes that customers would benefit from having the definition of Gross Power Rating readily available in the Standard Interconnection Agreement.<sup>2</sup>

- 19. In addition, customers typically receive the rating information required to be set forth in the Standard Interconnection Agreements from independent contractors that customers hire to perform the installation of the renewable generation system. Many contractors provide the rating information in "DC" format rather than the required "AC" format. For that reason, FPL proposes to specify as necessary throughout the Standard Interconnection Agreement that the rating should be provided in "AC" format.
- 20. Arming customers with this information in an easily accessible format is likely to reduce application errors, which, in turn, will avoid the delays caused by those errors. The requested modification thus benefits customers, and FPL's request should be approved.

# IV. Modification of Manual Disconnect Requirement

A. Elimination of the Manual Disconnect Switch Requirement for Systems Listed to U.L. 1741

- 21. Currently, Tiers 2 and 3 of FPL's Standard Interconnection Agreement require the customer to install, at the customer's expense, a manual disconnect switch of the visible load break type in order to provide a separation point between the AC power output of the customerowned renewable generation and any customer wiring connected to FPL's system. The purpose of a manual disconnect switch is to prevent backfeed from the customer's system to the utility in the event of an outage or other malfunction.
- 22. For two reasons, FPL requests approval to eliminate the manual disconnect switch requirement for systems listed to U.L. 1741 on the Standard Interconnection Agreements for Tiers 2 and 3. For Tier 1, FPL likewise seeks to add language expressing that no manual

8

<sup>&</sup>lt;sup>2</sup> For Tiers 1 and 2, the Gross Power Rating definition would appear as Section 1.1. For Tier 3, the Gross Power Rating definition would appear as Section 1.6.

disconnect switch is required for systems listed to U.L. 1741. First, systems listed to U.L. 1741 are designed to disconnect automatically from a utility within seconds of an outage and therefore will not backfeed the utility. Requiring a manual disconnect is therefore duplicative of the safety benefits already built in to U.L. 1741 systems.

- 23. Second, under the existing requirement, customers who wish to install a renewable energy system in high rise buildings must run conductors a substantial distance from the roof to the ground floor to connect to the switch, and then to their AC wiring. By eliminating the switch requirement, the renewable energy system can be connected near the roof of the building. Thus, eliminating the manual disconnect switch requirement reduces the cost to the customer for the system, and reduces the associated energy losses, thereby further encouraging the installation of customer-owned renewable generation systems.
  - 24. The proposed modified language is set forth below:

U.L.1741 Listed, inverter-based [Tier 1] customer-owned renewable generation systems do not require a customer-installed manual disconnect switch.<sup>3</sup>

- B. Include Requirement under Tier 1 that Customers Install Manual Disconnect Switch for Non-Inverter Based Systems at Customer's Expense.
- 25. For safety reasons, FPL will retain the current language requiring customers with non-inverter based energy sources to install a manual disconnect switch. FPL's existing Standard Interconnection Agreements for Tiers 2 and 3 require that the customer install the switch at the customer's expense. This is authorized under Rule 25-6.065(6)(a).
- 26. Under the existing Tier 1 Agreement, however, installation of a manual disconnect switch by the customer is not required. FPL's experience has revealed that safety warrants the installation of a manual disconnect switch for all non-inverter based systems. Non-

-

<sup>&</sup>lt;sup>3</sup> FPL proposes to use the same language for each tier.

inverter based systems are not equipped to shut down automatically in the event of an FPL system outage, which would result in backfeed to FPL's system. Protective relaying could be added, but that would not guarantee that the customer's renewable generation system will shut down properly. By contrast, installation of a manual disconnect switch provides a visual load break, which will ensure that the customer's system does not backfeed. Consistent with Rule 25-6.065(6)(a), the switch should be installed at the customer's expense.

- 27. Accordingly, in order to maintain appropriate safety protections, FPL requests that the Tier 1 Standard Interconnection Agreement be modified to require the installation of a manual disconnect switch for renewable generation systems that are not inverter based.
  - 28. The proposed modification is set forth below in legislative format:

In the event FPL electsOther customer-owned Tier 1 renewable generation systems that are not U.L. inverter based. FPL shall require the Customer to install a manual disconnect switch, it shall be installed, at FPLthe Customer's expense. The FPL installed, a manual disconnect switch shall beof the visible load break type to provide a separation point between the AC power output of the Customer-owned renewable generation and any Customer wiring connected to FPL's system. The manual disconnect switch shall be mounted separate from, but adjacent to, the FPL meter socket. The Customer shall ensure that such manual disconnect switch shall remain readily accessible to FPL and be capable of being locked in the open position with a single FPL utility padlock.

- C. Flexibility To Install Manual Disconnect Switch at Location Not Adjacent to the Meter Socket
- 29. Consistent with the goal of reducing costs and energy losses for customers, FPL seeks to add a provision to the Standard Interconnection Agreements that accords FPL and the Customer flexibility to install the manual disconnect switch at a location not adjacent to the meter socket. As explained above, this requested modification reduces the cost to the customer for the system, reduces the associated energy losses, and thus encourages the installation of customer-owned renewable generation systems.

30. The proposed language to be included is set forth below:

In the event that FPL has determined in respect of the Customerowned renewable generation that the installation of a manual disconnect switch or switches adjacent to FPL's meter socket would not be practical from a safety perspective and/or design considerations in accordance with good engineering practices; and FPL and the customer agree upon a location on the customer's premises for the switch or switches which meet all applicable safety and/or design considerations, then, pursuant to the conditions set forth in Section 5.2 above, each manual disconnect switch shall be mounted separate from FPL's meter socket at a location agreed to by the Customer and FPL, and a permanent weather-proof plaque shall be installed adjacent to FPL's meter socket indicating the location of the manual disconnect switch or switches.

31. Together, these proposed modifications benefit customers by reducing costs and energy losses and maintaining safety. The modifications thus benefit customers and promote the purpose of Rule 25-6.065. Accordingly, the request to modify the manual disconnect switch requirement described herein should be approved.

# V. Disconnection/Reconnection

- 32. The existing Standard Interconnection Agreement for Tiers 2 and 3 provide that customers, upon notice, must disconnect their renewable generation equipment if conditions on the FPL system could adversely affect the customer's equipment. This provision was previously inapplicable to Tier 1, since Tier 1 did not include the manual disconnect switch requirement for non-inverter based systems.
- 33. As explained above, FPL seeks to require the customer to install a manual disconnect switch for non-inverter based systems in order to maintain safety. As a corollary to that modification, it is now relevant and appropriate to include a provision identical to what already is approved and in place for Tiers 2 and 3, which advises Tier 1 customers that they must disconnect their renewable generation equipment if conditions on the FPL system could adversely affect the customer's equipment.

- 34. The proposed language to be included in Tier 1 is set forth below:
  - Upon notice by FPL, the Customer shall be solely responsible to disconnect the Customer-owned renewable generation and Customer's other equipment if conditions on the FPL distribution system could adversely affect the Customer-owned renewable generator. FPL will not be responsible for damage to the Customer-owned renewable generation system due to adverse effects on the distribution system. Reconnection will be the Customer's responsibility and will not require an additional application.
- 35. The Commission already has approved this language for inclusion in the Standard Interconnection Agreements for Tier 2 and 3. It is now appropriate to include the same language for Tier 1. Accordingly, FPL's request to include the disconnection provision set forth above should be approved.

## VI. Miscellaneous Matters

- 36. As a ministerial matter, FPL seeks approval to reverse the order of the signature block that appears at the end of the Standard Interconnection Agreements and to eliminate the triplication and witnessing requirement. In the existing agreements, FPL's signature appears before the customer's signature. FPL originally anticipated that the customer would submit completed, unsigned agreements in triplicate; then FPL would review, sign and return the three copies of the agreement to the customer for a countersignature and a witness signature. FPL's experience has revealed that this is impracticable for all parties involved, and it does not provide any material benefits to FPL or the Customer.
- 37. Accordingly, FPL's request to reverse the order of the signature block that appears at the end of the Standard Interconnection Agreements, and to eliminate the triplication and witnessing requirements should be approved.
- 38. In addition, minor edits to the Standard Interconnection Agreements are needed in order to incorporate and conform to the modifications requested herein, such as changes to

section numbers and other word changes. FPL also has identified a few scrivenors' errors and

updated its contact information. These changes are set forth in legislative format and clean

versions of the Standard Interconnection Agreements, attached as Exhibits "1" and "2"

respectively.

VII. Conclusion

For the reasons stated above, FPL respectfully requests that the Commission approve its

Petition. FPL attaches redline and clean versions of the proposed changes to its Standard

Interconnection Agreements. The modified tariffs are attached hereto in legislative format as

Exhibit 1 and in clean format as Exhibit 2.

Respectfully submitted,

Maria Jose Moncada

Principal Attorney

maria.moncada@fpl.com

Florida Power & Light Company

700 Universe Boulevard

Juno Beach, FL 33408


(561) 304-5795

(561) 691-7135 (fax)

By: <u>/s/ Maria Jose Moncada</u>

Maria Jose Moncada

13



	Interconnection Agreement for Customer-Owned Renewable Generation Tier 1 - 10 kW or Less										
("C	s Agreement, is made and entered into this day of, 20, by and between ustomer"), with an address of and FLORIDA										
	WER & LIGHT COMPANY ("FPL"), a Florida corporation with an address of P.O. Box 14000, 700 Universe Boulevard, Juno Beach, 33408-0429.										
	WITNESSETH:										
	<b>HEREAS</b> , the Customer has requested to interconnect its Customer-owned renewable generation, 10 kW_AC or less, to FPL's ctrical service grid at the Customer's presently metered location.										
	<b>W, THEREFORE,</b> for and in consideration of the mutual covenants and agreements herein set forth, the Parties hereto covenant agree as follows:										
1.	<ul> <li>Definitions</li> <li>1.1 Gross Power Rating means the total manufacturer's AC nameplate generating capacity of an on-site customer-owned renewable generation system that will be interconnected to and operate in parallel with FPL's distribution facilities. For inverter-based systems, the AC generating capacity shall be calculated by multiplying the total installed DC nameplate generating capacity by 0.85 in order to account for losses during the conversion from DC to AC.</li> <li>1.2 Capitalized Terms shall have the meanings set forth in Florida Public Service Commission Rule 25-6.065 F.A.C Interconnection and Net Metering of Customer-owned renewable generation.</li> </ul>										
2.	Customer Qualification and Fees  2.1. Customer-owned renewable generation shall have a Gross power ratingPower Rating that:  a) does not exceed 90% of the Customer's utility distribution service rating; and b) is 10 kW AC or less.  Gross power rating Power Rating for the Customer-owned renewable generation iskW AC.										
	2.2. The Customer shall not be required to pay any application fee for this Tier 1 Customer-owned renewable generation system.										
	2.3. In order to commence the process for interconnection the Customer shall provide FPL a completed application.										
3.	General Responsibilities of the Parties										
	3.1. Customer-owned renewable generation shall be considered certified for interconnected operation if it has been submitted by a manufacturer to a nationally recognized testing and certification laboratory, and has been tested and listed by the laboratory for continuous interactive operation with an electric distribution system in compliance with the applicable codes and standards of IEEE 1547, IEEE 1547.1, and UL 1741.										
	3.2. Customer-owned renewable generation shall include a utility-interactive inverter, or other device certified pursuant to Section 3.1 above, that performs the function of automatically isolating the Customer-owned generation equipment from electric grid in the event the electric grid loses power.										
	3.3. The Customer shall be responsible for protecting its Customer-owned renewable generation equipment, inverters, protective										

is operating correctly and safely.

3.4. The Customer agrees to provide Local Building Code Official inspection and certification of installation. The certification shall reflect that the local code official has inspected and certified that the installation was permitted, has been approved, and has met all electrical and mechanical qualifications.

devices, and other system components from damage from the normal and abnormal conditions and operations that occur on the FPL system in delivering and restoring power; and shall be responsible for ensuring that Customer-owned renewable generation equipment is inspected, maintained, and tested in accordance with the manufacturer's instructions to ensure that it

(Continued on Sheet No. 9.051)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.050)

- 3.5 The Customer shall notify FPL at least ten (10) calendar days prior to initially placing Customer's equipment and protective apparatus in service and FPL shall have the right to have personnel present on the in-service date.
- 3.6 Interconnection Agreement shall be executed by FPL within thirty (30) calendar days of receipt of a completed application.

## 4. Inspection and On-going Compliance

4.1 FPL will provide Customer with as much notice as reasonably practicable; either in writing, e-mail, facsimile or by phone as to when FPL may conduct inspection and/or document review. Upon reasonable notice, or at any time without notice in the event of an emergency or hazardous condition, FPL shall have access to the Customer's premises for the purpose of accessing the manual disconnect switch, performing an inspection or disconnection, or, if necessary, to meet FPL's legal obligation to provide service to its Customers.

#### 5. Manual Disconnect Switch

- 5.1 <u>U.L.1741 Listed, inverter-based Tier 1 customer-owned</u> renewable generation systems do not require a customer-installed manual disconnect switch.
- 5.2 5.1 In the event FPL electsOther customer-owned Tier 1 renewable generation systems that are not U.L. inverter based. FPL shall require the Customer to install a manual disconnect switch, it shall be installed, at FPLthe Customer's expense. The FPL installed, a manual disconnect switch shall beof the visible load break type to provide a separation point between the AC power output of the Customer-owned renewable generation and any Customer wiring connected to FPL's system. The manual disconnect switch shall be mounted separate from, but adjacent to, the FPL meter socket. The Customer shall ensure that such manual disconnect switch shall remain readily accessible to FPL and be capable of being locked in the open position with a single FPL utility padlock.
- 5.3 In the event that FPL has determined with respect to the Customer-owned renewable generation that the installation of a manual disconnect switch or switches adjacent to FPL's meter socket would not be practical from a safety perspective and/or design considerations in accordance with good engineering practices; and FPL and the customer agree upon a location on the customer's premises for the switch or switches which meet all applicable safety and/or design considerations, then, pursuant to the conditions set forth in Section 5.2 above, each manual disconnect switch shall be mounted separate from FPL's meter socket at a location agreed to by the Customer and FPL, and the customer shall install a permanent weather-proof plaque adjacent to FPL's meter socket indicating the location of the manual disconnect switch or switches.

## 6. Disconnection / Reconnection

- 6.1 FPL may open the manual disconnect switch, if available, or disconnect the Customer's meter, pursuant to the conditions set forth in Section 6.2-6.3 below, isolating the Customer-owned renewable generation, without prior notice to the Customer. To the extent practicable, however, prior notice shall be given. If prior notice is not given, FPL shall at the time of disconnection leave a door hanger notifying the Customer that its Customer-owned renewable generation has been disconnected, including an explanation of the condition necessitating such action. FPL will reconnect the Customer-owned renewable generation as soon as practicable after the condition(s) necessitating disconnection has been remedied.
- 6.2 Upon notice by FPL, the Customer shall be solely responsible to disconnect the Customer-owned renewable generation and Customer's other equipment if conditions on the FPL distribution system could adversely affect the Customer-owned renewable generation. FPL will not be responsible for damage to the Customer-owned renewable generation system due to adverse effects on the distribution system. Reconnection will be the Customer's responsibility and will not require an additional application.
- 6.2 FPL has the right to disconnect the Customer owned renewable generation at any time. This may result for the following
  - a) Emergencies or maintenance requirements on FPL's system;
  - b) Hazardous conditions existing on FPL's system due to the operation of the Customer's generating or protective

Issued by: S. E. Romig, Director, Rates and Tariffs

#### FLORIDA POWER & LIGHT COMPANY

equipment as determined by FPL; and

c) Adverse electrical effects, such as power quality problems, on the electrical equipment of FPL's other electric consumers caused by the Customer owned renewable generation as determined by FPL.

# 7. Modifications/Additions to Customer-owned Renewable Generation

- 7.1 If the Customer owned renewable generation system is subsequently modified in order to increase its Gross power rating, the Customer must notify FPL by submitting a new application specifying the modification at least thirty (30) calendar days prior to making the modification.
- 7.2 If the Customer adds another Customer owned renewable generator system which i.) utilizes the same utility inter active inverter, or other device certified pursuant to Section 3.1 above, for both systems; or ii.) utilizes a separate utility inter active inverter, or other device certified pursuant to Section 3.1 above, for each system the Customer shall provide thirty (30) calendar days notice prior to installation.

(Continued on Sheet No. 9.052)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.051)

- 6.3 FPL has the right to disconnect the Customer-owned renewable generation at any time. This may result for the following reasons, amongst others:
  - a) Emergencies or maintenance requirements on FPL's system;
  - b) Hazardous conditions existing on FPL's system due to the operation of the Customer's generating or protective equipment as determined by FPL; and
  - c) Adverse electrical effects, such as power quality problems, on the electrical equipment of FPL's other electric consumers caused by the Customer-owned renewable generation as determined by FPL.

#### 7. Modifications/Additions to Customer-owned Renewable Generation

- 7.1 If the Customer-owned renewable generation system is subsequently modified in order to increase its Gross Power Rating, the Customer must notify FPL by submitting a new application or interconnection agreement specifying the modification at least thirty (30) calendar days prior to making the modification.
- 7.2 If the Customer adds another Customer-owned renewable generator system which i.) Utilizes the same utility inter-active inverter, or other device certified pursuant to Section 3.1 above, for both systems; and ii.) Utilizes a separate utility inter-active inverter, or other device certified pursuant to Section 3.1 above, for each system the Customer shall provide thirty (30) calendar days notice prior to installation.
- 7.3 In the event any Customer modifications or additions result in the input to any FPL meter so as to qualify as a Tier 2 or Tier 3 system, then all terms and conditions, including appropriate notice, of the Interconnection Agreement for Tier 2 or Tier 3 systems shall apply.
- 7.4 The Interconnection Agreement which applies in instances described in Sections 7.1, 7.2, and 7.3 above shall be determined by the combined gross power rating of the generation system(s) which is connected to the FPL meter. In all instances described in this Section 7, the Customer shall submit a new application to FPL and shall enter into a new Interconnection Agreement. In no event shall the maximum output of the Customer-owned generation system(s), which is connected to the FPL meter exceed 2 MW Gross Power Rating.

## 8. **Indemnity**

- 8.1 Customer, to the extent permitted by law without waiving or limiting any defense of sovereign immunity, shall indemnify, hold harmless and defend FPL from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property, (including the Customer-owned renewable generation system), fines and penalties, costs and expenses arising out of or resulting from the operation of the Customer-owned renewable generation system, except in those instances where such loss is due to the negligent action or inactions of FPL. Nothing herein shall be intended to serve as a waiver or limitation of the Customer's sovereign immunity defense as allowed by law.
- 8.2 FPL shall indemnify, hold harmless and defend Customer from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property (including FPL's transmission system), fines and penalties, costs and expenses arising out of or resulting from the operation of FPL's system, except in those instances where such loss is due to the negligent action or inactions of the Customer.

## 9. Limitation of Liability

9.1. Liability under this Interconnection Agreement for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Interconnection Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall the indemnifying Party be liable to the other Party for any indirect, special, consequential, or punitive damages, except as authorized by this Interconnection Agreement.

Issued by: S. E. Romig, Director, Rates and Tariffs

#### FLORIDA POWER & LIGHT COMPANY

9.1. Liability under this Interconnection Agreement for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Interconnection Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall the indemnifying Party be liable to the other Party for any indirect, special, consequential, or punitive damages, except as authorized by this Interconnection Agreement.

#### 10. Assignment

- 10.1 The Interconnection Agreement shall not be assignable by either party without thirty (30) calendar days notice to the other Party and written consent of the other Party, which consent shall not be unreasonably withheld or delayed.
- 10.2 An assignee to this Interconnection Agreement shall be required to assume in writing the Customer's rights, responsibilities, and obligations under this Interconnection Agreement; or execute a new Interconnection Agreement.

#### 11. Insurance

— 11.1 FPL recommends that the Customer maintain Liability Insurance for Personal Injury and Property damage in amount of not less than \$100,000 during the entire term of this Interconnection Agreement.

## 12. Renewable Energy Certificates

— 12.1 The Customer shall retain any Renewable Energy Certificates associated with the electricity produced by their Customer owned renewable generation equipment; any additional meters necessary for measuring the total renewable electricity generated for the purposes of receiving Renewable Energy Certificates shall be installed at the Customer's expense, unless otherwise determined during negotiations for the sale of the Customer's Renewable Energy Certificates to FPL.

(Continued on Sheet No. 9.053)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.052)

# 9. Limitation of Liability

9.1 Liability under this Interconnection Agreement for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Interconnection Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall the indemnifying Party be liable to the other Party for any indirect, special, consequential, or punitive damages, except as authorized.

# 10. Assignment

- 10.1 The Interconnection Agreement shall be assignable by either Party upon thirty (30) calendar days notice to the other Party and written consent of the other Party, which consent shall not be unreasonably withheld or delayed.
- 10.2 An assignee to this Interconnection Agreement shall be required to assume in writing the Customer's rights, responsibilities, and obligations under this Interconnection Agreement; or execute a new Interconnection Agreement.

### 11. Insurance

11.1 FPL recommends that the Customer maintain Liability Insurance for Personal Injury and Property damage in amount of not less than \$100,000 during the entire term of this Interconnection Agreement to the extent permitted by law. For government entities, the policy coverage shall not exceed the entity's maximum liability established by law.

## 12. Renewable Energy Certificates

12.1 The Customer shall retain any Renewable Energy Certificates associated with the electricity produced by their Customer-owned renewable generation equipment; any additional meters necessary for measuring the total renewable electricity generated for the purposes of receiving Renewable Energy Certificates shall be installed at the Customer's expense, unless otherwise determined during negotiations for the sale of the Customer's Renewable Energy Certificates to FPL.

#### 13. Lease Agreements

- 13.1 The Customer shall provide FPL a copy of the lease agreement, as applicable, for any and all leased interconnection equipment.
- 13.2 The Customer shall not enter into any lease agreement that results in the retail purchase of electricity; or the retail sale of electricity from the Customer-owned renewable generation. Notwithstanding this restriction, in the event it is determined by the Florida Public Service Commission that the Customer has entered such an agreement, the Customer shall be in breach of this Interconnection Agreement and the lessor may also become subject to the jurisdiction and regulations of the Florida Public Service Commission as a public utility.

#### 14. **Dispute Resolution**

14.1 Disputes between the Parties shall be handled in accordance with subsection 11 of Florida Public Service Commission Rule 25-6.065F.A.C. - Interconnection and Net Metering of Customer-owned renewable generation.

## 15. Effective Date

15.1 The Customer must execute this Interconnection Agreement and return it to FPL at least thirty (30) calendar days prior to beginning parallel operations and the Customer must begin parallel operation within one year after FPL executes the Interconnection Agreement.

#### 16. Termination

16.1 Upon termination of this Interconnection Agreement, FPL shall open and padlock the manual disconnect switch, if applicable, and remove the Net Metering and associated FPL equipment. At the Customer's expense, the Customer agrees to permanently disconnect the Customer-owned renewable generation and associated equipment from FPL's electric service grid. The Customer shall notify FPL in writing within ten (10) calendar days that the disconnect procedure has been completed.

#### 17. Amendments to Florida Public Service Commission Rules

17.1 FPL and Customer recognize that the Florida Public Service Commission rules may be amended from time to time. In the event that Florida Public Service Commission rules are modified, FPL and Customer agree to supersede and replace this

Issued by: S. E. Romig, Director, Rates and Tariffs

# FLORIDA POWER & LIGHT COMPANY

Commission rules.

# 18. Entire Agreement

18.1 This Interconnection Agreement supersedes all previous agreements or representations, either written or oral, heretofore in effect between FPL and the Customer, made in respect to matters herein contained, and when duly executed, this Interconnection Agreement constitutes the entire agreement between Parties hereto.

(Continued on Sheet No. 9.054)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.053)

## 17. Amendments to Florida Public Service Commission Rules

17.1 FPL and Customer recognize that the Florida Public Service Commission rules may be amended from time to time. In the event that Florida Public Service Commission rules are modified, FPL and Customer agree to supersede and replace this Interconnection Agreement with a new Interconnection Agreement which complies with the amended Florida Public Service Commission rules.

#### 18. Entire Agreement

18.1 This Interconnection Agreement supersedes all previous agreements or representations, either written or oral, heretofore in effect between FPL and the Customer, made in respect to matters herein contained, and when duly executed, this Interconnection Agreement constitutes the entire agreement between Parties hereto.

#### 19. Governmental Entities

19.1 For those customers, which are government entities, provisions within this agreement will apply to the extent the agency is not legally barred from executing such provisions by State or Federal law.

(Continued on Sheet No. 9.054)

Issued by: S. E. Romig, Director, Rates and Tariffs

**Effective:** 

	Continued from Sheet No. 9.0539.053.1)
<b>IN WITNESS WHEREOF,</b> the Parties hereto be year first above written.	nave caused this Interconnection Agreement to be duly executed in triplicate the day ar
CUSTOMER	
(Signature)	
(Print or Type Name)	
Title:	
FLORIDA POWER & LIGHT COMPANY	
(Signature)	
(Print or Type Name) Title:	
CUSTOMER	
(Signature)	
(Print or Type Name) The completed agreement may be submitted to	FPL by:
Title:	
E-mail - scan and e-mail to Netmetering@fpl.co  Mail - send to: Net Metering FPL - Mail code CSF-GO 9250 W. Flagler St. Miami, FL 33174	<u>JIII</u>

Issued by: S. E. Romig, Director, Rates and Tariffs Effective: October 1, 2008

# FLORIDA POWER & LIGHT COMPANY

9250 W. Flagler St. Miami, FL 33174

**FAX** - 305-552-2275

(Print or Type Name)	
	(Print or Type Name)

Issued by: S. E. Romig, Director, Rates and Tariffs

	Interconnection Agreement for Customer-Owned Renewable Generation Tier 2 – Greater than 10 kW and Less than or Equal to 100 kW
("C PO	s Agreement, is made and entered into this day of, 20, by and between ustomer"), with an address of and FLORIDA WER & LIGHT COMPANY ("FPL"), a Florida corporation with an address of P.O. Box 14000, 700 Universe Boulevard, Juno Beach,
FL	33408-0429. <b>WITNESSETH:</b>
	<b>IEREAS,</b> the Customer has requested to interconnect its Customer-owned renewable generation, greater than 10 kW <u>AC</u> and less n or equal to 100 kW <u>AC</u> , to FPL's electrical service grid at the Customer's presently metered location.
	<b>W, THEREFORE,</b> for and in consideration of the mutual covenants and agreements herein set forth, the Parties hereto covenant agree as follows:
1.	<ul> <li>Definitions</li> <li>1.1 Gross Power Rating means the total manufacturer's AC nameplate generating capacity of an on-site customer-owned renewable generation system that will be interconnected to and operate in parallel with FPL's distribution facilities. For inverter-based systems, the AC generating capacity shall be calculated by multiplying the total installed DC nameplate generating capacity by 0.85 in order to account for losses during the conversion from DC to AC.</li> <li>1.2 Capitalized Terms shall have the meanings set forth in the Florida Public Service Commission Rule 25-6.065 F.A.C Interconnection and Net Metering of Customer-Owned Renewable Generation</li> </ul>
2.	Customer Qualification and Fees  2.1 Customer-owned renewable generation shall have a Gross power rating Power Rating that:  a) does not exceed 90% of the Customer's utility distribution service rating; and  b) is greater than 10 kW AC and less than or equal to 100 kW AC.
	Gross power rating Power Rating for the Customer-owned renewable generation is <u>kW AC</u> .  2.2 The Customer shall be required to pay an application fee of \$400 for this Tier 2 Customer-owned renewable generation.  2.3 In order to commence the process for interconnection, Customer shall provide FPL a completed application.
3.	General Responsibilities of the Parties  3.1 Customer-owned renewable generation shall be considered certified for interconnected operation if it has been submitted by a manufacturer to a nationally recognized testing and certification laboratory, and has been tested and listed by the laboratory for continuous interactive operation with an electric distribution system in compliance with the applicable codes and standards of IEEE 1547, IEEE 1547.1, and UL 1741. The Customer shall provide a written report that the Customer-owned renewable generation complies with the foregoing standards. The manufacturer's specification sheets will satisfy this requirement for a written report.
	3.2 Customer-owned renewable generation shall include a utility-interactive inverter, or other device certified pursuant to Section 3.1 above, that performs the function of automatically isolating the Customer-owned generation equipment from the electric

- grid in the event the electric grid loses power.
- 3.3 The Customer shall be responsible for protecting its Customer-owned renewable generation equipment, inverters, protective devices, and other system components from damage from the normal and abnormal conditions and operations that occur on the FPL system in delivering and restoring power; and shall be responsible for ensuring that Customer-owned renewable generation equipment is inspected, maintained, and tested in accordance with the manufacturer's instructions to ensure that it is operating correctly and safely.
- 3.4 The Customer agrees to provide Local Building Code Official inspection and certification of installation. The certification shall reflect that the local code official has inspected and certified that the installation was permitted, has been approved, and has met all electrical and mechanical qualifications.

(Continued on Sheet No. 9.056)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.056)

## 5. Manual Disconnect Switch

- 5.1 <u>U.L.1741 Listed, inverter-based Tier 2 customer-owned</u> renewable generation systems do not require a customer-installed manual disconnect switch.
- 5.2 5.1-Other customer-owned Tier 2 renewable generation systems that are not U.L. 1741 inverter based. FPL shall require the Customer to install, at the Customer's expense, a manual disconnect switch of the visible load break type to provide a separation point between the AC power output of the Customer-owned renewable generation and any Customer wiring connected to FPL's system. The manual disconnect switch shall be mounted separate from, but adjacent to, the FPL meter socket. The Customer shall ensure that such manual disconnect switch shall remain readily accessible to FPL and be capable of being locked in the open position with a single FPL utility padlock.
- 5.3 In the event that FPL has determined with respect to the Customer-owned renewable generation that the installation of a manual disconnect switch or switches adjacent to FPL's meter socket would not be practical from a safety perspective and/or design considerations in accordance with good engineering practices; and FPL and the customer agree upon a location on the customer's premises for the switch or switches which meet all applicable safety and/or design considerations, then, pursuant to the conditions set forth in Section 5.2 above, each manual disconnect switch shall be mounted separate from FPL's meter socket at a location agreed to by the Customer and FPL, and the customer shall install a permanent weather-proof plaque adjacent to FPL's meter socket indicating the location of the manual disconnect switch or switches.

#### 6. **Disconnection / Reconnection**

- 6.1 FPL may open the manual disconnect switch pursuant to the conditions set forth in Section 6.3 below, isolating the Customer-owned renewable generation, without prior notice to the Customer. To the extent practicable, however, prior notice shall be given. If prior notice is not given, FPL shall at the time of disconnection leave a door hanger notifying the Customer that its Customer-owned renewable generation has been disconnected, including an explanation of the condition necessitating such action. FPL will reconnect the Customer-owned renewable generation as soon as practicable after the condition(s) necessitating disconnection has been remedied.
- 6.2 Upon notice by FPL, the Customer shall be solely responsible to disconnect the Customer-owned renewable generation and Customer's other equipment if conditions on the FPL distribution system could adversely affect the Customer-owned renewable generation. FPL will not be responsible for damage to the Customer-owned renewable generation system due to adverse effects on the distribution system. Reconnection will be the Customer's responsibility and will not require an additional application.
- 6.3 FPL has the right to disconnect the Customer-owned renewable generation at any time. This may result for the following reasons, amongst others:
  - a) Emergencies or maintenance requirements on FPL's system;
  - b) Hazardous conditions existing on FPL's system due to the operation of the Customer's generating or protective equipment as determined by FPL;
  - c) Adverse electrical effects, such as power quality problems, on the electrical equipment of FPL's other electric consumers caused by the Customer-owned renewable generation as determined by FPL; and
  - d) Failure of the Customer to maintain the required insurance coverage as stated in Section 11.1 below.

# 7. <u>Modifications/Additions to Customer-owned Renewable Generation</u>

- 7.1 If the Customer-owned renewable generation is subsequently modified in order to increase its Gross power rating Power Rating, the Customer must notify FPL by submitting a new application and Interconnection Agreement specifying the modification at least thirty (30) days prior to making the modification.
- 7.2 If the Customer adds another Customer-owned renewable generation which: i.) utilizes the same utility inter-active inverter, or other device certified pursuant to Section 3.1 above, for both systems; or ii.) utilizes a separate utility inter-active inverter, or other device certified pursuant to Section 3.1 above, for each system the Customer shall provide thirty (30) calendar days notice prior to installation.

(Continued on Sheet No. 9.058)

Issued by: S. E. Romig, Director, Rates and Tariffs

## FLORIDA POWER & LIGHT COMPANY

- 7.3 In the event any Customer modifications or additions result in the input to any FPL meter so as to qualify as a Tier 3 system, then all terms and condition, including appropriate notice, of the Interconnection Agreement for Tier 3 systems shall apply. In no event shall the maximum output of the Customer owned generation system(s), which is connected to the FPL meter exceed 2 MW.
- 7.4 The Interconnection Agreement which applies in instances described in Sections 7.1, 7.2, and 7.3 above shall be determined by the combined gross power rating of the generation system(s) which is connected to the FPL meter. In all instances described in this Section 7, the Customer shall submit a new application to FPL and shall enter into a new Interconnection Agreement.

  (Continued on Sheet No. 9.058)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.057)

- 7.3 In the event any Customer modifications or additions result in the input to any FPL meter so as to qualify as a Tier 3 system, then all terms and condition, including appropriate notice, of the Interconnection Agreement for Tier 3 systems shall apply.

  In no event shall the maximum output of the Customer-owned generation system(s), which is connected to the FPL meter exceed 2 MW.
- 7.4 The Interconnection Agreement which applies in instances described in Sections 7.1, 7.2, and 7.3 above shall be determined by the combined Gross Power Rating of the generation system(s) which is connected to the FPL meter. In all instances described in this Section 7, the Customer shall submit a new application to FPL and shall enter into a new Interconnection Agreement.

## 8. **Indemnity**

- 8.1 Customer, to the extent permitted by law without waiving or limiting any defense of sovereign immunity, shall indemnify, hold harmless and defend FPL from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property (including the Customer-owned renewable generation system), fines and penalties, costs and expenses arising out of or resulting from the operation of the Customer-owned renewable generation system, except in those instances where such loss is due to the negligent action or inactions of FPL. Nothing herein shall be intended to serve as a waiver of limitation of Customer's sovereign immunity defense as allowed by law.
- 8.2 FPL shall indemnify, hold harmless and defend Customer from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property (including FPL's transmission system), fines and penalties, costs and expenses arising out of or resulting from the operation of FPL's system, except in those instances where such loss is due to the negligent action or inactions of the Customer.

# 9. <u>Limitation of Liability</u>

9.1 Liability under this Interconnection Agreement for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Interconnection Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall the indemnifying Party be liable to the other Party for any indirect, special, consequential, or punitive damages, except as authorized by this Interconnection Agreement.

## 10. Assignment

- 10.1 The Interconnection Agreement shall not be assignable by either Party without upon thirty (30) calendar days notice to the other Party and written consent of the other Party, which consent shall not be unreasonably withheld or delayed.
- 10.2 An assignee to this Interconnection Agreement shall be required to assume in writing the Customer's rights, responsibilities, and obligations under this Interconnection Agreement; or execute a new Interconnection Agreement.

# 11. Insurance

11.1 The Customer agrees to provide and maintain general liability insurance for personal and property damage, or sufficient guarantee and proof of self-insurance, in the amount of not less than \$1 million during the entire period of this Interconnection Agreement, to the extent permitted by law. Initial proof of insurance shall be in the form of a copy of the policy or certificate of insurance attached to this Interconnection Agreement evidencing the Homeowner's or other insurance policy in effect at the time of interconnection. For government entities, the policy coverage shall not exceed the entity's maximum liability established by law. Proof of self-insurance consistent with law shall satisfy this requirement.

(Continued on Sheet No. 9.059)

# 12. Renewable Energy Certificates

12.1The Customer shall retain any Renewable Energy Certificates associated with the electricity produced by their Customer owned renewable generation equipment; any additional meters necessary for measuring the total renewable electricity generated for the purposes of receiving Renewable Energy Certificates shall be installed at the Customer's expense, unless otherwise determined during negotiations for the sale of the Customer's Renewable Energy Certificates to FPL.

Issued by: S. E. Romig, Director, Rates and Tariffs

# 12. Renewable Energy Certificates

12.1The Customer shall retain any Renewable Energy Certificates associated with the electricity produced by their Customer owned renewable generation equipment; any additional meters necessary for measuring the total renewable electricity generated for the purposes of receiving Renewable Energy Certificates shall be installed at the Customer's expense, unless otherwise determined during negotiations for the sale of the Customer's Renewable Energy Certificates to FPL.

#### 13. Lease Agreements

- 13.1The Customer shall provide FPL a copy of the lease agreement, as applicable, for any and all leased interconnection equipment.
- 13.2The Customer shall not enter into any lease agreement that results in the retail purchase of electricity; or the retail sale of electricity from the Customer owned renewable generation. Notwithstanding this restriction, in the event it is determined by the Florida Public Service Commission that the Customer has entered such an agreement, the Customer shall be in breach of this Interconnection Agreement and may also become subject to the jurisdiction and regulations of the Florida Public Service Commission as a public utility.

## 14. Dispute Resolution

13.1 Disputes between the Parties shall be handled in accordance with subsection 11 of Rule 25-6.065 F.A.C. Interconnection and Net Metering of Customer Owned Renewable Generation.

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.058)

## 12. Renewable Energy Certificates

12.1 The Customer shall retain any Renewable Energy Certificates associated with the electricity produced by their Customer-owned renewable generation equipment; any additional meters necessary for measuring the total renewable electricity generated for the purposes of receiving Renewable Energy Certificates shall be installed at the Customer's expense, unless otherwise determined during negotiations for the sale of the Customer's Renewable Energy Certificates to FPL.

#### 13. Lease Agreements

- 13.1 The Customer shall provide FPL a copy of the lease agreement, as applicable, for any and all leased interconnection equipment.
- 13.2 The Customer shall not enter into any lease agreement that results in the retail purchase of electricity; or the retail sale of electricity from the Customer-owned renewable generation. Notwithstanding this restriction, in the event it is determined by the Florida Public Service Commission that the Customer has entered such an agreement, the Customer shall be in breach of this Interconnection Agreement and the lessor may become subject to the jurisdiction and regulations of the Florida Public Service Commission as a public utility.

## 14. **Dispute Resolution**

14.1 Disputes between the Parties shall be handled in accordance with subsection 11 of Rule 25-6.065 F.A.C. – Interconnection and Net Metering of Customer-Owned Renewable Generation.

#### 15. Effective Date

15.1 The Customer must execute this Interconnection Agreement and return it to FPL at least thirty (30) calendar days prior to beginning parallel operations and the Customer must begin parallel operation within one year after FPL executes the Interconnection Agreement.

# 16. **Termination**

16.1 Upon termination of this Interconnection Agreement, FPL shall open and padlock the manual disconnect switch, if applicable, and remove the Net Metering and associated FPL equipment. At the Customer's expense, the Customer agrees to permanently disconnect the Customer-owned renewable generation and associated equipment from FPL's electric service grid. The Customer shall notify FPL in writing within ten (10) calendar days that the disconnect procedure has been completed.

## 17. Amendments to Florida Public Service Commission Rules

17.1 FPL and Customer recognize that the Florida Public Service Commission rules may be amended from time to time. In the event that Florida Public Service Commission rules are modified, FPL and Customer agree to supersede and replace this Interconnection Agreement with a new Interconnection Agreement which complies with the amended Florida Public Service Commission rules.

## 18. Entire Agreement

18.1 This Interconnection Agreement supersedes all previous agreements or representations, either written or oral, heretofore in effect between FPL and the Customer, made in respect to matters herein contained, and when duly executed, this Interconnection Agreement constitutes the entire agreement between Parties hereto.

## 19. Governmental Entities

19.1 For those customers, which are government entities, provisions within this agreement will apply to the extent the agency is not legally barred from executing such provisions by State or Federal law.

IN WITNESS WHEREOF, the Parties hereto have caused this Interconnection Agreement to be duly executed in triplicate the day and year first above written.

Issued by: S. E. Romig, Director, Rates and Tariffs

First Revised Sheet No. 9.059
Cancels Original Sheet No. 9.059

# (Print or Type Name) Title: (Signature) (Print or Type Name) Title:

FLORIDA POWER & LIGHT COMPANY

(Print or Type Name)

(Continued on Sheet No. 9.060)

Issued by: S. E. Romig, Director, Rates and Tariffs

	(Continued from Sheet No. 9.059)
IN WITNESS WHEREOF, the Parties hereto above written.	o have caused this Interconnection Agreement to be duly executed the day and year first
CUSTOMER	
(Signature)	
(Print or Type Name)	
Title:	
FLORIDA POWER & LIGHT COMPANY	
(Signature)	
(Print or Type Name)	
Title:  The completed agreement may be submitted to  E-mail - scan and e-mail to Netmetering@fpl.c  Mail - send to: Net Metering  FPL - Mail code CSF-GO  9250 W. Flagler St.  Miami, FL 33174	o FPL by:
FAX - 305-552-2275	

Issued by: S. E. Romig, Director, Rates and Tariffs Effective:

# FLORIDA POWER & LIGHT COMPANY

				Iı							Renewable an or Equal		ion	
Thi	s A	greement,	is	made	and	entered	into	this			day	of	, 20,	by and
betv	veen												("Customer"), with an a	
													& LIGHT COMPANY (	'FPL"), a
Flo	rida c	orporation	with	an addr	ess of	P.O. Box	14000,	700 U		oulevard, Ju SSETH:	ıno Beach, I	FL 33408-0	)429.	
											wable gener etered location		ater than 100 kW <u>AC</u> and le	ss than or
	<b>W, T</b> ollow		)RE,	for and	in con	sideration	of the	mutua	l covenan	ts and agree	ments hereir	set forth,	the Parties hereto covenant	and agree
1.	<u>Def</u>	initions For the p	ourpos	es of th	is inte	rconnection	on agre	ement	only, the	following te	erms shall be	defined a	s follows:	
	1.1. <b>Point of Interconnection/Change of Ownership</b> – The point at which the Customer's wiring is connected to the lugs in metering cabinet where FPL's meter is located.										igs in the			
	1.2. <u>Interconnection Facilities and Distribution Upgrades</u> – All facilities and equipment on FPL's side of the Point of Interconnection/Change of Ownership, including any modifications, additions or upgrades that are necessary to physically and electrically interconnect the Customer-owned renewable generation to FPL's electric system.													
	1.3.	1.3. Prudent Utility Practice – Any of the practices, methods and acts engaged in or approved by a significant portion of the elementary during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts general accepted in the region.									dgment in easonable be limited			
	1.4.		ity C	oordina	ating								onics Engineers (IEEE), the (NERC) and the Federal	
	1.5. <u>Acceptable Level of Impact to FPL's Electric System</u> – The proposed interconnection does not have a negative impact reliability of the FPL's electric system or to its Customers.										act on the			
	1.6.	renewa inverte	ble ge r-base	eneration	on sys	tem that he AC go	will be enerati	e inter ng cap	connecte pacity sha	d to and op all be calcu	perate in pa	ırallel wit ıultiplying	ity of an on-site custom h FPL's distribution facil the total installed DC n to AC.	ities. For
	1.7.									rth in Flori ewable Gen		Service C	ommission Rule 25-6.065	F.A.C
2.		a) does r	er-ow ot exc	ned ren ceed 90	ewabl % of t	e generati	ner's ut	ility di	stribution	service rati	Power Rating; and	ng that:		
		Gross <del>p</del>	<del>ower 1</del>	rating P	ower l	Rating for	the Cu	stomei	r-owned r	enewable ge	eneration is		<u>kW AC</u> .	
	2.2.	In order	to co	mmenc	e the p	process for	r interc	onnect	ion, Custo	omer shall p	rovide FPL	a complete	ed application.	
	2.3.	intercor	necti	on requ	est. T	his applica	ation fe	e shall	cover the	e cost for pro	ocessing the	Customer	stomer-owned renewable g 's application and the cost of appact on the FPL's electric s	of the Fast

(Continued on Sheet No. 9.066)

Issued by: S. E. Romig, Director, Rates and Tariffs

such process is described in Section 8, hereto.

(Continued from Sheet No. 9.066)

#### 4. Inspection and On-Going Compliance

- 4.1. All initial physical inspections and inspection of Customer's documents must be completed by FPL within thirty (30) calendar days of receipt of the Customer's executed Interconnection Agreement. If the inspection is delayed at the Customer's request, the Customer shall contact FPL to reschedule an inspection. FPL shall reschedule the inspection within ten (10) business days of the Customer's request. Physical inspections and inspection of documents must be completed and approved by FPL prior to commencement of service of the Customer-owned renewable generation system.
- 4.2. Any inspection or observation by FPL shall not be deemed to be or construed as any representation, assurance, guarantee, or warranty by FPL of the safety, durability, suitability, or reliability of the Customer-owned Renewable Generation or any associated control, protective, and safety devices owned or controlled by the Customer or the quality of power produced by the Customer-owned Renewable Generation.
- 4.3. FPL shall have the right to inspect Customer-owned renewable generation and its component equipment to ensure compliance with this Interconnection Agreement. FPL's system inspections shall include, but shall not be limited to:
  - a) any installed manual disconnect switch, as applicable;
  - b) FPL's metering equipment;
  - c) Any additional metering equipment installed by Customer; and
  - d) Customer utility-interactive inverter, protective device or other similar devices for compliance to applicable code and standards, as described in this Interconnection Agreement.
- 4.4. FPL shall also have the right to review Customer documents to ensure compliance with this Interconnection Agreement. FPL shall have the right to, at a minimum review:
  - a) technical design parameters of the system and the manufacture's installation;
  - b) operation and maintenance instructions to ensure compliance with IEEE and UL standards;
  - c) local inspection and certifications; and
  - d) other documents associated with specific installations.
- 4.5. FPL will provide Customer with as much notice as reasonably practicable, either in writing, e-mail, facsimile or by phone as to when FPL will conduct inspection and/or document review. Upon reasonable notice, or at any time without notice in the event of an emergency or hazardous condition, FPL shall have access to the Customer's premises for the purpose of accessing the manual disconnect switch, performing an inspection or disconnection, or, if necessary, to meet FPL's legal obligation to provide service to its Customers.

## 5. Manual Disconnect Switch

- 5.1 U.L.1741 Listed, inverter-based Tier 3 customer-owned renewable generation systems do not require a customer-installed manual disconnect switch.
- 5.2 5.1. Other customer-owned Tier 3 renewable generation systems that are not U.L. 1741 inverter based. FPL shall require the Customer to install, at the Customer's expense, a manual disconnect switch of the visible load break type to provide a separation point between the AC power output of the Customer-owned renewable generation and any Customer wiring connected to FPL's system. The manual disconnect switch shall be mounted separate from, but adjacent to, the FPL meter socket. The Customer shall ensure that such manual disconnect switch shall remain readily accessible to FPL and be capable of being locked in the open position with a single FPL utility padlock.

#### 6. <u>Disconnection / Reconnection</u>

5.3 6.1. FPL may open the In the event that FPL has determined in respect of the Customer-owned renewable generation that the installation of a manual disconnect switch pursuant to the conditions set forth in Section 6.3 below, isolating the Customer owned renewable generation, without prior notice to the Customer. To the extent practicable, however, prior notice shall be given. If prior notice is not given, FPL shall at the time of disconnection leave a door hanger notifying the Customer that its Customer owned renewable generation has been disconnected, including an explanation of the condition necessitating such action. FPL will reconnect the Customer owned renewable generation as soon as practicable after the condition(s) necessitating disconnection has been remedied or switches adjacent to FPL's meter socket would not be practical from a safety

Issued by: S. E. Romig, Director, Rates and Tariffs

First Revised Sheet No. 9.067 Cancels Original Sheet No. 9.067

## FLORIDA POWER & LIGHT COMPANY

perspective and/or design considerations in accordance with good engineering practices; and FPL and the customer agree upon a location on the customer's premises for the switch or switches which meet all applicable safety and/or design considerations, then, pursuant to the conditions set forth in Section 5.2 above, each manual disconnect switch shall be mounted separate from FPL's meter socket at a location agreed to by the Customer and FPL, and the customer shall install a permanent weather-proof plaque adjacent to FPL's meter socket indicating the location of the manual disconnect switch or switches.

(Continued on Sheet No. 9.068)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.067)

# 6. Disconnection / Reconnection

- 6.1 FPL may open the manual disconnect switch pursuant to the conditions set forth in Section 6.3 below, isolating the Customer-owned renewable generation, without prior notice to the Customer. To the extent practicable, however, prior notice shall be given. If prior notice is not given, FPL shall at the time of disconnection leave a door hanger notifying the Customer that its Customer-owned renewable generation has been disconnected, including an explanation of the condition necessitating such action. FPL will reconnect the Customer-owned renewable generation as soon as practicable after the condition(s) necessitating disconnection has been remedied.
- 6.2 Upon notice by FPL, the Customer shall be solely responsible to disconnect the Customer-owned renewable generation and Customer's other equipment if conditions on the FPL distribution system could adversely affect the Customer-owned renewable generation. FPL will not be responsible for damage to the Customer-owned renewable generation system due to adverse effects on the distribution system. Reconnection will be the Customer's responsibility and will not require an additional application.
- 6.3 FPL has the right to disconnect the Customer-owned renewable generation at any time. This may result for the following reasons, amongst others:
  - a) Emergencies or maintenance requirements on FPL's system;
  - b) Hazardous conditions existing on FPL's system due to the operation of the Customer's generating or protective equipment as determined by FPL;
  - c) Adverse electrical effects, such as power quality problems, on the electrical equipment of FPL's other electric consumers caused by the Customer-owned renewable generation as determined by FPL; and
  - d) Failure of the Customer to maintain the required insurance coverage as stated in Section 13.1 below.

# 7. Modifications/Additions to Customer-owned Renewable Generation

- 7.1. If the Customer-owned renewable generation is subsequently modified in order to increase its Gross power rating Power Rating, the Customer must notify FPL by submitting a new application specifying the modification at least thirty (30) calendar days prior to making the modification.
- 7.2. If the Customer adds another Customer-owned renewable generation system which: i.) utilizes the same utility inter-active inverter, or other device certified pursuant to Section 3.1 above, for both systems; or ii.) utilizes a separate utility inter-active inverter, or other device certified pursuant to Section 3.1 above, for each system the Customer shall provide thirty (30) calendar days notice prior to installation.
- 7.3. The Interconnection Agreement which applies in instances described in Sections 7.1 and 7.2 above shall be determined by the combined Gross power rating Power Rating of the generation system(s) which is connected to the FPL meter. In all instances described in this Section 7, the Customer shall submit a new application to FPL and shall enter into a new Interconnection Agreement. In no event shall the maximum output of the Customer-owned generation system(s), which is connected to the FPL meter exceed 2 MW.

## 8. Interconnection Study Process

## 8.1. Fast Track Screens

- 8.1.1. Fast Track Screens, described in Attachment 3 hereto, provide for an initial review of Customer's request for interconnection which evaluates whether the Customer's request exceeds an acceptable level of impact to the FPL electric system, consistent with prudent utility practice.
- 8.1.2. In order to pass the Fast Track Screens, Customer's interconnection shall not exceed established industry criteria, as set forth in the Interconnection Study Process and shall not require construction of Interconnection Facilities and Distribution Upgrades on FPL's electric system.
- 8.1.3. If the Customer's interconnection request passes the Fast Track Screens, the Customer's request shall be approved and Customer will be provided an executable Interconnection Agreement.

Issued by: S. E. Romig, Director, Rates and Tariffs

# First Revised Sheet No. 9.068 Cancels Original Sheet No. 9.068

## FLORIDA POWER & LIGHT COMPANY

8.2. In those instances is which the Customer owned renewable generation does not pass the Fast Track Screens the Customer may elect to proceed with an Interconnection Study. In general, the purpose of the Interconnection Study will be to better determine what material adverse impacts the Customer owned renewable generation has on the FPL system and what facilities will be required to resolve such impacts.

(Continued on Sheet No. 9.069)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.068)

8.2 In those instances in which the Customer-owned renewable generation does not pass the Fast Track Screens the Customer may elect to proceed with an Interconnection Study. In general, the purpose of the Interconnection Study will be to better determine what material adverse impacts the Customer-owned renewable generation has on the FPL system and what facilities will be required to resolve such impacts.

#### 8.3 Interconnection Study

- 8.3.1. The Interconnection Study Process shall be used by a Customer proposing to interconnect its certified Customer-owned renewable generation, in those instances in which such system did not pass the Fast Track Screens.
- 8.3.2. Upon Customer execution of the Interconnection Agreement; the Customer shall be obligated to pay for any and all costs for Interconnection Facilities and Distribution Upgrades identified in the Interconnection Study in order to interconnect the proposed Customer-owned renewable generation.
- 8.3.3. The Interconnection Study fee shall be \$2000.00 and will be invoiced to the Customer once it is determined that an Interconnection Study will be required. This determination will be made within ten (10) business days after a completed application is received. To the extent the actual costs of the Interconnection Study total less than \$2,000, the difference between the Interconnection Study fee and the actual costs will be refunded to the Customer within thirty (30) calendar days with no interest.

# 9. Cost Responsibility for Interconnection Facilities and Distribution Upgrades

- 9.1. The Customer shall pay FPL for the actual cost of any and all FPL Interconnection Facilities and Distribution Upgrades, itemized in Attachment 2, required to implement this Interconnection Agreement. FPL shall provide a best estimate cost, including overheads, for the purchase and construction of FPL's Interconnection Facilities and Distribution Upgrades required and shall provide a detailed itemization of such costs.
- 9.2. The Customer shall be responsible for all reasonable expenses, including overheads, associated with: i.) owning, operating, maintaining, repairing, and replacing its own Interconnection Facilities and other equipment; and ii.) operating, maintaining, repairing, and replacing FPL's Interconnection Facilities and Distribution Upgrades.
- 9.3. FPL shall design, procure, construct, install and own the Interconnection Facilities and Distribution Upgrades, described in Attachment 2, required for FPL to implement this Interconnection Agreement. If FPL and the Customer agree, the Customer may construct Interconnection Facilities and Distribution Upgrades that are located on land owned by the Customer. The actual cost of Interconnection Facilities and Distribution Upgrades, including overheads, shall be directly assigned to and paid by the Customer.

#### 10. Indemnity

- 10.1. Customer, to the extent of the law without waiving or limiting any defense of sovereign immunity, shall indemnify, hold harmless and defend FPL from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property (including the Customer-owned renewable generation system), fines and penalties, costs and expenses arising out of or resulting from the operation of the Customer-owned renewable generation system, except in those instances where such loss is due to the negligent action or inactions of FPL. Nothing herein shall be intended to serve as a waiver or limitation of Customer's sovereign immunity defense as allowed by law.
- 11.1. Liability under this Interconnection Agreement for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Interconnection Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall the indemnifying Party be liable to the other Party for any indirect, special, consequential, or punitive damages, except as authorized by this Interconnection AgreementFPL.

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.069)

10.2. FPL shall indemnify, hold harmless and defend Customer from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property (including FPL's transmission system), fines and penalties, costs and expenses arising out of or resulting from the operation of FPL's system, except in those instances where such loss is due to the negligent action or inactions of the Customer.

# 11. Limitation of Liability

11.1. Liability under this Interconnection Agreement for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Interconnection Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall the indemnifying Party be liable to the other Party for any indirect, special, consequential, or punitive damages, except as authorized.

#### 12. Assignment

- 12.1. The Interconnection Agreement shall-not be assignable by either Pparty without upon thirty (30) calendar days notice to the other party and written consent of the other Party, which consent shall not be unreasonably withheld or delayed.
- 12.2. An assignee to this Interconnection Agreement shall be required to assume in writing the Customer's rights, responsibilities, and obligations under this Interconnection Agreement; or execute a new Interconnection Agreement.

# 13. <u>Insurance</u>

13.1. The Customer agrees to provide and maintain general liability insurance for personal and property damage, or sufficient guarantee and proof of self-insurance, in the amount of not less than \$2 million during the entire period of this Interconnection Agreement, to the extent permitted by law. Initial proof of insurance shall be in the form of a copy of the policy or certificate of insurance attached to this Interconnection Agreement evidencing the Homeowner's or other insurance policy in effect at the time of interconnection. For government entities, the policy coverage shall not exceed the entity's maximum liability established by law. Proof of self-insurance consistent with law shall satisfy this requirement.

## 14. Renewable Energy Certificates

14.1 The Customer shall retain any Renewable Energy Certificates associated with the electricity produced by their Customer-owned renewable generation equipment; any additional meters necessary for measuring the total renewable electricity generated for the purposes of receiving Renewable Energy Certificates shall be installed at the Customer's expense, unless otherwise determined during negotiations for the sale of the Customer's Renewable Energy Certificates to FPL.

## 15. Billing, Payment, and Financial Security

- 15.1. FPL shall bill the Customer for the design, engineering, construction, and procurement costs of FPL's Interconnection Facilities and Distribution Upgrades contemplated by this Interconnection Agreement on a monthly basis, or as otherwise agreed by the Parties. The Customer shall pay each bill within thirty (30) calendar days of receipt, or as otherwise agreed to by the Parties.
- 15.2. Within three months of completing the construction and installation of FPL's Interconnection Facilities and Distribution Upgrades, described in Attachment 2, required to implement this Interconnection Agreement, FPL shall provide the Customer with a final accounting report of any difference between i.) the Customer's cost responsibility for the actual cost of such Interconnection Facilities and Distribution Upgrades, and ii.) the Customer's previous aggregate payments to FPL for such Interconnection Facilities and Distribution Upgrades. If the Customer's cost responsibility exceeds its previous aggregate payments, FPL shall invoice the Customer for the amount due, without interest, and the Customer shall make payment to FPL within thirty (30) calendar days. If the Customer's previous aggregate payments exceed its cost

Issued by: S. E. Romig, Director, Rates and Tariffs

#### FLORIDA POWER & LIGHT COMPANY

Customer with a final accounting report of any difference between i.) the Customer's cost responsibility for the actual cost of such Interconnection Facilities and Distribution Upgrades, and ii.) the Customer's previous aggregate payments to FPL for such Interconnection Facilities and Distribution Upgrades. If the Customer's cost responsibility exceeds its previous aggregate payments, FPL shall invoice the Customer for the amount due, without interest, and the Customer shall make payment to FPL within thirty (30) calendar days. If the Customer's previous aggregate payments exceed its cost responsibility under this Interconnection Agreement, FPL shall refund to the Customer an amount equal to the difference, without interest, within thirty (30) calendar days of the final accounting report.

- 15.3. At least twenty (20) calendar days prior to the commencement of the design, procurement, installation, or construction of a discrete portion of FPL's Interconnection Facilities and Distribution Upgrades, the Customer shall provide FPL, at the Customer's option, a guarantee, a surety bond, letter of credit or other form of security that is reasonably acceptable to FPL and is consistent with the Uniform Commercial Code of the jurisdiction where the Point of Interconnection is located. Such security for payment shall be in an amount sufficient to cover the costs for constructing, designing, procuring and installing the applicable portion of FPL's Interconnection Facilities and Distribution Upgrades and shall be reduced on a dollar for dollar basis for payments made to FPL under this Interconnection Agreement during its term.
- 15.4. In accordance with Section 9.2 above, the Customer shall be billed by FPL for operation, maintaining, repairing, and replacining FPL's Interconnection Facilities and Distribution Upgrades. The Customer shall be billed upon completion of such work by FPL; Customer shall make payment to FPL within twenty (20) calendar days of the receipt of FPL's bill. (Continued on Sheet No. 9.071)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.070)

- 15.2. Within three months of completing the construction and installation of FPL's Interconnection Facilities and Distribution Upgrades, described in Attachment 2, required to implement this Interconnection Agreement, FPL shall provide the Customer with a final accounting report of any difference between i.) the Customer's cost responsibility for the actual cost of such Interconnection Facilities and Distribution Upgrades, and ii.) the Customer's previous aggregate payments to FPL for such Interconnection Facilities and Distribution Upgrades. If the Customer's cost responsibility exceeds its previous aggregate payments, FPL shall invoice the Customer for the amount due, without interest, and the Customer shall make payment to FPL within thirty (30) calendar days. If the Customer's previous aggregate payments exceed its cost responsibility under this Interconnection Agreement, FPL shall refund to the Customer an amount equal to the difference, without interest, within thirty (30) calendar days of the final accounting report.
- 15.3. At least twenty (20) calendar days prior to the commencement of the design, procurement, installation, or construction of a discrete portion of FPL's Interconnection Facilities and Distribution Upgrades, the Customer shall provide FPL, at the Customer's option, a guarantee, a surety bond, letter of credit or other form of security that is reasonably acceptable to FPL and is consistent with the Uniform Commercial Code of the jurisdiction where the Point of Interconnection is located. Such security for payment shall be in an amount sufficient to cover the costs for constructing, designing, procuring and installing the applicable portion of FPL's Interconnection Facilities and Distribution Upgrades and shall be reduced on a dollar-for-dollar basis for payments made to FPL under this Interconnection Agreement during its term.
- 15.4. In accordance with Section 9.2 above, the Customer shall be billed by FPL for operation, maintaining, repairing, and replacing FPL's Interconnection Facilities and Distribution Upgrades. The Customer shall be billed upon completion of such work by FPL; Customer shall make payment to FPL within twenty (20) calendar days of the receipt of FPL's bill.

#### 16. Lease Agreements

- 16.1. The Customer shall provide FPL a copy of the lease agreement, as applicable, for any and all leased interconnection equipment.
- 16.2. The Customer shall not enter into any lease agreement that results in the retail purchase of electricity; or the retail sale of electricity from the Customer-owned renewable generation. Notwithstanding this restriction, in the event it is determined by the Florida Public Service Commission that the Customer has entered such an agreement, the Customer shall be in breach of this Interconnection Agreement and <a href="the lessor">the lessor</a> may <a href="https://doi.org/10.1001/journal.org/10.10

#### 17. **Dispute Resolution**

17.1. Disputes between the Parties shall be handled in accordance with subsection 11 of Florida Public Service Commission Rule 25-6.065 F.A.C. - Interconnection and Net Metering of Customer-Owned Renewable Generation.

## 18. Effective Date

18.1. The Customer must execute this Interconnection Agreement and return it to FPL at least thirty (30) calendar days prior to beginning parallel operations and the Customer must begin parallel operation within one year after FPL executes the Interconnection Agreement.

#### 19. **Termination**

19.1. Upon termination of this Interconnection Agreement, FPL shall open and padlock the manual disconnect switch, if applicable, and remove the Net Metering and associated FPL equipment. At the Customer's expense, the Customer agrees to permanently disconnect the Customer-owned renewable generation and associated equipment from FPL's electric service grid. The Customer shall notify FPL in writing within ten (10) calendar days that the disconnect procedure has been completed.

Issued by: S. E. Romig, Director, Rates and Tariffs

## FLORIDA POWER & LIGHT COMPANY

## 20. Amendments to Florida Public Service Commission Rules

20.1. FPL and Customer recognize that the Florida Public Service Commission rules may be amended from time to time. In the event that Florida Public Service Commission rules are modified, FPL and Customer agree to supersede and replace this Interconnection Agreement with a new Interconnection Agreement which complies with the amended Florida Public Service Commission rules.

# 21. Notices

21.1. This Interconnection Agreement, any written notice, demand, or request required or authorized in connection with this
Total and the American American the Handaman decreases the Halling of the control
Interconnection Agreement shall be deemed properly given if delivered in person, delivered by recognized national courier service
or sent by first class mail, postage prepaid, to the person specified below:
CUSTOMER:

(Continued on Sheet No. 9.072)

Issued by: S. E. Romig, Director, Rates and Tariffs

	(Continued from Sheet No. 9.071)							
<u>20.</u>	Amendments to Florida Public Service Commission Rules							
	20.1 FPL and Customer recognize that the Florida Public Service Commission rules may be amended from time to time. In the event that Florida Public Service Commission rules are modified, FPL and Customer agree to supersede and replace this Interconnection Agreement with a new Interconnection Agreement which complies with the amended Florida Public Service Commission rules.							
<u>21.</u>	<u>Notices</u>							
	21.1 This Interconnection Agreement, any written notice, demand, or request required or authorized in connection with this Interconnection Agreement shall be deemed properly given if delivered in person, delivered by recognized national courier service, or sent by first class mail, postage prepaid, to the person specified below:							
<u>22.</u>	Entire Agreement							
	22.1 This Interconnection Agreement supersedes all previous agreements or representations, either written or oral, heretofore in effect between FPL and the Customer, made in respect to matters herein contained, and when duly executed, this Interconnection Agreement constitutes the entire agreement between Parties hereto.							
23.	Governmental Entities							
	23.1 For those customers, which are government entities, provisions within this agreement will apply to the extent the agency is not legally barred from executing such provisions by State or Federal law.  CUSTOMER:  FPL:							
<del>IN V</del>	WITNESS WHEREOF, the Parties hereto have caused this Interconnection Agreement to be duly executed in triplicate the day and first above written.							

# FLORIDA POWER & LIGHT COMPANY

<del>CUSTOMER</del>								
	(Signature)							
	(Print or Type Name)							
<u> Гitle:</u>								
Witness:								

(Continued on Sheet No. 9.072.1)


Issued by: S. E. Romig, Director, Rates and Tariffs

	(Continued from Sheet No. 9.072)
IN WITNESS WHEREOF, the Parties hereto above written.	have caused this Interconnection Agreement to be duly executed the day and year first
FLORIDA POWER & LIGHT COMPANY	
(Signature)	
(Print or Type Name)	
Title:	
CUSTOMER	
(Signature)	
(Print or Type Name)	
Title:	
Witness: (Print or Type Name)	_
Title:	
The completed agreement may be submitted to B. E-mail - scan and e-mail to Netmetering@fpl.co	<del></del>
Mail - send to: Senior Manager, Wholesale S FPL - Mail code TSP/LFO 4200 West Flagler St. Miami, FL 33134	
Phone – (305) 442-5199	
FAX - 305-552-2275	

# (Continued from Sheet No. 9.075)

- 2.1.1 If the proposed Customer-owned renewable generation system is to be interconnected on single-phase shared secondary, the aggregate generation capacity on the shared secondary, including the proposed Customer-owned renewable generation system, shall not exceed 90% of the Customer's utility distribution service rating.
- 2.1.2 If the proposed Customer-owned renewable generation system is single-phase and is to be interconnected on a center tap neutral of a 240 volt service, its addition shall not create an imbalance between the two sides of the 240 volt service of more than 20 % of the nameplate rating of the service transformer.
- 2.1.3 The proposed Customer-owned renewable generation system, in aggregate with other generation interconnected to the transmission side of a substation transformer feeding the circuit where the Customer-owned renewable generation system proposes to interconnect shall not exceed 10 MW in an area where there are known, or posted, transient stability limitations to generating units located in the general electrical vicinity (e.g., three or four transmission busses from the Point of Interconnection/Change of Ownership).
- 2.1.4 No construction of facilities by FPL on its own system shall be required to accommodate the Customer-owned renewable generation system.
- 2.2 If the proposed interconnection passes the Fast Track Screens, the interconnection request shall be approved and FPL will provide the Customer an executable Interconnection Agreement within ten (10) business days after such determination.

Issued by: S. E. Romig, Director, Rates and Tariffs



		Intercon	ection Agre		Customer-( - 10 kW or		enewable Ge	eneration		
This Agre	eement, is		entered i				("Custon	ner"), with	an	and between address of
("FPL"), a F	Florida corpora	tion with an a	address of P.0		00, 700 Uni	verse Bou				Γ COMPANY Э.
	<b>S</b> , the Customervice grid at the					owned rer	newable gen	eration, 10 kW	V AC or	less, to FPL's
NOW, THE		or and in cor	sideration of	the mutual	covenants	and agree	ments herein	set forth, the	Parties h	ereto covenant
re in	ross Power R newable gener	ration systen ystems, the	n that will b AC generati	e interconne	ected to and shall be c	d operate alculated	in parallel v	with FPL's dising the total in	tribution	ustomer-owned a facilities. For DC nameplate
	apitalized Ter terconnection							Commission R	ule 25-6	5.065 F.A.C
2.1. C	b) is 10	ed renewable s not exceed ) kW AC or	generation s 90% of the Cless.	ustomer's u	ıtility distrib	oution serv	vice rating; a			
2.2. T	Gross Power R The Customer ystem.								l renewa	able generation
2.3. I	n order to com	mence the pr	rocess for int	erconnection	n the Custo	mer shall	provide FPL	a completed a	pplicatio	on.
3.1. C	y a manufact	ed renewable urer to a nat continuous ir	e generation ionally reco	gnized testineration with	ng and cert an electric	ification l	laboratory, a	nd has been to	ested and	been submitted d listed by the oplicable codes
S	Customer-owner ection 3.1 about the electric grid	ve, that perfo	orms the fund	tion of auto	matically is					
3.3. T p tl	The Customer protective device that occur on the	shall be reces, and other FPL system eration equip	esponsible for system comment is inspection.	or protection inponents from and restorated, maint	ng its Cust rom damage ring power;	e from the and shall	e normal and be responsib	l abnormal con ole for ensurin	nditions g that Cu	nent, inverters, and operations astomer-owned instructions to
				_		_				he certification been approved,

(Continued on Sheet No. 9.051)

Issued by: S. E. Romig, Director, Rates and Tariffs Effective:

and has met all electrical and mechanical qualifications.

(Continued from Sheet No. 9.050)

- 3.5 The Customer shall notify FPL at least ten (10) calendar days prior to initially placing Customer's equipment and protective apparatus in service and FPL shall have the right to have personnel present on the in-service date.
- 3.6 Interconnection Agreement shall be executed by FPL within thirty (30) calendar days of receipt of a completed application.

#### **Inspection and On-going Compliance**

4.1 FPL will provide Customer with as much notice as reasonably practicable; either in writing, e-mail, facsimile or by phone as to when FPL may conduct inspection and/or document review. Upon reasonable notice, or at any time without notice in the event of an emergency or hazardous condition, FPL shall have access to the Customer's premises for the purpose of accessing the manual disconnect switch, performing an inspection or disconnection, or, if necessary, to meet FPL's legal obligation to provide service to its Customers.

#### **Manual Disconnect Switch**

- 5.1 U.L.1741 Listed, inverter-based Tier 1 customer-owned renewable generation systems do not require a customer-installed manual disconnect switch.
- 5.2 Other customer-owned Tier 1 renewable generation systems that are not inverter based. FPL shall require the Customer to install, at the Customer's expense, a manual disconnect switch of the visible load break type to provide a separation point between the AC power output of the Customer-owned renewable generation and any Customer wiring connected to FPL's system. The manual disconnect switch shall be mounted separate from, but adjacent to, the FPL meter socket. The Customer shall ensure that such manual disconnect switch shall remain readily accessible to FPL and be capable of being locked in the open position with a single FPL utility padlock.
- 5.3 In the event that FPL has determined with respect to the Customer-owned renewable generation that the installation of a manual disconnect switch or switches adjacent to FPL's meter socket would not be practical from a safety perspective and/or design considerations in accordance with good engineering practices; and FPL and the customer agree upon a location on the customer's premises for the switch or switches which meet all applicable safety and/or design considerations, then, pursuant to the conditions set forth in Section 5.2 above, each manual disconnect switch shall be mounted separate from FPL's meter socket at a location agreed to by the Customer and FPL, and the customer shall install a permanent weather-proof plaque adjacent to FPL's meter socket indicating the location of the manual disconnect switch or switches.

#### **Disconnection / Reconnection**

- 6.1 FPL may open the manual disconnect switch, if available, or disconnect the Customer's meter, pursuant to the conditions set forth in Section 6.3 below, isolating the Customer-owned renewable generation, without prior notice to the Customer. To the extent practicable, however, prior notice shall be given. If prior notice is not given, FPL shall at the time of disconnection leave a door hanger notifying the Customer that its Customer-owned renewable generation has been disconnected, including an explanation of the condition necessitating such action. FPL will reconnect the Customer-owned renewable generation as soon as practicable after the condition(s) necessitating disconnection has been remedied.
- 6.2 Upon notice by FPL, the Customer shall be solely responsible to disconnect the Customer-owned renewable generation and Customer's other equipment if conditions on the FPL distribution system could adversely affect the Customer-owned renewable generation. FPL will not be responsible for damage to the Customer-owned renewable generation system due to adverse effects on the distribution system. Reconnection will be the Customer's responsibility and will not require an additional application.

(Continued on Sheet No. 9.052)

(Continued from Sheet No. 9.051)

- 6.3 FPL has the right to disconnect the Customer-owned renewable generation at any time. This may result for the following reasons, amongst others:
  - a) Emergencies or maintenance requirements on FPL's system;
  - b) Hazardous conditions existing on FPL's system due to the operation of the Customer's generating or protective equipment as determined by FPL; and
  - c) Adverse electrical effects, such as power quality problems, on the electrical equipment of FPL's other electric consumers caused by the Customer-owned renewable generation as determined by FPL.

# 7. Modifications/Additions to Customer-owned Renewable Generation

- 7.1 If the Customer-owned renewable generation system is subsequently modified in order to increase its Gross Power Rating, the Customer must notify FPL by submitting a new application or interconnection agreement specifying the modification at least thirty (30) calendar days prior to making the modification.
- 7.2 If the Customer adds another Customer-owned renewable generator system which i.) Utilizes the same utility inter-active inverter, or other device certified pursuant to Section 3.1 above, for both systems; and ii.) Utilizes a separate utility inter-active inverter, or other device certified pursuant to Section 3.1 above, for each system the Customer shall provide thirty (30) calendar days notice prior to installation.
- 7.3 In the event any Customer modifications or additions result in the input to any FPL meter so as to qualify as a Tier 2 or Tier 3 system, then all terms and conditions, including appropriate notice, of the Interconnection Agreement for Tier 2 or Tier 3 systems shall apply.
- 7.4 The Interconnection Agreement which applies in instances described in Sections 7.1, 7.2, and 7.3 above shall be determined by the combined gross power rating of the generation system(s) which is connected to the FPL meter. In all instances described in this Section 7, the Customer shall submit a new application to FPL and shall enter into a new Interconnection Agreement. In no event shall the maximum output of the Customer-owned generation system(s), which is connected to the FPL meter exceed 2 MW Gross Power Rating.

# 8. **Indemnity**

- 8.1 Customer, to the extent permitted by law without waiving or limiting any defense of sovereign immunity, shall indemnify, hold harmless and defend FPL from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property, (including the Customer-owned renewable generation system), fines and penalties, costs and expenses arising out of or resulting from the operation of the Customer-owned renewable generation system, except in those instances where such loss is due to the negligent action or inactions of FPL. Nothing herein shall be intended to serve as a waiver or limitation of Customer's sovereign immunity defense as allowed by law.
- 8.2 FPL shall indemnify, hold harmless and defend Customer from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property (including FPL's transmission system), fines and penalties, costs and expenses arising out of or resulting from the operation of FPL's system, except in those instances where such loss is due to the negligent action or inactions of the Customer.

(Continued on Sheet No. 9.053)

(Continued from Sheet No. 9.052)

# 9. <u>Limitation of Liability</u>

9.1 Liability under this Interconnection Agreement for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Interconnection Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall the indemnifying Party be liable to the other Party for any indirect, special, consequential, or punitive damages, except as authorized.

## 10. Assignment

- 10.1 The Interconnection Agreement shall be assignable by either Party upon thirty (30) calendar days notice to the other Party and written consent of the other Party, which consent shall not be unreasonably withheld or delayed.
- 10.2 An assignee to this Interconnection Agreement shall be required to assume in writing the Customer's rights, responsibilities, and obligations under this Interconnection Agreement; or execute a new Interconnection Agreement.

#### 11. Insurance

11.1 FPL recommends that the Customer maintain Liability Insurance for Personal Injury and Property damage in amount of not less than \$100,000 during the entire term of this Interconnection Agreement to the extent permitted by law. For government entities, the policy coverage shall not exceed the entity's maximum liability established by law.

## 12. Renewable Energy Certificates

12.1 The Customer shall retain any Renewable Energy Certificates associated with the electricity produced by their Customerowned renewable generation equipment; any additional meters necessary for measuring the total renewable electricity generated for the purposes of receiving Renewable Energy Certificates shall be installed at the Customer's expense, unless otherwise determined during negotiations for the sale of the Customer's Renewable Energy Certificates to FPL.

# 13. Lease Agreements

- 13.1 The Customer shall provide FPL a copy of the lease agreement, as applicable, for any and all leased interconnection equipment.
- 13.2 The Customer shall not enter into any lease agreement that results in the retail purchase of electricity; or the retail sale of electricity from the Customer-owned renewable generation. Notwithstanding this restriction, in the event it is determined by the Florida Public Service Commission that the Customer has entered such an agreement, the Customer shall be in breach of this Interconnection Agreement and the lessor may become subject to the jurisdiction and regulations of the Florida Public Service Commission as a public utility.

# 14. **Dispute Resolution**

14.1 Disputes between the Parties shall be handled in accordance with subsection 11 of Florida Public Service Commission Rule 25 6.065 F.A.C. - Interconnection and Net Metering of Customer-owned renewable generation.

#### 15. Effective Date

15.1 The Customer must execute this Interconnection Agreement and return it to FPL at least thirty (30) calendar days prior to beginning parallel operations and the Customer must begin parallel operation within one year after FPL executes the Interconnection Agreement.

# 16. **Termination**

16.1 Upon termination of this Interconnection Agreement, FPL shall open and padlock the manual disconnect switch, if applicable, and remove the Net Metering and associated FPL equipment. At the Customer's expense, the Customer agrees to permanently disconnect the Customer-owned renewable generation and associated equipment from FPL's electric service grid. The Customer shall notify FPL in writing within ten (10) calendar days that the disconnect procedure has been completed.

(Continued on Sheet No. 9.054)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.053)

## 17. Amendments to Florida Public Service Commission Rules

17.1 FPL and Customer recognize that the Florida Public Service Commission rules may be amended from time to time. In the event that Florida Public Service Commission rules are modified, FPL and Customer agree to supersede and replace this Interconnection Agreement with a new Interconnection Agreement which complies with the amended Florida Public Service Commission rules.

# 18. Entire Agreement

18.1 This Interconnection Agreement supersedes all previous agreements or representations, either written or oral, heretofore in effect between FPL and the Customer, made in respect to matters herein contained, and when duly executed, this Interconnection Agreement constitutes the entire agreement between Parties hereto.

#### 19. Governmental Entities

19.1 For those customers, which are government entities, provisions within this agreement will apply to the extent the agency is not legally barred from executing such provisions by State or Federal law.

(Continued on Sheet No. 9.054)

Issued by: S. E. Romig, Director, Rates and Tariffs

# FLORIDA POWER & LIGHT COMPANY

		(Continued from Sheet No. 9.053.1)
IN WITNESS Wabove written.	THEREOF, the Parties hereto	have caused this Interconnection Agreement to be duly executed the day and year first
CUSTOMER		
	(Signature)	-
	int or Type Name)	_
Title:		-
	TER & LIGHT COMPANY	_
(Prin	t or Type Name)	_
Title:		-
The completed ag	reement may be submitted to	FPL by:
E-mail - scan and	l e-mail to Netmetering@fpl.c	<u>com</u>
Mail - send to:	Net Metering FPL – Mail code CSF-GO 9250 W. Flagler St. Miami, FL 33174	
FAX - 305-552-2	275	

Interconnection Agreement for Customer-Owned Renewable Generation Tier 2 – Greater than 10 kW and Less than or Equal to 100 kW									
This Agreement, is made and entered into this day of, 20, by and between									
("Customer"), with an address of and FLORIDA POWER & LIGHT COMPANY									
("FPL"), a Florida corporation with an address of P.O. Box 14000, 700 Universe Boulevard, Juno Beach, FL 33408-0429.  WITNESSETH:									
<b>WHEREAS,</b> the Customer has requested to interconnect its Customer-owned renewable generation, greater than 10 kW AC and less than or equal to 100 kW AC, to FPL's electrical service grid at the Customer's presently metered location.									
<b>NOW, THEREFORE,</b> for and in consideration of the mutual covenants and agreements herein set forth, the Parties hereto covenant and agree as follows:									
<ol> <li>Definitions         <ol> <li>1.1 Gross Power Rating means the total manufacturer's AC nameplate generating capacity of an on-site customer-owned renewable generation system that will be interconnected to and operate in parallel with FPL's distribution facilities. For inverter-based systems, the AC generating capacity shall be calculated by multiplying the total installed DC nameplate generating capacity by 0.85 in order to account for losses during the conversion from DC to AC.</li> </ol> </li> </ol>									
1.2 Capitalized Terms shall have the meanings set forth in the Florida Public Service Commission Rule 25-6.065 F.A.C Interconnection and Net Metering of Customer-Owned Renewable Generation.									
<ol> <li>Customer Qualification and Fees</li> <li>2.1 Customer-owned renewable generation shall have a Gross Power Rating that:         <ul> <li>a) does not exceed 90% of the Customer's utility distribution service rating; and</li> <li>b) is greater than 10 kW AC and less than or equal to 100 kW AC.</li> </ul> </li> </ol>									
Gross Power Rating for the Customer-owned renewable generation iskW AC.  2.2 The Customer shall be required to pay an application fee of \$400 for this Tier 2 Customer-owned renewable generation.  2.3 In order to commence the process for interconnection, Customer shall provide FPL a completed application.									
3. General Responsibilities of the Parties									
3.1 Customer-owned renewable generation shall be considered certified for interconnected operation if it has been submitted by a manufacturer to a nationally recognized testing and certification laboratory, and has been tested and listed by the laboratory for continuous interactive operation with an electric distribution system in compliance with the applicable codes and standards of IEEE 1547, IEEE 1547.1, and UL 1741. The Customer shall provide a written report that the Customer-owned renewable generation complies with the foregoing standards. The manufacturer's specification sheets will satisfy this requirement for a written report.									
3.2 Customer-owned renewable generation shall include a utility-interactive inverter, or other device certified pursuant to Section 3.1 above, that performs the function of automatically isolating the Customer-owned generation equipment from the electric grid in the event the electric grid loses power.									
3.3 The Customer shall be responsible for protecting its Customer-owned renewable generation equipment, inverters, protective devices, and other system components from damage from the normal and abnormal conditions and operations that occur on									

3.4 The Customer agrees to provide Local Building Code Official inspection and certification of installation. The certification shall reflect that the local code official has inspected and certified that the installation was permitted, has been approved, and has met all electrical and mechanical qualifications.

the FPL system in delivering and restoring power; and shall be responsible for ensuring that Customer-owned renewable generation equipment is inspected, maintained, and tested in accordance with the manufacturer's instructions to ensure that

(Continued on Sheet No. 9.056)

it is operating correctly and safely.

(Continued from Sheet No. 9.056)

## **Manual Disconnect Switch**

- 5.1 U.L.1741 Listed, inverter-based Tier 2 customer-owned renewable generation systems do not require a customer-installed manual disconnect switch.
- 5.2 Other customer-owned Tier 2 renewable generation systems that are not U.L. 1741 inverter based. FPL shall require the Customer to install, at the Customer's expense, a manual disconnect switch of the visible load break type to provide a separation point between the AC power output of the Customer-owned renewable generation and any Customer wiring connected to FPL's system. The manual disconnect switch shall be mounted separate from, but adjacent to, the FPL meter socket. The Customer shall ensure that such manual disconnect switch shall remain readily accessible to FPL and be capable of being locked in the open position with a single FPL utility padlock.
- 5.3 In the event that FPL has determined with respect to the Customer-owned renewable generation that the installation of a manual disconnect switch or switches adjacent to FPL's meter socket would not be practical from a safety perspective and/or design considerations in accordance with good engineering practices; and FPL and the customer agree upon a location on the customer's premises for the switch or switches which meet all applicable safety and/or design considerations, then, pursuant to the conditions set forth in Section 5.2 above, each manual disconnect switch shall be mounted separate from FPL's meter socket at a location agreed to by the Customer and FPL, and the customer shall install a permanent weather-proof plaque adjacent to FPL's meter socket indicating the location of the manual disconnect switch or switches.

#### **Disconnection / Reconnection**

- 6.1 FPL may open the manual disconnect switch pursuant to the conditions set forth in Section 6.3 below, isolating the Customer-owned renewable generation, without prior notice to the Customer. To the extent practicable, however, prior notice shall be given. If prior notice is not given, FPL shall at the time of disconnection leave a door hanger notifying the Customer that its Customer-owned renewable generation has been disconnected, including an explanation of the condition necessitating such action. FPL will reconnect the Customer-owned renewable generation as soon as practicable after the condition(s) necessitating disconnection has been remedied.
- 6.2 Upon notice by FPL, the Customer shall be solely responsible to disconnect the Customer-owned renewable generation and Customer's other equipment if conditions on the FPL distribution system could adversely affect the Customer-owned renewable generation. FPL will not be responsible for damage to the Customer-owned renewable generation system due to adverse effects on the distribution system. Reconnection will be the Customer's responsibility and will not require an additional application.
- 6.3 FPL has the right to disconnect the Customer-owned renewable generation at any time. This may result for the following reasons, amongst others:
  - Emergencies or maintenance requirements on FPL's system;
  - b) Hazardous conditions existing on FPL's system due to the operation of the Customer's generating or protective equipment as determined by FPL;
  - c) Adverse electrical effects, such as power quality problems, on the electrical equipment of FPL's other electric consumers caused by the Customer-owned renewable generation as determined by FPL; and
  - Failure of the Customer to maintain the required insurance coverage as stated in Section 11.1 below.

#### Modifications/Additions to Customer-owned Renewable Generation

- 7.1 If the Customer-owned renewable generation is subsequently modified in order to increase its Gross Power Rating, the Customer must notify FPL by submitting a new application and Interconnection Agreement specifying the modification at least thirty (30) days prior to making the modification.
- 7.2 If the Customer adds another Customer-owned renewable generation which: i.) utilizes the same utility inter-active inverter, or other device certified pursuant to Section 3.1 above, for both systems; or ii.) utilizes a separate utility inter-active inverter, or other device certified pursuant to Section 3.1 above, for each system the Customer shall provide thirty (30) calendar days notice prior to installation.

(Continued on Sheet No. 9.058)

(Continued from Sheet No. 9.057)

- 7.3 In the event any Customer modifications or additions result in the input to any FPL meter so as to qualify as a Tier 3 system, then all terms and condition, including appropriate notice, of the Interconnection Agreement for Tier 3 systems shall apply. In no event shall the maximum output of the Customer-owned generation system(s), which is connected to the FPL meter exceed 2 MW.
- 7.4 The Interconnection Agreement which applies in instances described in Sections 7.1, 7.2, and 7.3 above shall be determined by the combined Gross Power Rating of the generation system(s) which is connected to the FPL meter. In all instances described in this Section 7, the Customer shall submit a new application to FPL and shall enter into a new Interconnection Agreement.

#### 8. **Indemnity**

- 8.1 Customer, to the extent permitted by law without waiving or limiting any defense of sovereign immunity, shall indemnify, hold harmless and defend FPL from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property (including the Customer-owned renewable generation system), fines and penalties, costs and expenses arising out of or resulting from the operation of the Customer-owned renewable generation system, except in those instances where such loss is due to the negligent action or inactions of FPL. Nothing herein shall be intended to serve as a waiver of limitation of Customer's sovereign immunity defense as allowed by law.
- 8.2 FPL shall indemnify, hold harmless and defend Customer from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property (including FPL's transmission system), fines and penalties, costs and expenses arising out of or resulting from the operation of FPL's system, except in those instances where such loss is due to the negligent action or inactions of the Customer.

#### 9. Limitation of Liability

9.1 Liability under this Interconnection Agreement for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Interconnection Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall the indemnifying Party be liable to the other Party for any indirect, special, consequential, or punitive damages, except as authorized.

# 10. Assignment

- 10.1 The Interconnection Agreement shall be assignable by either Party upon thirty (30) calendar days notice to the other Party and written consent of the other Party, which consent shall not be unreasonably withheld or delayed.
- 10.2 An assignee to this Interconnection Agreement shall be required to assume in writing the Customer's rights, responsibilities, and obligations under this Interconnection Agreement; or execute a new Interconnection Agreement.

#### 11. **Insurance**

11.1 The Customer agrees to provide and maintain general liability insurance for personal and property damage, or sufficient guarantee and proof of self-insurance, in the amount of not less than \$1 million during the entire period of this Interconnection Agreement, to the extent permitted by law. Initial proof of insurance shall be in the form of a copy of the policy or certificate of insurance attached to this Interconnection Agreement evidencing the Homeowner's or other insurance policy in effect at the time of interconnection. For government entities, the policy coverage shall not exceed the entity's maximum liability established by law. Proof of self-insurance consistent with law shall satisfy this requirement.

(Continued on Sheet No. 9.059)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.058)

#### 12. Renewable Energy Certificates

12.1 The Customer shall retain any Renewable Energy Certificates associated with the electricity produced by their Customerowned renewable generation equipment; any additional meters necessary for measuring the total renewable electricity generated for the purposes of receiving Renewable Energy Certificates shall be installed at the Customer's expense, unless otherwise determined during negotiations for the sale of the Customer's Renewable Energy Certificates to FPL.

#### 13. Lease Agreements

- 13.1 The Customer shall provide FPL a copy of the lease agreement, as applicable, for any and all leased interconnection equipment.
- 13.2 The Customer shall not enter into any lease agreement that results in the retail purchase of electricity; or the retail sale of electricity from the Customer-owned renewable generation. Notwithstanding this restriction, in the event it is determined by the Florida Public Service Commission that the Customer has entered such an agreement, the Customer shall be in breach of this Interconnection Agreement and the lessor may become subject to the jurisdiction and regulations of the Florida Public Service Commission as a public utility.

#### 14. Dispute Resolution

14.1 Disputes between the Parties shall be handled in accordance with subsection 11 of Rule 25-6.065 F.A.C. – Interconnection and Net Metering of Customer-Owned Renewable Generation.

#### 15. Effective Date

15.1 The Customer must execute this Interconnection Agreement and return it to FPL at least thirty (30) calendar days prior to beginning parallel operations and the Customer must begin parallel operation within one year after FPL executes the Interconnection Agreement.

#### 16. Termination

16.1 Upon termination of this Interconnection Agreement, FPL shall open and padlock the manual disconnect switch, if applicable, and remove the Net Metering and associated FPL equipment. At the Customer's expense, the Customer agrees to permanently disconnect the Customer-owned renewable generation and associated equipment from FPL's electric service grid. The Customer shall notify FPL in writing within ten (10) calendar days that the disconnect procedure has been completed.

# 17. Amendments to Florida Public Service Commission Rules

17.1 FPL and Customer recognize that the Florida Public Service Commission rules may be amended from time to time. In the event that Florida Public Service Commission rules are modified, FPL and Customer agree to supersede and replace this Interconnection Agreement with a new Interconnection Agreement which complies with the amended Florida Public Service Commission rules.

# 18. Entire Agreement

18.1 This Interconnection Agreement supersedes all previous agreements or representations, either written or oral, heretofore in effect between FPL and the Customer, made in respect to matters herein contained, and when duly executed, this Interconnection Agreement constitutes the entire agreement between Parties hereto.

# 19. Governmental Entities

19.1 For those customers, which are government entities, provisions within this agreement will apply to the extent the agency is not legally barred from executing such provisions by State or Federal law.

(Continued on Sheet No. 9.060)

Issued by: S. E. Romig, Director, Rates and Tariffs

IN WITNESS WHEREOF, the Parties hereto have caused this Interconnection Agreement to be duly executed the day and year fabove written.  CUSTOMER  (Signature)	first
(Signature)	
(Print or Type Name)	
Title:	
FLORIDA POWER & LIGHT COMPANY	
(Signature)	
(Print or Type Name)	
Title:	
The completed agreement may be submitted to FPL by:	
E-mail - scan and e-mail to Netmetering@fpl.com	
Mail - send to: Net Metering FPL - Mail code CSF-GO 9250 W. Flagler St. Miami, FL 33174	
FAX - 305-552-2275	

				Int								vable Generat Iqual to 2 MW			
This	A	greement,	is	made	and	entered	into	this		day	of		_, 20	_, by	and between
											_	("Customer"	* *	an	address of
			••				000 50							COMPA	ANY ("FPL"), a
Flori	ida co	orporation	with a	an addres	ss of P.	O. Box 14	000, 70		rse Bouleva		о Веа	ach, FL 33408	-0429.		
									tomer-owne omer's prese				greater than 1	00 kW A	AC and less than
		HEREFO follows:	RE,	for and	in con	sideration	of the	mutual c	ovenants a	nd agre	emen	nts herein set t	forth, the Pa	rties here	to covenant and
1.	<u>Defi</u>	nitions For the pu	ırpos	es of this	s interc	connection	agreen	nent only	, the follow	ing teri	ns sh	all be defined	as follows:		
	1.1.					hange of s meter is			The point a	t which	the	Customer's v	viring is con	nected to	the lugs in the
	1.2.	Intercon	nectio	on/Chang	ge of (	Ownership	, includ	ding any	modification	ons, ad	ditior		s that are ne		of the Point of o physically and
	1.3. Prudent Utility Practice – Any of the practices, methods and acts engaged in or approved by a significant portion of the electrindustry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at reasonable cost consistent with good business practices, reliability, safety and expedition. Prudent Utility Practice is not intende to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, method or acts generally accepted in the region.							able judgment in sired result at a e is not intended							
	1.4.		ty C	oordinat											EEE), the Florida Federal Energy
	1.5.					t to FPL's				roposed	linte	rconnection de	oes not have	a negati	ve impact on the
	1.6.	renewab inverter-	le ge base	eneratior d systen	n syste ns, the	m that wi	ill be i erating	nterconr capacit	nected to a y shall be	nd ope calcula	rate ated	in parallel wi	ith FPL's di ig the total	stributio	ustomer-owned n facilities. For DC nameplate
	1.7.								et forth in Renewable				Commission	Rule 25	-6.065 F.A.C
2.	Cust	tomer Qua	alifica	ation an	d Fees										
		Custome	r-owi a) do	ned rene	wable xceed 9	generation 90% of the	Custor	ner's util	oss Power I lity distributequal to 2	tion ser	vice	rating; and			
												kW A	AC		
	2.2.	In order	to co	mmence	the pro	ocess for i	ntercon	nection,	Customer s	hall pro	vide	FPL a comple	eted applicati	on.	
	2.3.	interconi Fast Trac	nectic ck Sc	n reque	st. Th hich p	is applicat	ion fee initial	shall correview and 8, heret	over the cos nd screens	of the	roces: prope	sing the Custo osed interconr	omer's applic	ation an	vable generation d the cost of the ne FPL's electric

(Continued from Sheet No. 9.066)

#### 4. Inspection and On-Going Compliance

- 4.1. All initial physical inspections and inspection of Customer's documents must be completed by FPL within thirty (30) calendar days of receipt of the Customer's executed Interconnection Agreement. If the inspection is delayed at the Customer's request, the Customer shall contact FPL to reschedule an inspection. FPL shall reschedule the inspection within ten (10) business days of the Customer's request. Physical inspections and inspection of documents must be completed and approved by FPL prior to commencement of service of the Customer-owned renewable generation system.
- 4.2. Any inspection or observation by FPL shall not be deemed to be or construed as any representation, assurance, guarantee, or warranty by FPL of the safety, durability, suitability, or reliability of the Customer-owned Renewable Generation or any associated control, protective, and safety devices owned or controlled by the Customer or the quality of power produced by the Customer-owned Renewable Generation.
- 4.3. FPL shall have the right to inspect Customer-owned renewable generation and its component equipment to ensure compliance with this Interconnection Agreement. FPL's system inspections shall include, but shall not be limited to:
  - a) any installed manual disconnect switch, as applicable;
  - b) FPL's metering equipment;
  - c) Any additional metering equipment installed by Customer; and
  - d) Customer utility-interactive inverter, protective device or other similar devices for compliance to applicable code and standards, as described in this Interconnection Agreement.
- 4.4. FPL shall also have the right to review Customer documents to ensure compliance with this Interconnection Agreement. FPL shall have the right to, at a minimum review:
  - a) technical design parameters of the system and the manufacture's installation;
  - b) operation and maintenance instructions to ensure compliance with IEEE and UL standards;
  - c) local inspection and certifications; and
  - d) other documents associated with specific installations.
- 4.5. FPL will provide Customer with as much notice as reasonably practicable, either in writing, e-mail, facsimile or by phone as to when FPL will conduct inspection and/or document review. Upon reasonable notice, or at any time without notice in the event of an emergency or hazardous condition, FPL shall have access to the Customer's premises for the purpose of accessing the manual disconnect switch, performing an inspection or disconnection, or, if necessary, to meet FPL's legal obligation to provide service to its Customers.

#### 5. Manual Disconnect Switch

- 5.1 U.L.1741 Listed, inverter-based Tier 3 customer-owned renewable generation systems do not require customer-installed manual disconnect switch.
- 5.2 Other customer-owned Tier 3 renewable generation systems that are not U.L. 1741 inverter based. FPL shall require the Customer to install, at the Customer's expense, a manual disconnect switch of the visible load break type to provide a separation point between the AC power output of the Customer-owned renewable generation and any Customer wiring connected to FPL's system. The manual disconnect switch shall be mounted separate from, but adjacent to, the FPL meter socket. The Customer shall ensure that such manual disconnect switch shall remain readily accessible to FPL and be capable of being locked in the open position with a single FPL utility padlock.
- 5.3 In the event that FPL has determined in respect of the Customer-owned renewable generation that the installation of a manual disconnect switch or switches adjacent to FPL's meter socket would not be practical from a safety perspective and/or design considerations in accordance with good engineering practices; and FPL and the customer agree upon a location on the customer's premises for the switch or switches which meet all applicable safety and/or design considerations, then, pursuant to the conditions set forth in Section 5.2 above, each manual disconnect switch shall be mounted separate from FPL's meter socket at a location agreed to by the Customer and FPL, and the customer shall install a permanent weather-proof plaque adjacent to FPL's meter socket indicating the location of the manual disconnect switch or switches.

(Continued on Sheet No. 9.068)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.067)

# 6. **Disconnection / Reconnection**

- 6.1. FPL may open the manual disconnect switch pursuant to the conditions set forth in Section 6.3 below, isolating the Customer-owned renewable generation, without prior notice to the Customer. To the extent practicable, however, prior notice shall be given. If prior notice is not given, FPL shall at the time of disconnection leave a door hanger notifying the Customer that its Customer-owned renewable generation has been disconnected, including an explanation of the condition necessitating such action. FPL will reconnect the Customer-owned renewable generation as soon as practicable after the condition(s) necessitating disconnection has been remedied.
- 6.2. Upon notice by FPL, the Customer shall be solely responsible to disconnect the Customer-owned renewable generation and Customer's other equipment if conditions on the FPL distribution system could adversely affect the Customer-owned renewable generation. FPL will not be responsible for damage to the Customer-owned renewable generation system due to adverse effects on the distribution system. Reconnection will be the Customer's responsibility and will not require an additional application.
- 6.3. FPL has the right to disconnect the Customer-owned renewable generation at any time. This may result for the following reasons, amongst others:
  - a) Emergencies or maintenance requirements on FPL's system;
  - b) Hazardous conditions existing on FPL's system due to the operation of the Customer's generating or protective equipment as determined by FPL;
  - c) Adverse electrical effects, such as power quality problems, on the electrical equipment of FPL's other electric consumers caused by the Customer-owned renewable generation as determined by FPL; and
  - d) Failure of the Customer to maintain the required insurance coverage as stated in Section 13.1 below.

## 7. Modifications/Additions to Customer-owned Renewable Generation

- 7.1. If the Customer-owned renewable generation is subsequently modified in order to increase its Gross Power Rating, the Customer must notify FPL by submitting a new application specifying the modification at least thirty (30) calendar days prior to making the modification.
- 7.2. If the Customer adds another Customer-owned renewable generation system which: i.) utilizes the same utility inter-active inverter, or other device certified pursuant to Section 3.1 above, for both systems; or ii.) utilizes a separate utility inter-active inverter, or other device certified pursuant to Section 3.1 above, for each system the Customer shall provide thirty (30) calendar days notice prior to installation.
- 7.3. The Interconnection Agreement which applies in instances described in Sections 7.1 and 7.2 above shall be determined by the combined Gross Power Rating of the generation system(s) which is connected to the FPL meter. In all instances described in this Section 7, the Customer shall submit a new application to FPL and shall enter into a new Interconnection Agreement. In no event shall the maximum output of the Customer-owned generation system(s), which is connected to the FPL meter exceed 2 MW.

# 8. <u>Interconnection Study Process</u>

#### 8.1. Fast Track Screens

- 8.1.1. Fast Track Screens, described in Attachment 3 hereto, provide for an initial review of Customer's request for interconnection which evaluates whether the Customer's request exceeds an acceptable level of impact to the FPL electric system, consistent with prudent utility practice.
- 8.1.2. In order to pass the Fast Track Screens, Customer's interconnection shall not exceed established industry criteria, as set forth in the Interconnection Study Process and shall not require construction of Interconnection Facilities and Distribution Upgrades on FPL's electric system.
- 8.1.3. If the Customer's interconnection request passes the Fast Track Screens, the Customer's request shall be approved and Customer will be provided an executable Interconnection Agreement.

(Continued on Sheet No. 9.069)

(Continued from Sheet No. 9.068)

8.2 In those instances in which the Customer-owned renewable generation does not pass the Fast Track Screens the Customer may elect to proceed with an Interconnection Study. In general, the purpose of the Interconnection Study will be to better determine what material adverse impacts the Customer-owned renewable generation has on the FPL system and what facilities will be required to resolve such impacts.

#### 8.3 Interconnection Study

- 8.3.1. The Interconnection Study Process shall be used by a Customer proposing to interconnect its certified Customerowned renewable generation, in those instances in which such system did not pass the Fast Track Screens.
- 8.3.2. Upon Customer execution of the Interconnection Agreement; the Customer shall be obligated to pay for any and all costs for Interconnection Facilities and Distribution Upgrades identified in the Interconnection Study in order to interconnect the proposed Customer-owned renewable generation.
- 8.3.3. The Interconnection Study fee shall be \$2000.00 and will be invoiced to the Customer once it is determined that an Interconnection Study will be required. This determination will be made within ten (10) business days after a completed application is received. To the extent the actual costs of the Interconnection Study total less than \$2,000, the difference between the Interconnection Study fee and the actual costs will be refunded to the Customer within thirty (30) calendar days with no interest.

# Cost Responsibility for Interconnection Facilities and Distribution Upgrades

- 9.1. The Customer shall pay FPL for the actual cost of any and all FPL Interconnection Facilities and Distribution Upgrades, itemized in Attachment 2, required to implement this Interconnection Agreement. FPL shall provide a best estimate cost, including overheads, for the purchase and construction of FPL's Interconnection Facilities and Distribution Upgrades required and shall provide a detailed itemization of such costs.
- 9.2. The Customer shall be responsible for all reasonable expenses, including overheads, associated with: i.) owning, operating, maintaining, repairing, and replacing its own Interconnection Facilities and other equipment; and ii.) operating, maintaining, repairing, and replacing FPL's Interconnection Facilities and Distribution Upgrades.
- 9.3. FPL shall design, procure, construct, install and own the Interconnection Facilities and Distribution Upgrades, described in Attachment 2, required for FPL to implement this Interconnection Agreement. If FPL and the Customer agree, the Customer may construct Interconnection Facilities and Distribution Upgrades that are located on land owned by the Customer. The actual cost of Interconnection Facilities and Distribution Upgrades, including overheads, shall be directly assigned to and paid by the Customer.

# 10. **Indemnity**

10.1. Customer, to the extent permitted by law without waiving or limiting any defense of sovereign immunity, shall indemnify, hold harmless and defend FPL from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property (including the Customer-owned renewable generation system), fines and penalties, costs and expenses arising out of or resulting from the operation of the Customer-owned renewable generation system, except in those instances where such loss is due to the negligent action or inactions of FPL. Nothing herein shall be intended to serve as a waiver or limitation of Customer's sovereign immunity defense as allowed by law.

(Continued on Sheet No. 9.070)

(Continued from Sheet No. 9.069)

10.2 FPL shall indemnify, hold harmless and defend Customer from and against any and all judgments, losses, damages, claims relating to injury to or death of any person or damage to property (including FPL's transmission system), fines and penalties, costs and expenses arising out of or resulting from the operation of FPL's system, except in those instances where such loss is due to the negligent action or inactions of the Customer.

## 11. Limitation of Liability

11.1 Liability under this Interconnection Agreement for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Interconnection Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall the indemnifying Party be liable to the other Party for any indirect, special, consequential, or punitive damages, except as authorized.

#### 12. Assignment

- 12.1 The Interconnection Agreement shall be assignable by either Party upon thirty (30) calendar days notice to the other party and written consent of the other Party, which consent shall not be unreasonably withheld or delayed.
- 12.2 An assignee to this Interconnection Agreement shall be required to assume in writing the Customer's rights, responsibilities, and obligations under this Interconnection Agreement; or execute a new Interconnection Agreement.

#### 13. **Insurance**

13.1 The Customer agrees to provide and maintain general liability insurance for personal and property damage, or sufficient guarantee and proof of self-insurance, in the amount of not less than \$2 million during the entire period of this Interconnection Agreement, to the extent permitted by law. Initial proof of insurance shall be in the form of a copy of the policy or certificate of insurance attached to this Interconnection Agreement evidencing the Homeowner's or other insurance policy in effect at the time of interconnection. For government entities, the policy coverage shall not exceed the entity's maximum liability established by law. Proof of self-insurance consistent with law shall satisfy this requirement.

# 14. Renewable Energy Certificates

14.1 The Customer shall retain any Renewable Energy Certificates associated with the electricity produced by their Customerowned renewable generation equipment; any additional meters necessary for measuring the total renewable electricity generated for the purposes of receiving Renewable Energy Certificates shall be installed at the Customer's expense, unless otherwise determined during negotiations for the sale of the Customer's Renewable Energy Certificates to FPL.

#### 15. Billing, Payment, and Financial Security

15.1 FPL shall bill the Customer for the design, engineering, construction, and procurement costs of FPL's Interconnection Facilities and Distribution Upgrades contemplated by this Interconnection Agreement on a monthly basis, or as otherwise agreed by the Parties. The Customer shall pay each bill within thirty (30) calendar days of receipt, or as otherwise agreed to by the Parties.

(Continued on Sheet No. 9.071)

Issued by: S. E. Romig, Director, Rates and Tariffs

(Continued from Sheet No. 9.070)

- 15.2. Within three months of completing the construction and installation of FPL's Interconnection Facilities and Distribution Upgrades, described in Attachment 2, required to implement this Interconnection Agreement, FPL shall provide the Customer with a final accounting report of any difference between i.) the Customer's cost responsibility for the actual cost of such Interconnection Facilities and Distribution Upgrades, and ii.) the Customer's previous aggregate payments to FPL for such Interconnection Facilities and Distribution Upgrades. If the Customer's cost responsibility exceeds its previous aggregate payments, FPL shall invoice the Customer for the amount due, without interest, and the Customer shall make payment to FPL within thirty (30) calendar days. If the Customer's previous aggregate payments exceed its cost responsibility under this Interconnection Agreement, FPL shall refund to the Customer an amount equal to the difference, without interest, within thirty (30) calendar days of the final accounting report.
- 15.3. At least twenty (20) calendar days prior to the commencement of the design, procurement, installation, or construction of a discrete portion of FPL's Interconnection Facilities and Distribution Upgrades, the Customer shall provide FPL, at the Customer's option, a guarantee, a surety bond, letter of credit or other form of security that is reasonably acceptable to FPL and is consistent with the Uniform Commercial Code of the jurisdiction where the Point of Interconnection is located. Such security for payment shall be in an amount sufficient to cover the costs for constructing, designing, procuring and installing the applicable portion of FPL's Interconnection Facilities and Distribution Upgrades and shall be reduced on a dollar-for-dollar basis for payments made to FPL under this Interconnection Agreement during its term.
- 15.4. In accordance with Section 9.2 above, the Customer shall be billed by FPL for operation, maintaining, repairing, and replacing FPL's Interconnection Facilities and Distribution Upgrades. The Customer shall be billed upon completion of such work by FPL; Customer shall make payment to FPL within twenty (20) calendar days of the receipt of FPL's bill.

## 16. Lease Agreements

- 16.1. The Customer shall provide FPL a copy of the lease agreement, as applicable, for any and all leased interconnection equipment.
- 16.2. The Customer shall not enter into any lease agreement that results in the retail purchase of electricity; or the retail sale of electricity from the Customer-owned renewable generation. Notwithstanding this restriction, in the event it is determined by the Florida Public Service Commission that the Customer has entered such an agreement, the Customer shall be in breach of this Interconnection Agreement and the lessor may become subject to the jurisdiction and regulations of the Florida Public Service Commission as a public utility.

# 17. Dispute Resolution

17.1. Disputes between the Parties shall be handled in accordance with subsection 11 of Florida Public Service Commission Rule 25-6.065 F.A.C. - Interconnection and Net Metering of Customer-Owned Renewable Generation.

## 18. Effective Date

18.1. The Customer must execute this Interconnection Agreement and return it to FPL at least thirty (30) calendar days prior to beginning parallel operations and the Customer must begin parallel operation within one year after FPL executes the Interconnection Agreement.

# 19. **Termination**

19.1. Upon termination of this Interconnection Agreement, FPL shall open and padlock the manual disconnect switch, if applicable, and remove the Net Metering and associated FPL equipment. At the Customer's expense, the Customer agrees to permanently disconnect the Customer-owned renewable generation and associated equipment from FPL's electric service grid. The Customer shall notify FPL in writing within ten (10) calendar days that the disconnect procedure has been completed.

(Continued on Sheet No. 9.072)

(Continued from Sheet No. 9.071)

# 20. Amendments to Florida Public Service Commission Rules

20.1 FPL and Customer recognize that the Florida Public Service Commission rules may be amended from time to time. In the event that Florida Public Service Commission rules are modified, FPL and Customer agree to supersede and replace this Interconnection Agreement with a new Interconnection Agreement which complies with the amended Florida Public Service Commission rules.

## 21. Notices

21.1 This Interconnection Agreement, any written notice, demand, or request required or authorized in connection with this Interconnection Agreement shall be deemed properly given if delivered in person, delivered by recognized national courier service, or sent by first class mail, postage prepaid, to the person specified below:

## 22. Entire Agreement

22.1 This Interconnection Agreement supersedes all previous agreements or representations, either written or oral, heretofore in effect between FPL and the Customer, made in respect to matters herein contained, and when duly executed, this Interconnection Agreement constitutes the entire agreement between Parties hereto.

# 23. Governmental Entities

23.1 For those customers, which are government entities, provisions within this agreement will apply to the extent the agency is not legally barred from executing such provisions by State or Federal law.

CUSTOMER:										
FPL:										

(Continued on Sheet No. 9.072.1)

FLURIDA PUWER & LIGHT COMPANY	Original Sheet No. 9.072.1
(Continued from She	pet No. 9.072)
IN WITNESS WHEREOF, the Parties hereto have caused this Interconne above written.	ction Agreement to be duly executed the day and year first
FLORIDA POWER & LIGHT COMPANY	
(Signature)	
(Print or Type Name)	
Title:	
CUSTOMER	
(Signature)	
(Print or Type Name)	
Title:	
Witness: (Print or Type Name)	
Title:	
The completed agreement may be submitted to FPL by:	
E-mail - scan and e-mail to Netmetering@fpl.com	
Mail - send to: Senior Manager, Wholesale Services FPL - Mail code TSP/LFO 4200 West Flagler St. Miami, FL 33134	

**Phone** – (305) 442-5199

**FAX** - 305-552-2275

(Continued from Sheet No. 9.075)

- 2.1.1 If the proposed Customer-owned renewable generation system is to be interconnected on single-phase shared secondary, the aggregate generation capacity on the shared secondary, including the proposed Customer-owned renewable generation system, shall not exceed 90% of the Customer's utility distribution service rating.
- 2.1.2 If the proposed Customer-owned renewable generation system is single-phase and is to be interconnected on a center tap neutral of a 240 volt service, its addition shall not create an imbalance between the two sides of the 240 volt service of more than 20 % of the nameplate rating of the service transformer.
- 2.1.3 The proposed Customer-owned renewable generation system, in aggregate with other generation interconnected to the transmission side of a substation transformer feeding the circuit where the Customer-owned renewable generation system proposes to interconnect shall not exceed 10 MW in an area where there are known, or posted, transient stability limitations to generating units located in the general electrical vicinity (e.g., three or four transmission busses from the Point of Interconnection/Change of Ownership).
- 2.1.4 No construction of facilities by FPL on its own system shall be required to accommodate the Customer-owned renewable generation system.
- 2.2 If the proposed interconnection passes the Fast Track Screens, the interconnection request shall be approved and FPL will provide the Customer an executable Interconnection Agreement within ten (10) business days after such determination.

Issued by: S. E. Romig, Director, Rates and Tariffs