



Maria J. Moncada
Principal Attorney
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408-0420
(561) 304-5795
(561) 691-7135 (Facsimile)
maria.moncada@fpl.com

December 18, 2013

-VIA WEB BASED FILING-

Ms. Carlotta S. Stauffer
Office of Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850

Re: Docket No. 130225-EQ / Staff's First Data Request

Dear Ms. Cole:

Enclosed for filing on behalf of Florida Power & Light Company ("FPL") is FPL's supplemental response to Staff's First Data Request No. 11, relating to FPL's Petition for Approval of Modification to Standard Interconnection Agreements and for Waiver of Portion of Rule 25-6.015(6)(a).

If you should have any questions, please do not hesitate to contact me at (561) 304-5795 or maria.moncada@fpl.com.

Sincerely,

s/Maria J. Moncada
Maria J. Moncada

Enclosures

cc: Kelly Corbari, Esq. (with attachments)

QUESTION

Please state whether FPL has any connection requests pending for systems with the MDS mounted in a location other than adjacent to the meter. If so, please state how many such connection requests FPL has pending and when FPL learned these systems did not have the MDS mounted adjacent to the meter.

RESPONSE

FPL has five (5) additional connection requests pending at this time. Specific information regarding each of the connection requests is provided below:

- 1) Customer with an interconnection point 23 stories high. Customer requested an alternate MDS location on August 12, 2013. Customer failed to complete the requested supplemental agreement prior to our current discussions. System is ready to be energized.
- 2) Municipality requested on October 22, 2013 an alternate MDS location for its Mills Pond Park wind turbine project located in a public park. The meter is located on the opposite side of a football field with unique underground irrigation and drainage systems. This alternate location will significantly benefit the municipality as it is a significant expense to comply with the rule. The municipality plans to award the construction contract soon to commence construction in November. The municipality projects completion by year end to preserve \$250,000 grant funding.
- 3) Office building customer mounted the MDS on a readily accessible exterior wall close to the electrical room entrance. To gain access to the meter location would require entering through two secured doors within the facility. During our field verification on June 4, FPL observed the location of the MDS and provided a supplemental agreement. The customer did not complete a supplemental agreement. System requires signage and a supplemental agreement to energize system.
- 4) Customer installed a landfill gas generator at a processing plant. The interconnection point is where the customer's generator connects to FPL's 138kV transmission system at FPL's substation. On November 19, 2013, during a routine, cross-functional review of net metering customer records, FPL learned that the customer's MDS is not mounted adjacent to the meter. The meter is located within the substation approximately 500 feet away from the MDS. The customer executed a supplemental agreement. The customer's remaining documentation for this installation is not yet complete.

**Florida Power & Light Company
Docket No. 130225-EQ
Staff's First Data Request
Request No. 11 - Supplemental
Page 2 of 2**

- 5) Customer installed a landfill gas generator at a local wastewater treatment plant. During a routine, cross-functional review of net metering records, FPL became aware that certain documentation for this customer was incomplete. On December 10, 2013, FPL confirmed the generator did not have the MDS mounted adjacent to the meter. A supplemental agreement is pending execution by the customer. The customer's remaining documentation for this installation is not yet complete.