

Angela Charles

From: Kathy Shoaf
Sent: Thursday, December 03, 2015 9:04 AM
To: CLK - Agenda Staff; Commissioners & Staffs; Braulio Baez; Lisa Harvey; Apryl Lynn; Charlie Beck; Mary Anne Helton; Kyesha Mapp; 115A Conference Room; Jennifer Crawford; Greg Shafer; Jenny Wu
Cc: Kate Hamrick; Terri Fleming
Subject: Approved - Agenda Item No. 12 (Docket No. 150211-EI - Petition for approval of depreciation rates for solar photovoltaic generating units, by Tampa Electric Company.)
Attachments: TECO 150211 - rev.doc

Please see attached approved oral modification.

Kathy Shoaf

Executive Assistant to
Braulio Baez, Executive Director
Florida Public Service Commission
Telephone: (850)413-6053
kshoaf@psc.state.fl.us

From: Braulio Baez
Sent: Thursday, December 03, 2015 9:01 AM
To: Kathy Shoaf
Subject: FW: Agenda Item No. 12 (Docket No. 150211-EI - Petition for approval of depreciation rates for solar photovoltaic generating units, by Tampa Electric Company.)

From: Braulio Baez
Sent: Thursday, December 03, 2015 9:00 AM
To: Lisa Harvey
Subject: FW: Agenda Item No. 12 (Docket No. 150211-EI - Petition for approval of depreciation rates for solar photovoltaic generating units, by Tampa Electric Company.)

approved

From: Lisa Harvey
Sent: Thursday, December 03, 2015 8:53 AM
To: Braulio Baez
Subject: FW: Agenda Item No. 12 (Docket No. 150211-EI - Petition for approval of depreciation rates for solar photovoltaic generating units, by Tampa Electric Company.)

For you approval

From: Bill McNulty
Sent: Thursday, December 03, 2015 8:53 AM

To: Lisa Harvey

Cc: Jenny Wu; Greg Shafer

Subject: Agenda Item No. 12 (Docket No. 150211-EI - Petition for approval of depreciation rates for solar photovoltaic generating units, by Tampa Electric Company.)

Lisa,

Please consider the proposed oral modification to Agenda Item No. 12 at today's Agenda Conference contained in the attached file. Thank you.

Bill McNulty

Economist Supervisor

Florida Public Service Commission

(850)413-6848

bmcnulty@psc.state.fl.us

CORRECTED VERSION

Top of Page 2

Issue 1: Should the Commission approve TECO's proposed depreciation rate for solar photovoltaic generating units and associated equipment?

Recommendation: Yes. Staff recommends the Commission approve a 30 year life and whole life depreciation rate of 3.3 percent for TECO's solar photovoltaic generating units and associated equipment applied to each of the related subaccounts shown in the staff analysis.

Top of Page 4

Staff believes a 30 year life and whole life depreciation rate of 3.3 percent is appropriate for TECO's solar photovoltaic generating units and associated equipment. This rate should be applied to each of the related subaccounts shown in the staff analysis.

TYPE AND STRIKE VERSION

Top of Page 2

Issue 1: Should the Commission ~~establish subaccounts with~~ approve TECO's proposed depreciation rate for solar photovoltaic generating units and associated equipment?

Recommendation: Yes. Staff recommends the Commission ~~establish the subaccounts shown in the staff analysis with~~ approve a 30 year life and whole life depreciation rate of 3.3 percent for TECO's solar photovoltaic generating units and associated equipment applied to each of the related subaccounts shown in the staff analysis.

Top of Page 4

Staff believes ~~it would be appropriate for the Commission establish the Subaccounts 303.xx—Intangible Plant, 341.xx Structures and Improvements, 343.xx Other Generation Plant, and 345.xx Accessory Electric Equipment, with~~ a 30-year life and a whole life depreciation rate of 3.3 percent is appropriate for TECO's solar photovoltaic generating units and associated equipment. This rate should be applied to each of the related subaccounts shown in the staff analysis.