



DIANNE M. TRIPLETT
ASSOCIATE GENERAL COUNSEL

May 19, 2016

VIA ELECTRONIC FILING

Ms. Carlotta Stauffer, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Docket No.: 160001
Performance Data Report for April 2016

Dear Ms. Stauffer:

Enclosed for filing in the above docket is Duke Energy Florida, LLC's Performance Data Report for April 2016.

If you have any questions, please do not hesitate to contact me at (727) 820-4692.

Sincerely,

A handwritten signature in blue ink that reads 'Dianne M. Triplett'.

Dianne M. Triplett
Associate General Counsel

DMT/db
Enclosure

cc: Daniel Lee, Division of Engineering, FPSC
Parties of Record

CERTIFICATE OF SERVICE

Docket No. 160001-EI

I HEREBY CERTIFY that a true copy of Duke Energy Florida, LLC's Performance Data Report for the month of April 2016 has been furnished to the following individuals via e-mail on this 19th day of May, 2016.


Attorney

<p>Danijela Janjic John Villafrate Suzanne Brownless Office of General Counsel Florida Public Service Commission 2540 Shumard Oak Blvd. Tallahassee, FL 32399-0850 sbrownle@psc.state.fl.us djanjic@psc.state.fl.us jvillafr@psc.state.fl.us</p> <p>James D. Beasley J. Jeffrey Wahlen Ashley M. Daniels Ausley McMullen Law Firm P.O. Box 391 Tallahassee, FL 32302 jbeasley@ausley.com jwahlen@ausley.com adaniels@ausley.com</p> <p>Jeffrey A. Stone Russell A. Badders Steven R. Griffin Beggs & Lane P.O. Box 12950 Pensacola, FL 32591 jas@beggslane.com rab@beggslane.com srg@beggslane.com</p> <p>James W. Brew Laura A. Wynn Stone Matheis Xenopoulos & Brew 1025 Thomas Jefferson Street NW 8th Floor, West Tower Washington, DC 20007 jbrew@smxblaw.com law@smxblaw.com</p>	<p>Mike Cassel, Director Regulatory Affairs Florida Public Utilities Company 1750 S 14th Street, Suite 200 Fernandina Beach, FL 32034 mcassel@fpuc.com</p> <p>Robert L. McGee, Jr. Gulf Power Company One Energy Place Pensacola, FL 32520-0780 rlmgee@southernco.com</p> <p>Beth Keating Gunster, Yoakley & Stewart, P.A. 215 South Monroe Street, Suite 601 Tallahassee, FL 32301 bkeating@gunster.com</p> <p>Charles J. Rehwinkel / Erik Sayler J.R. Kelly / Patty Christensen Tarik Noriega Office of Public Counsel c/o The Florida Legislature 111 W. Madison Street, Room 812 Tallahassee, FL 32399-1400 rehwinkel.charles@leg.state.fl.us sayler.erik@leg.state.fl.us kelly.jr@leg.state.fl.us christensen.patty@leg.state.fl.us noriega.tarik@leg.state.fl.us</p> <p>Robert Scheffel Wright John T. LaVia, III c/o Gardner Law Firm 1300 Thomaswood Drive Tallahassee, FL 32308 schef@gbwlegal.com ilavia@gbwlegal.com</p>	<p>Ms. Paula K. Brown Manager, Regulatory Coordination Tampa Electric Company P.O. Box 111 Tampa, FL 33601 regdept@tecoenergy.com</p> <p>John Butler Maria Moncada Florida Power & Light Company 700 Universe Boulevard (LAW/JB) Juno Beach, FL 33408-0420 john.butler@fpl.com maria.moncada@fpl.com</p> <p>Kenneth Hoffman Florida Power & Light Company 215 S. Monroe Street, Suite 810 Tallahassee, FL 32301-1858 ken.hoffman@fpl.com</p> <p>Jon C. Moyle, Jr. Moyle Law Firm, P.A. 118 North Gadsden Street Tallahassee, FL 32301 jmoyle@moylelaw.com</p> <p>Raoul G. Cantero, III White & Case, LLP Southeast Financial Center, Suite 4900 200 South Biscayne Boulevard Miami, FL 33131-2352 rcantero@whitecase.com</p>
---	--	--

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2016

Bartow CC	Jan-16	Feb-16	Mar-16	Apr-16	May-16	Jun-16	Jul-16	Aug-16	Sep-16	Oct-16	Nov-16	Dec-16	Jan - Apr Period
1. EAF	90.99	98.10	76.99	52.57									79.58
2. PH	744	696	743	720									2,903
3. SH	648.7	645.8	548.9	378.5									2,222.0
4. RSH	28.3	37.0	23.1	0.0									88.4
5. UH	67.0	13.2	171.0	341.5									592.7
6. POH	0.0	0.0	171.0	340.6									511.5
7. FOH	67.0	13.2	0.0	0.9									81.2
8. MOH	0.0	0.0	0.0	0.0									0.0
9. PPOH	0.0	0.0	436.1	264.3									700.4
10. LR PP (MW)	0.0	0.0	120.0	118.3									119.4
11. PFOH	0.0	0.0	0.0	0.0									0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0									0.0
13. PMOH	0.0	0.0	0.0	0.0									0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0									0.0
15. NSC (MW)	1162	1162	1162	1162									1162
16. OPER MBTU	4,724,270	4,705,387	3,521,015	2,778,006									15,728,677
17. NET GEN (MWH)	640,347	644,116	488,672	306,456									2,079,591
18. ANOHR (BTU/KWH)	7,377.7	7,305.2	7,205.3	9,064.9									7,563.4
19. NOF (%)	84.95	85.83	76.61	69.68									80.54
20. NPC (MW)	1162	1162	1162	1162									1162

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2016

CRYSTAL RIVER 4	Jan-16	Feb-16	Mar-16	Apr-16	May-16	Jun-16	Jul-16	Aug-16	Sep-16	Oct-16	Nov-16	Dec-16	Jan - Apr Period
1. EAF	97.15	87.56	10.31	99.11									73.11
2. PH	744	696	743	720									2,903
3. SH	723.1	613.7	83.8	720.0									2,140.5
4. RSH	0.0	0.0	0.0	0.0									0.0
5. UH	20.9	82.4	659.2	0.0									762.5
6. POH	0.0	82.4	659.2	0.0									741.6
7. FOH	20.9	0.0	0.0	0.0									20.9
8. MOH	0.0	0.0	0.0	0.0									0.0
9. PPOH	0.0	0.0	0.0	0.0									0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0									0.0
11. PFOH	0.0	0.0	0.0	1.2									1.2
12. LR PF (MW)	0.0	0.0	0.0	92.7									92.7
13. PMOH	2.0	17.3	54.7	46.0									119.9
14. LR PM (MW)	93.0	174.0	93.0	96.5									106.0
15. NSC (MW)	712	712	712	712									712
16. OPER MBTU	3,181,413	2,381,195	328,279	3,293,827									9,184,715
17. NET GEN (MWH)	281,627	212,501	27,079	319,988									841,195
18. ANOHR (BTU/KWH)	11,296.5	11,205.6	12,123.0	10,293.6									10,918.7
19. NOF (%)	54.70	48.64	45.40	62.42									55.20
20. NPC (MW)	712	712	712	712									712

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2016

CRYSTAL RIVER 5	Jan-16	Feb-16	Mar-16	Apr-16	May-16	Jun-16	Jul-16	Aug-16	Sep-16	Oct-16	Nov-16	Dec-16	Jan - Apr Period
1. EAF	98.65	98.05	99.22	99.55									98.87
2. PH	744	696	743	720									2,903
3. SH	618.5	696.0	743.0	720.0									2,777.5
4. RSH	124.4	0.0	0.0	0.0									124.4
5. UH	1.2	0.0	0.0	0.0									1.2
6. POH	0.0	0.0	0.0	0.0									0.0
7. FOH	1.2	0.0	0.0	0.0									1.2
8. MOH	0.0	0.0	0.0	0.0									0.0
9. PPOH	0.0	0.0	0.0	0.0									0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0									0.0
11. PFOH	20.0	8.3	5.5	3.0									36.7
12. LR PF (MW)	303.7	91.1	91.0	63.0									204.7
13. PMOH	3.6	58.1	10.5	16.9									89.2
14. LR PM (MW)	63.1	152.7	345.0	126.3									166.7
15. NSC (MW)	710	710	710	710									710
16. OPER MBTU	2,805,817	2,583,132	2,935,831	3,207,108									11,531,887
17. NET GEN (MWH)	249,857	236,536	280,664	313,678									1,080,735
18. ANOHR (BTU/KWH)	11,229.7	10,920.7	10,460.3	10,224.2									10,670.4
19. NOF (%)	56.90	47.87	53.20	61.36									54.80
20. NPC (MW)	710	710	710	710									710

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2016

HINES Power Block 1	Jan-16	Feb-16	Mar-16	Apr-16	May-16	Jun-16	Jul-16	Aug-16	Sep-16	Oct-16	Nov-16	Dec-16	Jan - Apr Period
1. EAF	100.00	100.00	64.99	12.83									69.42
2. PH	744	696	743	720									2,903
3. SH	744.0	696.0	477.7	92.4									2,010.1
4. RSH	0.0	0.0	5.2	0.0									5.2
5. UH	0.0	0.0	260.1	627.6									887.7
6. POH	0.0	0.0	214.8	623.6									838.3
7. FOH	0.0	0.0	45.4	4.0									49.4
8. MOH	0.0	0.0	0.0	0.0									0.0
9. PPOH	0.0	0.0	0.0	0.0									0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0									0.0
11. PFOH	0.0	0.0	0.0	0.0									0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0									0.0
13. PMOH	0.0	0.0	0.0	0.0									0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0									0.0
15. NSC (MW)	518	518	518	518									518
16. OPER MBTU	2,438,979	2,267,530	1,577,217	218,014									6,501,740
17. NET GEN (MWH)	344,015	322,178	207,300	26,041									899,534
18. ANOHR (BTU/KWH)	7,089.7	7,038.1	7,608.4	8,372.0									7,227.9
19. NOF (%)	89.26	89.36	83.78	54.40									86.39
20. NPC (MW)	518	518	518	518									518

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2016

HINES Power Block 2	Jan-16	Feb-16	Mar-16	Apr-16	May-16	Jun-16	Jul-16	Aug-16	Sep-16	Oct-16	Nov-16	Dec-16	Jan - Apr Period
1. EAF	99.62	65.36	25.92	99.86									72.60
2. PH	744	696	743	720									2,903
3. SH	649.8	316.3	191.6	719.0									1,876.7
4. RSH	91.4	138.6	0.9	0.0									230.9
5. UH	2.9	241.1	550.4	1.0									795.4
6. POH	0.0	240.0	527.0	0.0									767.0
7. FOH	2.9	1.1	23.5	1.0									28.4
8. MOH	0.0	0.0	0.0	0.0									0.0
9. PPOH	0.0	1.7	0.0	1.0									2.7
10. LR PP (MW)	0.0	68.6	0.0	70.2									69.2
11. PFOH	0.0	0.0	0.0	0.0									0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0									0.0
13. PMOH	0.0	0.0	0.0	0.0									0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0									0.0
15. NSC (MW)	546	546	546	546									546
16. OPER MBTU	2,135,651	1,041,398	611,137	2,475,832									6,264,017
17. NET GEN (MWH)	288,534	138,689	84,068	341,940									853,231
18. ANOHR (BTU/KWH)	7,401.7	7,508.9	7,269.6	7,240.5									7,341.5
19. NOF (%)	81.33	80.30	80.35	87.10									83.27
20. NPC (MW)	546	546	546	546									546

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2016

HINES Power Block 3	Jan-16	Feb-16	Mar-16	Apr-16	May-16	Jun-16	Jul-16	Aug-16	Sep-16	Oct-16	Nov-16	Dec-16	Jan - Apr Period
1. EAF	100.00	100.00	100.00	83.79									95.98
2. PH	744	696	743	720									2,903
3. SH	699.6	647.3	700.1	601.0									2,648.0
4. RSH	44.4	48.7	43.0	2.3									138.3
5. UH	0.0	0.0	0.0	116.7									116.7
6. POH	0.0	0.0	0.0	95.6									95.6
7. FOH	0.0	0.0	0.0	5.5									5.5
8. MOH	0.0	0.0	0.0	15.6									15.6
9. PPOH	0.0	2.3	7.7	8.3									18.2
10. LR PP (MW)	0.0	52.4	59.5	57.4									57.7
11. PFOH	0.0	0.0	0.0	0.0									0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0									0.0
13. PMOH	0.0	0.0	0.0	0.0									0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0									0.0
15. NSC (MW)	544	544	544	544									544
16. OPER MBTU	2,363,034	2,105,001	2,263,623	1,970,384									8,702,042
17. NET GEN (MWH)	327,590	288,963	313,593	273,740									1,203,886
18. ANOHR (BTU/KWH)	7,213.4	7,284.7	7,218.3	7,198.0									7,228.3
19. NOF (%)	86.08	82.06	82.35	83.73									83.58
20. NPC (MW)	544	544	544	544									544

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2016

HINES Power Block 4	Jan-16	Feb-16	Mar-16	Apr-16	May-16	Jun-16	Jul-16	Aug-16	Sep-16	Oct-16	Nov-16	Dec-16	Jan - Apr Period
1. EAF	99.12	100.00	100.00	100.00									99.77
2. PH	744	696	743	720									2,903
3. SH	713.5	696.0	743.0	720.0									2,872.5
4. RSH	24.0	0.0	0.0	0.0									24.0
5. UH	6.6	0.0	0.0	0.0									6.6
6. POH	0.0	0.0	0.0	0.0									0.0
7. FOH	6.6	0.0	0.0	0.0									6.6
8. MOH	0.0	0.0	0.0	0.0									0.0
9. PPOH	1.5	8.0	1.2	1.0									11.7
10. LR PP (MW)	59.2	59.3	55.4	63.6									59.3
11. PFOH	0.0	0.0	0.0	0.0									0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0									0.0
13. PMOH	0.0	0.0	0.0	0.0									0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0									0.0
15. NSC (MW)	528	528	528	528									528
16. OPER MBTU	2,418,323	2,361,296	2,500,840	2,413,309									9,693,768
17. NET GEN (MWH)	348,625	337,289	358,855	342,436									1,387,205
18. ANOHR (BTU/KWH)	6,936.7	7,000.8	6,968.9	7,047.5									6,988.0
19. NOF (%)	92.54	91.78	91.47	90.08									91.46
20. NPC (MW)	528	528	528	528									528

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - April 2016

Bartow CC

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4A	1/24/2016	FFO	18.00	176.7	LOW PRESSURE COMPRESSURE BLEED VALVES
BCC 4A	1/27/2016	FFO	22.08	176.7	GAS TURBINE - COOLING WATER SYSTEM
BCC 4B	1/17/2016	FFO	9.00	177.7	GAS TURBINE - LOAD SHAFT AND BEARINGS
BCC 4B	1/27/2016	FFO	31.58	177.7	GAS TURBINE - COOLING WATER SYSTEM
BCC 4B	2/26/2016	FFO	21.23	177.7	GENERATOR METERING DEVICES
BCC 4B	3/5/2016	PO	1205.77	177.7	GAS TURBINE - EXHAUST SYSTEM VANES/NOZZLES
BCC 4B	4/28/2016	FFO	6.02	177.7	BLADE PATH TEMPERATURE SPREAD
BCC 4C	1/3/2016	FFO	2.00	180.9	OTHER GAS TURBINE PROBLEMS
BCC 4C	1/27/2016	FFO	86.70	180.9	CIRCULATING WATER PUMPS
BCC 4C	1/30/2016	FFO	19.80	180.9	NOX STACK EMISSIONS - GAS TURBINE UNITS
BCC 4C	2/19/2016	FFO	63.98	180.9	HP STARTUP BYPASS INSTRUMENTATION AND CONTROLS
BCC 4D	1/26/2016	FFO	1.98	175.6	GAS TURBINE COMPRESSOR - BLEED VALVES
BCC 4D	3/12/2016	PO	1189.40	175.6	GAS TURBINE - EXHAUST SYSTEM VANES/NOZZLES
BCC 4S	1/27/2016	FFO	96.70	451.1	CIRCULATING WATER SYSTEM INSTRUMENTS AND CONTROLS
BCC 4S	3/5/2016	PPO	986.63	129.4	MAJOR GAS TURBINE OVERHAUL
BCC 4S	3/12/2016	PPO	817.47	107.3	MAJOR GAS TURBINE OVERHAUL
BCC 4S	4/15/2016	PO	379.55	451.1	LP TURBINE BUCKETS OR BLADES

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - April 2016

Crystal River 4

Date	Outage Type	Hours	MW Affected	Description
1/2/2016	FFO	20.93	712.0	PRIMARY AIR HEATER
1/5/2016	PMO	2.00	92.9	PRIMARY AIR DUCTS AND DAMPERS
2/4/2016	PMO	4.28	69.0	INDUCED DRAFT FANS
2/15/2016	PMO	5.50	236.0	4000-7000-VOLT CIRCUIT BREAKERS
2/17/2016	PMO	2.50	93.1	4000-7000-VOLT CIRCUIT BREAKERS
2/17/2016	PMO	5.00	236.0	4000-7000-VOLT CIRCUIT BREAKERS
2/26/2016	PO	741.58	712.0	MINOR BOILER OVERHAUL (LESS THAN 720 HOURS)
3/28/2016	PMO	54.67	93.0	PULVERIZER MILLS
4/2/2016	PFO	1.17	92.7	HEATER DRAIN PUMPS
4/4/2016	PMO	7.00	93.0	PULVERIZER MILLS
4/13/2016	PMO	5.75	236.0	CONDENSATE/HOTWELL PUMPS
4/14/2016	PMO	5.50	65.0	PULVERIZED FUEL AND AIR PIPING (PULVERIZER TO WIND BOX)
4/21/2016	PMO	5.50	65.0	BURNERS
4/26/2016	PMO	11.00	65.0	PULVERIZER MILLS
4/27/2016	PMO	2.73	93.0	PULVERIZER FEEDERS
4/27/2016	PMO	1.00	188.0	PULVERIZER FEEDERS
4/27/2016	PMO	2.48	92.9	PULVERIZER FEEDERS
4/28/2016	PMO	5.00	64.9	PULVERIZED FUEL AND AIR PIPING (PULVERIZER TO WIND BOX)

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - April 2016

Crystal River 5

Date	Outage Type	Hours	MW Affected	Description
1/7/2016	FFO	1.15	710.0	FEEDWATER PUMP DRIVE - STEAM TURBINE
1/7/2016	PFO	12.35	424.0	FEEDWATER PUMP/DRIVE LUBE OIL SYSTEM
1/15/2016	PMO	3.63	62.9	PULVERIZER MOTORS AND DRIVES
1/29/2016	PFO	7.67	110.0	SOOT BLOWERS - STEAM
2/5/2016	PFO	2.43	91.0	WET COAL (OMC)
2/6/2016	PFO	5.83	91.0	PULVERIZER FEEDERS
2/15/2016	PMO	6.25	234.0	CONDENSATE/HOTWELL PUMPS
2/15/2016	PMO	6.50	472.0	OTHER FEEDWATER VALVES
2/16/2016	PMO	7.98	234.0	CONDENSATE/HOTWELL PUMPS
2/17/2016	PMO	3.33	91.0	HEATER LEVEL CONTROL
2/22/2016	PMO	33.08	63.0	PULVERIZER MILLS
2/27/2016	PMO	1.00	90.9	PULVERIZER FEEDERS
3/1/2016	PMO	5.00	472.0	OTHER FEEDWATER VALVES
3/18/2016	PMO	3.50	91.1	PRIMARY AIR DUCTS AND DAMPERS
3/24/2016	PMO	2.00	472.2	START-UP FEEDWATER PUMP
3/30/2016	PFO	5.45	91.1	HEATER DRAIN PUMPS
4/5/2016	PMO	0.45	148.3	FORCED DRAFT FANS
4/5/2016	PMO	2.63	234.1	CONDENSATE/HOTWELL PUMPS
4/6/2016	PMO	6.83	148.0	FORCED DRAFT FANS
4/18/2016	PFO	1.00	63.2	PULVERIZER FEEDERS
4/18/2016	PMO	7.00	63.0	PULVERIZER FEEDERS
4/19/2016	PFO	2.00	62.8	PULVERIZER FEEDERS

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - April 2016

Hines Power Block 1

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 1A	3/19/2016	FFO	30.00	169.3	GENERATOR SEAL OIL SYSTEM AND SEALS
HEP 1A	3/21/2016	FFO	6.02	169.3	GAS TURBINE - FUEL PIPING AND VALVES
HEP 1A	3/23/2016	PO	788.12	169.3	GENERAL GAS TURBINE UNIT INSPECTION
HEP 1A	4/29/2016	FFO	5.15	169.3	SWITCHYARD SYSTEM PROTECTION DEVICES - EXTERNAL (NOT OMC)
HEP 1B	3/19/2016	FFO	60.17	169.3	GENERATOR SEAL OIL SYSTEM AND SEALS
HEP 1B	3/23/2016	PO	788.12	169.3	GENERAL GAS TURBINE UNIT INSPECTION
HEP 1B	4/24/2016	PO	146.63	169.3	GENERAL GAS TURBINE UNIT INSPECTION
HEP ST1	3/19/2016	FFO	40.20	179.4	GENERATOR SEAL OIL SYSTEM AND SEALS
HEP ST1	3/23/2016	PO	794.63	179.4	GENERAL GAS TURBINE UNIT INSPECTION
HEP ST1	4/29/2016	FFO	6.80	179.4	SWITCHYARD SYSTEM PROTECTION DEVICES - EXTERNAL (NOT OMC)

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - April 2016

Hines Power Block 2

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 2A	1/27/2016	FFO	0.20	171.6	GAS TURBINE - FUEL PIPING AND VALVES
HEP 2A	1/27/2016	FFO	0.58	171.6	GAS TURBINE - FUEL PIPING AND VALVES
HEP 2A	1/29/2016	FFO	1.90	171.6	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEM
HEP 2A	1/29/2016	FFO	0.13	171.6	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
HEP 2A	1/29/2016	FFO	6.30	171.6	GAS TURBINE - FUEL PIPING AND VALVES
HEP 2A	2/9/2016	PPO	1.00	58.5	INTAKE GRATING FOULING
HEP 2A	2/13/2016	PPO	0.70	72.6	INTAKE GRATING FOULING
HEP 2A	2/20/2016	PO	767.45	171.6	GENERAL GAS TURBINE UNIT INSPECTION
HEP 2A	3/24/2016	FFO	30.03	171.6	FEEDWATER PUMP
HEP 2A	3/25/2016	FFO	35.47	171.6	FEEDWATER PUMP
HEP 2A	4/14/2016	PPO	1.00	58.5	INTAKE GRATING FOULING
HEP 2B	2/8/2016	FFO	3.43	171.6	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEM
HEP 2B	2/9/2016	PPO	1.00	58.5	INTAKE GRATING FOULING
HEP 2B	2/13/2016	PPO	0.70	72.6	INTAKE GRATING FOULING
HEP 2B	2/20/2016	PO	754.50	171.6	GENERAL GAS TURBINE UNIT INSPECTION
HEP 2B	3/22/2016	PO	9.88	171.6	OTHER FEEDWATER VALVES
HEP 2B	3/24/2016	FFO	1.93	171.6	FEEDWATER PUMP
HEP 2B	3/28/2016	FFO	3.17	171.6	OTHER INSTRUMENT AIR PROBLEMS
HEP 2B	4/2/2016	FFO	3.12	171.6	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEM
HEP 2B	4/14/2016	PPO	1.00	58.5	INTAKE GRATING FOULING
HEP ST2	2/9/2016	PPO	1.00	75.8	INTAKE GRATING FOULING
HEP ST2	2/13/2016	PPO	0.70	75.9	INTAKE GRATING FOULING
HEP ST2	2/20/2016	PO	768.75	202.8	INSPECTION
HEP ST2	3/24/2016	FFO	3.43	202.8	FEEDWATER PUMP
HEP ST2	4/14/2016	PPO	1.00	89.8	INTAKE GRATING FOULING

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - April 2016

Hines Power Block 3

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 3A	2/10/2016	PPO	1.53	52.7	INTAKE GRATING FOULING
HEP 3A	2/21/2016	PPO	0.75	52.8	INTAKE GRATING FOULING
HEP 3A	3/6/2016	PPO	1.25	63.7	INTAKE GRATING FOULING
HEP 3A	3/28/2016	PPO	6.42	59.8	CONDENSER TUBE AND WATER BOX CLEANING
HEP 3A	4/2/2016	PPO	7.00	59.8	CONDENSER TUBE AND WATER BOX CLEANING
HEP 3A	4/15/2016	FFO	17.42	172.8	GAS TURBINE - CONTROLS AND INSTRUMENTS
HEP 3A	4/19/2016	PPO	1.38	59.8	CIRCULATING WATER PUMPS
HEP 3A	4/27/2016	PO	95.45	172.8	GENERAL GAS TURBINE UNIT INSPECTION
HEP 3B	2/10/2016	PPO	1.53	52.7	INTAKE GRATING FOULING
HEP 3B	2/21/2016	PPO	0.75	52.8	INTAKE GRATING FOULING
HEP 3B	3/6/2016	PPO	1.25	63.7	INTAKE GRATING FOULING
HEP 3B	3/28/2016	PPO	6.42	59.8	CONDENSER TUBE AND WATER BOX CLEANING
HEP 3B	4/2/2016	PPO	7.00	59.8	CONDENSER TUBE AND WATER BOX CLEANING
HEP 3B	4/8/2016	FMO	49.18	172.8	GAS TURBINE - INLET AIR DUCTS
HEP 3B	4/19/2016	PPO	1.00	59.8	CIRCULATING WATER PUMPS
HEP 3B	4/27/2016	PO	95.47	172.8	GENERAL GAS TURBINE UNIT INSPECTION
HEP ST3	2/10/2016	PPO	1.53	51.4	INTAKE GRATING FOULING
HEP ST3	2/21/2016	PPO	0.75	51.3	INTAKE GRATING FOULING
HEP ST3	3/6/2016	PPO	1.25	60.5	INTAKE GRATING FOULING
HEP ST3	3/28/2016	PPO	6.42	57.4	CONDENSER TUBE AND WATER BOX CLEANING
HEP ST3	4/2/2016	PPO	7.00	53.4	CONDENSER TUBE AND WATER BOX CLEANING
HEP ST3	4/19/2016	PPO	1.38	53.4	CIRCULATING WATER PUMPS
HEP ST3	4/27/2016	PO	95.80	198.4	GENERAL GAS TURBINE UNIT INSPECTION

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - April 2016

Hines Power Block 4

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 4A	1/26/2016	PPO	1.50	56.0	INTAKE GRATING FOULING
HEP 4A	2/1/2016	PPO	1.62	55.9	INTAKE GRATING FOULING
HEP 4A	2/6/2016	PPO	1.00	55.9	INTAKE GRATING FOULING
HEP 4A	2/10/2016	PPO	0.83	56.0	INTAKE GRATING FOULING
HEP 4A	2/11/2016	PPO	0.97	55.9	INTAKE GRATING FOULING
HEP 4A	2/13/2016	PPO	0.88	61.0	INTAKE GRATING FOULING
HEP 4A	2/16/2016	PPO	0.58	60.8	INTAKE GRATING FOULING
HEP 4A	2/19/2016	PPO	1.33	55.9	INTAKE GRATING FOULING
HEP 4A	2/23/2016	PPO	0.50	56.1	INTAKE GRATING FOULING
HEP 4A	2/29/2016	PPO	0.50	56.1	INTAKE GRATING FOULING
HEP 4A	3/6/2016	PPO	1.17	60.9	INTAKE GRATING FOULING
HEP 4A	4/14/2016	PPO	1.00	55.9	INTAKE GRATING FOULING
HEP 4B	1/16/2016	FFO	9.05	168.9	FEEDWATER PUMP
HEP 4B	1/26/2016	PPO	1.50	56.0	INTAKE GRATING FOULING
HEP 4B	2/1/2016	PPO	1.62	55.9	INTAKE GRATING FOULING
HEP 4B	2/6/2016	PPO	1.00	55.9	INTAKE GRATING FOULING
HEP 4B	2/10/2016	PPO	0.83	56.0	INTAKE GRATING FOULING
HEP 4B	2/11/2016	PPO	0.97	55.9	INTAKE GRATING FOULING
HEP 4B	2/13/2016	PPO	0.88	61.0	INTAKE GRATING FOULING
HEP 4B	2/16/2016	PPO	0.58	60.8	INTAKE GRATING FOULING
HEP 4B	2/19/2016	PPO	1.33	55.9	INTAKE GRATING FOULING
HEP 4B	2/23/2016	PPO	0.50	56.1	INTAKE GRATING FOULING
HEP 4B	2/29/2016	PPO	0.50	56.1	INTAKE GRATING FOULING
HEP 4B	3/6/2016	PPO	1.17	60.9	INTAKE GRATING FOULING
HEP 4B	4/14/2016	PPO	1.00	55.9	INTAKE GRATING FOULING
HEP ST4	1/16/2016	FFO	10.15	190.2	FEEDWATER PUMP
HEP ST4	1/26/2016	PPO	1.50	65.2	INTAKE GRATING FOULING

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - April 2016

Hines Power Block 4

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP ST4	2/1/2016	PPO	1.62	65.2	INTAKE GRATING FOULING
HEP ST4	2/6/2016	PPO	1.00	65.2	INTAKE GRATING FOULING
HEP ST4	2/10/2016	PPO	0.83	65.3	INTAKE GRATING FOULING
HEP ST4	2/11/2016	PPO	0.97	65.1	INTAKE GRATING FOULING
HEP ST4	2/13/2016	PPO	0.88	65.3	INTAKE GRATING FOULING
HEP ST4	2/16/2016	PPO	0.58	65.2	INTAKE GRATING FOULING
HEP ST4	2/19/2016	PPO	1.33	65.2	INTAKE GRATING FOULING
HEP ST4	2/23/2016	PPO	0.50	45.3	INTAKE GRATING FOULING
HEP ST4	3/6/2016	PPO	1.17	46.1	INTAKE GRATING FOULING
HEP ST4	4/14/2016	PPO	1.00	77.2	INTAKE GRATING FOULING