

GULF POWER COMPANY
TEN YEAR SITE PLAN
For Electrical Generating Facilities
And
Associated Transmission Lines

Submitted to the
State of Florida
Department of Community Affairs
Division of Local Resource Management
Bureau of Land and Water Management
Power Plant Siting Program

April 1, 1980

TABLE OF CONTENTS

	<u>Page No.</u>
I. DESCRIPTION OF EXISTING FACILITIES	
DSP Form 1A "Existing Generating Facilities - Specifications"-----	1
DSP Form 1B "Existing Generating Facilities - Land Use and Investment"-----	2
DSP Form 1C "Existing Generating Facilities - Environmental Considerations"-	3
System Map-----	4
II. FORECAST OF ELECTRIC POWER DEMAND	
DSP Form 2 "History and Forecast of Energy Use"-----	5
Graph 1 "Energy Use"-----	7
DSP Form 3A "Energy Sources and Fuel Requirements"-----	8
DSP Form 4 "History and Forecast of Seasonal Peak Demand and Annual Net Energy for Load"-----	10
Graph 2 "Seasonal Peak Demand and Annual Net Energy for Load"-----	11
DSP Form 5 "Two-Year Actual and Two-Year Forecast of Peak Demand and Net Energy for Load by Month"-----	13
Forecasting Documentation	
General-----	14
Customer and Kilowatt Hour Forecasts (Micro Method)-----	15
Peak Hour Demand Forecasts (Micro Method)-----	19
Econometric Model	
Concepts-----	24
Energy and Customers-----	25
Peak Hour Demand-----	27
III. FORECAST OF FACILITIES REQUIREMENTS	
DSP Form 6 "Planned and Prospective Generating Facility Additions and Changes"-----	41
DSP Form 7A "Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak"-----	42
DSP Form 7B "Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Winter Peak"-----	43
Documentation of Facility Changes-----	44
IV. SITE DESCRIPTION AND IMPACT ANALYSIS	
DSP Form 8A "Status Report and Specifications of Proposed Generating Facilities"-----	45
DSP Form 8B "Status Report and Specifications of Proposed Directly Associated Transmission Lines"-----	48

CHAPTER I

DESCRIPTION OF EXISTING FACILITIES

UTILITY Gulf Power Company

EXISTING GENERATING FACILITIES

(1) Plant	(2) Unit No.	(3) Location	(4) Type	(5) Fuel	(6) Pri Alt	(7) Com'l In-Service Mo/Yr	(8) Exptd Retrmnt Mo/Yr	(9) Gen Max Nameplate Kw	(10) Net Capacity Summer MW	(11) Net Capacity Winter MW
Crist		Pensacola 25/1N/30W						<u>1,229,000</u>	<u>1041.6</u>	<u>1041.6</u>
	1		F	NG	HO	1/45	1990	28,125	21.6	21.6
	2		F	NG	HO	6/49	1990	28,125	20.3	20.3
	3		F	NG	HO	9/52	1990	37,500	37.5	37.5
	4		F	C	NG	7/59	1996	93,750	77.6	77.6
	5		F	C	NG	6/61	1996	93,750	81.9	81.9
	6		F	C	NG	5/70	2005	369,750	318.9	318.9
7		F	C	no	8/73	2008	578,000	483.8	483.8	
Lansing Smith		Panama City 36/2S/15W						<u>381,850</u>	<u>377.8</u>	<u>381.3</u>
	1		F	C	no	6/65	2002	149,600	159.5	159.5
	2		F	C	no	6/67	2004	190,400	187.0	187.0
Scholz	A		CT	LO	no	5/71	1991	41,850	31.3	34.8
		Sneads 12/3N/7W						<u>98,000</u>	<u>95.7</u>	<u>95.7</u>
	1		F	C	no	3/53	1990	49,000	48.0	48.0
2		F	C	no	10/53	1990	49,000	47.7	47.7	

Total System As of December 31, 1979: 1515.1 1518.6

UTILITY Gulf Power Company


EXISTING GENERATING FACILITIES
LAND USE AND INVESTMENT

(1) Plant Name	(2) Total Acres	(3) Land Area In Use Acres	(4) Land	(5) Plant Capital Investment Site Improvements	(6) Plant Capital Investment (in \$1,000) Buildings & Equipment	(7) Total
<u>STEAM TOTAL</u>			<u>384</u>	<u>44,056</u>	<u>251,961</u>	<u>296,401</u>
Crist	676.00	200	135	29,247	177,036	206,418
Lansing Smith	841.40	270	204	10,719	57,388	68,311
Scholz	293.15	168	45	4,090	17,537	21,672
<u>COMBUSTION TURBINES - TOTAL</u>			<u>104</u>	<u>104</u>	<u>3,771</u>	<u>3,875</u>
Lansing Smith CT			104		3,771	3,875

UTILITY Gulf Power Company

EXISTING GENERATING FACILITIES
 ENVIRONMENTAL CONSIDERATIONS FOR STEAM GENERATING UNITS

(1) Plant Name	(2) Unit	(3) Flue Gas Cleaning Particulate	(4) SOx	(5) NOx	(6) Cooling Type
Crist	1	no	no	no	WCTM
	2	no	no	no	WCTM
	3	no	no	no	WCTM
	4	EP	no	no	WCTM
	5	EP	no	no	WCTM
	6	EP	no	no	WCTM
	7	EP	no	no	WCTM
Lansing Smith	1	EP	no	no	OTS
	2	EP	no	no	OTS
Scholz	1	EP	no	no	OTF
	2	EP	no	no	OTF



CHAPTER II

FORECAST OF ELECTRIC POWER DEMAND

UTILITY Gulf Power Company

HISTORY AND FORECAST OF ENERGY USE

(1) Year	(2) GWH	(3) Rural & Residential		(4) Commercial		(5) Industrial		(6) Average No. of Customers	
		Average No. of Customers	Average KWH Consumption Per Customer	GWH	Average No. of Customers	GWH	Average No. of Customers	GWH	Average No. of Customers
1970	1,306	121,972	10,707	679	16,418	1,068	134	1,068	134
1971	1,425	127,233	11,200	752	17,212	1,164	141	1,164	141
1972	1,602	135,437	11,828	860	18,088	1,308	149	1,308	149
1973	1,800	142,434	12,637	946	18,938	1,382	159	1,382	159
1974	1,835	150,257	12,212	969	19,589	1,325	159	1,325	159
1975	1,889	154,170	12,253	1,041	19,769	1,340	160	1,340	160
1976	2,046	158,492	12,913	1,128	20,364	1,435	154	1,435	154
1977	2,156	163,121	13,220	1,207	20,964	1,494	156	1,494	156
1978	2,243	168,156	13,342	1,254	21,567	1,530	160	1,530	160
1979	2,225	172,906	12,868	1,269	21,949	1,552	164	1,552	164
1980	2,354	178,280	13,204	1,359	22,618	1,619	173	1,619	173
1981	2,447	183,604	13,328	1,407	23,205	1,672	177	1,672	177
1982	2,547	189,110	13,468	1,456	23,806	1,726	179	1,726	179
1983	2,651	194,805	13,608	1,508	24,428	1,779	181	1,779	181
1984	2,756	200,702	13,732	1,561	25,075	1,832	184	1,832	184
1985	2,865	208,988	13,709	1,616	25,853	1,887	191	1,887	191
1986	2,979	215,258	13,839	1,673	26,629	1,943	195	1,943	195
1987	3,097	221,716	13,968	1,732	27,428	2,001	200	2,001	200
1988	3,220	228,367	14,100	1,793	28,251	2,060	204	2,060	204
1989	3,348	235,218	14,234	1,856	29,099	2,121	209	2,121	209


UTILITY Gulf Power Company

HISTORY AND FORECAST OF ENERGY USE

(9) Year	(10) Street & Highway Lighting GWH	(11) Other Sales to Ultimate Consumers GWH	(12) Total Sales to Ultimate Consumers GWH	(13) Sales For Resale GWH	(14) Utility Use & Losses GWH	(15) Net Energy For Load GWH
1970	13	0	3,066	350	348	3,764
1971	13	0	3,354	384	334	4,072
1972	12	0	3,782	428	394	4,604
1973	9	0	4,137	448	393	4,978
1974	13	0	4,142	470	371	4,983
1975	13	0	4,283	505	360	5,148
1976	13	0	4,622	519	334	5,475
1977	14	0	4,871	551	401	5,823
1978	14	0	5,041	569	434	6,044
1979	14	0	5,060	558	412	6,030
1980	14	0	5,346	590	474	6,410
1981	14	0	5,540	416	477	6,433
1982	15	0	5,744	396	494	6,634
1983	16	0	5,954	415	511	6,880
1984	16	0	6,165	434	532	7,131
1985	16	0	6,384	453	561	7,398
1986	17	0	6,612	473	586	7,671
1987	17	0	6,847	494	613	7,954
1988	18	0	7,091	516	658	8,265
1989	19	0	7,344	539	670	8,553

Note: Columns (13) and (15) include energy allocated to certain resale customers by Southeastern Power Administration (SEPA).

GRAPH I
 HISTORY AND FORECAST
 OF ENERGY USE BY TYPE OF CUSTOMER



NOTE: (a) Includes energy allocated to certain resale customers by SEPA.

ENERGY SOURCES AND FUEL REQUIREMENTS

		Actual		1980	1981	1982	1983
		1978	1979				
(1)	PURCHASE & INTERCHANGE	(126)	(603)	274	(416)	(529)	(690)
(2)	NUCLEAR	NONE	NONE	NONE	NONE	NONE	NONE
(3)	COAL	5378	6000	5639	6428	6792	7195
(4)	RESIDUAL-TOTAL-	53	2	1	4	10	8
(5)	Steam	53	2	1	4	10	8
(6)	CC	NONE	NONE	NONE	NONE	NONE	NONE
(7)	CT	NONE	NONE	NONE	NONE	NONE	NONE
(8)	DISTILLATE-TOTAL-	22	3	14	14	14	14
(9)	CT	22	3	14	14	14	14
(10)	Diesel	NONE	NONE	NONE	NONE	NONE	NONE
(11)	NATURAL GAS-TOTAL-	717	628	482	403	347	353
(12)	Steam	717	628	482	403	347	353
(13)	CC	NONE	NONE	NONE	NONE	NONE	NONE
(14)	CT	NONE	NONE	NONE	NONE	NONE	NONE
(15)	Diesel	NONE	NONE	NONE	NONE	NONE	NONE
(16)	OTHER	NONE	NONE	NONE	NONE	NONE	NONE
(17)	NET ENERGY FOR LOAD (a)	6044	6030	6410	6433	6634	6880
FUEL REQUIREMENTS							
(18)	NUCLEAR	NONE	NONE	NONE	NONE	NONE	NONE
(19)	COAL	2613	2771	2685	3060	3236	3429
(20)	RESIDUAL-TOTAL-	134	4	2	10	24	20
(21)	Steam	134	4	2	10	24	20
(22)	CC	NONE	NONE	NONE	NONE	NONE	NONE
(23)	CT	NONE	NONE	NONE	NONE	NONE	NONE
(24)	DISTILLATE-TOTAL-	53	7	35	35	35	35
(25)	CT	53	7	35	35	35	35
(26)	Diesel	NONE	NONE	NONE	NONE	NONE	NONE
(27)	NATURAL GAS-TOTAL-	9141	7273	7213	6240	5434	5532
(28)	Steam	9141	7273	7213	6240	5434	5532
(29)	CC	NONE	NONE	NONE	NONE	NONE	NONE
(30)	CT	NONE	NONE	NONE	NONE	NONE	NONE
(31)	Diesel	NONE	NONE	NONE	NONE	NONE	NONE
(32)	OTHER	NONE	NONE	NONE	NONE	NONE	NONE
(33)	ANNUAL AVG. FOSSIL NET H.R.	11493	10982	11603	11516	11470	11456

NOTE: (a) Includes energy allocated to certain resale customers by Southeastern Power Administration (SEPA).

ENERGY SOURCES AND FUEL REQUIREMENTS

ENERGY SOURCES	1983	1984	1985	1986	1987	1988
(1) PURCHASES & INTERCHANGE						
(2) NUCLEAR	GWH	(539)	(168)	(358)	(704)	(1151)
(3) COAL	GWH	NONE	NONE	NONE	NONE	NONE
(4) RESIDUAL-TOTAL-	GWH	7337	7408	7869	8500	9539
(5) Steam	GWH	12	89	91	89	96
(6) CC	GWH	12	89	91	89	96
(7) CT	GWH	NONE	NONE	NONE	NONE	NONE
(8) DISTILLATE-TOTAL-	GWH	NONE	NONE	NONE	NONE	NONE
(9) CT	GWH	14	14	14	14	14
(10) Diesel	GWH	14	14	14	14	14
(11) NATURAL GAS-TOTAL-	GWH	NONE	NONE	NONE	NONE	NONE
(12) Steam	GWH	307	55	55	55	55
(13) CC	GWH	307	55	55	55	55
(14) CT	GWH	NONE	NONE	NONE	NONE	NONE
(15) Diesel	GWH	NONE	NONE	NONE	NONE	NONE
(16) OTHER	GWH	NONE	NONE	NONE	NONE	NONE
(17) NET ENERGY FOR LOAD (a)	GWH	7131	7398	7671	7954	8265

FUEL REQUIREMENTS

(18) NUCLEAR	BTUx10 ¹²	NONE	NONE	NONE	NONE	NONE
(19) COAL	1000 TON	3494	3452	3672	3937	4386
(20) RESIDUAL-TOTAL-	1000 BBL	31	230	235	230	248
(21) Steam	1000 BBL	31	230	235	230	248
(22) CC	1000 BBL	NONE	NONE	NONE	NONE	NONE
(23) CT	1000 BBL	NONE	NONE	NONE	NONE	NONE
(24) DISTILLATE-TOTAL-	1000 BBL	35	35	35	35	35
(25) CT	1000 BBL	35	35	35	35	35
(26) Diesel	1000 BBL	NONE	NONE	NONE	NONE	NONE
(27) NATURAL-GAS-TOTAL-	1000 MCF	4783	857	857	857	857
(28) Steam	1000 MCF	4783	857	857	857	857
(29) CC	1000 MCF	NONE	NONE	NONE	NONE	NONE
(30) CT	1000 MCF	NONE	NONE	NONE	NONE	NONE
(31) Diesel	1000 MCF	NONE	NONE	NONE	NONE	NONE
(32) OTHER	BTUx10 ⁶	NONE	NONE	NONE	NONE	NONE
(33) ANNUAL AVG. FOSSIL NET H. R.	BTUxKWH	11426	11120	11073	10983	10889

NOTE: (a) Includes energy allocated to certain resale customers by Southeastern Power Administration (SEPA).

UTILITY Gulf Power Company


HISTORY AND FORECAST OF SEASONAL PEAK DEMAND AND ANNUAL NET ENERGY FOR LOAD

(1) Year	(2) Summer Peak Demand Net MW		(3) Total	(4) Net Energy For Load - GWH	(5) Load Factor %	(6) Year	(7) Winter Peak Demand Net MW		(8) Total
	Interruptible	Non-Interruptible					Interruptible	Non-Interruptible	
1970			774	3,764	55.49	1970-71			600
1971			842	4,072	55.24	1971-72			648
1972			956	4,604	54.81	1972-73			764
1973			1,014	4,978	56.02	1973-74			790
1974			1,081	4,983	52.60	1974-75			826
1975			1,078	5,148	54.52	1975-76			976
1976			1,140	5,475	54.65	1976-77			1,121
1977			1,180	5,823	56.33	1977-78			1,072
1978			1,257	6,044	54.89	1978-79			1,154
1979			1,232	6,030	55.87	1979-80			1,111
1980			1,350	6,410	54.05	1980-81		NONE	1,118
1981			1,354	6,433	54.24	1981-82			1,161
1982			1,397	6,634	54.21	1982-83			1,214
1983			1,449	6,880	54.20	1983-84			1,269
1984			1,502	7,131	54.05	1984-85			1,327
1985			1,557	7,398	54.25	1985-86			1,388
1986			1,614	7,671	54.28	1986-87			1,451
1987			1,674	7,954	54.28	1987-88			1,517
1988			1,735	8,265	54.31	1988-89			1,586
1989			1,799	8,553	54.33	1989-90			1,658

Note: Includes capacity and energy allocated to certain resale customers by Southeastern Power Administration (SEPA)

SUMMER


GRAPH 2
HISTORY AND FORECAST OF LOAD
AND
CAPACITY ADDITIONS



NOTE: (a) Includes capacity allocated to certain resale customers by SEPA.

WINTER

GRAPH 2
HISTORY AND FORECAST OF LOAD
AND
CAPACITY ADDITIONS



NOTE: (a) Includes capacity allocated to certain resale customers by SEPA.

UTILITY Gulf Power Company

PREVIOUS YEAR ACTUAL AND TWO-YEAR FORECAST OF PEAK DEMAND AND NET ENERGY FOR LOAD BY MONTH

(1) MONTH	(2) ACTUAL 1979		(3)		(4)		(5) FORECAST		(6)		(7)	
	PEAK DEMAND MW	NET GWH	PEAK DEMAND MW	NET GWH	PEAK DEMAND MW	NET GWH	PEAK DEMAND MW	NET GWH	PEAK DEMAND MW	NET GWH	PEAK DEMAND MW	NET GWH
JAN	1,154	559	1,111	543	1,118	547	1,118	547	1,118	547	1,118	547
FEB	1,115	466	1,038	453	1,046	457	1,046	457	1,046	457	1,046	457
MAR	791	422	853	435	858	437	858	437	858	437	858	437
APR	760	402	799	423	802	425	802	425	802	425	802	425
MAY	967	480	1,107	530	1,110	531	1,110	531	1,110	531	1,110	531
JUN	1,202	576	1,265	637	1,263	635	1,263	635	1,263	635	1,263	635
JUL	1,232	624	1,274	674	1,274	675	1,274	675	1,274	675	1,274	675
AUG	1,216	636	1,350	663	1,354	663	1,354	663	1,354	663	1,354	663
SEP	1,159	525	1,195	589	1,195	589	1,195	589	1,195	589	1,195	589
OCT	964	440	1,055	490	1,062	492	1,062	492	1,062	492	1,062	492
NOV	973	419	910	443	916	446	916	446	916	446	916	446
DEC	1,033	481	1,077	530	1,088	536	1,088	536	1,088	536	1,088	536
TOTAL		6,030		6,410		6,433		6,433		6,433		6,433

Note: Includes Capacity and Energy Allocated to Certain Resale Customers by Southeastern Power Administration (SEPA)

FORECASTING DOCUMENTATION

I. General

Gulf uses two basic methods in its current peak hour demand forecasts, an in house micro method and an econometric model.

Since the micro method is dependent on customer and kilowatt hour forecasts, we begin with an explanation of these forecasts and then move on to the econometric forecast of energy and demand.

II. Customer and Kilowatt Hour Forecasts (Micro Method)

Customer and kilowatt hour forecasts begin with the gathering of information to determine the growth in all classes for the forecasting period.

For the industrial class, approximately 90% of the energy is consumed by the 34 largest customers. Local office personnel contact each of the 34 industries and discuss their power needs and employment projections for the forecast period. Our forecast data for energy is based on the long term planning of these 34 largest industrial customers with the remaining 10% projected using a time trend. No additional industrial load is included in our forecast until an industry makes a definite commitment to locate in our service area.

For the commercial class, information is obtained on new construction and expansion projects by contacting architects, engineers, developers, and community planning groups. These large block loads are planned well in advance and account for approximately two thirds of the customer and energy growth in the commercial sector. The remaining growth comes from small businesses which can be projected by its historical relationship with residential growth.

The forecasts for the street light and wholesale classes are the sum of the projections we received from the individual communities and wholesale customers. These projections are checked for reasonableness by comparing them to long term trends, contract capacities, and known changes which will occur.

The residential customer forecast begins with all the job information obtained from the survey of the industrial and commercial sectors and the projections for growth in employment obtained from State Employment Agencies and other sources. After this job information is assembled at the local level and adjusted for the number of persons and wage earners per household, it is combined into our service area residential customer forecast. This is tested for reasonableness by comparing it to other forecasts for our ten-county area, such as Kiplinger, University of Florida, and our own econometric forecast.

The kilowatt hour forecast methodology deals with the average residential customer as if Gulf had only one customer and utilizes the appliance saturation survey information and our load management programs to predict what will happen to that customer's KWH consumption assuming his willingness to purchase power remains at the last known level. This process begins by separating ten-year KWH/customer history into its weather sensitive and non-weather sensitive components.

This is done by using past appliance saturations and typical appliance usage to arrive at the non-weather sensitive component, which we assume remains relatively constant for each month within a given year. The weather sensitive component is left when the non-weather sensitive portion is subtracted from each month's KWH/customer.

The non-weather sensitive quantity is checked by comparing it with the average KWH/residential customer for the month of April, which is normally the least weather sensitive month for our system, and found to be extremely close for each of the ten Aprils in the history. After separating the two KWH/customer components and testing the primary component for validity, we are ready to project each component.

In order to project the weather sensitive component, there are some factors that vary from year to year that must be eliminated.

Just as customer growth can be eliminated from KWH growth by dividing KWH by the number of customers, we also eliminate the factors of weather and billing cycle length, resulting in a monthly factor with the dimensions of KWH/CUST/°HR/DAY.

For a weather sensitive component, this leaves only two variables: (1) load growth (for heating and air conditioning), and (2) level of customer usage.

With the customer usage variable held constant at the last known level, all that remains is to forecast the growth of the heating or cooling load.

This is done by determining from our saturation surveys and load reporting system the accumulated connected heating and cooling loads and then projecting, based on load management programs, future heating/cooling load to be added, taking into consideration the following:

1. Decrease in heating and cooling requirements caused by:
 - A. Smaller dwelling size
 - (1) Increased apartment, townhouses, and condominiums.
 - (2) Smaller single family residences.
 - B. More insulation
 - (1) Good Øents Home Program
 - (2) Insulation Surveys of Existing Homes
 - C. Improved equipment efficiency average from present 6.8 EER to 7.5 EER by 1985.
 - D. Customer Conservation and Changes in temperature levels maintained.

After the heating and cooling loads to be added in future years have been obtained, the annual growth factors for heating growth are applied to the monthly KWH/CUST/ØHR/DAY factor. When this monthly factor is multiplied by the average ØHRs and the number of billing days for that month, the result is a weather normalized, weather sensitive KWH/customer component of consumption.

A similar projection is made for the non-weather sensitive component by making projections for the future saturation limits. Using the typical appliance consumptions that were validated based on our customer historic usage and the number of days in the appropriate monthly billing period, the resulting figure is a future projection of the non-weather sensitive, or base load KWH/customer component.

The combined KWH/customer components for each month of the year are multiplied by the total number of residential customers for each month and the result is the annual distribution of KWH sales for the residential class based on normalized weather.

III. Peak Hour Demand Forecasts (Micro Method)

In addition to the econometric method for forecasting peak hour demand which we will discuss later, Gulf also utilizes a micro method which analyzes changes in numbers of customers and average use per customer, then converts KWH to demand through the use of class load factors.

This method begins with KWH projections by customer class which we discussed earlier. The next step is to utilize actual load data gathered from a random sampling of customers to determine annual class load factors.

Exhibit #MD-1 shows actual annual class load factors obtained from data gathered in 1976. These factors are applied to the KWH forecast to compute the five day average demand. The calculation for this is shown on Exhibit #MD-1 and equals 487.2 MW for the residential class in 1980. The five day average demand for each class is summed to equal 1120.9 MW, and then multiplied by a diversity factor that converts five day average demand to an unadjusted peak hour demand. This diversity factor, indicated on Exhibit #MD-2, is computed by dividing the actual 1976 system peak hour demand by the five day average demand for 1976 to account for system peak hour losses and diversity between five day average demand and peak hour demand.

Gulf's current demand forecast assumes the individual class load factors will remain essentially constant throughout the forecast period. The small changes in system annual load

factor shown in the projections result from differences in growth rates between the classes, and from a moderate band width added to the computed demands to account for the effect of minor temperature variations which occur at rather frequent intervals during the summer and winter peak months.

The last calculation needed to get forecast peak hour demand is to multiply the unadjusted peak hour demand by the weather factor. For 1980, this results in a peak hour demand of 1350 MW, which is shown on Exhibit #MD-3.

SAMPLE CALCULATIONS FOR YEAR 1980

5-Day Average Demand

<u>CUSTOMER CLASS</u>	<u>ANNUAL CLASS (1) LOAD FACTORS</u>	<u>PROJECTED BILL KWH SALES FOR 1980 (Millions)</u>	<u>5-DAY AVERAGE DEMAND (MW)</u>
Residential	.549	2342.9	487.2
Commercial	.570	1353.0	271.0
Industrial	.734	1618.8	251.8
FPU	.555	227.7	46.8
REA (2)	.575	323.1	64.1
TOTAL			<u>1120.9</u>

Residential 5-Day Average Demand = $\frac{\text{Projected Billed KWH Sales for Year}}{\text{Annual Class Load Factor x Hours in Year}}$

Residential 5-Day Average Demand = $\frac{2342.9}{.549 \times 8.76} = 487.2 \text{ MW}$

- (1) Annual class load factors from 1976 cost of service study.
- (2) REA does not include SEPA allocation of 12 MW.

DIVERSITY FACTOR

Historical Data

<u>Customer Class</u>	<u>5-Day Average Demands (MW)</u>
	<u>1976</u>
Residential	419.7
Commercial	224.0
Industrial	224.3
Florida Public Utilities	37.8
REA	67.3
	<hr/>
TOTAL	973.1
Actual System Peak Demand	1140.3
Diversity Factor =	$\frac{\text{Actual System Peak Hour Demand}}{\text{5-Day Average Demand}}$
Diversity Factor =	$\frac{1140.3}{973.1}$
Diversity Factor =	1.17

PEAK HOUR DEMAND (1980)

Peak Hour Demand = Sum of 5-Day Average Demands x Diversity Factor x Weather Factor

Sum of 5-Day Average Demands = 1120.9 MW

Diversity Factor = 1.17

Weather Factor = 1.02

1979 Peak Hour Demand = 1121 x 1.17 x 1.02 = 1338 MW + SEPA = 1350MW

IV. Econometric Model

(a) Concepts

An econometric model is one that relates a dependent variable, such as KWH sales, to socio-economic variables without regard for the reasonableness of the relationship. Our model, termed an "econometric-end use model", combines the best of two methods. Econometric techniques are used to develop end-use equations, with emphasis on assuring that these relationships are both meaningful and reasonable.

The econometric models were developed by Data Resources, Inc. (referred to as DRI) with Gulf Power Company providing data input and interpretive assistance. Of major importance is the National Economic Forecast, which begins the forecasting sequence through input to the service area economic model.

DRI's model of the U.S. economy is a computer based system of over 900 quarterly equations that describe the interactions of the measurable facets of the national economy, and is updated annually (Exhibit #E-1). This model is utilized by DRI to produce their short and long term forecast of the U. S. economy, by DRI's clients to test the impact of their own assumptions on the national economic outlook, and by DRI's clients as input into their own forecasting systems.

Exhibit #E-2 shows a block diagram which represents Gulf's econometric forecasting system. The system

begins a national forecast which drives the service area economic model to produce input into the energy model, which in turn produces energy forecasts by customer class. The energy forecasts by class are used in the peak demand model to produce the peak demand forecast. An electric energy price projection and a projection of losses from supply to sales is input to these models.

The major link between Gulf's service area economic model and the national economy is the employment sector. Factors such as tax rates, environmental regulations, transportation facilities, wage rates, etc., that influence an industry's decision to locate or expand in our service area as opposed to elsewhere are used to capture employment opportunities. Other segments of the economy, such as population, income, prices, etc., interact with the employment sector to produce a consistent economic scenario.

Some of the variables forecast in the service area economic model are shown in Exhibit #E-3.

(b) Energy and Customers

Variables forecast within the energy model are classified by residential, commercial, industrial, wholesale, and street lights.

The residential portion of the energy model contains sub-models to forecast customers, appliance saturation, and usage per customer (Exhibit #E-4).

Customers are forecast as a function of population 21 years of age and older (the household forming age group) and a two year weighted average of real per capita income. Income here is used to measure the capability to form a household (Exhibit #E-5).

Usage per customer (Exhibit #E-6) is a function of the stock of appliances owned by the average customer, the price of electricity, weather, and income. The price of electricity influences the use of the appliances the customer owns (Exhibit #E-7).

The commercial portion of the energy model is a function of commercial employment, price of electricity, and weather. Here commercial employment tracks the growth of commercial activity while price measures the incentives for conservation (Exhibit #E-8).

The industrial portion is divided into four sub-models:

- Chemicals
- Paper
- Other Manufacturing
- Non-Manufacturing

Each of these sub-models is a function of local production, price of electricity, pollution control equipment, and the availability of natural gas (Exhibit #E-9).

The wholesale portion is a function of the sales of commercial and residential energy, since the REA Cooperatives do not have any large industrial loads.

(c) Peak Hour Demand

Three steps are required to develop this model. First, historical peaks are normalized for weather. Second, the normalized peaks are separated into the components of demand associated with each class of customer. Finally, equations are developed for each customer class.

The historical weather normalized peaks are determined by developing for each year an equation for hourly demand as a function of weather variation. Then, typical peak day weather conditions are used to compute the normalized peak.

These normalized peaks are separated into residential/commercial, industrial, and wholesale components.

Exhibits #E-10, #E-11, and #E-12 show the actual equations developed for each of the customer classes.

With the exception of the residential/commercial class, the demand contribution is a function of energy sales to that class only. Residential/commercial includes a factor to account for the change in appliance mix, and thus a change in load factor.

The equation for the industrial class indicates a slightly deteriorating load factor, while the wholesale equation indicates a slightly improving load factor.

Using these equations, the actual peaks are weather normalized and the forecasted peaks computed

as a sum of the class components.

Local service area input data to the econometric model is continually refined and improved to enhance the accuracy of projections.

DESCRIPTION OF THE DRI MACRO MODEL OF THE U.S. ECONOMY

WHAT?

- SYSTEM OF 900 QUARTERLY EQUATIONS DESCRIBING THE INTERACTIONS OF THE U.S. ECONOMY.
- COMPUTER BASED
- CURRENT, UPDATED ANNUALLY.


USES?

- BY DRI TO DEVELOP SHORT-TERM (TO 1980) AND LONG-TERM (TO 1990) FORECASTS OF THE U.S. ECONOMY.
- BY DRI'S CLIENTS TO TEST AND EVALUATE THEIR OWN SET OF ASSUMPTIONS ON THE MACRO ECONOMIC OUTLOOK.
- BY DRI'S CLIENTS AS INPUTS INTO THEIR OWN FORECASTING SYSTEMS.

WHO?

- MANAGED BY A STAFF OF 25 FULL-TIME PROFESSIONALS
- DIRECTION OF OTTO ECKSTEIN, PRESIDENT

FUNCTIONAL BLOCK DIAGRAM
GULF ECONOMETRIC LOAD FORECASTING SYSTEM



SERVICE AREA ECONOMIC MODEL

<u>FORECASTED VARIABLES</u>	<u>GEOGRAPHICAL AREA COVERED</u>	<u>SOURCE OF DATA</u>
<u>I. INCOME, WAGES AND PRICES</u>		
● PERSONAL INCOME	10 COUNTY AREA	BUREAU OF ECONOMIC ANALYSIS
● AVERAGE HOURLY EARNINGS - MANUFACTURING WORKERS	PENSACOLA SMSA	BUREAU OF LABOR STATISTICS
● CONSUMER PRICE INDEX - ATLANTA	ATLANTA SMSA	BUREAU OF LABOR STATISTICS
<u>II. POPULATION</u>		
● TOTAL POPULATION	10 COUNTY AREA	BUREAU OF ECONOMIC ANALYSIS
● POPULATION-AGES 21 & OVER	10 COUNTY AREA	DERIVED USING FLORIDA AGE BREAKDOWN AND 10 COUNTY POPULATION TOTAL
<u>III. EMPLOYMENT</u>		
● MANUFACTURING		
● PAPER & ALLIED PRODUCTS	PENSACOLA SMSA	BUREAU OF LABOR STATISTICS
● CHEMICAL PRODUCTS	PENSACOLA SMSA	BUREAU OF LABOR STATISTICS
● OTHER MANUFACTURING	10 COUNTY AREA	FLORIDA DEPARTMENT OF COMMERCE
● NONMANUFACTURING	10 COUNTY AREA	FLORIDA DEPARTMENT OF COMMERCE

RESIDENTIAL CUSTOMERS

$$\text{CUST} * = f(\text{POP}, \bar{Y})$$

INPUTS FROM SERVICE AREA ECONOMIC MODEL:

POP = POPULATION 21 YEARS AND OLDER.

\bar{Y} = TWO YEAR WEIGHTED AVERAGE OF
REAL PER CAPITA INCOME

USAGE PER CUSTOMER

$$\text{KWH/CUST} = f(\text{APPL, PRICE, WEATHER, } \bar{Y})$$

WHERE:

APPL = WEIGHTED STOCK OF APPLIANCES (APPLIANCE SATURATION MODEL)

PRICE = PRICE OF ELECTRICAL ENERGY (FINANCIAL MODEL)

WEATHER = ASSUMED NORMAL FOR FORECASTS

Y = REAL PER CAPITA INCOME (SERVICE AREA ECONOMIC MODEL)

\bar{Y} = TWO YEAR WEIGHTED AVERAGE OF REAL PER CAPITA INCOME (SERVICE AREA ECONOMIC MODEL)

APPLIANCE MODELS

- RANGES (ELECTRIC AND TOTAL)
- WATER HEATERS (ELECTRIC AND TOTAL)
- CLOTHES DRYERS (ELECTRIC AND TOTAL)
- DISHWASHERS
- CLOTHES WASHERS
- FREEZERS
- REFRIGERATORS (TOTAL AND FROSTFREE)
- RESISTANCE HEAT
- HEAT PUMPS
- CENTRAL AIR CONDITIONING
- WINDOW UNIT AIR CONDITIONING

COMMERCIAL ENERGY MODEL

$$\text{KWH}_{\text{COM}} = f(\text{E}_{\text{NM}}, \text{PRICE}, \text{WEATHER})$$

WHERE:

E_{NM} = NONMANUFACTURING EMPLOYMENT EXCLUDING GOVERNMENT
(SERVICE AREA ECONOMIC MODEL)

PRICE = PRICE OF ELECTRICAL ENERGY (FINANCIAL MODEL)

WEATHER = ASSUMED NORMAL FOR FORECASTS

INDUSTRIAL MODEL SPECIFICATION

● AREA INDUSTRIAL PRODUCTION:

FRB INDEX * $\frac{\text{AREA EMPLOYMENT}}{\text{U.S. EMPLOYMENT}}$

● POLLUTION CONTROL EQUIPMENT

● PRICE OF ELECTRICITY

● AVAILABILITY OF NATURAL GAS

RESIDENTIAL/COMMERCIAL DEMAND MODEL

$$\begin{aligned}
 MW_{RES/COM} &= 467.9 + 0.95 \left(\frac{MWH_R}{LF_R * 8760} + \frac{MWH_C}{LF_C * 8760} \right) \\
 &\quad - 0.094 \left(\frac{APPL_{MWH}}{APPL_{MW}} \right)
 \end{aligned}$$

WHERE:

- $MW_{RES/COM}$ = PEAK DEMAND CONTRIBUTION OF RESIDENTIAL PLUS COMMERCIAL
- MWH_R = ANNUAL RESIDENTIAL ENERGY SALES
- MWH_C = ANNUAL COMMERCIAL ENERGY SALES
- LF_R = RESIDENTIAL LOAD FACTOR
- LF_C = COMMERCIAL LOAD FACTOR
- $APPL_{MWH}$ = ANNUAL MWH OF APPLIANCE STOCK
- $APPL_{MW}$ = SUMMER MW OF APPLIANCE STOCK

INDUSTRIAL DEMAND MODEL

$$MW_{IND} = 0.0001 (MWH_{IND})^{1.03}$$

(RESULTS IN SLIGHTLY DECREASING LOAD FACTOR)

WHERE:

MW_{IND} = PEAK DEMAND CONTRIBUTION OF INDUSTRIAL

MWH_{IND} = ANNUAL INDUSTRIAL ENERGY SALES

WHOLESALE DEMAND MODEL

$$MM_{WS} = 0.0003 (MWH_{WS})^{0.97}$$

(RESULTS IN SLIGHTLY INCREASING LOAD FACTOR)

WHERE:

MM_{WS} = PEAK DEMAND CONTRIBUTION OF WHOLESale.

MWH_{WS} = ANNUAL WHOLESale ENERGY SALES.

CHAPTER III

FORECAST OF FACILITIES
REQUIREMENTS

UTILITY Gulf Power Company

PLANNED AND PROSPECTIVE GENERATING FACILITY ADDITIONS AND CHANGES

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Plant Name	Unit No.	Location	Type	Fuel	Pri Alt	Const Start Mo/Yr	Com'l In-Service Mo/Yr	Gen Nameplate KW	Max Summer MW	Net Capability Winter MW
V. J. Daniel	(1)	Jackson Co. Mississippi							505	505
							5/81		(1) 505	(1) 505
Robert W. Scherer	(2) (3)	Monroe Co. Georgia							404	404
							2/87		(2) 202	(2) 202
							2/89		(3) 202	(3) 202

Total additions to system as of December 31, 1979 907.0 907.0

- (1) Gulf to acquire 50% of the total plant capacity in May, 1981.
- (2) Gulf to acquire 202 MW, of the total plant capacity in 1987.
- (3) Gulf to acquire an additional 202 MW of the total plant capacity in 1989.

FORECAST OF CAPACITY, DEMAND, AND SCHEDULED MAINTENANCE
AT TIME OF SUMMER PEAK (a)

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Year	Total Installed Capacity MW	Firm Capacity Import MW	Total Available Capacity MW	Peak Demand MW (b)	Margin Before Maintenance MW	Margin Before Maintenance % of PK.	Scheduled Maintenance MW	Margin After Maintenance MW	Margin After Maintenance % of PK.
1980	1515	40	1555	1350	205	15.2		205	15.2
1981	2020	34	2054	1354	700	51.7		700	51.7
1982	2020	34	2054	1397	657	47.0		657	47.0
1983	2020	47	2067	1449	618	42.7		618	42.7
1984	2020	47	2067	1502	565	37.6		565	37.6
1985	2020	47	2067	1557	510	32.8	4	510	32.8
1986	2020	47	2067	1614	453	28.1	4	453	28.1
1987	2222	47	2269	1674	595	35.5	4	595	35.5
1988	2222	47	2269	1735	534	30.8		534	30.8
1989	2424	47	2471	1799	672	37.4		672	37.4

NOTE: a. Capacity additions and changes must be made by May 31 to be considered in effect at the time of the Summer Peak. All values are Summer Net MW.

b. Includes capacity allocated to certain resale customers by Southeastern Power Administration (SEPA).

FORECAST OF CAPACITY, DEMAND, AND SCHEDULED MAINTENANCE
AT TIME OF WINTER PEAK (a)

Year	Total Installed Capacity MW	Firm Capacity Import MW	Total Available Capacity MW	Peak Demand MW (b)	Margin Before Maintenance MW % of PK.	Scheduled Maintenance MW	Margin After Maintenance MW % of PK.
1980-81	1519	16	1535	1118	417 37.3	20	397 35.5
1981-82	2024	16	2040	1161	879 75.7		
1982-83	2024	16	2040	1214	826 68.0		
1983-84	2024	29	2053	1269	784 61.8		
1984-85	2024	29	2053	1327	726 54.7		
1985-86	2024	29	2053	1388	665 47.9		
1986-87	2024	29	2053	1451	602 41.5		
1987-88	2226	29	2255	1517	738 48.6		
1988-89	2226	29	2255	1586	669 42.2		
1989-90	2428	29	2457	1658	799 48.2		

NOTE: a. Capacity additions and changes must be made by November 30 to be considered in effect at the time of the Winter peak. All values are Winter Net MW.
b. Includes capacity allocated to certain resale customers by Southeastern Power Administration (SEPA).

DOCUMENTATION OF FACILITY CHANGES

Availability of Purchased Power

Gulf Power Company coordinates its planning and operation with the other operating companies of the Southern electric system: Alabama Power Company, Georgia Power Company, and Mississippi Power Company. In any year an individual operating company may have a temporary surplus or deficit in generating capacity, depending on the relationship of its planned generating capacity to its load and reserve responsibility. Each company buys or sells its temporary deficit or surplus capacity from or to the pool. This is done through the mechanism of an Inter-company Interchange Contract among the companies which is reviewed and updated annually.

CHAPTER IV

SITE DESCRIPTION

AND

IMPACT ANALYSIS

UTILITY Gulf Power Company

STATUS REPORT
SPECIFICATIONS OF PROPOSED GENERATING FACILITIES

V. J. Daniel Electric Generating Unit 1

This facility is not located in the state of Florida.

(1) Plant Name & Unit

(2) Status

(3) Anticipated Construction Timing

(4) Capacity

Summer 507.7 MW⁽¹⁾
Winter 507.7 MW

(5) Type

(6) Primary and Alternate Fuel

(7) Air Pollution Control Strategy

(8) Cooling Method

(9) Total Site Area

(10) Anticipated Capital Investment

(11) Certification Status

(12) Status With Federal Agencies

(1) Gulf to acquire 50% of total plant capacity in May, 1981.

UTILITY Gulf Power Company

STATUS REPORT
SPECIFICATIONS OF PROPOSED GENERATING FACILITIES

(1) Plant Name & Unit V. J. Daniel Electric Generating Unit 2

(2) Status This facility is not located in the state of Florida

(3) Anticipated Construction Timing

(4) Capacity Summer 503 MW (1)
Winter 503 MW

(5) Type

(6) Primary and Alternate Fuel

(7) Air Pollution Control Strategy

(8) Cooling Method

(9) Total Site Area

(10) Anticipated Capital Investment

(11) Certification Status

(12) Status With Federal Agencies

(1) Gulf to acquire 50% of total plant capacity in May, 1981.

UTILITY Gulf Power Company

STATUS REPORT
SPECIFICATIONS OF PROPOSED GENERATING FACILITIES

(1) Plant Name & Unit Robert W. Scherer Electric Generating Center

(2) Status This facility is not located in the State of Florida.

(3) Anticipated Construction Timing

(4) Capacity (1)
Summer 404 MW
Winter 404 MW

(5) Type

(6) Primary and Alternate Fuel

(7) Air Pollution Control Strategy

(8) Cooling Method

(9) Total Site Area

(10) Anticipated Capital Investment

(11) Certification Status

(12) Status With Federal Agencies

¹Gulf to acquire 202 MW of Unit 3 in February, 1987, and 202 MW of Unit 4 in February, 1989, for a total of 404 MW.

UTILITY Gulf Power Company

STATUS REPORT AND SPECIFICATIONS OF PROPOSED
DIRECTLY-ASSOCIATED TRANSMISSION LINES

(1) Point of Origin and Termination
(2) Number of Lines
(3) Right-Of-Way
(4) Line Length
(5) Voltage
(6) Anticipated Construction Timing
(7) Anticipated Capital Investment
(8) Substations
(9) Participation

No new directly-associated transmission lines in Florida are required.