

From: chriskw@bellsouth.net [mailto:chriskw@bellsouth.net]
Sent: Tuesday, November 10, 2009 12:00 PM
To: Carmona-Gina; Stone-Bob; stone-robert@MonroeCounty-FL.Gov
Subject: Pump Seal Fail Proposal

Gina/Bob,

Attached you will find a proposal sent in August to fix a seal in your pump. The manufacturer built control circuitry into the pump to detect when this failure occurs. The panel manufacturer put a warning light on the panel to indicate when the event is happening. This prevents further damage to the pump and insures operation. This failure indicator has been "ON" since August 2009. This pump is in the jail's main lift station. Failure could result in a major repair/problem. -Chris

Christopher A. Johnson
 President, Keys Environmental, Inc.
 6630 Front Street
 Key West, FL 33040
 305.295.3301
 FAX 305.295.0143
www.keysenvironmental.com

Attachment 1: Aug 09_MCDC_proposal.doc (application/msword)

Change your options to hide images within all messages.

Message: 2 of 1294 < Previous | Next >

Check Mail | Compose | Folders | Mailboxes | E-mail Help
 Sign Out | E-mail | Address Book | Calendar | E-mail Options

AT&T | Advertising | Help & Contact Us | Terms of Service | Copyright | Privacy Policy | Acceptable Use Policy
 © 2009 AT&T Intellectual Property. All rights reserved.
 AT&T and the AT&T logo are trademarks of AT&T Intellectual Property.