Summary tables for all three sectors (Res/Com/Ind):

Table 1. Theoretical Technical Potential Savings for Residential and Non-Residential Sectors

	Residential	Non-Residential	Total
2020 Summer Peak (MW)	4,998	3,227	8,225
Technical Summer Peak Savings (MW)	1,434	1,857	3,292
% of Summer Peak	29%	58%	40%
2020 Winter Peak (MW)	5,652	3,025	8,677
Technical Winter Peak Savings (MW)	2,627	1,788	4,415
% of Winter Peak	46%	59%	51%

Table 2. Summer Peak Demand by Segment by Sector

Residential		
Segment	MW	% of Sector Peak
Single Family	3,575	72%
Multi-Family	910	18%
Mobile Home/Other	513	10%
Total	4,998	<u>100%</u>

GS		
Segment	MW	% of Sector Peak
0-15,000 kWh	153	47%
15,001-25,000 kWh	63	20%
25,001-50,000 kWh	56	17%
50,000 kWh+	51	16%
<u>Total</u>	<u>324</u>	<u>100%</u>

Table 3. Winter Peak Demand by Segment by Sector

Residential		
Segment	MW	% of Sector Peak
Single Family	4,063	72%
Multi-Family	959	17%
Mobile Home/Other	630	11%
Total	<u>5,652</u>	<u>100%</u>

 Table 4. Summer Peak Potential by End Use by Sector (UNADJUSTED)

Residential		
End Use	MW	% of Sector Peak
Space Heating	0	0%
Space Cooling	2,932	59%
Water Heater	338	7%
Pool Pump	287	6%
<u>Total</u>	<u>3,557</u>	<u>71%</u>

 Table 5. Winter Peak Potential by End Use by Sector (UNADJUSTED)

Residential		
End Use	MW	% of Sector Peak
Space Heating	3,669	65%
Space Cooling	0	0%
Water Heater	651	12%
Pool Pump	218	4%
Total	<u>4,538</u>	<u>80%</u>

 Table 6. Summer Peak Potential by End Use by Sector (ADJUSTED FOR EXISTING DR)

Residential		
End Use	MW	% of Sector Peak

GS		
Segment	MW	% of Sector Peak
0-15,000 kWh	126	46%
15,001-25,000 kWh	57	21%
25,001-50,000 kWh	50	18%
50,000 kWh+	38	14%
<u>Total</u>	<u>271</u>	<u>100%</u>

GS		
End Use	MW	% of Sector Peak
Space Heating	0	0%
Space Cooling	143	44%
Total	<u>143</u>	44%

GS		
End Use	MW	% of Sector Peak
Space Heating	86	32%
Space Cooling	0	0%
Total	<u>86</u>	32%

Results Compare from 2013 Revision

	Residential	Non-Residential	Total
Summer Peak (MW)	4,713	2,277	6,990
Summer Peak Savings (MW)	735	270	1,005
% of Summer Peak	16%	12%	14%
Winter Peak (MW)	5,262	1,546	6,808
Winter Peak Savings (MW)	868	89	957
% of Winter Peak	16%	6%	14%

GS	
End	Use

MW	% of Sector Peak

Results Compare from ITRON 2	2009		
	Residential	Non-Residential	Total
Summer Peak (MW)	4,698	2,307	7,005
Summer Peak Savings (MW)	734	272	1,006
% of Summer Peak	16%	12%	14%
Winter Peak (MW)	5,175	1,599	6,774
Winter Peak Savings (MW)	856	92	948
% of Winter Peak	17%	6%	14%

Total	<u>2,903</u>	<u>100%</u>
501 kW+	919	32%
301-500 kW	350	12%
51-300 kW	957	33%
0-50 kW	677	23%
Segment	MW	% of Sector Peak
GSD		

<u>Total</u>	<u>2,754</u>	<u>100%</u>
501 kW+	980	36%
301-500 kW	315	11%
51-300 kW	823	30%
0-50 kW	636	23%
Segment	MW	% of Sector Peak
GSD		

GSD

End Use	MW	% of Sector Peak
All	2,903	100%
<u>Total</u>	<u>2,903</u>	<u>100%</u>

GSD MW % of Sector Peak End Use 2,754 All 100% <u>2,754</u> <u>Total</u> <u>100%</u>

GSD		
End Use	MW	% of Sector Peak

Space Heating	0	0%
Space Cooling	2,127	43%
Water Heater	246	5%
Pool Pump	209	4%
<u>Total</u>	<u>2,581</u>	<u>52%</u>

 Table 7. Winter Peak Potential by End Use by Sector (ADJUSTED FOR EXISTING DR)

474	8%
159	3%

 Table 8. Summer Peak Potential by End Use by Sector (ADJUSTED FOR EE MEASURES AND FOR EXISTING DR)


Residential		
End Use	MW	% of Sector Peak
Space Heating	0	0%
Space Cooling	1,066	21%
Water Heater	188	4%
Pool Pump	181	4%
<u>Total</u>	<u>1,434</u>	<u>29%</u>

 Table 9. Winter Peak Potential by End Use by Sector (ADJUSTED FOR EE MEASURES AND FOR EXISTING DR)

Residential		
End Use	MW	% of Sector Peak
Space Heating	2,196	39%
Space Cooling	0	0%
Water Heater	354	6%
Pool Pump	76	1%
<u>Total</u>	<u>2,627</u>	<u>46%</u>

Residential

End Use	Summer MW	Winter MW
Space Heating	0	2,196
Space Cooling	1,066	0
Water Heater	188	354
Pool Pump	181	76
Total	<u>1,434</u>	<u>2,627</u>




	_	
Space Heating	0	0%
Space Cooling	143	44%
<u>Total</u>	143	<u>44%</u>

GS	
End Use	
Space Heating	
Space Cooling	
Total	

GS		
End Use	MW	% of Sector Peak
Space Heating	0	0%
Space Cooling	104	32%
<u>Total</u>	<u>104</u>	32%

GS		
End Use	MW	% of Sector Peak
Space Heating	73	27%
Space Cooling	0	0%
<u>Total</u>	<u>73</u>	27%

End Use	Summer MW	Winter MW
Space Heating	0	73
Space Cooling	104	0
Total	<u>104</u>	<u>73</u>



MW	% of Sector Peak
86	32%
0	0%
<u>86</u>	<u>32%</u>

1

All	2,266	78%
Total	<u>2,266</u>	<u>78%</u>


GSD		
End Use	MW	% of Sector Peak
All	1,950	71%
<u>Total</u>	<u>1,950</u>	<u>71%</u>

GSD

MW	% of Sector Peak
1,754	60%
<u>1,754</u>	<u>60%</u>
	1,754

GSD		
End Use	MW	% of Sector Peak
All	1,715	62%
Total	<u>1,715</u>	<u>62%</u>

GSD		
Segment	Summer MW	Winter MW
0-50 kW	503	537
51-300 kW	702	684
301-500 kW	174	160
501 kW+	374	334
<u>Total</u>	<u>1,754</u>	<u>1,715</u>



20190018-DEF-0040344

	Residential	Non-Residential	Total
2020 Summer Peak (MW)	4,998	3,227	8,225
Technical Summer Peak Savings (MW)	1,434	1,857	3,292
% of Summer Peak	29%	58%	40%
2020 Winter Peak (MW)	5,652	3,025	8,677
Technical Winter Peak Savings (MW)	2,627	1,446	4,073
% of Winter Peak	46%	48%	47%

	2020 Summer Peak (MV Technical Summer	Peak S; % of Summer Peak	2020 Winter Peak (N	1W) Technical Winte
Residential	4,998	1,434	29%	5,652
Non-Residential	3,227	1,857	58%	3,025
Total	8,225	3,292	40%	8,677

r Peak Savings (MW % of Winter Peak	
2,627	46%
1,446	48%
4,073	47%



								-				
	Des Custeileble Lood (NA)A()		1	- 2018 Study (Scaled to 2020)	Tatal Curtailable Load (NANA)	Custom Lond (MAAA)	0/ of Custom Lood	1				
Summer	Res Curtailable Load (MW) 2,581	GS Curtailable Load (MW) 143	GSD Curtailable Load (MW) 2,502	Non-Res Curtailable 2,645	Total Curtailable Load (MW) 5,510	System Load (MW) 9,193	% of System Load 56.9%	1				
Winter	3,295	86	2,502	2,645	6,024	9,193 9,537	60.1%	1				
winter	3,295	80	2,352	2,438	6,024	9,537	00.1%]				
				DEF Technical Potential	- 2009 Study					_		
	Res Curtailable Load (MW)	GS Curtailable Load (MW)	GSD Curtailable Load (MW)	Non-Res Curtailable	Total Curtailable Load (MW)	Res Baseline	NonRes Baseline	System Load (MW)	% of System Load			
Summer	734	252	20	272	1,006	4,698	2,307	7,005	14.4%	4		
Winter	856	86	6	92	948	5,175	1,599	6,773	14.0%	1		
	Des Costella La est (NAMA)			DEF Technical Potential	· · ·		New Deer Deersting	Custom Lond (MMM)	l et contant land	1		
Summor	Res Curtailable Load (MW) 735	GS Curtailable Load (MW) 250	GSD Curtailable Load (MW)	Non-Res Curtailable 270	Total Curtailable Load (MW) 1,005	Res Baseline	NonRes Baseline 2,277	System Load (MW) 6,990	% of System Load	1		
Summer Winter	868	83	20 6	89	957	4,713 5,262	1,546	6,809	14.4% 14.1%	1		
winter	808	85	0	65	557	5,202	1,540	0,809	14.170	1		
				Winter Pe	ak Loads (kW)					!	1	
	Res Segments He	eating Load (kW)	GS Segments He	eating Load (kW)	GSD Segments Total	l Load (kW)	Residen	ntial Pool Pump and Water	Heater Load			
Population	Single Family	1,452,979	0-15,000 kWh	33,176	0-50 kW	492,511	SF Pool Pump	-	SF Water Heater	222,274		
	Multi-Family	424,913	15,001-25,000 kWh	15,473	51-300 kW	627,324	ini reerranip	-	MF Water Heater	115,215		
	Mobile Home/Other	269,782	25,001-50,000 kWh	12,912	301-500 kW	147,008		-	MH Water Heater	44,367		
	Total	2,147,674	50,001 kWh +	7,911	501 kW +	305,876	Total Pool Pump	128,049	9 Total Water Heater	381,856		
			Total	69,471	Total	1,572,719					1	
				Summer Peak Lo	ads by End Use (kW)						1	
	Res Segments Co	ooling Load (kW)	GS Segments Co		GSD Segments Total	Load (kW)	Residen	ntial Pool Pump and Water	Heater Load		1	
Population	Single Family	1,410,266	0-15,000 kWh	83,177	0-50 kW	613,870		-	SF Water Heater	135,188	1	
	Multi-Family	342,967	15,001-25,000 kWh	22,811	51-300 kW	857,049	MF Pool Pump	-	MF Water Heater	70,074		
	Mobile Home/Other	254,687	25,001-50,000 kWh	13,982	301-500 kW	212,383	MH Pool Pump	-	MH Water Heater	26,984	1	
	Total	2,007,919	50,001 kWh +	15,228	501 kW +	456,451	Total Pool Pump	197,257	7 Total Water Heater	232,246	1	
			Total	135,198	Total	2,139,753					1	
				2016 Technical Bota	ntial with DR Adjustment						1	
			Residential Curtailable Load	2010 recimical Poter	ndar with Dit Aujustillent			Total Curtailable Load		% of System	1	
	Peak Day	Peak Hour (HE)	(MW)	Total Residential Load (MW)*	GS Curtailable Load (MW)	GS Total Load (MW)	GSD Curtailable Load (MW)		System Load (MW)		4	
Summer	22-Aug-16	17	2,437	4,678	135	322	2,140	4,712	8,680	54.3%	4	
Winter	25-Jan-16	8	2,658	4,774	69	228	1,573	4,300	7,691	55.9%	4	
				2016 Technical Potenti	ial Without DR Adjustment							
			Residential Heating/Cooling	Residential Water Heater	Residential Pool Pump Curtailable	GS Heating/Cooling						
	Peak Day	Peak Hour (HE)	Curtailable Load (MW)	Curtailable Load	Load	Curtailable Load	GSD Curtailable Load (MW)					
Summer	22-Aug-16	17	2,768	319	271	135	2,741			· · · · ·		
Winter	25-Jan-16	8	2,959	525	176	69	2,221					
			RES	ADJUSTED TP RESU	JLTS for Both EE and DR			SMB			LCI	
Housing Type	Winter Res Heating (kW)	Summer Res Cooling (kW)		Summer Res Water Heater (kW)) Winter Res Pool Pump (kW)	Vinter Res Water Heater (kV	Segment	SMB Heating (kW)	SMB Cooling (kW)	Segment	LCI Winter kV	ACI Su
Single Family	1,485,571	748,362	181,081	109,332	76,380	206,218	0-15,000 kWh	34,849	63726	0-50 kW	537,123	5
Multi Family	434,444	181,996		56,672		106,893	15,001-25,000 kWh	16,253	17477	51-300 kW	684,147	7
Mobile Home/Other	275,834	135,150		21,823		41,162	25,001-50,000 kWh	13,563	10,712	301-500 kW	160,325	1
							50,001 kWh +	8,309	11,667	501 kW +	333,583	3
	2020 system peak (from 10 year s	ite plan):			2016 Deak Load Du Comments (b)				г			
Summer: Winter:	6% 24%		Customer Counts (ALL		2016 Peak Load By Segments (No Avg Winter Peak	o Disaggregation) Avg Summer Peak	Winter Peak Load	Summer Peak Load	4			
willer.	2470		Single Family	924,706	3.54	3.65	3,276,173	3,375,723	4			
			Multi-Family	431,225	1.79	1.99	773,276	858,797				
			Mobile Home/Other	168,898	3.01	2.87	508,315	484,677				
			Total	1,524,829		-	4,557,764	4,719,197				
		_										
0-50 kW	44,938		0-15,000 kWh	124,529	0.81	1.16	101,423	144,434				
51-300 kW	10,922		15,001-25,000 kWh	14,816	3.09	4.04	45,761	59,837				
301-500 kW	1,067		25,001-50,000 kWh	7,474	5.40	7.10	40,387	53,073				
501 kW +	1,160		50,001 kWh +	3,032	10.18	15.94	30,855	48,315				
Total	58,087]	Total	149,851	4		218,425	305,660				
			0-50 kW	44,938	11.42	14.23	513,097	639,577				
				-								
			51-300 kW	10,922	60.75	82.75	663,570	903,836				
			301-500 kW	1,067	237.70	309.67	253,703	330,511				

		Table 4-7	: 2013 Forec	ast Refresh o	f iTron DR Teo	chnical Poten	tial Study		
	Sum	mer System I	Peak			Wir	nter System P	eak	
Baseline	Hi	gh	Lo	w	Baseline	Hi	gh	Lo	w
(MW)	(MW)	(%)	(MW)	(%)	(MW)	(MW)	(%)	(MW)	



			Table 4-7: 2009 DR Technic	cal Potential in PEF by Sector, DR Enabling Tec	hnology/Tariff, and Scenario								99	2.1%	174	3.7%		105	2.0%	189	3.6
			S	ummer System Peak				Winter Syste	m Peak			1 1	156	3.3%	283	6.0%	1	174	3.3%	310	5.99
	DR-Enabling Technology and	Baseline	High		Low		Baseline	High		Lo	ow		283	6.0%	57	1.2%	1	310	5.9%	63	1.2%
Sector	Tariff	(MW)	(MW)	(%)	(MW)	(%)	(MW)	(MW)	(%)	(MW)	(%)		66	1.4%	14	0.3%] [184	3.5%	37	0.7%
	A/C Cycling Switch w/ flat rate		97	2.1%	175	3.7%		105	2.0%	189	3.6%		52	1.1%	9	0.2%		11	0.2%	2	0.0%
	A/C Shedding Switch w/ flat rate		157	3.3%	282	6.0%		169	3.3%	304	5.9%		80	1.7%	14	0.3%] [89	1.7%	16	0.3%
	Smart Thermostats for A/C w/ CPP		282	6.0%	56	864	1	304	5.9%	61	1.2%	4,713	735	15.6%	556	11.8%	5,262	868	16.5%	621	11.89
Residential	On-Off Switching via low-power wireless networks for water heating w/ CPP		65	1.4%	13	0.3%		180	3.5%	36	0.7%		108	6.2%	31	1.8%		53	4.7%	15	1.3%
	On-Off Switching via low-power wireless networks for pool systems w/ CPP		51	1.1%	10	0.2%		10	0.2%	2	0.0%		142	8.2%	142	8.2%	1 [30	2.7%	30	2.7%
	In-home displays and pre-set control strategies w/ CPP		82	1.7%	16	0.3%		89	1.7%	18	0.3%	1,734	250	14.4%	172	9.9%	1,125	83	7.4%	45	4.0%
	Total Residential	4,698	734	15.6%	553	11.8%	5,175	856	16.5%	609	11.8%		9	1.6%	3	0.5%		4	1.0%	1	0.3%
	Automated control strategies w/ CPP		109	6.2%	31	1.8%		55	4.7%	16	1.3%		11	2.0%	11	2.0%		2	0.4%	2	0.4%
Commercial	Direct load control system		144	8.2%	144	8.2%		31	2.7%	31	2.7%	543	20	3.6%	13	2.4%	421	6	1.4%	3	0.7%
	Total Commercial	1,757	252	14.4%	175	9.9%	1,166	86	7.4%	47	4.0%	6,990	1,004	14.4%	741	10.6%	6,809	957	14.0%	669	9.7%
	Automated control Strategies w/ CPP		9	1.6%	3	0.5%		4	1.0%	1	0.3%										
Industrial	Direct load control system	1	11	2.0%	11	2.0%	1	2	0.4%	2	0.4%	1									
	Total Industrial	550	20	3.6%	13	2.4%	433	6	1.4%	3	0.7%	1									
TOTAL		7,005	1,006	14.4%	741	10.6%	6,773	948	14.0%	659	9.7%	1									

DEF Peak Demand Forecast (from 10 year site plan)

DUKE ENERGY FLORIDA

SCHEDULE 3.1.1 HISTORY AND FORECAST OF SUMMER PEAK DEMAND (MW) BASE CASE

(1) (2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(OTH)	(10)	(1)	(2)	(3)	(4)	(5)	(6)	Ø	(8)	(9)	(OTH)	
				RESIDENTIAL		COMM. / IND.		OTHER							RESIDENTIAL		COMM / IND.		OTHER	
				LOAD	RESIDENTIAL	LOAD	COMM. / IND.	DEMAND	NET FIRM						LOAD	RESIDENTIAL	LOAD	COMM / IND.	DEMAND	N
YEAR TOTAL	WHOLESALE	RETAIL	INTERRUPTIBLE	MANAGEMENT	CONSERVATION	MANAGEMENT	CONSERVATION	REDUCTIONS	DEMAND	YEAR		WHOLESALE	RETAIL	INTERRUPTIBLE	MANAGEMENT	CONSERVATION	MANAGEMENT	CONSERVATION	REDUCTIONS	I
										HISTORY										
HISTORY:										2006/07	9,894	1,576	8,318	304	671	450	26	127	262	
2007 10,931	1544	9,387	334	291	239	45	177	110	9,735	2007/08	10,962	1,828	9,134	234	763	483	34	133	278	
2008 10,592	1512	9,080	500	284	255	66	192	110	9,185	2008/09	12,089	2,229	9,860	268	759	518	71	148	291	
2009 10,853	1618	9,235	262	291	271	84	211	110	9,624	2009/10	13,694	2,189	11,505	246	651	563	80	163	322	
2010 10,242	1272	8,970	271	304	298	96	234	110	8,929	2010/11	11,343	1,625	9,718	271	661	628	94	180	221	
2011 9,972	934	9,038	227	317	329	97	256	110	8,636	2011/12	9,721	905	8,816	186	643	686	96	203	206	
2012 9,788	1080	8,708	262	328	358	98	280	124	8,337	2012/13	9,109	831	8,278	287	652	747	97	220	213	
2013 9,581	581	9,000	317	341	382	101	298	124	8,017	2013/14	9,467	658	8,809	257	654	785	101	229	219	
2014 10,067	814	9,253	232	355	404	108	313	132	8,523	2014/15	10,648	1,035	9,613	273	669	815	109	236	237	
2015 10,058	772	9,286	303	360	435	124	324	80	8,431	2015/16	9,678	1,275	8,403	224	681	845	113	240	189	
2016 10,593	947	9,646	235	366	466	100	333	80	9,014											
										FORECAS	D.									
FORECAST:										2016/17	11,338	1,197	10,141	203	682	879	74	242	193	
2017 10,537	751	9,785	225	372	499	78	340	80	8,943	2017/18	11,494	1,198	10,296	230	694	909	78	243	194	
2018 10,700	753	9,948	255	378	530	82	346	80	9,030	2018/19	11,630	1,198	10,432	246	706	934	82	244	196	
2019 11,095	1,004	10,092	272	384	554	87	351	80	9,368	2019/20	12,001	1,408	10,592	264	718	955	86	245	197	
2020 11,219	965	10,254	292	390	575	91	354	80	9,436	2020/21	11,369	659	10,711	284	730	973	91	246	199	
2021 11,082	715	10,367	314	396	594	95	357	80	9,246	2021/22	11,481	659	10,823	285	742	989	95	246	200	
2022 11,191	715	10,476	316	402	610	99	359	80	9,325	2022/23	11,590	659	10,931	285	754	1,004	99	247	201	
2023 11,299	715	10,583	316	408	625	103	360	80	9,407	2023/24	11,701	659	11,042	274	766	1,018	103	247	202	
2024 11,405	715	10,690	303	414	638	108	361	80	9,501	2024/25	11,775	659	11,116	250	778	1,033	107	247	203	
2025 11,482	716	10,766	276	420	653	112	361	80	9,579	2025/26	11,858	660	11,198	250	790	1,047	112	247	204	

Historical Values (2007 - 2016):

Col. (2) = recorded peak + implemented load control + residential and commercial/industrial conservation and customer-owned self-service cogeneration.

Cols. (5) - (9) = Represent total cumulative capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) =Customer-owned self-service cogeneration.

Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

Projected Values (2017 - 2026):

Cols. (2) - (4) = forecasted peak without load control, cumulative conservation, and customer-owned self-service cogeneration.

Cols. (5) - (9) = cumulative conservation and load control capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = customer-owned self-service cogeneration. Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

Historical Values (2007 - 2016): Col (2) = recorded peak + implemented load control + residential and commercial/industrial conservation and customer-owned self-service cogeneration. Cols. (5) - (9) = Represent total cumulative capabilities at peak. Col. (8) includes commercial load management and standby generation. Col. (OTH) = Voltage reduction and customer-owned self-service cogeneration. Col. (10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH). Projected Values (2017 - 2026): Cols. (2) - (4) = forecasted peak without load control, cumulative conservation, and customer-owned self-service cogeneration. Cols. (5) - (9) = Represent cumulative conservation and load control capabilities at peak. Col. (8) includes commercial load management and standby generation.

Col. (OTH) = Voltage reduction and customer-owned self-service cogeneration. Col(10) = (2) - (5) - (6) - (7) - (8) - (9) - (OTH).

DUKE ENERGY FLORIDA

SCHEDULE 3.2.1 HISTORY AND FORECAST OF WINTER PEAK DEMAND (MW) BASE CASE

3.6%
5.9%
1.2%
0.7%
0.0%
0.3%
11.8%
1.3%
2.7%
4.0%
0.3%
0.4%
0.7%
9.7%

NOTES ON TABLES FOR DASHBOARD

Table 1 Peak demand (Row 6 and Row 9) includes all customers in each segment (both customers enrolled in DR and customers not enrolled in DR), TP (Row 7 and Row 10) is adjusted to exclude DR customers and make EE adjustments Tables 2-3 Record system peaks for all customers in each segment, this is the total demand for each customer segment during the DEF system peak

Tables 4-5 Record TP for all customers including DR customers - this is not the true TP for DEF, it is just for reference

Tables 6-7 Record TP excluding existing DR customers, but do not include EE adjustment

Tables 8-9 Record TP excluding existing DR customers and include EE adjustment

Peak demands include all customers and have not been adjusted for EE measures

20190018-DEF-0040348