FILED 2/10/2020 DOCUMENT NO. 00853-2020 FPSC - COMMISSION CLERK

STATE OF FLORIDA

COMMISSIONERS:
GARY F. CLARK, CHAIRMAN
ART GRAHAM
JULIE I. BROWN
DONALD J. POLMANN
ANDREW GILES FAY



DIVISION OF ECONOMICS
JUDY HARLOW
DIRECTOR
(850) 413-6410

Public Service Commission

February 10, 2020

Staff's First Data Request Via E-mail

Beth Keating, Esq. Gunster, Yoakley & Stewart, P.A. 215 South Monroe St., Suite 601 Tallahassee, FL 32301

Re: Docket No. 20200046-GU - Petition to revise tariffs for Florida Public Utilities Company, Florida Public Utilities Company - Indiantown Division, Florida Public Utilities Company - Fort Meade, Florida Division of Chesapeake Utilities Corporation, and Peninsula Pipeline Company to update the description of gas quality, character of service, and pressure.

Dear Ms. Keating:

By this letter, the Commission staff respectfully requests the following information. For the following, please refer to Original Sheet No. 22.4, provided for FPUC, and the respective sheets for all other Companies:

- 1. Does the proposed Quality of Gas table have any impact on the receipt of any current or future renewable natural gas?
- 2. Please list all potential sources of natural gas entering the system that are not coming from an interconnected pipeline.
- 3. Please explain why these revisions are now being requested and if there have been any occurrences that highlighted the need for these revisions.
- 4. For the following questions, please also refer to the proposed revisions to the Character of Service section of all rate schedules for FPUC and FPUC- Fort Meade.
 - a. Present tariffs require a nominal heat content of 1,000 Btu per cubic foot, but the proposed revision provides a range of 967-1,100 Btu per cubic foot. Please explain why the Companies believe this new range is necessary.

PSC Website: http://www.floridapsc.com

Internet E-mail: contact@psc.state.fl.us

Ms. Keating Page 2 February 5, 2020

b. FGT's tariffs require a Btu content of no less than 1,000 Btu per cubic foot (FGT Tariff Fifth Rev. Volume No.1, Part IV, effective Feb 1, 2016), please explain why the Companies propose accepting a Btu content lower than what FGT requires.

Please file all responses electronically no later than February 24, 2020, via the Commission's website at www.floridapsc.com by selecting the Clerk's Office tab and Electronic Filing Web Form. If you have any questions please contact me at champson@psc.state.fl.us or at (850) 413-6676.

Thank you,

/s/Corey Hampson Corey Hampson Public Utility Analyst I

cc: Tripp Coston, Economic Supervisor (tcoston@psc.state.fl.us) Office of the Commission Clerk