## FILED 12/30/2020 DOCUMENT NO. 13806-2020 FPSC - COMMISSION CLERK

## FLORIDA UTILITY SERVICES 1, LLC 5911 TROUBLE CREEK RD. NEW PORT RICHEY, FL. 34652 863-904-5574

December 23, 2020

Commission Clerk Florida Public Service Commission 2540 Shumard Oak Blvd. Tallahassee, FL. 32399

RE: Application for a staff assisted rate case for Lake Yale Utilities Docket # 20200169

Dear Commission Clerk:

Please find attached invoice for the above docket file.

This invoice is for emergency repairs to a lift station that failed over the weekend. The utility requests these costs be included in this rate case.

On behalf of the company,

Mike Smallridge.

## A.T. Environmental Services

PO Box 271 Anthony, FL 32617

LYU

...

| : |  |
|---|--|
|   |  |
|   |  |

.

| Invoice | Ś |
|---------|---|
|---------|---|

| Date       | Invoice # |
|------------|-----------|
| 12/21/2020 | 935       |

|  | ş.e |  |
|--|-----|--|
|  |     |  |
|  |     |  |
|  |     |  |
|  |     |  |
|  |     |  |
|  |     |  |

| Description   |      | Amount        |
|---|------|---------------|
| Sand Piper<br>Service call for high level alarm at lift station                             |      |               |
| Diagnostics and install new starters  |      | 1,600.00      |
| Install new phase monitor module  |      | 125.00        |
|   |      |               |
|   |      |               |
|   |      |               |
|   |      |               |
|   |      |               |
|   |      |               |
|   |      |               |
|   |      |               |
|   |      |               |
|   |      |               |
|   |      |               |
|   |      |               |
| Payment is due upon receipt.<br>Thank you for your business.<br>Billing/Teresa 352-207-4742 | Tota | al \$1,725.00 |