

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION


In the Matter of : DOCKET NO.
: 950495-WS

Application for a rate increase and :
Increase in service availability charges :
By SOUTHERN STATES UTILITIES, INC., for :
Orange-Osceola Utilities, Inc., in :
Osceola County, and in Bradford, Brevard, :
Charlotte, Citrus, Clay, Collier, Duval, :
Highlands, Lake, Lee, Marion, Martin, :
Nassau, Orange, Osceola, Pasco, Putnam, :
Seminole, St. Johns, St. Lucie, Volusia, :
and Washington Counties. :

SECOND DAY - EVENING SESSION

VOLUME 10

Pages 926 through 1081



PROCEEDINGS:

HEARING

BEFORE:

CHAIRMAN SUSAN F. CLARK
COMMISSIONER J. TERRY DEASON
COMMISSIONER JULIA L. JOHNSON
COMMISSIONER DIANE K. KIESLING
COMMISSIONER JOE GARCIA

DATE:

May 1, 1996

TIME:

Commenced at 4:50 p.m.

PLACE:

Betty Easley Conference Center
Room 148
4075 Esplanade Way
Tallahassee, Florida

REPORTED BY:

PEGGY L. OWENS, RMR, RPR

APPEARANCES:

(As heretofore noted.)

FLORIDA PUBLIC SERVICE COMMISSION

DOCUMENT NUMBER-DATE

04941 MAY-28

FPSC-RECORDS/REPORTING

1	EXHIBITS		
2	NUMBER	ID.	ADMTD.
3	90		936
	91		936
4	92		936
	94		937
5	95		937
	96		937
6	97		937
	98	(Edmunds) RCE-1	971 1030
7	99	(Edmunds) Schedule F-7(W)	997 1030
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			

P R O C E E D I N G S

(Transcript continues from Volume 9.)

CHAIRMAN CLARK: Redirect.

MR. FEIL: Thank you, Commissioners.

GERALD C. HARTMAN

resumed the stand on behalf of Southern States Utilities, and having previously been duly sworn, testified as follows:

REDIRECT EXAMINATION

BY MR. FEIL:

Q Mr. Hartman, you were asked a number of questions about the use of a five day average, and whether or not you could expect a differential of the five maximum days on average being different from the highest single maximum day.

Is it your testimony the single maximum day is what is required to use for permitting and design purposes?

A Yes.

Q And did you say earlier that you have not conducted an evaluation of the relationship between the five average days used in this case to the single maximum day used in this case?

A That's correct.

Q Did SSU do such an analysis? Was that done

1 by Mr. Bliss, if you know?

2 A I don't know.

3 Q You said in your testimony that in this
4 case SSU requested 100 percent used and useful on
5 reuse for public accessory use facilities; is that
6 correct?

7 A That's correct. That's the highest level
8 of reuse facility.

9 Q Is it your understanding that the comments
10 you made concerning the four different types of reuse
11 coincide with how DEP defines reuse?

12 A Typically, yes, generally.

13 Q So the rapid infiltration basins you
14 referred to are defined by DEP as reuse?

15 A Yes.

16 Q But do you know whether or not SSU
17 requested rapid infiltration basins in this case to
18 be 100 percent used and useful?

19 A To my knowledge, they did not. It is only
20 the public access reuse facilities that make up the
21 overintegrated service for public access reuse that
22 were utilized for 100 percent use and reuse.

23 Q Mr. Riley asked you a number of questions
24 about how DEP has interpreted the statutes regarding
25 100 percent used and useful on reuse. Do you believe

1 that letters that DEP sent to the PSC are DEP's
2 interpretation of those statutes?

3 A By their senior staff, yes.

4 Q Do you have the F schedules from the MFRs
5 in front of you?

6 A Yes, I do.

7 Q Mr. Riley asked you a number of questions
8 about whether or not the PSC had historically rounded
9 off used and useful figures so as to give the utility
10 100 percent used and useful on something when
11 mathematically it was calculated to be 90 or 95
12 percent. Could you refer to the MFR schedules?

13 A Yes.

14 Q Could you tell me whether or not the
15 Commission did, in fact, do that in the last rate
16 case?

17 A In the last rate case there are a lot of
18 96's, 97's, 98's, and things like that that were not
19 rounded off.

20 Q Thank you. Are there benefits other than
21 long-term cost benefits to the customers resulting
22 from economies of scale?

23 A Oh, yes. We were only talking about a
24 tank; but if you looked at a treatment plant, you get
25 internal digestion of the sludge which reduces your

1 operation and maintenance cost for sludge disposal.

2 You get a better treatment level. You get
3 better protection of the environment. It is a buffer
4 basically for the public health, safety and welfare.
5 When you run these facilities 100 percent all the way
6 out, it is like running your car at 120 miles an hour
7 all the time. You are on the ragged edge. And an
8 upset of your treatment plan, especially wastewater
9 treatment plant, would then of course create an event
10 which allows for pollution. But if you are below
11 that, then the upset can be handled within the volume
12 of the plant. So there is a lot more environmental
13 protection, many other benefits that are not easily
14 quantified.

15 Q Mr. Riley asked you a number of questions
16 about the plants at SSU acquired from Deltona and I
17 suppose various other plants. Then in some of those
18 questions he asked about or he suggested that SSU was
19 seeking to take a benefit now from plants designed by
20 Deltona or other utilities in the past.

21 And the question I would like to ask you
22 is, to the extent that Mr. Riley was suggesting that
23 used and useful should be calculated one way for
24 acquired facilities or facilities designed at one
25 point in time versus used and useful for facilities

1 designed at a subsequent point in time, do you think
2 that such a scheme is workable?

3 A The used and useful percentage, once it is
4 established, should be maintained if there is no
5 changes. It is not workable to start creating new
6 criterion, and then adjusting way down the used and
7 useful or way up the used and useful. What you've
8 got is you've got historical determined used and
9 useful. Then you work through the regulatory
10 requirement and get the full recovery of the
11 investment. But, no, it is not workable to go
12 retroactively backwards.

13 Q Do you think it is workable to have, for
14 instance, if one were applying a formula approach, do
15 you think it is workable to have one formula that
16 applies to plants acquired at time T-1 and another
17 formula to apply to plants required at time T-2?

18 A I don't think it is workable to do that.
19 It puts the investment at risk.

20 Q You had a discussion with Commissioner
21 Clark regarding the use of the peaking factor. Could
22 you explain the relationship of the peaking factor,
23 briefly explain the relationship of the peaking
24 factor to design criteria?

25 A Yes. Like a peak hour, it is an event that

1 would happen that you have to meet in your system
2 that may happen due to half time in the Super Bowl or
3 something like that. It reoccurs in a system. In a
4 small system that peaking factor is great because
5 everybody in that small town or that small
6 subdivision may be doing similar things.

7 As you get bigger, let's say the City of
8 Tampa, everyone in the City of Tampa will not be
9 going to Mr., you know, Smith's party in his
10 subdivision. The diversity of the customer base off-
11 sets that peaking situation and dampens the peak.

12 So to understand the 1.3 versus the 2, in a
13 large system where you have people doing all kinds of
14 different things, the peaking factor for peak hour
15 that you have to meet for the public health, safety,
16 and welfare, you have to meet that, is lower. But
17 when you have a smaller system, the peak factor is
18 much greater because of commonality of use.

19 Q So that peaking factor is something you
20 have to design for?

21 A Definitely. And it is invested, money is
22 invested to pay for the facilities.

23 Q By the same token, if you design for an
24 average of the five highest days rather than for the
25 maximum day would you be able to meet the customer's

1 requirements for service?

2 A No. Or public health, safety, and welfare
3 requirements for the state. Regulatory requirements
4 would not be met.

5 Q Is the gist of your testimony that SSU has
6 included as used and useful the facilities required
7 for SSU to provide service from a technical and
8 engineering standpoint?

9 A All facilities require it? No, I don't
10 think they have. I think they provided a used and
11 useful amount less than that.

12 Q Thank you. Mr. Pelligrini asked you
13 whether or not it was practical or workable for the
14 PSC to device a way to account for the economies of
15 scale in a formula approach.

16 Has SSU requested that the Commission
17 account for economies of scale through the margin
18 reserve calculation?

19 A It buttressed the margin reserve
20 calculation, yes. There is no doubt about it. And
21 when you consider the margin reserve, economy of
22 scale should be a consideration in there.

23 MR. FEIL: I have nothing further.

24 CHAIRMAN CLARK: Thank you. Exhibits?

25 MR. FEIL: I believe SSU moves 90 and 91,

1 which should have been Mr. Hartman's prefiled
2 exhibits.

3 (Exhibit Nos. 90 and 91 admitted.)

4 CHAIRMAN CLARK: That's correct. 92 is a
5 late filed exhibit.

6 MR. TWOMEY: 93 is --

7 CHAIRMAN CLARK: Just a minute.

8 MR. PELLIGRINI: 92 is the Hartman
9 summary.

10 CHAIRMAN CLARK: It is a late-filed
11 exhibit.

12 (Late-Filed Exhibit No. 92 admitted.)

13 MR. PELLIGRINI: All right.

14 CHAIRMAN CLARK: 93.

15 MR. FEIL: Commissioner, I have an
16 objection to 93. It is a relatively large compendium
17 of documents of which Mr. Hartman spoke of only one
18 page. I mean, if Mr. Twomey wishes to ask another
19 SSU questions regarding the other pages included in
20 this compendium, that's fine; but in terms of what
21 Mr. Hartman spoke of, he spoke of only one page and
22 basically said that Mr. Twomey's questions would best
23 be directed to SSU witness Bliss.

24 MR. TWOMEY: We can wait on this.

25 CHAIRMAN CLARK: You want to wait. Okay.

1 CHAIRMAN CLARK: I think 94 is a late-filed
2 exhibit, also.

3 (Late-Filed Exhibit No. 94 admitted.)

4 MR. PELLIGRINI: Staff would move to have
5 Exhibits 95, 96 and 97 placed into the record.

6 MR. FEIL: Commissioner, I have an
7 objection to Exhibits 96 and 97.

8 CHAIRMAN CLARK: Okay.

9 MR. FEIL: And the objection is that I
10 don't understand what issue it goes to. I don't
11 understand the relevance of it. I don't understand
12 the materiality of it.

13 MR. PELLIGRINI: Commissioner Clark, we
14 feel these two exhibits and the line of questioning
15 is relevant to the rate case expense, issue 93.

16 MR. FEIL: So it is your position these
17 exhibits pertain only to the amount of rate case
18 expense and the amount of charges that Mr. Hartman
19 billed for the economies of scale evaluation, that
20 may or may not be included in rate case expense?

21 MR. PELLIGRINI: Yes.

22 MR. FEIL: All right. With that
23 understanding, commissioner, I will withdraw my
24 objection.

25 CHAIRMAN CLARK: 96 and 97 are admitted

1 without objection.

2 (Exhibit Nos. 95, 96 and 97 admitted.)

3 CHAIRMAN CLARK: Thank you, Mr. Hartman.

4 You are excused. It seems to me it may be prudent to
5 take up Mr. Edmunds before Mr. Elliott. We will take
6 a ten-minute break and allow Mr. Edmunds to get
7 arranged on the stand. We will be back at ten
8 minutes after 5:00.

9 (Brief recess.)

10 CHAIRMAN CLARK: Let's reconvene the
11 hearing. Mr. Feil.

12 MR. FEIL: Mr. Edmunds. Have you been
13 sworn?

14 WITNESS EDMUNDS: No, sir, I don't believe I
15 have.

16 **ROBERT C. EDMUNDS**

17 resumed the stand on behalf of Southern States
18 Utilities, and having first been duly sworn, testified
19 as follows:

20 **DIRECT EXAMINATION**

21 BY MR. FEIL:

22 Q Could you please state your name and
23 business address for the record?

24 A My name is Robert C. Edmunds, business
25 address is 730 N. Waldo Road, Gainesville, Florida.

1 Q Are you the same Robert C. Edmunds for whom
2 prefiled direct testimony in this case was filed
3 consisting of 16 pages?

4 A Yes, sir, I am.

5 Q If I ask you the questions in that prefiled
6 direct testimony today would your answers to those
7 questions be the same?

8 A Yes, sir, they would.

9 Q So you have no corrections to your prefiled
10 direct testimony?

11 A No, sir, I don't.

12 MR. FEIL: Commissioner, I ask that
13 Mr. Edmunds prefiled direct be inserted into the
14 record as though read.

15 CHAIRMAN CLARK: The prefiled direct
16 testimony of Mr. Robert Edmunds will be inserted into
17 the record as though read.

18 (Prefiled Direct Testimony of Robert C.
19 Edmunds inserted as follows:)

20

21

22

23

24

25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DIRECT TESTIMONY OF ROBERT C. EDMUNDS, P.E.
BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
ON BEHALF OF
SOUTHERN STATES UTILITIES, INC.
DOCKET NO. 950495-WS

DOCUMENT NUMBER-DATE
06025 JUN 28 1984
FPSC-RECORDS/REPORTING

1 **Q. WHAT IS YOUR NAME AND BUSINESS ADDRESS?**

2 A. My name is Robert C. Edmunds, P.E. My business address is Jones
3 Edmunds & Associates, Inc., 730 N. Waldo Road, Gainesville, Florida
4 32601.

5 **Q. BY WHOM ARE YOU EMPLOYED AND WHAT IS YOUR**
6 **POSITION?**

7 A. I am Executive Vice President and Chief of Project Design at Jones
8 Edmunds & Associates, Inc.

9 **Q. WHAT IS YOUR EDUCATIONAL BACKGROUND AND WORK**
10 **EXPERIENCE?**

11 A. I graduated from the University of Florida with a B.C.E. in Civil
12 Engineering in 1968 and an M.C.E. in Engineering in 1975. Before
13 becoming a founding member of Jones Edmunds in 1974, I was the
14 Manager of Plant Design at Black, Crow & Eidness, which is now CH2M
15 Hill, in Gainesville, Florida. I am a registered professional engineer in
16 the States of Florida, Georgia, Kentucky, Alabama, North Carolina, South
17 Carolina, Pennsylvania, New York and Ohio. I am also a certified general
18 contractor in the State of Florida.

19 I have planned, analyzed, and designed water supply, transmission,
20 and distribution facilities of many types: those serving residential
21 developments, multi-million dollar pipelines spanning hundreds of miles,
22 and specialized water and fire protection facilities for launch pads at

1 Kennedy Space Center. My clients have included private utilities, cities,
2 counties, and other governmental agencies.

3 My recent experience relative to my testimony in this case includes
4 serving as project manager or engineer on several large scale projects for
5 which I directed extensive hydraulic modeling. For instance, I served as
6 project engineer for Pinellas County's comprehensive master plan for its
7 water system. For this project, I directed a complete hydraulic analysis for
8 maximum day, peak hour, fire flow, and other conditions for water supply,
9 transmission, and distribution facilities serving commercial, industrial, and
10 residential customers throughout the entire county, and I completed
11 conceptual designs for additional supply, storage, transmission, and
12 distribution facilities throughout the county. I also served as project
13 manager for the West Coast Regional Water Supply Authority's master
14 plan for the Brandon, Florida, water system. For this project, I directed
15 extensive hydraulic modeling for the primarily residential and commercial
16 demands of the system and completed the conceptual design of facilities
17 and improvements needed to meet demand for the 1988-2005 planning
18 period, including the addition of a fifteen million gallon per day wellfield
19 and treatment plant. I also served as project engineer for Hillsborough
20 County's evaluation of its 20-year master plan for its water system. For
21 this project, I performed extensive hydraulic modeling for the commercial,
22 industrial, and residential demand of the system through the 20-year

1 planning period and completed conceptual designs for supply, transmission,
2 and distribution main additions throughout south-central Hillsborough
3 County.

4 **Q. WHAT ARE YOUR PROFESSIONAL AFFILIATIONS?**

5 A. I am a participating member of the American Society of Civil Engineers,
6 the American Water Resources Association, the American Water Works
7 Association, and several other professional societies and associations.

8 **Q. HAVE YOU PREVIOUSLY TESTIFIED BEFORE THE FLORIDA
9 PUBLIC SERVICE COMMISSION?**

10 A. No.

11 **Q. HAVE YOU PREVIOUSLY TESTIFIED BEFORE A STATE OR
12 FEDERAL REGULATORY AGENCY OR IN A STATE OR
13 FEDERAL COURT AS AN EXPERT IN THE AREA OF WATER
14 TRANSMISSION AND DISTRIBUTION FACILITY ANALYSIS AND
15 DESIGN?**

16 A. Yes, I have testified as an expert in the area of water transmission and
17 distribution facilities analysis, design, and construction on several
18 occasions in both court and administrative proceedings. For example, I
19 recently testified as an expert on the subject of transmission and
20 distribution facilities design before a Division of Administrative Hearings
21 Hearing Officer in a case concerning a request by the West Coast Regional
22 Water Supply Authority for a 45 million gallon per day consumptive use

1 permit. I also testified as the plaintiff's chief expert in a suit brought by
2 Pinellas County against several parties for claims arising from pipeline
3 deterioration.

4 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

5 A. For this case, Southern States prepared hydraulic models of its water
6 transmission and distribution facilities in Citrus Springs, Marion Oaks,
7 Pine Ridge, and Sunny Hills. The purpose of my testimony is to inform
8 the Commission of the basic tenets of hydraulic modeling and of the use
9 of this modeling in designing and evaluating transmission and distribution
10 facilities. I will also testify that hydraulic modeling is the most accurate
11 way of evaluating the demands placed on transmission and distribution
12 facilities.

13 **Q. COULD YOU BRIEFLY EXPLAIN THE PURPOSE OF**
14 **HYDRAULIC MODELING?**

15 A. Basically, hydraulic modeling is a means of evaluating the ability of
16 designed or existing transmission and distribution facilities to transmit
17 water safely and reliably under various demand conditions, including peak
18 hour demand, maximum day demand, and fire flow conditions.

19 **Q. DO GOVERNMENTAL REGULATIONS OR GENERALLY**
20 **ACCEPTED DESIGN CRITERIA SPECIFICALLY REQUIRE SOME**
21 **FORM OF HYDRAULIC MODELING TO EVALUATE THE**
22 **ADEQUACY OF TRANSMISSION AND DISTRIBUTION**

1 **FACILITIES FOR A RESIDENTIAL COMMUNITY WATER**
2 **SYSTEM PRIOR TO PERMITTING OR AT ANY OTHER TIME?**

3 A. Over the last twenty-five to thirty years, regulations and generally accepted
4 design criteria have undergone evolution, as has the sophistication of
5 various modeling techniques. For instance, twenty-five to thirty years ago,
6 which I am told is about the time the transmission and distribution
7 facilities were designed for Southern States' Citrus Springs, Marion Oaks,
8 Pine Ridge and Sunny Hills service locations, generally accepted
9 engineering practice called for pipe sizes of four inches and larger within
10 residential developments. Today, the generally accepted minimum line
11 size for residential developments is six inches and larger, and some local
12 government ordinances or regulations require eight inches and larger.

13 As a matter of accepted professional practice, design engineers rely
14 on the guidance and direction provided in a number of authoritative
15 publications and manuals addressing distribution facilities design in detail.
16 DEP has incorporated some of these materials into its rules by reference.
17 Specifically, I refer the Commission to the Recommended Standards For
18 Water Works ("The Ten States' Standards"), a design manual incorporated
19 by reference in Rule 62-555.330, F.A.C. In The Ten States' Standards,
20 section 8, subsection 8.1, under the heading "Water Main Design," it states
21 as follows:

22 8.1.1 Pressure. All water mains, including those not designed to

1 provide fire protection, shall be sized after a hydraulic analysis
2 based on flow demands and pressure requirements. The system
3 shall be designed to maintain a minimum pressure of 20 psi at
4 ground level at all points in the distribution system under all
5 conditions of flow. The normal working pressure in the
6 distribution system should be approximately 60 psi and not less
7 than 35 psi.

8 8.1.2 Diameter. The minimum size of the water main for
9 providing fire protection and serving fire hydrants shall be six-inch
10 diameter. Larger size mains will be required if necessary to allow
11 the withdrawal of the required fire flow while maintaining residual
12 pressure specified in Section 8.1.1.

13 Rule 62-555.330, F.A.C., expressly states that DEP is to consider
14 these criteria from The Ten States' Standards when evaluating permit
15 applications to construct or alter distribution facilities.

16 In the way of providing an example of the local requirements which
17 vary from jurisdiction to jurisdiction, I refer the Commission to Section 2
18 of Citrus County's Public Water System Design and Construction
19 Standards, which states as follows:

20 A. General Design Criteria. A water distribution network analysis
21 shall be required with all distribution submittals. The supplying
22 utility shall provide the available pressure and flow at the proposed

1 point of connection under the following flows to the proposed
2 connection:

3 1. Estimated Peak Demand, as determined by the methods
4 of AWWA publication M22, current edition, inclusive of any
5 proposed irrigation facilities, and applicable criteria from Section
6 I, herein, whichever is greater.

7 2. Fire Flow, as estimated by the criteria addressed in
8 Section I, "Public Water Supply and Treatment Facilities."

9 Hydraulic modeling is the only reliable way of determining whether these
10 design criteria are met. Several county review agencies have in recent
11 years gone so far as to require a computer program's hydraulic model
12 output as part of the permit application for a new water distribution system
13 or the expansion of existing facilities. It should also be noted that, aside
14 from these requirements, hydraulic modeling is an important tool used
15 regularly by practicing professional engineers to evaluate the capabilities
16 of utility facilities.

17 My understanding from Southern States' witness Terrero is that
18 when Deltona Utilities, Inc. designed the transmission and distribution
19 facilities for the locations I have referred to, it performed a Hardy-Cross
20 analysis to evaluate the capacity of the facilities. The Hardy-Cross
21 analysis is a type of hydraulic modeling, and its use as an aid in designing
22 the referenced facilities would have been consistent with design

1 requirements and practices at the time those facilities were designed.
2 Hydraulic modeling today can be done by use of a Hardy-Cross analysis
3 which, as evolved, can still produce a fairly reliable result, or by use of
4 sophisticated computer programs available, such as Haestad Methods,
5 Inc.'s Cybernet® computer software which Southern States has utilized in
6 this case.

7 **Q. CAN YOU GENERALLY DESCRIBE HOW COMPUTERIZED**
8 **HYDRAULIC MODELING IS PERFORMED FOR EXISTING**
9 **WATER TRANSMISSION AND DISTRIBUTION FACILITIES**
10 **SERVING A RESIDENTIAL COMMUNITY?**

11 **A.** As I indicated earlier, hydraulic modeling takes into consideration two
12 basic categories of calculations: demand and capacity. It should also be
13 kept in mind that transmission and distribution facilities will not only be
14 evaluated on a network basis, but analyses are often made and needed on
15 a component basis, where the demand and capacity of a part or portions
16 of a network are examined based on their type and function.

17 The first step typically performed for a hydraulic model of existing
18 facilities is the preparation of a schematic representation of the supply,
19 transmission, and distribution facilities. This schematic is prepared using
20 lines and dots representing pipes and nodes respectively. Nodes are
21 locations in the existing piping network where water is added (supply),
22 where water is removed (demand), and where two or more pipes intersect,

1 including all joints where pipe diameters change. Essentially, the
2 schematic is the framework for the capacity side of the evaluation. The
3 next step would be to define demands to be assigned to the nodes in the
4 model. Supply, transmission, and distribution facilities serving a
5 residential community must, by regulation and accepted practice, be
6 designed to meet maximum day, peak hour, and fire flow conditions.
7 Accordingly, demand data reflecting these conditions is determined and,
8 along with any other required information, is entered into the program
9 input data file. The model is then compiled and the output data file
10 created.

11 **Q. WHAT IS YOUR TESTIMONY RELATIVE TO THE HYDRAULIC**
12 **MODELING DONE IN SUPPORT OF SOUTHERN STATES' RATE**
13 **APPLICATION?**

14 A. As explained in detail by Southern States' witness Bliss, Southern States
15 has conducted hydraulic modeling analyses for Southern States'
16 transmission and distribution facilities in Citrus Springs, Marion Oaks,
17 Pine Ridge and Sunny Hills. The computer software Southern States used
18 to perform its modeling, Cybernet®, is very well regarded by and widely
19 used in the industry and, in my experience, produces very reliable results.
20 Further, it is my professional opinion that hydraulic modeling is the
21 preferred and the most accurate way of evaluating the demands placed on
22 water transmission and distribution facilities.

1 **Q. HAVE YOU HAD THE OPPORTUNITY TO REVIEW ANY**
2 **FLORIDA PUBLIC SERVICE COMMISSION ORDERS**
3 **ADDRESSING THE SUBJECT OF THE USED AND USEFULNESS**
4 **OF TRANSMISSION AND DISTRIBUTION FACILITIES FOR**
5 **RATEMAKING PURPOSES?**

6 A. Yes, Southern States has provided me copies of the order issued in
7 Southern State's 1992 consolidated rate case -- that order was issued on
8 March 22, 1993, in Commission Docket No. 920199-WS -- and a copy of
9 an order in a consolidated General Development Utilities, Inc. rate case --
10 that order was issued March 30, 1993, in Commission Dockets Nos.
11 920733-WS and 920734-WS. I have reviewed the used and useful
12 portions of both of those orders.

13 **Q. ASSUMING BOTH OF THOSE ORDERS ARE REPRESENTATIVE**
14 **OF COMMISSION DETERMINATIONS OF USED AND USEFUL**
15 **FOR WATER TRANSMISSION AND DISTRIBUTION FACILITIES,**
16 **WHAT IS YOUR OPINION OF THE RELATIONSHIP BETWEEN**
17 **THE RATEMAKING CONCEPT OF USED AND USEFUL AND**
18 **THE ENGINEERING REQUIREMENTS FOR TRANSMISSION**
19 **AND DISTRIBUTION FACILITIES?**

20 A. There does not seem to be a direct relationship between the two. It
21 appears that in an attempt to allocate costs between current and future
22 connections, the Commission would not adequately consider the criteria

1 which a utility must follow in designing the facilities which serve both
2 current and future connections. As a design engineer, the ramifications of
3 the Commission's methodology are a matter of concern to me. The
4 Commission's methodology can make it difficult for me to recommend to
5 a private utility that its facilities be designed in accordance with regulatory
6 requirements and accepted design criteria -- as I have a professional
7 obligation to do -- when the Commission's allocation methodology poses
8 an economic disincentive for the utility to construct adequately designed
9 facilities (so as to avoid the risk of not recovering the associated
10 investment) and an economic disincentive for the utility to take advantage
11 of economies of scale.

12 **Q. HAS THIS TYPE OF QUANDARY PRESENTED ITSELF IN THE**
13 **COURSE OF YOUR ADVISING CLIENTS WHO ARE NOT**
14 **REGULATED BY THE FLORIDA PUBLIC SERVICE**
15 **COMMISSION?**

16 A. Although cost pressures frequently come into play, I can think of no
17 instance where those pressures acted as such a direct disincentive for
18 proper design and utilization of economies of scale as the used and useful
19 methodology presented in these Commission orders potentially does.

20 **Q. IS IT YOUR TESTIMONY THAT HYDRAULIC MODELING WILL**
21 **MORE ACCURATELY REFLECT THAT PORTION OF PLANT**
22 **ACTUALLY UTILIZED BY CURRENT CONNECTIONS THAN**

1 **DOES THE COMMISSION'S METHOD?**

2 A. Yes, I believe hydraulic modeling is considerably more accurate and is
3 preferable to the method described in the orders I have reviewed. The
4 method used by the Commission, referred to as the lot count method, does
5 not provide an accurate representation of or consider the demands placed
6 on transmission and distribution facilities by current connections. Current
7 connections utilize that portion of the transmission and distribution
8 facilities which are required to meet the existing demand conditions placed
9 on the facilities by those connections. Hydraulic modeling will clearly
10 demonstrate this demand.

11 **Q. OTHER THAN A GENERALLY INACCURATE RECOGNITION OF**
12 **THE DEMAND PLACED ON THE FACILITIES BY CURRENT**
13 **CONNECTIONS, WHAT OTHER SPECIFIC PROBLEMS DO YOU**
14 **PERCEIVE WITH THE COMMISSION'S METHODOLOGY?**

15 A. From a design engineer's point of view, the Commission's method fails to
16 recognize that transmission and distribution facilities must accommodate
17 fire flow and must be designed and sized to accommodate fire flow.
18 Further, the Commission's methodology can also, depending on the manner
19 of its application, ignore the current connections' utilization of looped
20 lines.

21 **Q. WHAT PARTICULAR CONCERNS DO YOU HAVE REGARDING**
22 **FIRE FLOW?**

1 A. The design criteria and regulations I referred to earlier require that if fire
2 flow is provided to a service area, the transmission and distribution
3 facilities serving that area must be designed and sized to accommodate the
4 applicable level of fire flow. This requirement is supported by the
5 fundamental design principle that a water utility system's ability to provide
6 reliable fire flow is only as effective as the weakest link in the withdrawal-
7 to-delivery sequence. If the distribution lines were not designed and sized
8 so as to accommodate peak demands plus fire flow, the utility's ability to
9 provide reliable fire flow would be diminished. Using a hydraulic analysis
10 as the basis for the used and useful allocation is preferable not only
11 because hydraulic considerations for fire flow are a design requirement, but
12 also because the hydraulic analysis will accurately portray that portion of
13 the transmission and distribution facilities necessary to provide those
14 connections with adequate and reliable fire flow. The Commission's lot
15 count methodology is fundamentally flawed because it does not -- or
16 cannot -- recognize the demand for fire flow placed on transmission and
17 distribution facilities by current connections.

18 **Q. YOU HAVE SAID YOU REVIEWED THE COMMISSION'S 1993**
19 **GDU RATE CASE ORDER. DO YOU DISAGREE WITH THE**
20 **COMMISSION'S REFUSAL TO RECOGNIZE FIRE FLOW FOR**
21 **TRANSMISSION AND DISTRIBUTION LINES IN THAT ORDER?**

22 A. Yes. I believe the Commission's refusal to recognize fire flow for

1 distribution lines simply because fire flow is considered a function of
2 water storage is incorrect for the reasons I have just stated. Moreover,
3 storage will not serve to put out a fire if the transmission and distribution
4 lines are too small to handle the flow.

5 **Q. DO YOU HAVE ANY PARTICULAR COMMENTS WITH REGARD**
6 **TO LINE LOOPING?**

7 A. Yes. From my experience, sound system design for residential service
8 areas requires line looping in order to improve pressure and the continuity
9 of quality water service throughout a distribution network. That portion
10 of transmission and distribution facilities attributable to looping is utilized
11 by current connections for these purposes. Under the Commission's
12 method, portions of the transmission and distribution facilities utilized to
13 loop the system are not subjected to direct analysis and therefore could, by
14 using the lot count methodology, not be considered. Conversely, with
15 hydraulic modeling, lines used for looping purposes may be specifically
16 analyzed.

17 **Q. YOU MENTIONED A DISINCENTIVE FOR PROPER DESIGN**
18 **POSED BY THE COMMISSION'S LOT COUNT METHOD.**
19 **COULD YOU ELABORATE WHAT YOU MEAN?**

20 Yes. The non-recognition of the fire flow demands placed on transmission
21 and distribution lines, for example, brings the disincentive for proper
22 design clearly into focus. The lot count method sends an economic signal

1 to the regulated utility to reduce its line sizes, despite design requirements
2 to accommodate fire flow, so the utility will decrease the risk of not
3 recovering the investment associated with proper design. The disincentive
4 against sizing lines to meet maximum day and peak hour requirements is
5 the same. I believe that this disincentive would be abated if the
6 Commission used a hydraulic analysis to determine used and useful for
7 transmission and distribution facilities.

8 **Q. YOU ALSO MENTIONED ECONOMIES OF SCALE. IN YOUR**
9 **EXPERIENCE, DO UTILITIES AND OTHER WATER SUPPLIERS**
10 **GENERALLY PREFER TO CONSTRUCT TRANSMISSION AND**
11 **DISTRIBUTION FACILITIES IN ORDER TO TAKE ADVANTAGE**
12 **OF ECONOMIES OF SCALE?**

13 **A.** Yes. Utilities and water suppliers take advantage of economies of scale
14 by bulk purchasing materials, taking advantage of the time value of
15 money, competitively bidding projects, paralleling water lines with other
16 utility facilities, and minimizing other costs such as contractor mobilization
17 costs, permitting costs, pressure testing, bacteriological testing and
18 engineering costs. By taking advantage of available economies of scale,
19 utilities and water suppliers can provide water at a lower per unit cost, and
20 that lower per unit cost is in the long term best interests of the parties
21 paying for the facilities.

22 **Q. IS IT YOUR TESTIMONY THAT THE COMMISSION'S LOT**

1 **COUNT METHODOLOGY FOR DETERMINING USED AND**
2 **USEFUL DISCOURAGES UTILITIES FROM TAKING**
3 **ADVANTAGE OF THESE ECONOMIES?**

4 A. Yes. The lot count methodology would act as a disincentive to taking
5 advantage of economies of scale. To illustrate, under the lot count
6 method, a water utility regulated by the Commission is discouraged from
7 installing water lines concurrent with the electric, telephone, or other utility
8 facilities laid by county, city, or other entities despite the fact that the
9 water utility could save money on construction by doing so. Again, I
10 think a hydraulic analysis would pose less of a disincentive.

11 **Q. DO YOU HAVE ANYTHING FURTHER TO ADD?**

12 A. No.

1 BY MR. FEIL:

2 Q Mr. Edmunds, did you also have prefiled
3 rebuttal testimony filed in this case consisting of
4 11 pages?

5 A Yes, sir, I did.

6 Q Do you have any changes or corrections to
7 those 11 pages of testimony?

8 A I have one in the answer given on line 18,
9 Page 7, where my answer states in part, "regarding
10 peak demand for equivalent residential connection in
11 particular," the clarification requires that state,
12 "regarding maximum day demand per equivalent
13 residential connection in particular."

14 That's the only correction or
15 clarification.

16 Q So if I ask you the questions in your
17 prefiled rebuttal testimony today your answers would
18 be the same except with that one correction?

19 A Yes, sir, that's correct.

20 CHAIRMAN CLARK: Mr. Feil, just so I'm
21 clear on the correction, the word "peak" should be
22 deleted and maximum day substituted?

23 MR. FEIL: Yes, ma'am.

24 CHAIRMAN CLARK: Okay. With that
25 correction?

1 MR. FEIL: I would ask his testimony be
2 inserted in the record as though read.

3 CHAIRMAN CLARK: With that correction, the
4 prefiled rebuttal testimony of Robert Edmunds will be
5 inserted in the record as though read.

6 (The Prefiled Rebuttal Testimony of Robert
7 C. Edmunds is inserted as follows:)

8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

REBUTTAL TESTIMONY OF ROBERT C. EDMUNDS, P.E.
BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
ON BEHALF OF
SOUTHERN STATES UTILITIES, INC.
DOCKET NO. 950495-WS

1 Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS FOR THE
2 RECORD.

3 A. My name is Robert C. Edmunds, P.E. My business
4 address is Jones Edmunds & Associates, Inc., 730 N.
5 Waldo Rd., Gainesville, Florida 32601.

6 Q. ARE YOU THE SAME ROBERT C. EDMUNDS WHO PREVIOUSLY
7 PROVIDED DIRECT TESTIMONY?

8 A. Yes, I am.

9 Q. HAVE YOU REVIEWED THAT PORTION OF THE PREFILED
10 DIRECT TESTIMONY OF OPC WITNESS TED BIDDY WHICH
11 CONCERNS HYDRAULIC MODELING?

12 A. Yes, I have.

13 Q. DO YOU AGREE WITH MR. BIDDY'S TESTIMONY REGARDING
14 HYDRAULIC MODELING?

15 A. No, I do not, and I would like to specifically
16 address several aspects of Mr. Biddy's testimony
17 regarding hydraulic modeling. First, it is
18 inconceivable to me to suggest, as Mr. Biddy does,
19 that the Commission ignore hydraulic modeling when,
20 as I explained in my prefiled direct testimony,
21 hydraulic modeling is the preferred and the most
22 accurate way of quantifying the actual used
23 capacity of water transmission and distribution
24 facilities. Once the appropriate flow rate is
25 selected to apply for used and useful

1 determinations, it is indisputably true that no
2 more valid technique exists for projecting the
3 actual flow in each and every pipe than hydraulic
4 modeling, short of installing devices to record
5 simultaneous flow rate measurements in each and
6 every pipe. This latter alternative would be so
7 complicated and costly as to be impractical;
8 consequently, hydraulic modeling is the only valid,
9 realistic approach. The lot-count method cannot
10 even be characterized as a method for evaluating
11 used capacity and is absolutely and undeniably
12 erroneous by comparison. I also disagree with Mr.
13 Biddy's statements regarding calibration.
14 Calibration is not, as he suggests, mandatory for
15 hydraulic models in all cases. Additionally, I
16 note that Mr. Biddy avoids entirely the importance
17 of having used and useful considerations parallel
18 design requirements.

19 **Q. WOULD YOU ADDRESS MR. BIDDY'S ASSERTION THAT THE**
20 **LOT-COUNT METHOD IS A BETTER METHOD THAN THE**
21 **HYDRAULIC MODELING ANALYSIS TO EVALUATE USED AND**
22 **USEFUL FOR DISTRIBUTION AND TRANSMISSION**
23 **FACILITIES?**

24 **A. I disagree with Mr. Biddy in a very fundamental**
25 **sense. Current connections utilize that portion of**

1 the transmission and distribution facilities which
2 are required to meet the existing demand conditions
3 placed on the facilities by those connections. The
4 hydraulic modeling analysis will clearly quantify
5 those demands. The hydraulic analysis is a flow-
6 based approach similar to the flow-based approach
7 utilized by the Commission in the past for
8 evaluating used and useful for other components of
9 water service facilities, and which Mr. Bidy
10 himself recommends for those other water plant
11 components. The lot-count method has no rational
12 correlation whatsoever to the demand placed on
13 transmission and distribution facilities by current
14 customers and should be rejected on that basis
15 alone.

16 **Q. HAS YOUR FIRM PERFORMED A FIELD CALIBRATION OF THE**
17 **TRANSMISSION AND DISTRIBUTION FACILITIES SERVING**
18 **SSU'S PINE RIDGE SERVICE AREA?**

19 A. Yes, we have.

20 **Q. COULD YOU DESCRIBE THE RESULTS OF THAT CALIBRATION?**

21 A. Yes. The calibration testing confirmed the
22 validity of the hydraulic model for the east part
23 of the Pine Ridge service area. In addition, test
24 results clearly indicate that following
25 installation of appropriately placed air release

1 valves to purge entrapped air, the west part of the
2 Pine Ridge model will achieve full calibration as
3 well.

4 **Q. COULD YOU DESCRIBE HOW THE PINE RIDGE FACILITIES**
5 **WERE CALIBRATED?**

6 A. Yes. A copy of the calibration report prepared
7 under my supervision and control is identified as
8 Exhibit 98 (RCE-1). To perform calibration, the
9 Pine Ridge distribution facilities were
10 hydraulically stressed at various locations by
11 opening fire hydrants, with flows and pressures
12 measured or computed at key locations. The field
13 measured values then were compared with values
14 predicted by the hydraulic model. The eastern part
15 of the Pine Ridge model was immediately found to be
16 satisfactorily calibrated, but the western part was
17 found to be experiencing pressures as much as 13
18 psi lower than predicted by the model. As
19 explained in the calibration report, experienced
20 pressures within approximately 5 psi of modelled
21 pressures are typically considered acceptable.
22 Using the model as an investigative tool, a
23 specific piping reach was found to be air bound.
24 Upon air purging, a 12.5 psi measured versus
25 modeled pressure disagreement was reduced to 5.3

1 psi. This indicates that, following installation
2 of appropriate air release valves, the western part
3 of the Pine Ridge model would be expected to
4 achieve satisfactory calibration as well.

5 **Q. ON THE SUBJECT OF CALIBRATION, YOU SAID YOU**
6 **DISAGREE WITH MR. BIDDY'S STATEMENT THAT**
7 **CALIBRATION IS REQUIRED FOR HYDRAULIC MODELS THAT**
8 **ARE UTILIZED TO EVALUATE USED AND USEFUL. COULD**
9 **YOU EXPLAIN YOUR STATEMENT.**

10 A. Yes, I believe Mr. Biddy errs in stating an
11 absolute regarding the need for calibration.
12 Calibration is important in many cases; in other
13 cases, it is less important. In designing new
14 facilities, for example, modeling is relied on
15 without the benefit of field calibration. Further,
16 in certain cases, it is perfectly appropriate to
17 undertake measures short of full calibration to
18 confirm the reliability of a model's results.
19 Whether a hydraulic model should be fully
20 calibrated depends on a number of factors,
21 particularly the cost-effectiveness of full
22 calibration in light of the use being made of the
23 model. Full calibration is a fairly expensive
24 proposition. For the service areas the size of the
25 four at issue in this case, complete calibration

1 could cost anywhere in the approximate range of
2 \$25,000 to \$60,000 for each service area, depending
3 upon the difficulties encountered.

4 **Q. COULD YOU ADDRESS THE NEED FOR FULL CALIBRATION ON**
5 **THE SSU MODELS OTHER THAN PINE RIDGE?**

6 A. There are several factors the Commission must keep
7 in mind regarding the need for calibrating all of
8 the models in this case. Considering all of these
9 factors, I do not believe it necessary to require
10 SSU to fully calibrate all four of the models
11 submitted.

12 As I have stated, calibration, while always
13 desirable, is not a mandatory industry practice in
14 all cases. Hydraulic modeling is an important tool
15 used regularly by practicing professional engineers
16 to evaluate utility facilities for various
17 purposes. In this case, the model is being used as
18 a tool to compile flow ratios to arrive at a used
19 and useful percentage. Considering this use to
20 which the model is being put, I do not believe full
21 calibration is particularly essential. However, I
22 think it desirable to have adequate insurance that
23 the ratios developed have a sufficient correlation
24 to the facilities capabilities, and SSU has
25 provided as much in this case through (1) the

1 confirmation of the Pine Ridge model results as I
2 have already explained and as stated in the
3 calibration report and (2) Mr. Terrero's direct
4 knowledge that all four of the distribution
5 networks at issue were designed in the same way,
6 constructed at about the same time, by the same
7 firm, in accordance with those designs using the
8 same materials. If deemed necessary, spot-testing
9 of facility performance, rather than full
10 calibration, may also be a useful verification
11 mechanism to demonstrate that the model accurately
12 reflects actual hydraulic performance. One
13 additional consideration which carries somewhat
14 more weight than those I just mentioned concerns
15 how SSU's models were developed. In creating the
16 steady state models for this filing, SSU made
17 assumptions of a conservative nature, regarding
18 ~~peak demand~~ ^{Maximum day demand} per equivalent residential connection
19 in particular, such that calibrated results would
20 very likely reveal overall current flows throughout
21 each distribution network higher than those in the
22 models SSU filed. Thus, the used and useful
23 computations should be relatively insensitive to
24 minor variations in actual versus modeled flows.

25 **Q. YOU MENTIONED EARLIER THAT MR. BIDDY IGNORES THE**

1 **IMPORTANCE OF HAVING USED AND USEFUL CONSIDERATIONS**
2 **PARALLEL DESIGN REQUIREMENTS. COULD YOU EXPLAIN**
3 **WHAT YOU MEAN?**

4 A. Yes. Mr. Biddy acknowledges, at page 5 line 17 of
5 his testimony, that mains must be sized to
6 accommodate fireflow. He also seems to concede
7 proper distribution network design requires system
8 looping, for instance at page 18, line 6 of his
9 testimony. He acknowledges, at page 15, line 8,
10 that a hydraulic model is a reliable design tool.
11 But he then concludes that design considerations
12 should not be the same as used and useful
13 considerations for distribution and transmission
14 facilities. As I mentioned above, Mr. Biddy
15 consistently invokes design considerations to
16 support his views as to the used and useful
17 percentages of all other water facility components,
18 but eschews them as to transmission and
19 distribution facilities.

20 Mr. Biddy does not address, and therefore
21 seems wholly unconcerned with, the message the
22 Commission sends utilities and design engineers
23 through his proposed use of the lot-count method.
24 As stated in my direct testimony, that message to
25 utilities and engineers is basically two-fold: 1)

1 design and construct transmission and distribution
2 facilities properly at the utility's economic peril
3 and 2) ignore available economies of scale.

4 Mr. Biddy states that the lot-count method
5 recognizes an allowance for fireflow and looped
6 lines in that current customers have allocated to
7 them a portion of the total cost for all
8 transmission and distribution lines throughout a
9 service area or defined portion thereof. I believe
10 Mr. Biddy glosses over several key points I made in
11 my direct testimony.

12 Under the lot-count method, a utility's
13 ability to recover investment associated with
14 looping installations is entirely dependent upon
15 the number of customers, if any, which connect
16 directly to the loop lines. Thus, the utility's
17 ability for meaningful recovery of investment
18 associated with looping facilities is subject to an
19 unknown variable. Contingent recovery of this
20 sort, I maintain, poses little incentive to a
21 utility to loop lines where installation of such
22 facilities is required by design criteria to insure
23 adequate and proper service to the customers. Mr.
24 Biddy would put a utility in a position of being
25 required to install looping facilities but being

1 completely uncertain as to its ability to recover
2 the costs therefor.

3 Another critical point Mr. Biddy glosses over
4 is that the lot-count method attributes to current
5 connections only a small fraction of that portion
6 of the existing lines' capacity needed to meet the
7 water service requirements of those current
8 connections. As a result, the lot-count method
9 provides little or no incentive to the utility to
10 size its lines in accordance with the design
11 standards and requirements mentioned in my direct
12 testimony and basically penalizes the utility for
13 proper design.

14 Mr. Biddy also apparently attempts to bolster
15 his argument by stating that even under the lot-
16 count method, current connections must bear a
17 portion of the additional cost of a utility's
18 sizing lines to accommodate a defined buildout
19 condition. This, I believe, is an irrelevant
20 consideration, primarily because a flow-based used
21 and useful approach allocates these so-called
22 additional costs to future customers anyway and
23 also because current connections will benefit from
24 the offsetting savings associated with a one-time
25 facilities installation designed to meet a buildout

1 condition (i.e., the economies of scale, avoided
2 cost of facilities upgrading, and time value of
3 money) when future connections come on line. Using
4 Mr. Biddy's proposal, a utility would not be able
5 to recover its full investment in transmission and
6 distribution facilities even if the utility sized
7 and structured such facilities to serve only
8 current connections.

9 The more rational approach for measuring used
10 and useful for transmission and distribution
11 facilities is one which represents that portion of
12 installed facilities utilized to meet the needs of
13 current connections, incents a utility to follow
14 design criteria, and incents a utility to take
15 advantage of economies of scale. The hydraulic
16 analysis approach fulfills all of these criteria
17 infinitely better than the lot-count method.

18 **Q. DO YOU HAVE ANYTHING FURTHER TO ADD?**

19 **A.** No, not at this time.

1 BY MR. FEIL:

2 Q Mr. Edmunds, to your prefiled direct
3 testimony you had no exhibits attached; is that
4 correct?

5 A That is correct.

6 Q To your rebuttal testimony you had one
7 exhibit attached identified as RCE-1 consisting of 48
8 pages?

9 A Yes, sir.

10 MR. FEIL: Madam Commissioner, I ask that
11 RCE-1 be given an exhibit number for identification.

12 CHAIRMAN CLARK: It will be given Exhibit
13 No. 98.

14 (Exhibit No. 98 identified.)

15 MR. FEIL: I tender the witness for cross.

16 CHAIRMAN CLARK: Mr. Riley.

17 **CROSS EXAMINATION**

18 BY MR. RILEY:

19 Q Okay. Mr. Edmunds, I have just a few
20 questions for you. The problem we have, of course,
21 is we have six or seven engineering witnesses all
22 pretty much oftentimes saying the same things and
23 supporting each other. There is some question as to
24 the value of plodding through the same series of
25 questions to solicit the same approximate answers

1 from six or seven engineering witnesses. So I am
2 endeavoring to not replod those territories that we
3 did with several of the other witnesses.

4 But Mr. Edmunds, if I could direct your
5 attention to Page 11 of your testimony.

6 A Which testimony sir?

7 Q Your prefiled direct, particularly around
8 lines 8 through 11 were you speak of the lot count as
9 an economic disincentive for the utility to take
10 advantage of economies of scale.

11 Is it not true, though, that if a system is
12 serving a relatively well-developed subdivision that
13 is 80 or percent more built out that the lot count
14 method and hydraulic analysis method would generate
15 very similar used and useful percentages; is that
16 true?

17 A I don't know where the threshold is, where
18 the true convergence would take place. It certainly
19 is correct that as the subdivision approaches
20 buildout that the lot count method and the hydraulic
21 method would be expected to converge.

22 Q You couldn't enlighten us at all as to --

23 A I don't know if it would be 80 percent or
24 not. No, I've not studied that.

25 Q On Page 12 of your prefiled direct, around

1 lines 2 through 10, you are talking about hydraulic
2 analysis is more accurate reflecting actual use than
3 lot count.

4 A That's correct.

5 Q My question to you is to validate a
6 hydraulic model an engineer has to calibrate the
7 model to be, to certain levels; is that not correct?

8 A I think the answer to that is that it
9 depends on the use to which the model is being put.
10 In some cases, calibration is not possible. In other
11 cases, full calibration is not necessary. In some
12 cases, full calibration is necessary.

13 Q And may I assume the purpose of the
14 calibration is to attempt to verify the validity of
15 the model?

16 A Yes, but my response was specific toward
17 the purpose and use to which the model was being
18 made. Modelling is utilized for a variety of
19 purposes in the engineering field. So the answer to
20 your question is it depends upon the purpose of the
21 model.

22 Q Okay. But if in our case we are talking
23 about an existing system, would the calibration be
24 necessary to validate?

25 A Not necessarily. It depends upon the use,

1 the useful purpose of the model.

2 Q Isn't it correct that the quantity of water
3 carried or passed through each pipe increases with
4 pumping pressure?

5 A It increases with many, many things.
6 Pumping pressure is merely one of them.

7 Q What would be some of the other factors
8 that would increase the capacity of an existing pipe?

9 A Increased demand.

10 Q Isn't it correct that the real capacity of
11 each pipe is not necessarily limited by build-out
12 conditions, the demand factor, that you could have a
13 pipe that is designed let's say in our example to
14 serve a section of say ten lots. And it is designed
15 to serve those; but if, in fact, that section is
16 completely built out and all ten lots are developed
17 and connected to that line, that by increasing the
18 pump pressure that same line could serve still
19 another five connections? Is that an engineering --

20 A That's a very hypothetical question. The,
21 I think we need to recognize that a hydraulic network
22 is an organism that is unique. It is composed of
23 pipes. Each pipe, if it were removed and placed in
24 another hydraulic organism, could function at a
25 different capacity. But in that organism, in that

1 network, at the buildout, that is the maximum
2 capacity that pipe would be expected to function at.

3 Q I think we are not talking so much about
4 hydraulic analysis as we are that the pipe -- that as
5 an engineer looking at a system, that normally pipes,
6 in fact, could carry more water than build-out
7 conditions. Or would you say otherwise, that in
8 engineering that the pipe will only carry out what is
9 a buildout?

10 A I really don't understand the context of
11 the question. I don't understand that question. I
12 believe I was responsive in that "a" section of pipe
13 can be utilized in a variety of different ways and a
14 variety of different contexts. It will function at a
15 variety of different flows depending upon the system
16 it is placed in or the network and the functioning of
17 the network.

18 I'm sorry, I'm not trying to be evasive. I
19 just don't understand from a technical standpoint the
20 question.

21 Q From an engineering standpoint is it not
22 possible that even the lot count method could
23 overstate the used and useful percentage if, in fact,
24 the pipe which is in the ground to serve buildout
25 could, in fact, serve greater than buildout by

1 increasing such factors as pump pressure?

2 A I would say no.

3 Q Why is that?

4 A It is very difficult for me to imagine any
5 cases in which that might take place. The lot count
6 method completely fails to recognize the conveyance
7 capacity that is required in order to transmit flow
8 past vacant lots. And yet, in order to service those
9 lots that lie down stream of the vacant lots the
10 piping has to be in the ground abutting those vacant
11 lots.

12 So it is my opinion that the lot count
13 method is always biased on the low side, that it
14 doesn't reflect reality at all, and that it is
15 irrational and an erroneous technique to attempt to
16 simulate reality with.

17 Q And nevertheless, though, as an engineer it
18 is possible that these lines could, in fact, be
19 understated if these pump pressures are increased?

20 A Only if the buildout is incorrect; and in
21 fact, the buildout is greater than the buildout that
22 is being used in the computations. But that isn't
23 the context of your question, as I understand it.

24 Q On this same page, and even going over to
25 Page 13, you talk about the lot count method does not

1 recognize fire flow. You say that the lot count
2 method fails to recognize water main size and cost to
3 accommodate fire flow and loop lines. However, isn't
4 it correct that lot count method still uses the same
5 cost that includes those loop lines and proper size
6 mains for fire flow?

7 A No. The lot count method completely
8 neglects lines that are looped -- that need to be
9 looped -- to provide reliable service, to provide
10 chlorine residual, and to provide fire flow, unless
11 those lines happen to be abutted by an occupied lot.
12 But in order to provide the level of service, and in
13 order to provide the quality of drinking water that
14 the regulations require, looping is required.

15 Q So you are suggesting that the lot count
16 method does not count the loop lines and the proper
17 size mains, that the lot count does not take into
18 account the entire distribution system?

19 A That is correct. It doesn't take into
20 account the entire distribution system until it
21 approaches buildout. When, in fact, theoretically,
22 using your hypothetical, all lots would be built
23 upon; in which case, presumably the lots that abut
24 those line loops would also be built upon, and the
25 loops, themselves, would have some used and useful

1 attributed to them.

2 But the problem with the lot count
3 technique is that it is completely erroneous and does
4 not in any way simulate the hydraulic reality of a
5 water system.

6 Q Well, I understand your opinion on that
7 point, but isn't the lot count applied to the total
8 cost of the system?

9 A The lot count is applied incrementally to
10 each pipe on the basis of the frontage of property
11 that abuts that pipe. It makes no allowance for
12 whether that pipe is required to be placed in the
13 ground in order to provide service in the system.

14 Q So your understanding of the lot count
15 method is that there is, that it is not applied to
16 the total cost of the complete system, but somehow
17 portions of the system are deemed not even plant in
18 service?

19 A The lot count method allocates used and
20 useful costs on the basis of which lots are
21 occupied. And that is not the reality of the way the
22 system functions hydraulically.

23 Q Do you understand what I'm trying to say
24 about the difference between plant in service and
25 rate base? Are you suggesting that the lot count

1 method is a means used by Public Counsel or any other
2 intervenor to get utility plant to not even be
3 considered plant in service?

4 A I guess I don't understand your question.
5 Maybe you need to rephrase it in a fashion that I
6 will understand.

7 Q Do we not apply the lot count methodology
8 against the total cost of all of the utility plant in
9 service to arrive at a used and useful figure?

10 A Yes.

11 Q So I'm not sure how applying that
12 methodology -- you will have to explain to me how
13 that takes out or reduces the size of lines that are
14 sized for fire flow, or comes over here and takes out
15 three of the loops that are otherwise part of the
16 plant in service, and doesn't take those into account
17 because we are applying a percentage against these
18 elements of the system which are part of plant in
19 service.

20 A My understanding of the way that the lot
21 count is applied is that it does not take into
22 account fire flow, A. And it does not take into
23 account loops that may be necessary in the system for
24 water quality purposes, but are not involved in the
25 early distribution of local flow.

1 Q Well, if I told you, though, that the lot
2 count method is applied against the total cost of
3 plant in service, which includes these loops you are
4 speaking of, which includes a larger diameter of pipe
5 that is sufficient to take care of fire flow, would
6 you change your opinion --

7 A No, I would not.

8 Q -- about the lot count method?

9 A No, I would not.

10 Q Okay.

11 A The reason that I would not is that the lot
12 count method does not reflect the hydraulic reality
13 of what actually happens in the system.

14 Q Let's turn, if you would, to Page 14 and 15
15 of your prefiled direct. Here you state that the lot
16 count method encourages the utility to reduce the
17 water main size; is that correct?

18 A Yes.

19 Q Has the PSC ever used the lot count method
20 to alter an engineer's design?

21 A I don't know whether the PSC has done that
22 or not. I know the lot count approach coerces, by
23 virtue of the way it is structured, the utility to
24 put in less than the minimum requirements.

25 Q Well, but if we have a series of lots out

1 there and we are dealing with a 12-inch water main,
2 does the lot count used and useful percentage change
3 when you use a 12-inch water main instead of a
4 six-inch water main? Isn't it just the same
5 percentage being applied against whatever plant in
6 service is there serving the customers?

7 A That is correct. The problem, though, is
8 that hydraulically more actual capacity on a
9 percentage basis is required in the hydraulic system
10 than the lot count method allows for.

11 Q And yet the main size -- I mean, I
12 understand the company is not recovering as much
13 money as a result of applying the lot count method,
14 but to suggest that it is changing the size of the
15 mains is the thing we had a problem with.

16 A Well, you know, I don't understand your
17 problem, because hydraulically the system does not
18 function the way the lot count method infers that it
19 functions. Hydraulically, a greater pro rata share
20 of the installed system capacity is required
21 hydraulically than the lot count method permits.

22 As a consequence, there is a financial
23 pressure on the utility to do less than that which is
24 necessary in order to provide appropriate level of
25 service and to comply with the regulations.

1 MR. RILEY: No further questions.

2 CHAIRMAN CLARK: Mr. Twomey.

3 CROSS EXAMINATION

4 BY MR. TWOMEY:

5 Q Good afternoon, sir.

6 A How are you, sir?

7 Q I'm good, thanks. Did you drive here or
8 fly?

9 A Drove.

10 Q Let's say you were, say you were flying to
11 Atlanta and you got on the airplane, and it had 100
12 seats, and only ten of the seats were occupied.

13 Would you expect to pay for the full cost of the
14 aircraft, you and your nine fellow passengers, or
15 would you expect to pay some type of a tariff rate?

16 A I would expect to pay a tariff rate, but I
17 would not expect the pilot to fly me 10 percent of
18 the way and then say he couldn't take me the other 90
19 percent of the way.

20 Q Okay. Let me ask you, you've got pretty
21 extensive credentials here. You are a professional
22 engineer.

23 A Yes, sir.

24 Q I wanted to ask you on Page 2 --

25 A Which testimony, please.

1 Q I'm sorry, your direct, line 19. It starts
2 out, "I also served as project engineer for the
3 Hillsborough County's evaluation of its 20-year
4 master plan."

5 In that regard, I want to ask you did you
6 have an opportunity to conduct any used and useful
7 analysis of that system for economic rate setting
8 purposes?

9 A No, we did not.

10 Q What was your assignment in that regard?

11 A The assignment was to basically bring that
12 system into the 20th century. It was a series of
13 very marginal, developer-constructed systems that did
14 not function well. It had zero chlorine residual in
15 some locations, negative pressures at maximum demand
16 periods at some locations.

17 And our charge was to provide a master plan
18 that would provide a unified water system, made the
19 regulations, met the requirements for dependable
20 service, and then to master plan the design of the
21 piping network, pumping and treatment facilities, and
22 to implement the design of the pumping and treatment
23 facilities.

24 Q I take that to mean that you were
25 commissioned to do that job and to do an engineering

1 task.

2 A Comprehensive master planning and design
3 and construction.

4 Q But it did not involve economic rate
5 setting?

6 A No, we did not set the rates.

7 Q You would concede, would you not, sir,
8 irrespective of what your other views are on
9 hydraulic analysis versus the connected lot, that
10 this setting here is one of economic rate setting;
11 right?

12 A I would concede that this is a setting of
13 economic rate setting. I would not concede that the
14 rate setting should be divorced from reality.

15 Q So you are saying that these people are
16 divorced from reality in what they established in the
17 last case?

18 A I would say, as my testimony states, that
19 the lot count technique for determining used and
20 useful is divorced from reality.

21 Q Your testimony is it is divorced from
22 engineering design reality; isn't that correct?

23 A No, I'm saying it is divorced from the
24 physical reality from the way the system actually
25 works and it has to work.

1 Q The way the system has to work?

2 A The way the network that is being reviewed
3 has to work.

4 Q Okay. Help me understand this. Let's say
5 that I come to you and I have some land I want to
6 develop. And I have a three-mile stretch, and I want
7 you to lay water pipe, a single main down the three
8 miles. It stops at the end of three miles. I want
9 to put 100 homes on that system, okay?

10 A All right.

11 Q I assume you have to make some type of
12 assumptions on -- and I want you to design it for 100
13 homes, okay?

14 A (Nodding head.)

15 Q What type of assumption do you make or
16 would you make for the consumption of each home?

17 A That would depend on the area. I tend to
18 distrust rules of thumb and prefer to use local
19 information from comparable water systems, if I can;
20 if not, regional information. Generally, some --

21 COMMISSIONER GARCIA: What do you mean by
22 information from local water systems? Are you
23 talking about their pricing schemes or their cost of
24 service?

25 WITNESS EDMUNDS: No, sir, I'm talking about

1 consumption information. For example, the water
2 consumption in Minnesota is very different from the
3 water consumption in Florida. So I would, I would
4 prefer to, rather than use national rules of thumb, I
5 prefer to use data that is as local as possible.

6 If, for example, this three-mile stretch of
7 pipeline were an adjunct to an existing network, my
8 preference would be to go into that network and
9 determine what is happening within that network from the
10 standpoint of average day flow, max day flow, peak hour
11 flow, and then use that data in the planning and the
12 design of the facility.

13 BY MR. TWOMEY:

14 Q If you used local data, would you come up
15 with some figure like two gallons per minute per
16 connection or something in that -- I mean, not that
17 number, is that the kind of thing you look for?

18 A I would come up with all of the variables
19 that are used in design.

20 Q Okay.

21 A Of which would be average day flow, max day
22 flow, peak hour flow.

23 Q Okay. And then you would design the pipe
24 to accommodate that, right?

25 A That plus the projections of growth, yes, I

1 would.

2 Q I'm sorry, I asked you to design it for 100
3 homes.

4 A Yes.

5 Q Period.

6 A Well, if that is the ultimate limit, then
7 that is what I would design it for.

8 Q Now --

9 A If there was a possibility of more, I might
10 have some conversations about the future.

11 Q Yes, sir. Now, you get, if -- you build
12 the system and advise the developer sell the last lot
13 at the end of the three miles, and it is connected to
14 the system, how much is the hydraulic capacity of
15 that system might that one home take?

16 A That would depend upon the time for
17 buildout and the decisions that were made about the
18 piping, interim and ultimate piping. It would also
19 depend upon the regulations that were applied to that
20 specific subdivision area.

21 Q Yes, sir, but I guess that wasn't specific
22 enough in my assumptions. I want you to build the
23 entire system at one time. Assume that 100 people
24 are going to move in. I don't want to go ripping up
25 any of the main as people add on. Okay. I want to

1 let them build wherever they darn well please on that
2 three mile stretch, okay?

3 Now, given those assumptions, if I move
4 myself in, in the very last lot, furthest lot away
5 from the water treatment plant, it strikes me that
6 every foot of that main from my house to the water
7 treatment plant is necessary to serve me.

8 A That's absolutely right. That's the
9 point.

10 Q That's what I thought you were saying. You
11 are saying, are you not, that if there was one home,
12 one customer at the very end of my system, that under
13 hydraulic analysis methodology that home, that
14 customer is responsible for 100 percent of the
15 system; right?

16 A No, I did not say that.

17 Q I'm sorry. What did you say?

18 A I said that every foot of that main was
19 necessary. I agreed with you that every foot of that
20 main is necessary.

21 Q Well, what hydraulic capacity, what
22 percentage of the hydraulic capacity of the entire
23 system approximately would be necessary to serve me
24 at the end?

25 A Well, I don't know until I know the way the

1 numbers roughly come out. It would be more than one
2 percent.

3 Q Well, it would be a lot more than one
4 percent, wouldn't it?

5 A Well, it depends upon how the numbers come
6 out.

7 Q Would it necessarily be more than 50
8 percent?

9 A That depends on a number of things. Would
10 you like me to enumerate what they are?

11 Q Yes, sir.

12 A Okay. This is more complex than lay people
13 tend to understand because regulations are
14 imperatives. Local regulations are imperatives, and
15 state regulations are imperatives.

16 If, for example, the local regulations
17 require that fire flow has to be provided to that
18 connection that you have hypothesized, and the
19 developer is constrained to do that, then in a one
20 hundred unit line extension it is probable that the
21 fire flow would be the predominant flow and would
22 greatly overshadow the maximum day or peak hour
23 flows.

24 So in that case, that single user at the
25 end of our hypothetical main could require the

1 developer to provide, in essence, the full size main,
2 the full extent of that block or of that
3 subdivision.

4 Q I see.

5 A If on the other hand fire flow --

6 COMMISSIONER GARCIA: Could you go back --
7 I'm sorry, could you go back a second? Start at the
8 beginning of that statement again because I just
9 missed the end of it. I'm sorry.

10 WITNESS EDMUNDS: All right, sir. What I
11 was saying, sir, is that if the developer is required
12 by some means -- be it local regulation, be it
13 commitment to seller, be it master plan -- to provide
14 fire flow and a hydrant to that lot purchaser at the
15 very limit of that line, then the fire flow will
16 probably be the predominant flow in that pipe line.

17 The fire flow will be order of magnitude of
18 about 500 GPM. Peak hour flow in that line will
19 probably be, oh, goodness, maybe half that at
20 buildout, roughly. So we can see from that the fire
21 flow is the predominant flow. So the developer has
22 to provide the maximum line size or something close
23 to that in order to provide the fire flow that he is
24 constrained to provide at the end of the
25 subdivision.

1 COMMISSIONER GARCIA: Right, but that he is
2 having to provide it out there is the developer's
3 problem, not the person that is receiving that
4 service, wouldn't you say?

5 WITNESS EDMUNDS: The developer has to
6 provide the service.

7 COMMISSIONER GARCIA: Absolutely. But if I
8 let someone build out a mile -- if I have a five-mile
9 development, and instead of building mile one out
10 first and I sell -- because I have ambitions of a
11 great development, and I sell at the end of my
12 development, and it costs me more to maintain that
13 pressure, which I'm required to by local ordinance,
14 that cost, though, is my fault as a developer,
15 correct?

16 WITNESS EDMUNDS: Well, the cost has to be
17 paid. If, for example, we are talking about a municipal
18 or a governmental water system, 100 percent of the
19 installed facility is carried by the rate payer.

20 COMMISSIONER GARCIA: But as a general rule
21 those systems don't make money, as a general rule they
22 lose money and they are subsidized by the general base
23 of tax payers and not rate payers.

24 WITNESS EDMUNDS: Not in my experience.

25 COMMISSIONER GARCIA: Let's say they

1 aren't. Neither here nor there. In this case we are
2 in a profit-making venture, or at least trying to
3 be. So if a system is built out in a certain way,
4 that because of ordinances I have to pay more -- I'm
5 sorry, Mr. Twomey, I jumped in.

6 MR. TWOMEY: No, sir, you just keep going
7 as long as you want.

8 COMMISSIONER GARCIA: And I build it out in
9 a certain way that in the end it will incur greater
10 costs on it because of local regulation and
11 ordinances, is that not my mistake as a developer as
12 opposed to the rate payer who received service from
13 the developer because it was in the developer's
14 interest at that time?

15 WITNESS EDMUNDS: I don't believe that it is
16 because the rate payer receives the service. It is
17 always done in governmentally-owned facilities, that the
18 cost of those very extreme situations -- this
19 hypothetical is a very extreme situation -- is spread
20 over the entire rate base. And as a consequence, it
21 disappears into the rate base because this kind of
22 situation doesn't happen that frequently.

23 You know, one could argue, sir, that a
24 variable rate is appropriate for each residence in a
25 system, depending upon the cost of his --

1 COMMISSIONER GARCIA: Let's say --

2 WITNESS EDMUNDS: -- specific service.

3 COMMISSIONER GARCIA: Let's say --

4 CHAIRMAN CLARK: Hang on a minute. You guys
5 need to remember we have one court reporter and she
6 can't take both of your conversations at the same time.

7 COMMISSIONER GARCIA: That's my fault. I'm
8 sorry. I have a tendency to do that.

9 Let's say that is the case, and I agree with
10 you philosophically, but let's go back to Mr. Twomey's
11 system, and we will call it hypothetically Sunny Hills,
12 where I develop a huge system in anticipation of a great
13 development; but with that forecasting, I make an
14 error. But clearly the provision of water was essential
15 for me to do the development, by local ordinance and by
16 simply as you put it reality when you described
17 hydraulic.

18 If I didn't have water, I wouldn't have anyone
19 because I couldn't get occupancy; and therefore, I
20 couldn't sell the property, and so on. In this
21 particular case, you put people out there in the system
22 because you knew that sooner or later, because of the
23 great benefit of the sales that would incur as a
24 developer, your system would be perfectly situated to
25 serve all these people that you were going to sell to,

1 but unfortunately you had another reality.

2 Someone moved in mile ten from your source,
3 and you are having to provide hydraulic pressure all the
4 way out there and all the problems. There is clearly an
5 additional cost for providing service to that person all
6 the way at the end.

7 If I understand you correctly you said that,
8 right, that persons costs a little bit more and they
9 should pay a little bit more, or you are saying to me
10 that person should pay exactly the same and the company
11 should be reimbursed for the provision of that service?

12 WITNESS EDMUNDS: What I am saying is that
13 reality that you described exists at every connection
14 in the water system. For example, the homes that are
15 right next door to the water plant should have by one
16 argument a very low rate because the cost of getting
17 water to them is right next door, and so they should
18 have a very low rate.

19 If we take the same argument out to that
20 person who is at the very end of the line, he should
21 have a very high rate by that argument. I don't
22 agree with that argument. It is not my opinion that
23 argument is appropriate. But what I do believe
24 though is that the utility has an obligation to
25 provide the service.

1 If the utility has the obligation to also
2 provide the fire flow, then in this extreme case
3 there is an anomalous cost. The reason that common
4 rates, uniform rates, are utilized in public water
5 works is to level the playing field for all
6 customers.

7 COMMISSIONER GARCIA: But in this
8 particular case it wasn't the utility who had an
9 obligation to serve, let's say, but it was the
10 developer who wanted to sell; and therefore, provided
11 service at an additional cost, nonetheless, but he
12 sold the property. He derived the benefit.
13 Unfortunately, it didn't end up the way he wanted.
14 But that provision of service was contingent on the
15 sale and not necessarily on the obligation to serve.

16 If that were the case, would that not be
17 the developer's mistake as opposed to the rate
18 payer's mistake?

19 WITNESS EDMUNDS: Our hypothetical is getting
20 pretty hypothetical here. I mean, a number of
21 predicates are being laid that could lead to the answer
22 to your question being, yes, that was his problem; but
23 with the change of just one predicate the answer could
24 be, no, that is not his problem. And so I guess I would
25 prefer to leave the domain of hypothesis and look a

1 little more at reality. Now --

2 COMMISSIONER GARCIA: All right. But since my
3 question is about the hypothetical, let's answer that
4 one and then tell me why it doesn't work. In that
5 particular case you would then answer, yes, that it was
6 the developer's error that perhaps made that provision
7 of service more expensive; correct?

8 WITNESS EDMUNDS: I think my answer would
9 be it depends upon the conditions under which the
10 decision was made to sell that lot, to provide
11 service to that lot, a number of conditions that
12 we're really speculating over.

13 What I can tell you is that this is not a
14 new problem. This is a problem that has been
15 addressed in water works probably since Ben Franklin
16 helped to start the first water work in 1800. And
17 the common answer has been a uniform rate so that all
18 customers have a level playing field, no matter how
19 they are stressing the system.

20 COMMISSIONER GARCIA: Thank you, Mr.
21 Twomey.

22 MR. TWOMEY: Thank you. Let me pass
23 something out. Can I have the next number, please?

24 CHAIRMAN CLARK: The next number is 99.

25 MR. TWOMEY: 99, thank you.

1 (Exhibit No. 99 identified.)

2 CHAIRMAN CLARK: Just a minute, Mr.
3 Twomey. I think we don't have enough copies. Mr.
4 Feil, you can have mine and I will look on with
5 Commissioner --

6 MR. TWOMEY: I apologize. I made one more
7 than last time.

8 CHAIRMAN CLARK: I will look on with
9 Commissioner Johnson.

10 MR. TWOMEY: We are running a big tab at
11 the Clerk's Office.

12 MR. TWOMEY: This is three sheets of paper,
13 Madam Chairman. It is four sides, four pages. .
14 Taken from the company's MFRs. It is a schedule F-7,
15 Pages 115, 119, 120 and 122.

16 BY MR. TWOMEY:

17 Q I want to make sure again I understand
18 this, Mr. Edmunds. You don't purport at all to be an
19 economic rate analyst or rate setter, right?

20 A That is correct.

21 Q You are a professional engineer whose
22 experience solely resides in designing systems,
23 that's where most of it is?

24 A I won't say that it is where it solely
25 resides, but that is one area of expertise I have,

1 yes, sir.

2 Q But you don't have any expertise in rate
3 setting; is that correct?

4 A I have not been asked to set rates.

5 Q So but to answer my question, if I said to
6 you, "Do you have any rate setting expertise,
7 economic, water or sewer rate setting expertise,"
8 what would your answer be?

9 A I think my answer would have to be "yes",
10 because as I understand the concept of used and
11 useful, it is an attempt to allocate to today's
12 customers the portion of the facility that they
13 actually account for. And to that extent I would
14 have to say, yes, that I do have the expertise in
15 being able to testify here and to derive the portion
16 of the installed facility that they actually account
17 for.

18 Q Okay. I forgot to ask you, how much are
19 you being paid for this assignment?

20 A I'm being paid by the hour.

21 Q How much are you being paid?

22 A I don't recall. My billing rate exactly,
23 it is, I think it is around \$150 an hour.

24 Q All right, sir. Do you do other
25 engineering assignments -- have you done other

1 engineering assignments for SSU?

2 A No, I have not.

3 Q Now, if you would look at Page 1, that is
4 Page 115 of this exhibit, 99, my understanding is --
5 do you know which system on this page is the system
6 for which SSU is requesting hydraulic analysis?

7 A I believe Citrus Springs.

8 Q Okay, sir. Now, just before we get into
9 that, if we look at some of the apparent realities of
10 some of the numbers that might reflect wild-eyed
11 optimism in the developer's mind, the Citrus Park has
12 got 355 connected lots based on 1996, with the one
13 year margin of reserve; right?

14 A That is what it says, yes.

15 Q They have, and they only have 335 lots,
16 right?

17 A That is what it says.

18 Q Okay. So that would be, the calculated
19 percentage would be more than 100 percent, but SSU is
20 not asking for more than 100 percent; right?

21 A I'm not sure I understand.

22 Q Well --

23 A -- the calculation.

24 Q Well, if you have, if you have, if you take
25 355 as a percentage of 335, it is more than 100

1 percent; isn't it?

2 A Yes. That indicates that there is some
3 question about the 335.

4 Q Or the methodology?

5 A Something needs to be questioned, yes.

6 Q But they've only asked for 100 percent.

7 A Yes.

8 Q Because they don't want to, well, never
9 mind. Now, if we look at Crystal River, for example,
10 they have 78 out of '91 lots, right?

11 A Yes.

12 Q And the other systems, even Deltona Lakes
13 has got twenty-four thousand five out of
14 approximately 35,000 connections or lots; right?

15 A Yes.

16 Q Now, when we get to Citrus Springs,
17 Mr. Edmunds, they only have -- based on what SSU is
18 projecting for 1996, plus one year's margin reserve
19 -- they only show 1,944 connections; right?

20 A Yes.

21 Q That we know is a number that doesn't exist
22 today, right, by definition?

23 A Yes, that's the assumption.

24 Q Yet, Citrus Springs has 11,667 lots;
25 right?

1 A Yes.

2 Q Okay. It is perhaps something close to
3 what Commissioner Garcia had in mind in his example.
4 Now, the calculated percentage on line four, can you
5 tell me what that means in terms of SSU's filing?

6 A I have not been asked to consult on this.
7 I can only project the calculated percentages on the
8 basis of the lot count method.

9 Q That the 16.66 percent?

10 A I would assume so.

11 Q Do you have a calculator?

12 A Yes, sir, I do.

13 Q Would you run that and let's see if --

14 A It is.

15 Q It is.

16 A To the one-hundredth.

17 Q Sir?

18 A It is correct to the hundredth.

19 Q Yes. Now, do you have any greater
20 understanding of what they are asking for in line
21 five, the used and useful per order, 21 percent?

22 A I do not.

23 Q And yet, sir, line six, they are asking for
24 42.71 percent, correct?

25 A That is what it says.

1 Q And the double asterisk apparently
2 indicates that is based on the Cybernet Hydraulic
3 Model Results, right?

4 A Yes.

5 Q Which is, I'm sorry to interrupt you, which
6 is the methodology that the company has utilized in
7 this filing, right?

8 A That's my understanding, yes.

9 Q So that is approximately, that is
10 approximately 270, 280 percent of what the calculated
11 percentage is, right, 42.71 versus 16.66?

12 A Approximately two and a half.

13 Q And --

14 A 2.56 times.

15 Q Okay, sir. And you support that?

16 A I support what, sir?

17 Q You support that number, that used and
18 useful calculation.

19 A I have not, as I believe I've just
20 testified, I have not been asked to review
21 specifically the used and useful calculations which
22 SSU has provided.

23 Q Okay, sir.

24 A I'm testifying as to the reliability of the
25 technique of utilizing hydraulic modelling, to

1 understand the actual portion of the capacity on a
2 line-by-line basis that is required by today's
3 connected users.

4 Q Yes, sir. Were you here this morning early
5 at the outset?

6 A I got in about 9:15.

7 Q Did you hear any of the customers
8 testifying about their high water rates?

9 A I believe I recall a gentleman testifying
10 about that, yes.

11 Q Okay. Now, I don't mean to be unfair about
12 this, but what I meant to try and ask you was that,
13 is that you support the results, don't you? Which is
14 to say, you support the Commission who is charged by
15 the company's request with giving them quote,
16 unquote, affordable rates, who are charged by law
17 with approving fair and reasonable rates.

18 You approve a methodology, do you not, that
19 would have them increase a lot connection, used and
20 useful calculation, for the transmission and
21 distribution system at Citrus Springs of 16.66
22 percent; and you would, your testimony is that based
23 on what the company has asked for, they should
24 increase that by 250 percent to 42.71 percent;
25 right?

1 A No, that's not my testimony. I have not,
2 as I've testified I believe several times now, I have
3 not reviewed the specifics of the used and useful
4 calculations that SSU has presented. I am here to
5 say to you that the lot count approach is irrational
6 and erroneous, does not reflect reality, and is
7 scientifically unfounded.

8 I'm here to tell you that it creates a
9 disincentive to comply with the regulations and to
10 provide service. I'm not here to say that I have
11 reviewed their calculations meticulously, and that
12 42.71 percent is the number.

13 There may be some adjustments that may be
14 desirable. I don't know. But I am here to tell you
15 that on the lot count basis that an underutilization
16 is always projected. And that does not meet a
17 fairness standard by any measure.

18 Q I'm sorry, fairness in what sense?

19 A Fairness in terms of incentivising the
20 developer to provide service, incentivising the
21 developer to comply with regulations, and providing
22 appropriate rates to the developer for the pro rata
23 share of the system that is actually utilized.

24 COMMISSIONER GARCIA: What do you mean by
25 incentivising the developer, I guess, with the water

1 company to comply with regulations?

2 WITNESS EDMUNDS: Sir, I think the most
3 dramatic example of this is the fire flow case where
4 if the percentage of the installed pipe that the
5 developer is permitted to recover is solely on the
6 basis of the lot count, that he is not permitted to
7 recover the actual costs of the installed facility
8 that he has to provide.

9 So there is a coercion in the rate process
10 on the developer to not meet the regulations and not
11 to provide the standard of service that the
12 regulations require.

13 MR. FEIL: Mr. Edmunds, just for
14 clarification, you are referring to the developer,
15 but you are also referring to utilities, as well?

16 WITNESS EDMUNDS: Yes, sir, I think I'm still
17 following on with this hypothetical that perhaps we
18 should dispense with.

19 BY MR. TWOMEY:

20 Q We'll see. Did you take a course in
21 fairness at the University of --

22 MR. FEIL: Objection, irrelevant,
23 immaterial.

24 MR. TWOMEY: Let's see, Madam Chair. Did
25 you take --

1 CHAIRMAN CLARK: Mr. Twomey, he has
2 objected.

3 MR. TWOMEY: I would like to finish my
4 question.

5 CHAIRMAN CLARK: I thought you did finish
6 your question.

7 MR. TWOMEY: I didn't finish my question.
8 He interrupted me.

9 CHAIRMAN CLARK: Go ahead.

10 MR. TWOMEY: I would like to finish my
11 question.

12 CHAIRMAN CLARK: Finish your question.

13 MR. TWOMEY: Then he can object.

14 BY MR. TWOMEY:

15 Q My question, sir, is at the University of
16 Florida, when you were acquiring your bachelor's and
17 master's of engineering, did you take any courses in
18 fairness in those schools?

19 MR. FEIL: Same objection, irrelevant,
20 immaterial. A course in fairness, never heard of
21 such a thing.

22 CHAIRMAN CLARK: Mr. Twomey.

23 MR. TWOMEY: The point is this, Madam
24 Chair, the gentleman is an engineer. He has conceded
25 that he has, with the one exception, no experience in

1 economic rate setting. It is a caveat, I should say,
2 that he threw in.

3 He just said he doesn't think that the lot
4 connection method is fair. And I want to know from
5 him whether fairness is something he was taught in
6 engineering school, if it is something that is a
7 consideration in the designing of water systems.

8 CHAIRMAN CLARK: So you want him to explain
9 what he means by fairness?

10 MR. TWOMEY: Yes.

11 WITNESS EDMUNDS: By God's grace I was born
12 with common sense. And common sense tells me that
13 one cannot totally violate reality in rate setting or
14 anything else. The reality that is being violated by
15 the lot count method is that it has no basis in the
16 way a system actually has to function, and the system
17 that the utility has to actually provide in order to
18 comply with the regulations and to provide the
19 service that is required for the safety, health, and
20 welfare of the customer.

21 BY MR. TWOMEY:

22 Q Mr. Edmunds, in the Citrus Springs example,
23 do you know whether SSU developed that system or they
24 purchased it?

25 A I do not.

1 Q There is --

2 A Excuse me, a moment. Let me think back.
3 I'm not certain of this, but that may have been a
4 Deltona system.

5 Q If it is a Deltona system, there have been
6 a number of Deltona systems in this state that have
7 failed, right? That is, developments that have
8 bankrupted, right, do you know?

9 A I believe that there have been a number of
10 systems that have been sold and Deltona Corporation
11 no longer exists.

12 Q My question to you, though, is we've
13 already established that even taking projected
14 customers and adding a year of margin reserve, that
15 there is less than 17 percent of the existing lots in
16 this development connected after however many years
17 it has been in existence.

18 And my question to you is do you think it
19 is the fault of the customers that is the
20 relationship of connected lots versus the total
21 lots?

22 A Sir, I don't have that level of knowledge
23 concerning Citrus Springs or any other development.
24 I do not know who is at fault, if anyone is.

25 Q Well, if, in fact, Southern States went in

1 and purchased this system and the connected lot, the
2 total lot situation was as it is now or smaller,
3 don't you find, don't you hold them responsible,
4 don't you hold SSU responsible for a caveat emptor
5 approach?

6 A In what way?

7 Q That if they bought a system that had less
8 than 2,000 connected lots out of close to 12,000,
9 wouldn't you expect them to know that when they
10 bought it?

11 A I would expect them to know how many lots
12 were occupied when they bought the system, yes. I
13 would expect them to know how many lots ultimately
14 were platted.

15 Q Sir?

16 A I would expect them to know how many lots
17 also were ultimately platted. Is that your question?

18 Q Yes.

19 A Okay.

20 Q Now, if you turn to Page 119, please. Let
21 me ask you this. If I didn't know which system SSU
22 was proposing for hydraulic analysis here, would I be
23 safe in taking the system that had the lowest
24 percentage of connected versus total lots?

25 A I don't know the answer to that.

1 Q Isn't that the case on this page, though?

2 A I'm not sure I understand your question.

3 Q Which system is the one on this page that
4 is proposed for hydraulic analysis?

5 A Marion Oaks.

6 Q Okay. And doesn't it appear -- not doesn't
7 it appear -- isn't it a fact, Mr. Edmunds, that when
8 you look at the calculated percentage that Marion
9 Oaks is by far the smallest percentage?

10 MR. FEIL: Commissioner, aren't we getting
11 a little repetitious here? The exhibit shows what
12 the exhibit shows. Why is it that Mr. Edmunds has to
13 say what the exhibit shows whatever it is that it
14 shows?

15 CHAIRMAN CLARK: I think -- Mr. Twomey, do
16 you want to respond?

17 MR. TWOMEY: Yes, because we are talking
18 about only four systems, Madam Chair, okay? They are
19 distinct. The company has made a big deal of this.
20 And I think that we can go through this real quick
21 and establish the percentages, ask Mr. Edmunds if he
22 thinks that is fair, and we can dispense with it. I
23 mean, we are not talking -- I didn't hear him say it
24 was irrelevant.

25 MR. FEIL: I said it is cumulative and

1 repetitious is what I said.

2 MR. TWOMEY: You said it twice. So I would
3 suggest that we could just go ahead and it won't take
4 but a few more minutes.

5 CHAIRMAN CLARK: You aren't really
6 responding to his objection, but I will allow the
7 line of questioning. Go ahead.

8 MR. TWOMEY: Thank you. I won't --

9 CHAIRMAN CLARK: Take it and go with it,
10 Mr. Twomey.

11 MR. TWOMEY: Yes.

12 BY MR. TWOMEY:

13 Q Now, I'm going to move, Mr. Edmunds, to not
14 be repetitious, I will move to a different system. I
15 will ask you to turn to Page 120. Pine Ridge is the
16 hydraulic analysis system, right?

17 A Yes.

18 Q Okay. And you don't, if I heard you
19 before, you don't vouch for anything on this except
20 for the methodology that was used.

21 A That's correct. That's correct.

22 Q If you look at Sunny Hills, which sounds
23 remarkably like Commissioner Garcia's hypothetical on
24 Page 122, is that the system for which SSU is seeking
25 hydraulic analysis?

1 A Yes, although I see two Sunny Hills here,
2 yes, I see the one that is identified as the one
3 based on the Cybernet model. It would be the one
4 under column three.

5 Q Okay. And I'm having a hard time with the
6 number, but doesn't it appear to you that the number
7 looks like 8.09 percent calculated percentage?

8 A Yes, sir, I believe that is what it says.

9 Q They are asking for 28.09, right?

10 A Yes, sir.

11 Q Now, I'm holding in my hand Volume 6, Book
12 2 of 2 of the company's MFR F schedule. It says it
13 contains the water hydraulic analysis. Have you
14 examined this document?

15 A No, I have not.

16 Q Do you know whether or not the hydraulic
17 analysis is a fairly lengthy process? I shouldn't
18 say lengthy. It is complicated, is it not?

19 A Relative to what?

20 Q Relative to the lot count methodology.

21 A Oh, yes, it is complicated relative to the
22 lot count method because the lot count method is very
23 simplistic.

24 Q Okay. My client can handle the lot count
25 methodology. Do you think that my clients would have

1 a chance at trying to analyze whether SSU or any
2 utility has conducted the hydraulic analysis
3 methodology properly?

4 A I believe they would if they hired an
5 expert that has that capability, yes.

6 Q I see. Would you turn to Page 8 of your
7 direct testimony, please?

8 A I'm sorry?

9 Q Page 8 of your direct testimony.

10 A Page 8? Did you say Page 8?

11 Q I'm sorry, eight, yes, sir.

12 A Eight.

13 Q Line three, what do you mean by the
14 apparent qualification of the Hardy-Cross analysis
15 can still produce fairly reliable results? What do
16 you mean by the caveat of fairly reliable?

17 A Hardy-Cross analysis was a manual technique
18 that had a number of mathematical simplifications for
19 solving loop hydraulic network analyses. It is
20 time-consuming. It is an iterative process. It does
21 not converge to accuracy in a time-saving fashion.

22 And so very often the hydraulic engineers
23 who utilize the Hardy-Cross technique would not
24 converge to a very accurate answer, because it is so
25 time-consuming. Whereas, the mathematical computer

1 model will converge very quickly on an accurate
2 solution. So that is what that means, that
3 Hardy-Cross analysis is fairly reliable, but it is
4 very time-consuming, and as a consequence is not the
5 preferred means of performing these analyses.

6 Q Okay, sir. On Page 9 of your testimony at
7 line, beginning at line 17, you say the computer
8 software Southern States used to prepare its
9 modeling, Cybernet, is very well regarded by and
10 widely used in the industry and in my experience
11 produces very reliable results.

12 My question to you is by industry do you
13 mean in the engineering design industry?

14 A I mean in the engineering community and
15 also the utilities community.

16 Q I see. Do you mean that, is it your
17 testimony that the utility industry finds this system
18 to be well regarded and widely used for rate making
19 purposes?

20 A My testimony is that all who are
21 knowledgeable in the hydraulics field in this country
22 today consider Cybernet one of the very well regarded
23 modeling software techniques.

24 Q Okay, sir. On Page 11, Mr. Riley asked you
25 earlier about the statement beginning at line 16, and

1 on 17 where you say these pressures, those pressures
2 act as a direct disincentive to proper design. How
3 about situations where an utility goes out and
4 acquires other systems. There is no direct
5 disincentive, is there, when they acquire an existing
6 system as opposed to designing a new system?

7 A I'm not sure I understand your question.

8 Q The lot, I thought it was your testimony
9 that -- in fact, you said I think at one point that
10 the direct, the lot connection methodology coerced
11 utilities so that they had less than the minimum
12 requirements. Do you recall that?

13 A Yes, that is correct.

14 Q I intended to ask you, how can you have
15 less than minimum?

16 A Well, that is the point, isn't it? If you
17 are going to remain within the law and comply with
18 the regulations, that you would have to cheat to do
19 that. And from a public policy standpoint it isn't
20 sensible for a rate making body to coerce a utility
21 or anyone else in that direction.

22 Q Right. And I took from that statement that
23 you were speaking in the context of somebody
24 designing a system, were you not?

25 A Yes.

1 Q That you were afraid that the lot
2 connection methodology would result in them building
3 less than it otherwise should?

4 A I think it provides a uniform coercion in
5 that direction.

6 Q How does that uniform coercion apply, if it
7 does, when a utility goes out and buys a complete
8 existing system?

9 A In expansions to that system?

10 Q No, sir. I'm a utility -- SSU goes out and
11 buys a system, an existing system, without any plans
12 for expansion or anything else. Is it your testimony
13 that the lot count or connection method provides a
14 disincentive there?

15 A Is your hypothetical including that the
16 system they purchase is 100 percent used and useful?

17 Q No, sir. They go out and they buy Sunny
18 Hills where only eight percent of the lots are
19 connected.

20 A Well, I believe, sir, that Sunny Hills will
21 be extended and expanded. It is my testimony that it
22 is in that extension and that expansion that the
23 coercion exists.

24 Q I see. One last series of questions. Do
25 you understand that this company proposes to not only

1 pass -- you recognize from Exhibit 99 that increased
2 rate base and, therefore, increased revenue
3 requirements have to result from the Cybernet
4 methodology; do you not?

5 A I assume that from what I am seeing here;
6 but once again let me say, sir, that I have not in a
7 detailed fashion reviewed the used and useful
8 calculations that SSU has made.

9 Q Yes, sir. But in answer to my question,
10 you do recognize that if, do you not, that if used
11 and useful goes from 8 percent to 28 percent, that
12 revenue requirement has to go up, all other things
13 being equal; right?

14 A Yes, I would assume that would be the
15 case.

16 Q Now, do you understand as well that this
17 company is asking that not only the customers of that
18 system, Sunny Hills in this example, pay that
19 additional revenue requirement, but that they try and
20 spread it around the state to other systems including
21 my clients through the device of uniform rates?

22 A I would hope that would be done because
23 that is in the utilities industry and
24 governmentally-owned utilities recognized as being
25 the fairest standard to set rates by.

1 Q Is that right?

2 A Yes.

3 Q Can you tell me of any two separate and
4 distinct municipalities that set rates on an
5 averaging basis, or did you mean within a
6 municipality?

7 A I'm saying within a system; and SSU in
8 whole is one system.

9 Q Is it?

10 A Yes. They utilize and apply their
11 personnel over the entire system, their overhead
12 costs over the entire system, which is composed of a
13 great number of these local sub systems, if you
14 will. They operate it as a single system.

15 Q I see. Last question. Isn't it true, if
16 you know, that the federal environmental protection
17 agency has a definition of system that encompasses a
18 facility or plant by plant? Do you know?

19 A System is used in a variety of contexts and
20 a variety of different ways. I am using it in the
21 context of a multitude of networks, if you will, that
22 are basically operated as a single unified system
23 from a management, personnel, labor allocation,
24 maintenance standpoint.

25 Q Yes, sir, but do you know if the federal

1 EPA -- I don't think, I don't think I got an answer
2 to my question is why I'm asking it again. Do you
3 know if the federal EPA has a definition of system
4 that is consistent with a plant facility geographic
5 location?

6 A They may have, but it would be a function
7 of the specific context of what is being dealt with.

8 MR. TWOMEY: Okay. Thank you.

9 CHAIRMAN CLARK: Staff? How much do you
10 have?

11 MR. PELLIGRINI: Not very much.

12 CHAIRMAN CLARK: Okay.

13 CROSS EXAMINATION

14 BY MR. PELLIGRINI:

15 Q Good evening, Mr. Edmunds.

16 A How are you, sir?

17 Q Good. How are you?

18 A Oh, I'm fine.

19 Q Mr. Edmunds, it seems that the basic used
20 and useful analysis problem we have is how does the
21 utility recoup its expenses for putting in a
22 distribution or collection system? Would you agree?

23 A Yes, I believe I would agree with that.

24 Q Are you familiar with AFPI, the Allowance
25 for Funds Prudently Invested mechanism?

1 A In general, yes.

2 Q Would you agree then that what we need as a
3 solution to this difficulty is some wise mix of
4 margin reserve and AFPI?

5 A No, I'm afraid I would not be able to agree
6 with that. The reason I could not agree with that is
7 because the hydraulic modeling tells us the pro rata
8 share of each line in a network that is being
9 utilized for the customers who exist today.

10 And I believe that if that allocation is
11 made correctly, then there may be some other
12 adjustments that would be appropriate for AFPI, for
13 margin reserve; but my concern is with the
14 misallocation of the affect on the network of the
15 customer base that exists today.

16 Q You would not see in that then an
17 inequitable distribution of costs or an inequitable
18 allocation between present and future customers?

19 A I don't believe so because of the effect of
20 the uniform rate, if the uniform rate is applied.
21 That is the intention of the uniform rate.

22 Q Mr. Edmunds, isn't it correct that you have
23 stated that there are basically two components to a
24 water system; that is, the water supply side and then
25 the transmission and distribution piping?

1 A Yes, sir, I believe I did say that.

2 Q And when you were asked how an ultimate
3 build-out flow of 4,300 GPMs could be a valid output
4 in a hydraulic analysis when there was only 500 GPMs
5 supplied, you stated that you needed to look at the
6 two components separately; isn't that correct?

7 A Yes.

8 Q And further, you stated that the
9 distribution piping -- you stated that distribution
10 piping is installed for its ultimate sizing so that
11 the utility would not need to dig up streets every
12 year, every two years, et cetera; is that correct?

13 A That is the usual practice, yes.

14 Q With respect to the water supply component,
15 you said that it can be expanded more incrementally
16 or it can be expanded incrementally more easily, did
17 you not?

18 A Yes.

19 Q Would that be like adding another well or
20 storage?

21 A Yes.

22 Q Did you also say that as the water supply
23 increases, for example, you incrementally expanded
24 the water supply, that the pipe flows generally go
25 up?

1 A Yes.

2 Q Okay. So, are you aware that the utility
3 compared, SSU in this proceeding, that the utility
4 compared the flows in the pipe today with today's
5 water supply calling that the numerator, and then
6 compared it to the flows in the pipes at buildout
7 with today's water supply, calling that the
8 denominator, to derive the used and useful ratio?

9 A I don't know that I am aware that they
10 assume there would be no expansion to the water
11 supply, but that would be the appropriate way to
12 determine used and useful for the distribution
13 component.

14 Q Would you accept my statement of the
15 methodology subject to check?

16 A I'm willing to for hypothetical purposes.
17 As I also said, that would be the appropriate
18 methodology for determining used and useful for the
19 distribution component.

20 Q If the Commission were to accept hydraulic
21 modeling, the hydraulic modeling methodology, would
22 it not be a better comparison to use today's flows
23 supplied by today's sources compared to build-out
24 flows supplied by sources needed at buildout?

25 A No, because if we are evaluating the used

1 and useful for the distribution component, as I've
2 testified we can divorce our look at the distribution
3 component from our look at the supply component. And
4 we can say on the basis of the assumption that water
5 supply will be provided to meet buildout, what is the
6 pro rata share of today's hydraulic impact on the
7 system relative to the build-out impact on the
8 system.

9 Q But would you not agree that when I add
10 supply to the system that the hydraulics change, the
11 flows change?

12 A I would agree that the flows change, yes.

13 MR. PELLIGRINI: Just a moment, please.

14 MR. FEIL: Madam Chairman, do you know how
15 long we intend to go to this evening?

16 CHAIRMAN CLARK: 8:00 o'clock.

17 MR. FEIL: Thank you.

18 CHAIRMAN CLARK: We will go ahead and take
19 a 20 minute break right now. You can order food or
20 maybe you have it here. I know some commissioners
21 have already gotten their food. We will take until
22 7:00 o'clock. We will reconvene at 7:00.

23 (Brief recess.)

24 CHAIRMAN CLARK: We will reconvene the
25 hearing. Mr. Pelligrini.

1 MR. PELLIGRINI: I would like the court
2 reporter to read back Mr. Edmunds' answer to I
3 believe the last question or two questions ago.

4 COMMISSIONER KIESLING: Charlie, You have
5 to stop talking so she can go back, because she can't
6 write down what you are saying and go back.

7 MR. PELLIGRINI: I'm sorry. That never
8 occurred to me.

9 COMMISSIONER KIESLING: I'm trying to help
10 you out.

11 (The preceding questions were read back.)

12 MR. PELLIGRINI: Thank you.

13 BY MR. PELLIGRINI:

14 Q Mr. Edmunds, would you clarify what you
15 meant by assuming no expansion of the water supply?

16 A If the water supply that is in place today
17 is not sufficient to provide the build-out demands to
18 meet the build-out demands, then that would obviously
19 be a limitation on the future modeling case.

20 What I believe that the utility did was to
21 model today's condition, using today's demand, and
22 the future condition using the future demand in the
23 numerator and denominator.

24 Q I believe that rather than that, the
25 methodology used compared -- used today's supply in

1 both numerator and denominator.

2 MR. FEIL: Are we talking about source of
3 supply, is that the source of the confusion?

4 MR. PELLIGRINI: I'm not sure about that.

5 WITNESS EDMUNDS: I'm not sure what we are
6 talking about here. That would not make any sense.

7 BY MR. PELLIGRINI:

8 Q Well --

9 A What makes sense is that the today's demand
10 is, and the effect of today's demand is the
11 numerator. And it insofar as the future condition
12 where the distribution system -- I'm not dealing with
13 the supply side of the system, I'm dealing with the
14 distribution side of the system -- that is demand
15 driven.

16 The assumption is that supply will be
17 developed to meet the demand of that day. That is
18 always the assumption that is made.

19 Q But what I'm suggesting is that in the
20 comparison of today's conditions to build-out
21 conditions, for today's conditions the present source
22 of supply should be considered; and for build-out
23 conditions, the necessary supply to meet the
24 build-out conditions should be considered.

25 A It doesn't matter when we are talking about

1 the distribution facilities, because the assumption
2 is always made that supply will be provided to
3 satisfy the demands.

4 Q The difficulty we have with that,
5 Mr. Edmunds, is that as supply increases, the
6 hydraulics of the system changes, the flows change.

7 A Of course. Why is that a problem? I mean,
8 if the flows don't change then the system is at
9 buildout and it is 100 percent used and useful now,
10 so, by anybody's definition.

11 Q We think that unless that consideration is
12 taken into account that the comparison is really an
13 inconsistent one and apparently you don't agree?

14 A I don't agree. The reason that I don't
15 agree is that when a system is initially or when a
16 network is initially designed, the ultimate location
17 of all future sources supply is assumed as part of
18 the, as part of the analysis, or can be assumed, or
19 can be assumed when the evaluation of the ultimate
20 build-out situation is prepared.

21 And so, yes, it is true that the flows do
22 change as the network evolves and grows to maturity.
23 But assumptions are always made either at the time of
24 design or the time that the future, that the future
25 network is being modeled concerning the sources of

1 supply.

2 Now, from a global standpoint, if the
3 source of supply is at one location in the system or
4 at another location in the system, the sensitivity of
5 the used and useful number would not be that great
6 under most circumstances as the source of supply, the
7 location of supply changes.

8 MR. PELLIGRINI: We have no further
9 questions. Thank you, Mr. Edmunds.

10 CHAIRMAN CLARK: Thank you.
11 Commissioners?

12 COMMISSIONER DEASON: I have a question.
13 Mr. Edmunds, I believe before we took the break, in
14 response to a question in Mr. Pelligrini you
15 indicated that you did not believe there would be an
16 unfair allocation between existing and future
17 customers if the uniform rate structure is adopted.
18 I think his question was in relation to utilization
19 of the hydraulic model. Do you recall that
20 question?

21 WITNESS EDMUNDS: Yes, sir, I believe I
22 do.

23 COMMISSIONER DEASON: My question is what
24 if the Commission adopts a stand alone rate
25 structure? Would there be then an unfair allocation

1 between existing and future customers?

2 WITNESS EDMUNDS: Between existing and
3 future customers, or between customers in different
4 networks?

5 COMMISSIONER DEASON: Well, as I understand
6 his question, my notes may be incorrect, I thought
7 his original question was in relation to existing and
8 future customers in the sense that use of the
9 hydraulic model would be allocating more to existing
10 customers than the traditional lot count method.

11 WITNESS EDMUNDS: Yes.

12 COMMISSIONER DEASON: I think that was the
13 nature of his question. And you said, no, there
14 would not be an unfair allocation, but you put the
15 caveat on that answer, assuming a uniform rate
16 structure.

17 WITNESS EDMUNDS: Yes.

18 COMMISSIONER DEASON: My question is, what
19 if there is going to be a stand-alone rate.

20 WITNESS EDMUNDS: If there was a
21 stand-alone rate structure with no cap, in other
22 words, no modification, there is the potential for,
23 depending upon the physical setting, for there to be
24 an unfair rate allocation. There is the potential.
25 And that might have to be dealt with on a

1 case-by-case basis or a network-by-network basis.

2 COMMISSIONER DEASON: Thank you.

3 CHAIRMAN CLARK: Redirect?

4 REDIRECT EXAMINATION

5 BY MR. FEIL:

6 Q I just have one question. Mr. Edmunds,
7 when Mr. Twomey was questioning you he referred to a
8 Volume 6, Book 2 of 2, and did not show you the
9 volume. He just recited the number. I would like to
10 show this to you and have you answer the question of
11 whether or not you've seen this volume before.

12 A Yes, sir. In answer to your question, I
13 have seen this. I have not reviewed it in great
14 detail. I have glanced through it and I've looked at
15 some of the summary pages.

16 Q But you know it to be the hydraulic
17 analysis in used and useful tabulations?

18 A Yes, sir.

19 MR. FEIL: Nothing further.

20 CHAIRMAN CLARK: Thank you, Mr. Edmunds.

21 Exhibits?

22 MR. FEIL: SSU moves Exhibit 98.

23 MR. TWOMEY: 99.

24 CHAIRMAN CLARK: Without objection Exhibit
25 98 and 99 will be entered in the record.

1 (Exhibit Nos. 98 and 99 admitted.)

2 CHAIRMAN CLARK: Mr. Elliott. Thank you,
3 Mr. Edmunds. You are excused.

4 **JAMES P. ELLIOTT**

5 was called as a witness on behalf of Southern States
6 Utilities and, having been previously duly sworn,
7 testified as follows:

8 CHAIRMAN CLARK: Go ahead, Mr. Feil.

9 **DIRECT EXAMINATION**

10 BY MR. FEIL:

11 Q Mr. Elliott, you have been sworn in;
12 correct?

13 A That's correct.

14 Q Would you please state your name and
15 business address for the record.

16 A James Paul Elliott. My business address is
17 1334 Lafayette Street in Cape Coral, Florida.

18 Q Are you the same James P. Elliott for whom
19 prefiled direct testimony was filed in this case
20 consisting of six pages?

21 A That's correct.

22 Q Do you have any changes or corrections to
23 that prefiled testimony?

24 A No, I do not.

25 Q If I asked you the questions asked in the

1 prefiled direct testimony today would your answers be
2 the same?

3 A They would.

4 MR. FEIL: I ask that Mr. Elliott's
5 prefiled direct testimony be inserted in the record
6 as though read.

7 CHAIRMAN CLARK: The prefiled direct
8 testimony of Mr. James Elliott will be inserted in
9 the record as though read.

10 (The Prefiled Direct Testimony of James P.
11 Elliott was inserted in the record as follows:)

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DIRECT TESTIMONY OF JAMES P. ELLIOTT
BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
ON BEHALF OF
SOUTHERN STATES UTILITIES, INC.
DOCKET NO. 950495-WS

1 Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

2 A. James P. Elliott, 1334 Lafayette Street, Cape Coral, Florida 33904.

3 Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?

4 A. I am employed by Source, Inc., an engineering and planning firm, as
5 President.

6 Q. PLEASE DESCRIBE YOUR EDUCATIONAL AND PROFESSIONAL
7 BACKGROUND?

8 A. I am a graduate engineer with a Bachelor of Science degree in Civil
9 Engineering from Kansas State University in 1968. I am a registered
10 Professional Engineer in Florida and Illinois. Prior to founding Source,
11 Inc. in 1979, I was employed for four years with Black Crow and
12 Eidness/CH2M Hill ("CH2M Hill") in Gainesville, Florida. At CH2M
13 Hill, I was the Construction Service Manager for a wide variety of Florida
14 projects. Prior to joining CH2M Hill, I worked for Greeley and Hansen
15 in Chicago for five years as a design engineer, project manager, and
16 resident engineer.

17 Q. ARE YOU A MEMBER OF ANY PROFESSIONAL SOCIETIES OR
18 AFFILIATIONS?

19 A. Yes. I am a member of the American Society of Civil Engineers,
20 American Water Works Association, Florida Engineering Society, National
21 Society of Professional Engineers, Water Environment Federation,
22 American Desalting Association and the Southeast Desalting Association.

1 **Q. HAVE YOU PREVIOUSLY TESTIFIED BEFORE THE FLORIDA**
2 **PUBLIC SERVICE COMMISSION OR ANY OTHER**
3 **REGULATORY BODY?**

4 A. Yes. I testified in three administrative hearings relating to Florida
5 Department of Environmental Protection (then the Department of
6 Environmental Regulation) permitting issues. I also testified before the
7 Commission on behalf of Southern States in Docket No. 920655-WS.

8 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

9 A. I support Southern States' proposal to use the hydraulic flow method to
10 determine the used and useful capacity of the water transmission and
11 distribution lines and the maximum day flow from 1994 to determine the
12 used and useful capacity of supply and treatment facilities. I also support
13 the Company's proposal to use two service classifications for water service
14 -- conventional treatment and reverse osmosis treatment.

15 **Q. COULD YOU EXPLAIN WHY THE USE OF THE HYDRAULIC**
16 **FLOW METHOD IS JUSTIFIED FOR WATER TRANSMISSION**
17 **AND DISTRIBUTION LINES?**

18 A. Use of the hydraulic flow method to determine the used and useful
19 capacity of water transmission and distribution lines is justified primarily
20 because the hydraulic flow method is used to design those facilities. I
21 have designed facilities for private as well as governmental utilities and,
22 without exception, I have used the hydraulic flow method to design the

1 capacities and configuration of transmission and distribution lines. The
2 hydraulic flow method not only is most reasonable to use because it is the
3 method used to design such facilities but it also is the most accurate means
4 of simulating the hydraulic capacity being used in the distribution system.
5 A lot count method for determining the used and useful capacity has no
6 basis in reality. It is beyond dispute that flows are determined more by the
7 type of customer being served, the personal water consuming habits or
8 needs of the people being served, the irrigation requirements, the number
9 of people in each household and a number of other factors than from a
10 simplistic determination of lots platted versus lots connected. Therefore,
11 I believe the Commission's current practice is overly simplistic and bears
12 no relationship to reality. As an engineer, I cannot accept it as a valid
13 flow measurement or projected flow measurement technique. In contrast,
14 the hydraulic flow method is rooted in reality and precision.

15 **Q. COULD YOU EXPLAIN WHY YOU BELIEVE THE USE OF THE**
16 **MAXIMUM DAY FLOW IS THE MOST REASONABLE MEANS OF**
17 **DETERMINING THE USED AND USEFUL LEVEL OF WATER**
18 **SUPPLY AND TREATMENT FACILITIES?**

19 **A.** When designing water supply and treatment facilities, an engineer must
20 utilize the maximum day demand projections as the basis for his or her
21 design. To use any other basis would be a dereliction of the professional
22 engineer's obligation and responsibilities. Since the maximum day criteria

1 is the basis for designing the facilities, it appears to me to be unreasonable
2 to measure the used and useful level of the facilities using any
3 measurement other than the maximum day criteria.

4 **Q. IS A PROFESSIONAL ENGINEER REQUIRED TO CONSIDER**
5 **POTENTIAL FIRE FLOW DEMANDS WHEN DESIGNING WATER**
6 **SUPPLY, STORAGE, TREATMENT AND DISTRIBUTION**
7 **FACILITIES?**

8 A. Yes. A professional engineer must design water supply, storage, treatment
9 and distribution facilities to accommodate fire flow requirements in
10 addition to residential and other water needs which may exist. Therefore,
11 I believe that actual fire flows which may have been experienced in a
12 maximum day should be included for purposes of determining the used
13 and useful levels of these facilities.

14 **Q. DO YOU BELIEVE THAT IT WOULD BE REASONABLE TO**
15 **EXCLUDE FROM MAXIMUM DAY FLOWS THE AMOUNT OF**
16 **WATER LOST TO WATER MAIN BREAKS, FOR EXAMPLE, FOR**
17 **USED AND USEFUL PURPOSES?**

18 A. No, I do not. Water main breaks and other occurrences such as line
19 flushing, fire incidence and fire department use are expected, ordinary
20 occurrences for all water facilities. As such, if the facilities experience
21 such occurrences and nevertheless continue to meet the water needs of
22 customers served by them, I see no reason to exclude volumes of water

1 lost to such occurrences for purposes of calculating the facilities' used and
2 useful levels and, in fact, for this reason I believe it would be unreasonable
3 to do so.

4 **Q. COULD YOU EXPLAIN WHY YOU AGREE WITH SOUTHERN**
5 **STATES' DIVISION OF WATER CUSTOMERS INTO SEPARATE**
6 **SERVICE CLASSIFICATIONS DEPENDING UPON WHETHER**
7 **THEY ARE SERVED BY CONVENTIONAL OR REVERSE**
8 **OSMOSIS WATER TREATMENT FACILITIES?**

9 A. I agree that the classification of customers into two groups based on
10 whether the customers are served by conventional or reverse osmosis water
11 treatment facilities is appropriate because the existence of reverse osmosis
12 facilities confirms that the customers are served by brackish water supplies.
13 Brackish water, without exception, must be treated, at minimum, by
14 reverse osmosis facilities which undeniably are the most expensive
15 treatment methods available other than facilities treating seawater. The
16 existence of brackish water is evidence that the fresh water supplies
17 previously had been consumed to such an extent that treatment of brackish
18 water became necessary. It appears logical that one of the indirect benefits
19 of the division into conventional and reverse osmosis service classifications
20 would be to dissuade customers currently served by conventional treatment
21 facilities from consuming water in quantities which would hasten the
22 deterioration of the supply source to brackish water and thus the need for

1 higher cost reverse osmosis facilities as well as the corresponding higher
2 rates proposed by Southern States.

3 **Q. DOES THAT CONCLUDE YOUR TESTIMONY?**

4 **A. Yes, it does.**

1 BY MR. FEIL:

2 Q Mr. Elliott, you had no exhibits attached
3 to your prefiled direct?

4 A That's correct, I did not.

5 Q Mr. Elliott, you also had prefiled rebuttal
6 testimony filed in this case consisting of eight
7 pages; is that correct?

8 A That's correct.

9 Q Do you have any changes or corrections to
10 that prefiled rebuttal testimony?

11 A No, I do not.

12 Q If I ask you the questions in the prefiled
13 rebuttal testimony today, would your answers be the
14 same to those questions?

15 A They would be, yes.

16 MR. FEIL: I ask that Mr. Elliott's
17 prefiled rebuttal testimony be inserted in the record
18 as though read.

19 CHAIRMAN CLARK: Mr. Elliott's prefiled
20 rebuttal testimony will be inserted in the record as
21 though read.

22 (Prefiled Rebuttal Testimony of James P.
23 Elliott was inserted as follows:)

24

25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

REBUTTAL TESTIMONY OF JAMES P. ELLIOTT
BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
ON BEHALF OF
SOUTHERN STATES UTILITIES, INC.
DOCKET NO. 950495-WS

1 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

2 A. James P. Elliott, 1334 Lafayette Street, Cape
3 Coral, Florida 33904.

4 **Q. ARE YOU THE SAME JAMES P. ELLIOTT WHO PROVIDED**
5 **DIRECT TESTIMONY IN THIS PROCEEDING?**

6 A. Yes.

7 **Q. WHAT IS THE PURPOSE OF YOUR REBUTTAL TESTIMONY?**

8 A. The purpose of my testimony is to rebut certain
9 portions of the direct testimony of Office of
10 Public Counsel ("OPC") witness Mr. Ted L. Bidy and
11 Sugar Mill Woods Civic Association ("SMWCA")
12 witness Mr. Buddy L. Hansen. Specifically, I will
13 rebut some of the arguments made by these witnesses
14 on the subject of SSU's hydraulic modeling
15 analysis.

16 **Q. DO YOU AGREE WITH MR. BIDDY'S ARGUMENT THAT**
17 **HYDRAULIC MODELING SHOULD BE REJECTED BECAUSE IT IS**
18 **"UNDULY COMPLICATED" AND AN "UNNECESSARY BURDEN"?**

19 A. No, I do not. Today, hydraulic modeling is an
20 everyday tool used by engineers for design purposes
21 as well as other purposes. The computer software
22 necessary for modeling is standard office equipment
23 for most engineering firms. I would assume Mr.
24 Bidy has hydraulic modeling capability in his
25 office, as I do, and it is my understanding that

1 the Commission staff also has Cybernet software
2 available for its use. To effectively regulate
3 water and wastewater utilities, the Commission must
4 refer to and rely on sound engineering principles
5 and practices. It therefore makes little sense for
6 the Commission to reject out-of-hand an accepted
7 engineering tool of commonly available technology
8 as Mr. Bidy recommends.

9 Mr. Bidy supports his opinion that hydraulic
10 modeling is too complicated by arguing that used
11 and useful should be a cost allocation technique,
12 not related to utility engineering. This rationale
13 should be rejected on its own merit for the reasons
14 Mr. Hartman has already enumerated at length and
15 because Mr. Bidy is inexplicably inconsistent in
16 his views. The Commission should note that
17 throughout his testimony, Mr. Bidy makes a number
18 of recommendations whereby used and useful
19 evaluations parallel his perception of proper
20 engineering considerations. Yet, he recommends
21 that engineering considerations be ignored for
22 transmission and distribution facilities. Mr.
23 Bidy states that hydraulic modeling will
24 unnecessarily complicate used and useful, yet he
25 advocates a very detailed used and useful

1 partitioning of every water well, every treatment
2 unit, every pump, every hydropneumatic tank, every
3 storage facility, every auxiliary power generator,
4 every square foot of land -- every nut and bolt the
5 utility invested in -- all according to his
6 perception of which fragments are needed to provide
7 service. I do not think the hydraulic models filed
8 in this case are more complicated than the other
9 used and useful evaluations the Commission will be
10 asked to make in this case.

11 In addition, contrary Mr. Bidby's assertion, I
12 do not believe the economic feasibility for other
13 utilities to use a hydraulic model to evaluate used
14 and useful is relevant in this case. This case
15 involves SSU and its hydraulic models, not other
16 utilities. Besides, for the reasons I have already
17 indicated, I think it very advisable for investor-
18 owned utilities of suitable size to make use of
19 hydraulic models for designing and evaluating
20 facilities, as well as for used and useful
21 analyses. By accepting SSU's hydraulic used and
22 useful analyses, the Commission does not force
23 every last one of the utilities it regulates to use
24 hydraulic models to evaluate used and useful for
25 transmission and distribution facilities, as Mr.

1 Biddy seems to believe. Each situation must be
2 evaluated on its own merits. And regardless of Mr.
3 Biddy's unfounded concern for other cases, the
4 simple fact of the matter is that the hydraulic
5 method SSU has proposed in this case is vastly
6 superior to the illogical and inherently flawed
7 lot-count method, as a number of SSU witnesses have
8 already explained.

9 **Q. DO YOU AGREE WITH MR. BIDDY'S AND MR. HANSEN'S**
10 **ARGUMENTS THAT THE HYDRAULIC ANALYSIS METHOD IS AN**
11 **UNREASONABLE WAY TO ALLOCATE COSTS TO CURRENT**
12 **CONNECTIONS?**

13 A. No. As a starting point for my comments, I think
14 one of Mr. Hansen's statements may serve to bring
15 the issue more into focus. Beginning at line 24 of
16 page 28 of his testimony, Mr. Hansen asks how SSU
17 could serve more customers at Pine Ridge if the
18 Pine Ridge transmission and distribution facilities
19 are 100% used and useful according to the hydraulic
20 analysis. Mr. Hansen's statement illustrates the
21 distorted perception the lot-count method, or any
22 other used and useful method, produces when viewed
23 exclusively as a crude point-in-time measuring
24 stick instead of being viewed as an evaluation of
25 needs and uses. To illustrate what a crooked

1 measuring stick the lot-count method is, one need
2 only consider that in a service area where the
3 distribution piping is sized just large enough to
4 meet the needs of the current connections, and
5 where additional connections may impair service to
6 current connections, the distribution facilities
7 would still not be 100% used and useful because not
8 all lots are receiving service. In such a
9 situation, the utility might even be penalized for
10 not being able to provide service to additional
11 connections. SSU would therefore like to know how
12 properly-sized lines cannot be 100% used and useful
13 when those lines are used and needed to provide
14 service to customers notwithstanding any ability to
15 serve additional connections.

16 In the way of analogy, I would point out that
17 auxiliary power generators are not put to their
18 full use at all times, yet by the Commission's
19 order in SSU's last case and by staff's May 1995
20 draft used and useful rules, auxiliary power
21 generators, as well as hydropneumatic tanks and
22 disinfection facilities among others, are properly
23 be considered 100% used and useful. Again, a
24 properly-sized facility which is needed and used to
25 provide service should be 100% used and useful. I

1 don't use my car to its fullest by driving it 24
2 hours a day. But I still need the whole car to get
3 me around -- a fraction of a car would not do me
4 much good. I could use the car more often if I
5 needed to. And, of course, I still have to make my
6 entire car payment no matter how much I use the
7 car.

8 Current connections should pay at least for
9 that portion of the transmission and distribution
10 facilities which those connections utilize. SSU
11 used a hydraulic analysis to assess what current
12 connections utilize, including what is needed to
13 provide current connections fireflow. Mr. Biddy
14 states that the lot-count method allocates to
15 current connections a portion of the costs
16 associated with sizing lines to provide fireflow.
17 However, the lot-count method allocates to current
18 connections only a fraction of the actual capacity
19 which the existing lines must have available to
20 provide fireflow to those connections. Under the
21 lot-count method, current connections would not
22 have to pay the cost of sizing lines to provide
23 them with fireflow unless and until the service
24 area was completely built-out, despite the fact
25 that the utility's lines, just like its wells,

1 pumps, and storage facilities, must be capable of
2 providing current connections with the same amount
3 of fireflow it must provide all connections at
4 build-out. Thus, Mr. Bidy's proposal is not only
5 incorrect because current connections would not pay
6 the costs of providing them fireflow under the lot-
7 count method, but Mr. Bidy is inconsistent because
8 he recommends that if a utility can provide
9 fireflow, current connections should pay the full
10 cost of sizing wells, pumps, and storage to meet
11 fireflow for a built-out service area, but not
12 distribution facilities for a built-out service
13 area.

14 Any relationship between potable demand and
15 fireflow is site specific and will vary to some
16 degree between current and build-out conditions for
17 those components needed to provide fireflow. Total
18 fireflow requirements, however, must be met with
19 the first building even though the total potable
20 demand capacity is not realized until the last
21 building is occupied. It is simply unreasonable to
22 put SSU in a position where it has been required by
23 local codes and ordinances to follow minimum line
24 size, looping, and fireflow criteria based on
25 building classifications without providing a

1 mechanism for recovering the costs for compliance.

2 **Q. DOES THAT CONCLUDE YOUR TESTIMONY?**

3 A. Yes, it does.

1 BY MR. FEIL:

2 Q Mr. Elliott, you had no exhibits attached
3 to your prefiled rebuttal testimony, as well?

4 A That's correct.

5 Q Do you have a prepared summary of prefiled
6 direct and prefiled rebuttal?

7 A I do.

8 Q Could you please read from those summaries,
9 please?

10 A Yes. Some of this will be redundant from
11 the previous witnesses, but I support SSU's use of
12 hydraulic flow method for the used and useful
13 capacity determinations for water transmission and
14 distribution lines, as well as the use of maximum
15 daily flows to determine the used and useful capacity
16 of supply and treatment facilities.

17 I also support Southern States proposal for
18 two water treatment classifications being
19 conventional and reverse osmosis types.

20 The hydraulic flow modeling method for used
21 and useful determination is justified, as this is the
22 method used for engineering, planning and design.
23 The hydraulic flow analysis method is by far the most
24 accurate method simulating pipeline capacity, which
25 accounts for the consuming habits, needs of people

1 served, irrigation requirements, and fire flow. And
2 all this is in contrast to the simplistic lot count
3 method.

4 Lot count method has no relationship to
5 reality. I cannot accept the lot count method as a
6 flow measurement technique. The maximum daily flow
7 must be used when designing facilities. It is
8 unreasonable to expect the utility's engineers to use
9 flow factors other than maximum daily flow, which is
10 a design convention.

11 Fire flow statements here, as professional
12 engineers we are obligated to design water supply
13 treatment, storage, transmission, and distribution
14 facilities to accommodate fire flow, in addition to
15 residential consumption and other needs that may
16 exist. All flows must be included in the used and
17 useful levels of those facilities.

18 On the existence of reverse osmosis, the
19 existence of reverse osmosis water plant indicates
20 the available water supply is brackish, such that an
21 expensive treatment method process is required, as
22 compared to conventional treatment processes that
23 treat basically water from a potable quality
24 supplies. The use of brackish water implies that
25 fresh water may have been depleted.

1 That ends my summary from my direct.

2 Q Could you please proceed with the summary
3 from your rebuttal?

4 A Yes. The purpose of my testimony to rebut,
5 is to rebut the arguments made by Mr. Bidy and
6 Mr. Hansen regarding the use of hydraulic modeling.
7 Hydraulic modeling is used as an everyday tool by
8 utility engineers for planning and design purposes.

9 Software for hydraulic modeling is standard
10 office equipment for most firms. I understand
11 Cybernet modeling is available to the Commission
12 staff. Used and useful determinations should not be
13 solely a cost allocation technique, as it has no
14 basis in reality as compared to the piping
15 functions.

16 Mr. Bidy presents a detailed used and
17 useful partitioning for every well, treatment unit,
18 hydropneumatic tank, storage tanks, and auxiliary
19 powered generators, but not for transmission and
20 distribution lines.

21 I feel the hydraulic modeling filed in this
22 case, the models are not more complicated than other
23 use and usefulness evaluations presented for the
24 consideration of the Commission.

25 The hydraulic modeling analysis best

1 simulates the actual flow behavior that accounts for
2 existing use, fire flow irrigation demands, et
3 cetera, yet allows for the future customers due to
4 design considerations primarily of looping.

5 The lot count method, by contrast, is a
6 crude linear point in time measuring stick. All
7 required facilities must be considered 100 percent
8 used and useful, same as auxiliary power generation
9 facilities, hydropneumatic tanks and disinfection
10 facilities.

11 Properly-sized facilities needed and used
12 to provide service should be a hundred percent used
13 and useful. As an example, I don't use my car 24
14 hours a day, but I still need the whole car. The car
15 is available certainly for more use; and of course, I
16 have to make my car payments every month regardless
17 of that use.

18 Current connections should pay for at least
19 that portion of the transmission and distribution
20 facilities they utilize, including fire flow. The
21 flaw in the lot count method is the current
22 connections do not pay for fire flow, unless and
23 until the facilities are at buildout.

24 Mr. Bidy is inconsistent in that he
25 recommends current connections pay the full cost of

1 wells, pumps and storage for fire flow for a
2 build-out service area. Total fire flow must be
3 available with the first building, even though the
4 total potable demand is not realized until the last
5 lot is occupied, the last building is occupied.

6 It is totally unreasonable to put SSU in a
7 position where it is required by local codes to
8 follow minimum line sizing, looping, and fire flow
9 criteria based on building classifications without
10 providing a means of assuring recovery with the cost
11 of compliance. That ends my --

12 Q That concludes your summary?

13 A Yes.

14 MR. FEIL: Thank you, sir. Tender for
15 cross.

16 CHAIRMAN CLARK: Mr. Riley.

17 **CROSS EXAMINATION**

18 BY MR. RILEY:

19 Q Mr. Elliott, just a few questions for you
20 this evening. I could direct your attention to Page
21 4 of your prefiled direct, lines 8 and 9. You state
22 a professional engineer must design water supply,
23 storage, treatment and distribution facilities to
24 accommodate fire flow requirement; is that correct?

25 A That's correct.

1 Q Is it your testimony that water supply and
2 treatment alone should meet fire flow requirements
3 when fire storage does not exist?

4 A Could you repeat that question, please?

5 Q Is it your testimony that water supply and
6 treatment alone should meet fire flow requirements
7 when fire storage does not exist?

8 A I would say in the cases I heard
9 Mr. Hartman elaborated on.

10 Q The answer is yes?

11 A Yes.

12 Q Would there be instances when you wouldn't
13 think it would be appropriate to size supply and
14 treatment sufficient to meet fire flow needs?

15 A I would say yes, if you are in an aquifer
16 that provides that utilization. In my area of
17 Florida that is not a very typical case.

18 Q Is the reason for that, that it is an
19 extremely -- it is not at all a cost-effective way of
20 meeting the fire flow demand; is that correct?

21 A What is not?

22 Q Meeting the fire flow through supply and
23 treatment as opposed to storage.

24 A It depends on the circumstance of the
25 system and the aquifer and several other factors.

1 Q Could you elaborate?

2 A For example, some systems in northern
3 Florida where you might have the Florida aquifer, and
4 I think Mr. Hartman alluded to some examples in Duval
5 County and Jacksonville where they yielded to the
6 aquifer. He was equating the aquifer of being the
7 reservoir. In those cases it would be quite, it
8 would be much more economical to provide that flow
9 through the aquifer system and the pumping system.

10 Q So in South Florida it would not be
11 appropriate?

12 A Again, it depends on the circumstances of
13 the aquifer, the size of the system, and probably
14 several other factors.

15 Q But generally speaking it might not be
16 appropriate in that area of the state?

17 A Again, I would have to say that it depends
18 on the aquifer. I'm not familiar with all the areas
19 of the state, but I would say in Lee County, in most
20 portions of Lee County, that is probably not a
21 potential because of the circumstance of the
22 aquifer.

23 Q Isn't it correct that fire flow should come
24 from storage or high service pumping when elevated
25 storage is not available?

1 A I'm not aware of -- could you repeat the
2 question, please?

3 Q The question is do you believe it is
4 correct that fire flow should come from storage or
5 high service pumping when elevated storage is not
6 available?

7 A I would say that is probably most often the
8 case in design we do these days. We are providing
9 the flow from grounds storage reservoirs if you don't
10 have an aquifer capable of doing that.

11 Q Could I have you turn back to Page 3 and
12 look at lines 19 and 20 on that page. This is your
13 prefiled direct.

14 A Yes.

15 Q You state that an engineer must utilize the
16 maximum day demand projections. This is I guess in
17 reference to water again, supply and treatment. As
18 you stated, the engineers must use maximum day demand
19 projections in design. But my question is that
20 projection does not include fire fighting, main
21 breaks, and line leaks; is that correct? That
22 projection of max day does not include fire fighting,
23 main breaks and line leaks?

24 A It would depend whether you are talking
25 about historical data that you have collected and

1 known events, or if it is a case where you are
2 talking about design, whether you are projecting a
3 maximum day and a new design.

4 Q I think we are talking about design,
5 maximum daily flow.

6 A Yes. I think that the answer is that
7 maximum day demand projections would not include fire
8 flow.

9 Q Or those other?

10 A Pardon me?

11 Q Or the other two I mentioned, main breaks
12 and line leaks?

13 A No.

14 Q If the maximum day flow already includes
15 unaccounted for water, would you still include fire
16 fighting and main breaks in design?

17 A I would in design of storage facilities.
18 Again, that depends on the aquifer and the
19 circumstance of supply.

20 Q One other question. When Mr. Feil was
21 posing some redirect questions to Mr. Hartman, I
22 believe he asked him concerning what the regulatory
23 requirements were for, and I use the term single max
24 day.

25 And I'm not sure whether that was just a

1 slip or a term of art that he was using; but of
2 course, we understand a lot of the requirements have
3 used the term max day flow. As you understand, there
4 are those of us who believe the more appropriate
5 representation of max day is this by average of the
6 five max days.

7 Can you share with me your understanding of
8 any governmental regulation or DEP rule that would
9 require a single max day flow as opposed to just the
10 max day flow?

11 A I can't site the rule specific, but DEP
12 requires that you use the max day. I don't recall of
13 any circumstance where they call for the average of
14 five days. We are always lead to the standards and a
15 lot of local ordinances, for example. I looked at
16 Collier, Lee and the City of Naples. They all
17 reference to maximum day.

18 Q Max day.

19 A That's what we have to design to.

20 Q So you can't share with this Commission any
21 regulatory requirement that uses that extra word that
22 was put in that question; is that correct?

23 A No, that's not a familiar word to me.

24 MR. RILEY: Okay. That concludes our
25 questions.

1 CHAIRMAN CLARK: Mr. Twomey.

2 MR. TWOMEY: Yes, Madam Chairman, thank you.

3 CROSS EXAMINATION

4 BY MR. TWOMEY:

5 Q Mr. Elliott, if I were to ask you all the
6 same questions I asked Mr. Edmunds would your answer
7 be the same?

8 A They might be identical, and I didn't take
9 a course in reasonableness.

10 Q How about common sense?

11 A That either.

12 CHAIRMAN CLARK: Does that conclude your
13 cross examination?

14 WITNESS ELLIOTT: Could I go now?

15 MR. TWOMEY: Not quite.

16 BY MR. TWOMEY:

17 Q But you are a professional registered
18 engineer.

19 A That's correct.

20 Q A registered professional engineer.

21 A Yes, in Florida and Illinois.

22 Q Okay, sir. I want to ask you to look at
23 Exhibit 99, which I hope Mr. Edmunds didn't cart off
24 with him.

25 A I don't have it or see it here.

1 Q Before you examine it, because you don't
2 need to look at the whole thing, let me ask you,
3 throughout your testimony you referred to, for
4 example, at Page 2, line 22, I have used the
5 hydraulic flow method to design?

6 A Is this in my direct?

7 Q Direct, I'm sorry. I won't ask you any
8 questions on your rebuttal.

9 A Page two.

10 Q Page 2, line 22. You say I've used the
11 hydraulic flow method to design the capacities and
12 configuration and transmission and distribution
13 lines, right?

14 A That's --

15 Q I'm sorry.

16 A No. Finish the question.

17 Q Well, that's correct, right, you say
18 design?

19 A Yes.

20 Q And line 3, Page 3, you say used that
21 method to design such facilities, right? And you
22 used design again a couple other times again
23 throughout your testimony.

24 A Yes.

25 Q My question is, that is your focus, isn't

1 it, that you think it is appropriate to use the
2 hydraulic method in designing systems, right?

3 A That is not the only place that it is used,
4 but as I have referred to design in my testimony,
5 however, that we used it in planning and master
6 planning utilities, preliminary planning, verifying
7 systems in design that will meet the county
8 requirements.

9 Q Engineering requirements?

10 A Engineering requirements, that's correct.

11 Q Okay. Because isn't it true, Mr. Elliott,
12 that you don't either -- you do not claim economic
13 regulatory rate making experience?

14 A No, I do not.

15 Q Okay. I would like to ask you to look at
16 page 120, which should be the third page.

17 A Oh, this.

18 Q I'm sorry, of Exhibit 99.

19 A Yes.

20 Q Now, it is your testimony, is it not, that
21 as a professional engineer you have to design systems
22 using the methodologies employed in the hydraulic
23 model, right?

24 A That's correct.

25 Q Okay. I want to ask you, sir, to look at

1 the system described in Page 120 as Pine Ridge. It
2 is in the third column. And tell me in your
3 professional opinion as a professional engineer how
4 much additional capacity does the Department of
5 Environmental Protection require for Pine Ridge
6 before SSU can add another customer to its existing
7 system?

8 A Could you repeat that question, please?

9 Q Yes, sir. Look at the Pine Ridge system.

10 A I am.

11 Q My question is how much additional capacity
12 in terms of water distribution systems, transmission
13 and distribution, must SSU add by DEP requirement
14 before they can add another single customer to the
15 system?

16 A I'm not familiar with the details of that
17 system, so I would have to -- I wasn't asked to
18 review that.

19 Q Well, okay, fair. Let me ask you this.
20 Doesn't it appear from the analysis reflected here
21 that SSU is claiming that the system is 100 percent
22 used and useful?

23 A That's what it says here, yes.

24 Q Doesn't it stand to reason -- and they are
25 using the Cybernet hydraulic model to make that

1 determination; correct?

2 A That's what it asterisked here, that's what
3 it says.

4 Q Okay. And you support that methodology,
5 correct?

6 A That's correct.

7 Q And my question to you is if the system is
8 now 100 percent used and useful, doesn't common sense
9 say that you have to build some more capacity before
10 you can add additional customers?

11 A I have to look at this case specifically.
12 I haven't had that opportunity, nor was I asked to do
13 that.

14 Q Let me explore that just a little bit
15 more. The system apparently was designed to serve
16 3,828 lots, was it not?

17 A That's what it says here, number of lots.

18 Q It only has connected, when you throw in
19 the one-year margin reserve in 1996 projections, 892
20 connections, right, connected lots?

21 A That's what it says under line 2.

22 Q Okay. And line 4, the calculated
23 percentage is 23.3 percent, right?

24 A That's what it says.

25 Q Okay. Well, help me understand,

1 Mr. Elliott. Do you think that this reflects a
2 situation where SSU really can't add customers and
3 still provide them with adequate service?

4 A Not specifically to this example because
5 they haven't reviewed it, but in a network system,
6 that is entirely possible. Because again, back to my
7 testimony that you have to provide service, it is in
8 context of the service that you are providing these
9 people that in the loop system that it could be
10 integrated throughout that system; and providing fire
11 flow to that very first building, this is a possible
12 scenario. But I'm not saying without reviewing this
13 whether this is absolutely correct. I can endorse
14 the methodology.

15 Q You recognize, don't you, that SSU has only
16 requested the hydraulic model methodology be utilized
17 in four systems of the many that are included in this
18 file, correct?

19 A I'm aware of that, yes.

20 Q And if that is the case, don't we suffer a
21 risk of some sort that there are a lot of other
22 systems out there that SSU has that, because they are
23 having their used and useful calculated on the
24 connected lot method, are on the verge of being
25 populated with excessive numbers of customers; is

1 that a possibility?

2 A I can't really address that. I don't
3 really know what the other systems -- I haven't
4 investigated the other systems. And to that point I
5 would say had there been time, opportunity, money,
6 and everything else available, I'm sure that it would
7 be nice to have modeled all the systems. And maybe
8 in time they will model all the systems.

9 Q It would give them a whole lot more rate
10 base, wouldn't it, Mr. Elliott?

11 A It would be an appropriate rate base
12 because the modeling would be a function of what is
13 actually in the ground, how the pipes actually
14 perform in the field in relation to the design
15 facilities.

16 Q I don't intend to be argumentative, but
17 that didn't answer my question.

18 A Okay. Repeat the question.

19 Q Yes, sir. That would give them a whole lot
20 more rate base, wouldn't it, if they modeled all
21 their systems using the hydraulic model in this
22 case?

23 A Well, again, I'm not familiar with all the
24 systems. And I don't -- I'm not a rate making
25 expert, so I don't know if I can answer that

1 question. You might better ask it of somebody else.

2 Q Okay. Are you aware that SSU apparently
3 took the fire hydrants out of Spring Gardens in
4 Homosassa after it purchased the system, do you have
5 any knowledge of that?

6 A I have no knowledge of that.

7 Q On the subject of the division of SSU's
8 water customers in the separate classifications,
9 depending upon conventional or reverse osmosis water
10 treatment, you endorse that, right?

11 A Yes, I do.

12 Q It appears to me that you endorse it on the
13 basis of operating and maintenance costs, am I
14 correct?

15 A No, I endorse that partly, but partly
16 because of the source of supply. The distinction is
17 saline water versus potable supply, one that is more
18 easily treatable. The distinction is basically the
19 quality of the supply.

20 Q Yes, sir, but doesn't it necessarily follow
21 that the distinction you make from that or one of the
22 distinctions you make from that is that it cost more
23 to treat brackish or saline water than it does to
24 treat non-brackish or saline water?

25 A That's correct.

1 Q And therefore, isn't one of the bases for
2 your adoption of this classification based upon
3 cost?

4 A Correct.

5 Q But it is not total cost of the rates, is
6 it, it is operation and maintenance expense?

7 A That would have to be a component of it.
8 I'm not familiar with the exact operation maintenance
9 expense, but it is definitely more treatment. I mean
10 it is more treatment intensive, equipment intensive.
11 Then there is also a regulatory element to it that
12 you have in -- in reverse osmosis you have a unique
13 feature that you have to comply with the industrial
14 waste charge requirements which greatly increases the
15 cost depending on what is available for disposal.

16 Q Yes, sir. My question to you is if I could
17 show you a standard or traditional treatment, non-
18 saline water plant whose total revenue requirement,
19 that is total of all of its associated cost, was more
20 expensive than a reverse osmosis plant, would your
21 endorsement of the division remain the same?

22 A I'm not sure. I would have to study -- I'm
23 not sure what you are talking about. I know that in
24 my experience and in southwest Florida and I think
25 two plants are within my area, that I've reviewed

1 them both, you know, Marco Island and Burnt Store.
2 And I was involved in the design and permitting of
3 Burnt Store. I know that is a lot more expensive
4 than a conventional treatment process from potable
5 supply.

6 Q Yes, sir, but my point is this, do you
7 understand economic regulation sufficiently well to
8 understand the concept of contribution in aid of
9 construction?

10 A Contribution in aid of construction? I've
11 heard the term, I'm not real familiar with that.

12 Q Do you know the effect that the
13 relationship that contribution in aid of construction
14 has on a utility's rate base, and therefore its
15 investment base?

16 A I'm not familiar with that.

17 Q Okay. Wouldn't it be -- well, let me ask
18 you this. You say Page 5, line 18, it appears
19 logical that one of the indirect benefits of the
20 division into conventional and reverse osmosis
21 service classifications would be to dissuade
22 customers currently served by conventional treatment
23 facilities from consuming water in quantities which
24 would hasten the deterioration of the supply source
25 of brackish water, and thus the need for higher cost

1 reverse osmosis facilities, as well as the
2 corresponding higher rates proposed by Southern
3 States.

4 Let me ask you first, did you write that or
5 did someone else write it for you?

6 A I wrote that. In our area we are probably
7 tuned in, this may not have been case specific, but
8 more of a local issue of salt water intrusion. It
9 obviously wouldn't apply to customers in the northern
10 part of Florida, the middle of Florida, because that
11 is not an issue, but it is an issue in our area.

12 Q Help me understand. Why do you think this
13 classification into two entities, two classes would
14 dissuade customers from using more water? What
15 mechanism would derive that?

16 A Well, the cost.

17 Q You mean supply and demand or just cost?

18 A Just cost. Your rates, the cost -- for
19 example, if you were in Lee County and you are
20 comparing utilities and you were aware that you had,
21 if you used up all the potable water, that you would
22 end up with a reverse osmosis process, for example,
23 for demineralizing the water, that you would be
24 paying a lot higher rate.

25 Q You are saying it is the price signal that

1 would be sent that would dissuade people from using
2 more?

3 A I don't know that is a big issue. That was
4 a statement in my direct testimony.

5 Q Yes, sir, but it is part of your
6 testimony. I wanted to ask you, if I could show you
7 that some of the customers using standard treatment
8 didn't get the proper price signal because their
9 rates were supported by subsidies, would that change
10 your view on this?

11 A I don't believe so. That wouldn't change
12 my view, not in the context that my testimony is
13 presented.

14 Q It is your testimony that if prices were
15 modified by subsidies, that is the prices were made
16 to be less than their true cost, that this wouldn't
17 affect your conclusion?

18 A That's outside of my area, I don't -- I
19 guess I'm not connecting with your question.

20 MR. TWOMEY: That's all I have.

21 CHAIRMAN CLARK: Staff.

22 **CROSS EXAMINATION**

23 BY MR. PELLIGRINI:

24 Q Good evening, Mr. Elliott.

25 A Good evening.

1 Q I want to take you back to your deposition
2 of January 11, 1996. Do you have a transcript
3 available?

4 A I'm not sure. Just a minute. Yes, sir, I
5 have it.

6 Q Very well. Let me refer you to pages 10,
7 11 and 12, which all appear -- you have the
8 compressed format?

9 MR. FEIL: What page references?

10 BY MR. PELLIGRINI:

11 Q Beginning at the middle of Page 10 and
12 continuing to the top of Page 12. There you will
13 note that -- I asked you some questions relative to
14 the classification of facilities based upon treatment
15 type.

16 A Yes. I'm on the same page, I believe.

17 Q Did you not agree that -- did you not agree
18 at that time that it was possible that you would
19 accept three classifications based on treatment, on
20 treatment type?

21 A Hypothetically I would if I had, you know,
22 had that opportunity and --

23 Q What three class -- I'm sorry.

24 A The classifications I stated here, let's
25 see, lime softening, iron filtration, and I guess we

1 will partition out reverse osmosis. You also have, I
2 guess, another type where you are treating the
3 Floridan aquifer, pumping it out of the ground,
4 perhaps aerating it and disinfecting it. I didn't --
5 what's the question?

6 Q Well, I'm asking you to identify the
7 classifications that would be acceptable to you based
8 on treatment type.

9 MR. FEIL: I don't think he testified in
10 his deposition there were any classifications that
11 were acceptable based on treatment type other than
12 those he mentioned in his direct testimony.

13 Q Would you read, Mr. Elliott, your testimony
14 beginning at line 21 on Page 11, with the sentence
15 beginning as you mentioned?

16 A 21 is a question, the beginning of 20, I
17 would have to read the whole thing to put it in
18 context.

19 Q On page 11?

20 A No, excuse me.

21 Q Line 21, Page 11, the sentence beginning,
22 "as you mentioned". The question was --

23 A That's an answer, yes.

24 Q The question was, "And what would the three
25 structures be?"

1 A As you mentioned, lime softening and iron
2 removal are technologies that would probably have the
3 same cost factor. Brackish water reverse osmosis
4 system would have the distinctly higher number. That
5 continues onto 25.

6 Q These three classifications, as I
7 understand in your view, would justify three
8 different rate structures.

9 A Not in this case. That's not what we
10 proposed here. My testimony was that it was in two
11 categories.

12 Q I realize that.

13 A I would say if I were to create a case from
14 scratch and had the opportunity, that would be maybe
15 a possibility. Again, that is kind of hypothetical.

16 Q Yes, I appreciate that. Let me take you to
17 line 17 on Page 11. Would you read the last part of
18 that, sir, the last part of that answer?

19 A I would start at 15 and read the answer.
20 "In general, if I were creating or working on a rate
21 case that had starting from scratch a theoretical
22 model I would have perhaps three different rate
23 structures."

24 I think you have to read the whole answer.

25 MR. PELLIGRINI: Fair enough. I have no

1 further questions.

2 CHAIRMAN CLARK: Redirect. Excuse me,
3 Commissioners? Redirect.

4 MR. FEIL: No questions.

5 CHAIRMAN CLARK: No exhibits?

6 MR. FEIL: That's correct.

7 CHAIRMAN CLARK: Okay. Thank you,
8 Mr. Elliott. You are excused.

9 CHAIRMAN CLARK: We are just about at 8:00
10 o'clock. I do want to inquire, I notice Mr. Ludsen
11 is not going to be available on the 3rd and the 4th.
12 Does it make sense to take him up first thing in the
13 morning?

14 MR. ARMSTRONG: If that's acceptable to the
15 parties, Madam Chair, that would be fine.

16 COMMISSIONER GARCIA: Who is it you are
17 taking up?

18 CHAIRMAN CLARK: If you will notice,
19 Mr. Ludsen will not be available on Friday or
20 Saturday. And my question is would it be appropriate
21 to take him up tomorrow.

22 MR. TWOMEY: My personal preference would
23 be as opposed to tomorrow, Monday, if it wouldn't
24 kill anybody else. The Ludsen is an important,
25 extremely important witness. I will do, of course,

1 whatever you want to do.

2 COMMISSIONER KIESLING: Let me kind of
3 indicate as having looked through the testimony and
4 judging how it was going, I kind of looked at how we
5 could finish in two weeks. I had Mr. Ludsen for
6 tomorrow, plus Mr. Bliss and Mr. Westrick and
7 Mr. Bencini, which would give us another from 9:00 in
8 the morning to 8:00 at night kind of day. Because
9 then on Friday we have to take our Staff witness, one
10 of the Staff witnesses out of order, which everyone
11 agreed to at the pre-hearing, Dr. Beecher.

12 CHAIRMAN CLARK: Yes.

13 MS. O'SULLIVAN: Commissioners, Staff would
14 request if we do take Mr. Ludsen tomorrow that it be
15 after 10:00 o'clock to let Staff prepare for him
16 because we are going by the list right now.

17 CHAIRMAN CLARK: Mr. Riley, who is
18 questioning Mr. Ludsen for --

19 MR. RILEY: As I understand it, it is
20 Charlie.

21 CHAIRMAN CLARK: Okay. What we will do
22 then is just skip over Mr. Ludsen on those days and
23 continue on. I hope that doesn't put us beyond,
24 well, he may have to testify after we begin testimony
25 from Intervenors. Is that acceptable?

1 MR. TWOMEY: Yes, it is acceptable, sure.

2 CHAIRMAN CLARK: It is preferable to you to
3 take him up tomorrow.

4 MR. TWOMEY: Pardon?

5 CHAIRMAN CLARK: It is preferable to you,
6 that if that happens as opposed to taking up
7 Mr. Ludsen tomorrow.

8 COMMISSIONER DEASON: What if we get to
9 Mr. Ludsen tomorrow through normal course of
10 business? I may be overly optimistic, but what if we
11 do him in the normal course of business?

12 MR. TWOMEY: Then that's what we will do.
13 I just had the expectation, frankly, I could use more
14 time, that he was in the order. That's my problem,
15 to be frank about it.

16 COMMISSIONER DEASON: It would appear to me
17 that the only flip-flop would be if we take
18 Mr. Ludsen last tomorrow, that he would go in front
19 of Ms. Kimball. That would be the only --

20 CHAIRMAN CLARK: Yeah, but I don't think
21 taking him last will get it done.

22 COMMISSIONER KIESLING: I do.

23 MS. O'SULLIVAN: We also are concerned we
24 just received the rate case expense information and
25 we are trying to prepare that to cross Mr. Ludsen

1 with.

2 CHAIRMAN CLARK: He is back on rebuttal,
3 too.

4 MR. FEIL: SSU stipulated to Staff if they
5 wanted to cross him about rate case expense they
6 could do that on rebuttal, that's fine.

7 CHAIRMAN CLARK: We will continue on in the
8 order we have.

9 COMMISSIONER GARCIA: Just to make sure, we
10 are doing Bliss, Westrick and Bencini and Kimball
11 tomorrow, and Mr. Ludsen if all goes well.

12 CHAIRMAN CLARK: At least. We may just skip
13 Mr. Ludsen even if he comes up rather than splitting
14 his testimony and move on to Ms. Lock.

15 COMMISSIONER KIESLING: I would just
16 indicate that were we to do that we would get to
17 intervenors sometime Friday afternoon or Saturday. I
18 knew that Mr. Twomey had at least requested at the
19 pre-hearing, you had one witness that had a date
20 problem.

21 MR. TWOMEY: Judge Mann.

22 COMMISSIONER KIESLING: When was it going
23 to be he was going to be available?

24 MR. TWOMEY: I was hoping toward the first
25 of next week.

1 COMMISSIONER KIESLING: So Saturday?

2 MR. TWOMEY: No, not Saturday, no. I mean,
3 the beginning of next week.

4 CHAIRMAN CLARK: Mr. Hoffman.

5 MR. HOFFMAN: Madam Chairman, with respect
6 to Judge Mann, I spoke with staff this afternoon.
7 And if staff doesn't have any questions for Judge
8 Mann, the company is willing to stipulate Judge Mann
9 in. I don't know about Public Counsel, but I just
10 assume Public Counsel might not have questions
11 because it is a rate design witness.

12 MR. RILEY: That would be a fair
13 assumption.

14 MS. O'SULLIVAN: Staff would agree.

15 CHAIRMAN CLARK: It looks like we can
16 stipulate Judge Mann --

17 COMMISSIONER GARCIA: I was hoping we would
18 get to meets him.

19 CHAIRMAN CLARK: I'm sure you will.

20 COMMISSIONER KIESLING: I do have one more
21 question. Someone will have to present witnesses on
22 Saturday. That's just the way it fell. It looks
23 like it will be Mr. Twomey. Do you have other
24 witnesses that are not going -- who don't want to be
25 here on Saturday?

1 MR. TWOMEY: Well, I guess Mr. Hansen is
2 here. And currently I didn't plan for Mr. Woelffer
3 to be here until first thing Monday morning or Sunday
4 night. My expectation was it will go a little bit
5 slow. . But I will call him, I guess.

6 COMMISSIONER KIESLING: All right.

7 CHAIRMAN CLARK: We will reassess it when
8 we get to the end of tomorrow. Okay.

9 COMMISSIONER KIESLING: I just wanted you
10 to have as much notice as possible, but it may fall
11 that most of your witnesses are going to be
12 Saturday.

13 MR. TWOMEY: I appreciate that.

14 COMMISSIONER GARCIA: We have stipulated
15 Judge Mann in, also.

16 CHAIRMAN CLARK: Can I ask this, Stephanie
17 Smith was stipulated into the record, right? Will
18 be.

19 COMMISSIONER KIESLING: Will be.

20 CHAIRMAN CLARK: All right.

21 COMMISSIONER GARCIA: Madam Chairman, are
22 we going all day Saturday? Because I would rather
23 have time left over at the end of the week, if we
24 can. If Mr. Twomey can't have his people for a
25 reason, I would like to make sure we fill up

1 Saturday.

2 CHAIRMAN CLARK: We will fill up Saturday.

3 COMMISSIONER KIESLING: Could I just
4 clarify one more thing, Mr. Twomey? I think that you
5 had made a decision not to call Charles Dusseau?

6 MR. TWOMEY: Yes.

7 COMMISSIONER KIESLING: So --

8 CHAIRMAN CLARK: He can be stricken from
9 the witness list.

10 MR. TWOMEY: I think I will strike Koch, as
11 well.

12 COMMISSIONER KIESLING: That takes care of
13 a couple of hours I thought we wouldn't have.

14 CHAIRMAN CLARK: Okay. We will look at it
15 again tomorrow, and take some assessment as to how
16 the schedule looks, and who will be testifying on
17 Saturday. But at least tomorrow we will go through
18 the order of witnesses as they appear on the
19 hearing.

20 COMMISSIONER GARCIA: If we have some more
21 stipulations we may not have to come in Saturday.

22 CHAIRMAN CLARK: I'm sure that is a
23 possibility. Mr. Hansen says it is a possibility.
24 All right. With that, this hearing is adjourned. We
25 will reconvene tomorrow at 9:00 o'clock and start

1 with the testimony of Mr. Bliss. Thank you.

2 (Thereupon, the hearing adjourned at 8:00
3 p.m. to reconvene May 2, 1996 at 9:00 a.m.)

4

- - - - -

5 (Transcript continues in sequence in Volume
6 11.)

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

DOCKET NO. 950495-445
EXHIBIT NO. 98
CASE NO. 96-04227

EXHIBIT _____ (RCE-1)

PAGE 1 OF 48

**STEADY-STATE MODEL
CALIBRATION OF PINE RIDGE
WATER TRANSMISSION AND
DISTRIBUTION NETWORK**

Presented to:

**SOUTHERN STATES UTILITIES, INC.
Apopka, Florida**

Presented by:

**JONES, EDMUNDS & ASSOCIATES, INC.
730 Northeast Waldo Road
Gainesville, Florida 32641**

March 1996
FLORIDA PUBLIC SERVICE COMMISSION
DOCKET NO. 950495 EXHIBIT NO. 98
COMPANY/ WITNESS: SSU/EDMUNDS
DATE: 4/29/96

DOCUMENT NUMBER-DATE
03389 MAR 21 96
FPSC-RECORDS/REPORTING

TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
1.0	<u>INTRODUCTION</u>	1-1
1.1	PURPOSE	1-1
1.2	SCOPE	1-1
2.0	<u>HYDRAULIC MODELING</u>	2-1
2.1	THEORY	2-1
2.2	MODELING PROGRAM	2-1
2.3	MODEL DESCRIPTION	2-2
2.4	DEVELOPMENT OF PINE RIDGE WATER DISTRIBUTION MODEL ...	2-2
2.5	ADJUSTMENT OF DEMAND FOR SIMULATIONS	2-3
2.6	MODELING AND THE NEED FOR MODEL CALIBRATION	2-3
3.0	<u>FIELD CALIBRATION</u>	3-1
3.1	PROGRAM	3-1
3.2	FIELD DATA	3-2
3.3	DATA ANALYSIS	3-3
3.4	FIRST FIELD INVESTIGATION	3-4
3.5	SECOND FIELD INVESTIGATION	3-4
3.6	AIR BINDING	3-6
3.7	MODEL CALIBRATION	3-7
4.0	<u>CONCLUSION AND RECOMMENDATIONS</u>	4-1
4.1	RESULTS	4-1
4.2	RECOMMENDATIONS	4-1

2.0 HYDRAULIC MODELING

2.1 THEORY

Two basic principles are involved in steady-state modeling. These principles are the conservation of mass and the First Law of Thermodynamics. The conservation of mass principle states that the time rate of change of the system mass equals zero. The application of this principle leads to the continuity equation. The First Law of Thermodynamics states that the time rate of increase of the total stored energy of the system equals the net time rate of energy addition by heat transfer into the system plus the net time rate of energy addition by work transfer into the system. Steady-state application of this law leads to the energy equation. Energy dissipation due to wall shear stress (i.e., the energy lost due to friction at the pipe wall) is the most difficult term in the energy equation to accurately describe. The Hazen-Williams equation is an industry standard and is used herein to describe this energy dissipation.

Although manual solution to the energy and continuity equations is possible, it is very time consuming and prohibitive as a practical matter. Therefore, it is advantageous to solve the equations by use of a steady-state hydraulic computer program.

2.2 MODELING PROGRAM

The computer program used in this steady-state model calibration is Cybernet by Haestad Methods. Cybernet is basically a version of Kentucky Pipes with an AutoCAD graphical interface. Specifically, Cybernet solves the pressure network using the state-of-the-art KYPIPE2 computational algorithm. The program permits use of a variety of boundary conditions including constant head (given as elevation), pumps, constant demand, valves, and storage tanks. Pumps may be represented as useful power or by using head-discharge data from a pump curve.

internal condition. Some of the considerations associated with this type of modeling are as follows:

- A. The Hazen-Williams "C" coefficient is a function of pipe inside diameter, pipe roughness, and the Reynold's number of flow in the pipe.
- B. The Hazen-Williams equation is an empirical equation that describes the frictional energy loss in the pipe. However, the equation has to be adjusted to account for local energy losses. (i.e., fitting losses, etc.)
- C. Depending on pipe material and water chemistry, the pipe roughness and inside diameter may change with age.
- D. The hydraulic performance of certain elements in the water network and facilities may deteriorate.
- E. Other factors, such as air binding, network blockages, installed utilities differing from those in utility records, etc., may affect network performance.

Therefore, it is sometimes difficult for a model to accurately predict pressure and flow distribution in real water transmission and distribution networks. Model calibration is performed for reliable prediction of field pressure and flow distribution. Typically, a model is considered calibrated if it can predict field pressures within 5 psi. However, if fluctuations are 10 psi or greater and occur at fairly short intervals, one must select a pressure level during a cycle (a high, medium, or low point) and attempt to calibrate the model for that condition, recognizing that there are some inherent inaccuracies in using a steady-state model to describe unsteady conditions (*Water Systems: Simulation and Sizing*, Walski, Gessler and Sjostrom).

3.0 FIELD CALIBRATION

3.1 PROGRAM

Prior to developing a field test program the following events occurred:

- A. Production meter calibration.
- B. Well pump capacity tests.
- C. Week long data logging for development of diurnal curves.
- D. Survey of test locations for elevations.

The field test program was developed by selecting specific hydrants to impose a demand that hydraulically stressed the facilities by dropping local pressures in the network to 20 psi. The number of supply sources was kept to the minimum number which could provide for current customer and test demands while maintaining adequate network pressure performance. The test configuration included a listing of the operating status of all supply wells, booster pumping station, PRVs, and locations of pressure and flow monitoring points.

Each field test configuration included the following items:

- A. Monitor each operating well for flow, pressure, and hydropneumatic tank level.
- B. Monitor each booster pump for suction and discharge pressure.
- C. Monitor each PRV for pressure upstream and downstream of the valve.
- D. Monitor each operating hydrant for flow and monitor residual pressure at a location nearby.
- E. Monitor network pressure at selected residual monitoring points.

3.4 FIRST FIELD INVESTIGATION

On February 2, 1996, SSU performed a field investigation in an attempt to locate the source of the head loss. The results of the field investigation are as follows:

- A. A fully closed field valve (10 inch gate valve) was found on the eastern side of the tee that connects modeled pipe nos. 511, 516, and 3241.
- B. A field valve (12 inch gate valve) 7/36th closed was found in model pipe no. 851.
- C. A notable head loss was found at the northern connection between the eastern and western parts of the network.
- D. The pressure at the hydrant closest to Pine Ridge Boulevard and North Perry Drive (Perry Hydrant) was not fluctuating as was the pressure at the hydropneumatic tank at Well No. 4.
- E. Closing and opening of a valve on North Perry Drive appeared to remove the source of the head loss and pressures began fluctuating at the referenced hydrant in synchronization with the pressure at the hydropneumatic tank at Well No. 4.

3.5 SECOND FIELD INVESTIGATION

A second field investigation to evaluate the overall network performance was conducted by SSU and JEA on February 28, 1996 and February 29, 1996.

8 inch pipeline reduced the measured versus modeled pressure disagreement at the Perry Hydrant from 12.5 psi to 5.3 psi. Because pressure loss in the 8 inch main affects pressures throughout the western part of the network, a comparable reduction in pressure discrepancies would be expected at all pressure measuring locations in the western part of the network as well. Consequently, it is our opinion that the pressure discrepancies and model calibration in the western part of the network are being adversely effected by occasional or chronic air binding. Installation of properly placed air release valves to purge pockets of entrapped air would be expected to permit the western part of the network to function hydraulically as indicated by the hydraulic model.

4.0 CONCLUSION AND RECOMMENDATIONS

4.1 RESULTS

The hydraulic model accurately predicts pressure within 5 psi for the eastern part of the network. Therefore, the model can be considered calibrated with respect to the eastern part. A head loss is experienced in the western part, which we believe is due to air binding. The results of various field investigations have confirmed the presence of air in the network and expulsion of some of the air from the network has resulted in a decrease of head loss in the western part of Pine Ridge.

Expulsion of air from the network resulted in the following:

- A. Field pressure recorded at Well No. 2 went from 13.2 psi below model prediction to 8.18 psi below model prediction for the same test configuration.
- B. Field pressure recorded at Perry Hydrant went from 12.48 psi below model prediction to 5.27 psi below model prediction for the same test configuration.

Following installation of devices that will allow air to be continually purged from the network, we expect that the model will calibrate at a C-value of 145.

4.2 RECOMMENDATIONS

The following recommendations are provided for operation of the Pine Ridge water transmission and distribution network.

- A. Air release valves should be installed at critical points throughout the water distribution network.

- B. Following this, if air binding persists, air traps should be installed at specific locations around all wells.

EXHIBIT (2CE-1)

PAGE 18 OF 48

ATTACHMENT 1

TEST #1

EVENT	TIME	PUMP STATUS	HYDRANT STATUS OPEN/CLOSE	DISCHARGE PRESSURE (PSIG)	"PUMP ON" TOTALIZER READING (GAL)	"PUMP OFF" TOTALIZER READING (GAL)	HYDROTANK LEVEL (INCHES)	PRV #1 UPSTREAM PRESSURE (PSIG)	PRV #2		PRV #3		BOOSTER STATION				WELL #2 (PSIG)	BUFFALO (PSIG)	PRINCEWOOD (PSIG)	RESIDUAL HYDRANT (PSIG)	STRESSED HYDRANT MICROMETER (GPM)
									UPSTREAM PRESSURE (PSIG)	DOWNSTREAM PRESSURE (PSIG)	UPSTREAM PRESSURE (PSIG)	DOWNSTREAM PRESSURE (PSIG)	PUMP #1		PUMP #2						
												SUC. PRES. (PSIG)	DISC. PRES. (PSIG)	SUC. PRES. (PSIG)	DISC. PRES. (PSIG)						
1																					
2																					
3	1:20:00	ON	CLOSED				18.75	64	62	54	53	40	56	98	58	97	58	52	54	64	0
4	1:21:00		CLOSED				21	73	75	54	61	50	68	105	72	105	64	54	51	72	0
5	1:27:00	OFF	CLOSED																		
6	1:33:00	ON	CLOSED																		
7	1:33:00		CLOSED				16	64	67	53	52	40	58	97	58	97	58	54	65	64	0
8	1:36:00	OFF	CLOSED				21	71	74	55	60	50	70	105	70	105	64	52	61	72	0
9	1:55:00	ON	OPEN		288,000,180																
7	1:57:00		OPEN	60			17.5	64	64	53	49	32	51	98	52	98	45	44	64	35	280
8	1:58:00		OPEN	63			19.5	65	65	54	51	33	53	98	53	99	48	45	74	35	280
9	1:59:00		OPEN	69			20.5	69	70	54	55	38	55	103	58	103	52	45	78	38	280
10	2:06:00	ON	CLOSED		288,002,410	288,002,410															
10	2:06:00		CLOSED	57			18	63	65	54	51	40	56	98	58	97	54	52	65	64	0
11	2:07:00		CLOSED	70			21	72	74	54	60	48	68	105	68	105	60	52	75	68	0
11	2:07:42	OFF	CLOSED			288,003,900															

EVENT	TIME	HYDRANT STATUS OPEN/CLOSE	DISCHARGE HGL (FT)	PRV #1			PRV #2		PRV #3		BOOSTER STATION				WELL #2 (FT)	BUFFALO (FT)	PRINCEWOOD (FT)	RESIDUAL HYDRANT (FT)
				UPSTREAM HGL (FT)	DOWNSTREAM HGL (FT)	UPSTREAM HGL (FT)	DOWNSTREAM HGL (FT)	UPSTREAM HGL (FT)	DOWNSTREAM HGL (FT)	PUMP #1		PUMP #2						
1																		
2																		
3	1:21	CLOSED	285.282	273.307	254.935	278.228	248.228	201.681	298.604	208.298	286.296	215.171	221.590	224.582	231.532			
4	1:27	CLOSED	305.052	303.397	254.935	284.699	256.305	229.373	314.758	238.604	314.758	233.632	228.205	228.763	248.694			
5	1:33	CLOSED	285.282	284.935	252.628	273.020	248.228	208.298	298.298	208.298	298.298	215.171	228.205	228.670	231.532			
6	1:36	CLOSED	301.438	301.260	287.243	282.382	289.305	233.083	314.758	233.083	314.758	233.632	221.590	263.783	249.694			
7	1:57	OPEN	220.302	285.282	278.012	252.628	288.907	227.785	192.142	208.604	192.450	208.604	192.054	203.128	224.582	185.917		
8	1:58	OPEN	227.315	287.590	280.320	254.935	271.612	230.074	194.758	208.604	194.758	300.912	198.700	205.438	247.639	184.600		
9	1:59	OPEN	241.161	298.821	291.858	254.935	280.843	241.612	201.681	310.142	208.298	310.142	208.940	205.438	252.259	171.532		
10	2:06	CLOSED	213.468	282.975	280.320	254.935	271.612	248.228	201.681	283.988	208.298	286.298	210.555	221.590	228.670	231.532		
11	2:07	CLOSED	243.468	303.744	301.089	254.935	292.382	284.699	224.758	314.758	224.758	314.758	224.402	221.590	249.947	240.783		

NOTE: ONLY USE EVENT 7 THROUGH EVENT 11.

TEST #2

EVENT	TIME	PUMP STATUS	HYDRANT STATUS (OPEN/CLOSE)	DISCHARGE PRESSURE (PSIG)	"PUMP ON" TOTALIZER READING (GAL)	"PUMP OFF" TOTALIZER READING (GAL)	HYDROTANK LEVEL (INCHES)	PRV #1 UPSTREAM PRESSURE (PSIG)	PRV #2		PRV #3		BOOSTER STATION				WELL #2 (PSIG)	BUFFALO (PSIG)	PRINCEWOOD (PSIG)	RESIDUAL HYDRANT (PSIG)	STRESSED HYDRANT MICROMETER (GPA)
									UPSTREAM PRESSURE (PSIG)	DOWNSTREAM PRESSURE (PSIG)	UPSTREAM PRESSURE (PSIG)	DOWNSTREAM PRESSURE (PSIG)	PUMP #1		PUMP #2						
													SUC. PRES. (PSIG)	DISC. PRES. (PSIG)	SUC. PRES. (PSIG)	DISC. PRES. (PSIG)					
	2:32:30	ON			298,007,100																
1	2:33:21	CLOSED	62				18	64	67	64	52	40	58	97	58	97	54	52	68	68	0
2	2:34:13	CLOSED	70				20.75	68	70	53	56	44	62	100	62	101	58	52	75	68	0
	2:34:22	OFF			298,008,770																
	2:36:30	ON			298,008,770																
3	2:38:44	OPEN	61				18	53	67	63	43	32	47	91	48	91	48	44	69	58	300
4	2:39:28	OPEN	68				19.5	55	67	63	44	34	50	94	50	93	49	44	71	58	320
5	2:40:05	OPEN	70				21	57	62	63	47	38	52	95	52	96	52	44	77	58	320
	2:40:40	OFF			298,011,150																
	2:45:40	ON			268,011,150																
6	2:46:00	CLOSED	63				18.5	66	69	63	53	42	60	98	60	98	54	50	67	68	0
7	2:47:00	CLOSED	72				22	73	78	63	62	51	71	105	70	108	64	52	77	74	0
	2:47:13	OFF			298,012,550																

EVENT	TIME	HYDRANT STATUS (OPEN/CLOSE)	DISCHARGE HGL (FT)	PRV #1 UPSTREAM HGL (FT)	PRV #2		PRV #3		BOOSTER STATION				WELL #2 HGL (FT)	BUFFALO HGL (FT)	PRINCEWOOD HGL (FT)	RESIDUAL HYDRANT HGL (FT)
					UPSTREAM HGL (FT)	DOWNSTREAM HGL (FT)	UPSTREAM HGL (FT)	DOWNSTREAM HGL (FT)	PUMP #1		PUMP #2					
									SUC. HGL (FT)	DISC. HGL (FT)	SUC. HGL (FT)	DISC. HGL (FT)				
					130.32	130.32	153.02	153.02	72.45	72.45	72.45	72.45	85.04	101.50	76.87	129.4
1	2:33:21	CLOSED	225.007	295.282	294.935	294.935	273.920	248.228	208.296	298.298	208.296	298.298	210.555	221.500	233.703	291.708
2	2:34:13	CLOSED	243.468	294.513	291.858	252.628	283.151	255.458	215.527	303.219	215.527	305.527	219.786	221.500	248.947	298.323
3	2:38:44	OPEN	222.690	290.806	284.935	252.628	253.151	227.786	180.912	282.450	183.219	282.450	192.004	203.128	238.101	288.631
4	2:39:28	OPEN	234.238	284.513	284.935	252.628	255.458	232.382	187.835	289.373	187.835	287.085	199.017	203.128	240.718	288.631
5	2:40:05	OPEN	243.468	289.128	273.307	252.628	262.382	241.812	192.450	291.681	192.450	293.968	205.940	203.128	254.562	273.248
6	2:46:00	CLOSED	227.315	289.806	289.581	252.628	278.228	250.843	210.912	298.604	210.912	298.604	210.555	216.975	231.485	298.323
7	2:47:00	CLOSED	248.084	308.052	305.705	252.628	298.997	271.812	238.208	314.758	233.968	317.085	233.632	221.500	254.562	310.189

TEST #3

EVENT	TIME	PUMP STATUS	HYDRANT STATUS OPEN/CLOSE	DISCHARGE PRESSURE (PSIG)	PUMP ON TOTALIZER READING (GAL)	PUMP OFF TOTALIZER READING (GAL)	HYDROTANK LEVEL (INCHES)	PRV #1 UPSTREAM PRESSURE (PSIG)	PRV #2		PRV #3		BOOSTER STATION				WELL #2 (PSIG)	BUFFALO (PSIG)	PRINCEWOOD (PSIG)	RESIDUAL HYDRANT (PSIG)	STRESSED HYDRANT MICROMETER (GPM)
									UPSTREAM PRESSURE (PSIG)	DOWNSTREAM PRESSURE (PSIG)	UPSTREAM PRESSURE (PSIG)	DOWNSTREAM PRESSURE (PSIG)	PUMP #1		PUMP #2						
													SUC. PRES. (PSIG)	DISC. PRES. (PSIG)	SUC. PRES. (PSIG)	DISC. PRES. (PSIG)					
	3:44:05	ON			286,020,170																
1	3:44:34		CLOSED	61			18.25	64	67	54	52	40	50	97	50	97	56	55	64	85	0
2	3:45:20		CLOSED	62		286,021,630	21	71	72	54	58	48	68	103	67	103	66	55	78	90	0
	3:49:22	ON			286,021,630																
3	3:49:57		OPEN	61			18	65	67	53	52	37	50	98	51	99	48	44	65	75	310
4	3:50:33		OPEN	64			19	68	70	53	54	38	52	101	53	101	48	44	71	75	300
5	3:51:51		OPEN	71.5			21.75	70	71	53	56	42	60	102	60	102	55	44	78	79	340
	3:52:10	OFF				286,024,160															
	3:56:00	ON			286,024,160																
6	3:56:22		CLOSED	62			18.5	67	70	53	55	42	59	100	59	100	54	51	65	85	0
7	3:57:21		CLOSED	70			21.25	72	72	54	60	48	68	104	68	105	62	52	74	90	0
	3:57:47	OFF				286,025,740															

EVENT	TIME	HYDRANT STATUS OPEN/CLOSE	ELEVATIONS														WELL #2 HGL (FT)	BUFFALO HGL (FT)	PRINCEWOOD HGL (FT)	RESIDUAL HYDRANT HGL (FT)
			81.93	137.59	130.32	130.32	153.92	153.92	72.45	72.45	72.45	72.45	85.94	101.59	78.87	25.01				
			DISCHARGE HGL (FT)	PRV #1 UPSTREAM HGL (FT)	UPSTREAM HGL (FT)	DOWNSTREAM HGL (FT)	PRV #3 UPSTREAM HGL (FT)	DOWNSTREAM HGL (FT)	PUMP #1		PUMP #2									
1	3:44:34	CLOSED	222.699	285.282	294.935	254.935	273.920	246.226	206.604	296.296	206.604	296.296	215.171	228.513	224.562	221.164				
2	3:45:20	CLOSED	241.161	301.436	296.474	254.935	287.786	260.074	229.373	310.142	227.065	310.142	238.248	228.513	252.255	232.702				
3	3:49:57	OPEN	222.699	287.590	284.935	252.626	273.920	239.305	187.835	296.604	190.142	300.912	192.004	203.126	226.870	196.067				
4	3:50:33	OPEN	229.622	294.513	291.858	252.626	278.535	241.612	192.450	305.527	194.758	305.527	196.709	203.126	240.718	198.067				
5	3:51:51	OPEN	248.930	290.128	294.168	252.626	283.151	250.843	210.912	307.835	210.912	307.835	212.863	203.126	252.255	207.318				
6	3:56:22	CLOSED	225.007	292.205	291.858	252.626	280.843	250.843	206.604	303.219	206.604	303.219	210.555	219.282	228.870	221.164				
7	3:57:21	CLOSED	243.488	303.744	296.474	254.935	292.382	264.689	229.373	312.450	229.373	314.758	229.017	221.590	247.639	232.702				

TEST #4

EVENT	TIME	PUMP STATUS	HYDRANT STATUS OPEN/CLOSE	DISCHARGE PRESSURE (PSIG)	"PUMP ON" TOTALIZER READING (GAL)	"PUMP OFF" TOTALIZER READING (GAL)	HYDROTANK LEVEL (INCHES)	PRV #1 UPSTREAM PRESSURE (PSIG)	PRV #2		PRV #3		BOOSTER STATION				WELL #2 (PSIG)	BUFFALO (PSIG)	PRINCEWOOD (PSIG)	STRESSED HYDRANT MICROMETER (GPM)
									UPSTREAM PRESSURE (PSIG)	DOWNSTREAM PRESSURE (PSIG)	UPSTREAM PRESSURE (PSIG)	DOWNSTREAM PRESSURE (PSIG)	PUMP #1		PUMP #2					
													SUC. PRES. (PSIG)	DISC. PRES. (PSIG)	SUC. PRES. (PSIG)	DISC. PRES. (PSIG)				
	4:24:47	ON			269,031,430															
1	4:25:15	CLOSED	61				18	64	67	58	51	39	56	97	58	87	52	54	64	0
2	4:26:12	CLOSED	60				21	70	72	59	57	46	66	104	65	103	50	54	74	0
	4:26:45	OFF			268,033,170															
	4:29:30	ON			268,033,170															
3	4:30:07	OPEN	60				18	62	64	63	60	36	52	96	52	85	46	46	60	270
4	4:31:05	OPEN	65				19.5	66	68	63	63	38	53	100	53	100	48	44	69	310
5	4:32:12	OPEN	70				20.25	69	72	63	56	41	58	102	58	102	51	44	75	320
	4:33:00	OFF			268,036,200															
	4:36:20	ON			268,036,200															
6	4:37:10	CLOSED	62.5				19	68	70	53	55	42	60	101	60	101	62	52	68	0
7	4:38:10	CLOSED	70.5				21.75	71	74	53	59	48	68	104	68	104	62	54	75	0
	4:38:20	OFF			268,037,970															

EVENT	TIME	HYDRANT STATUS OPEN/CLOSE	DISCHARGE HGL (FT)	PRV #1 UPSTREAM HGL (FT)	PRV #2		PRV #3		BOOSTER STATION				WELL #2 HGL (FT)	BUFFALO HGL (FT)	PRINCEWOOD HGL (FT)
					UPSTREAM HGL (FT)	DOWNSTREAM HGL (FT)	UPSTREAM HGL (FT)	DOWNSTREAM HGL (FT)	PUMP #1		PUMP #2				
									SUC. HGL (FT)	DISC. HGL (FT)	SUC. HGL (FT)	DISC. HGL (FT)			
1	4:25:15	CLOSED	222.639	295.282	294.826	294.186	271.612	243.020	208.298	296.298	208.298	298.298	205.940	228.205	224.562
2	4:26:12	CLOSED	241.161	298.126	298.474	294.186	285.458	260.074	224.758	312.450	222.450	310.142	222.094	228.205	247.639
3	4:30:07	OPEN	220.362	290.687	278.012	275.705	269.305	236.937	192.450	293.966	192.450	291.661	192.094	207.744	215.332
4	4:31:05	OPEN	231.930	290.866	287.243	275.705	278.228	241.612	194.758	303.219	194.758	303.219	198.709	203.128	238.101
5	4:32:12	OPEN	243.468	296.621	296.474	275.705	283.151	248.535	208.298	307.635	208.298	307.635	203.632	203.128	249.947
6	4:37:10	CLOSED	226.161	294.513	291.958	252.626	280.843	250.843	210.912	305.527	210.912	305.527	205.940	221.560	238.101
7	4:38:10	CLOSED	244.622	301.436	301.089	252.626	280.074	264.686	228.373	312.450	229.373	312.450	229.017	228.205	249.947

TEST #5

EVENT	TIME	PUMP STATUS	HYDRANT STATUS (OPEN/CLOSE)	DISCHARGE PRESSURE (PSIG)	"PUMP ON" TOTALIZER READING (GAL)	"PUMP OFF" TOTALIZER READING (GAL)	HYDROTANK LEVEL (INCHES)	PRV #1 UPSTREAM PRESSURE (PSIG)	PRV #2		PRV #3		BOOSTER STATION				WELL #2 (PSIG)	BUFFALO (PSIG)	PRINCEWOOD (PSIG)	STRESSED HYDRANT MICROMETER (GPM)
									UPSTREAM PRESSURE (PSIG)	DOWNSTREAM PRESSURE (PSIG)	UPSTREAM PRESSURE (PSIG)	DOWNSTREAM PRESSURE (PSIG)	PUMP #1		PUMP #2					
													SUC. PRES. (PSIG)	DISC. PRES. (PSIG)	SUC. PRES. (PSIG)	DISC. PRES. (PSIG)				
	5:25:08	ON	CLOSED		266,049,710															
1	5:26:00		CLOSED	64			19.5	66	60	53	54	40	58	98	58	97	53	54	73	0
2	5:27:00		CLOSED	63			21	67	60	53	55	42	60	100	60	100	56	54	73	0
	5:27:30	OFF	CLOSED			266,051,790														
MISSED CYCLE																				
	5:35:38	ON	OPEN		266,058,670															
3	5:39:15		OPEN	61			18.75	64	70	51	53	40	58	98	58	98	52	54	54	410
4	5:40:20		OPEN	64			19.75	66	70	51	54	40	59	100	59	99	53	54	58	420
5	5:42:30		OPEN	66			20.5	65	70	53	54	44	64	98	63	99	56	54	61	400
	5:44:22	OFF	CLOSED			266,063,890														
	5:48:50	ON	CLOSED		266,063,890															
6	5:49:30		CLOSED	62			19	64	64	53	52	40	58	98	58	98	53	54	67	0
7	5:50:15		CLOSED	68			21.25	72	69	51	55	42	60	101	60	101	56	54	73	0
	5:51:06	OFF	CLOSED			266,065,900														

EVENT	TIME	HYDRANT STATUS (OPEN/CLOSE)	ELEVATIONS														
			DISCHARGE HGL (FT)	PRV #1 UPSTREAM HGL (FT)	PRV #2		PRV #3		BOOSTER STATION				WELL #2 HGL (FT)	BUFFALO HGL (FT)	PRINCEWOOD HGL (FT)		
			81.83	137.59	130.32	130.32	153.92	153.92	72.45	72.45	72.45	72.45	85.94	101.59	78.87		
1	5:25:15	CLOSED	228.822	289.898	289.551	252.626	278.535	248.228	208.298	298.604	208.298	298.298	208.248	228.205	245.332		
2	5:26:12	CLOSED	241.181	292.205	289.551	252.626	280.843	250.843	210.912	303.219	210.912	303.219	215.171	228.205	245.332		
3	5:30:07	OPEN	222.699	285.282	291.858	248.012	278.228	248.228	208.298	298.604	208.298	298.604	205.940	228.205	201.485		
4	5:31:05	OPEN	228.822	289.898	291.858	248.012	278.535	248.228	208.604	303.219	208.604	300.912	208.248	228.205	210.718		
5	5:32:12	OPEN	234.238	287.590	291.858	252.626	278.535	255.458	220.142	298.604	217.835	300.912	222.094	228.205	217.839		
6	5:37:10	CLOSED	225.057	285.282	278.012	252.626	273.928	248.228	208.298	298.604	208.298	298.604	208.248	228.205	231.485		
7	5:38:10	CLOSED	238.853	303.744	289.551	248.012	280.843	250.843	210.912	305.527	210.912	305.527	215.171	228.205	245.332		

ATTACHMENT 2

RESULTS OF MODEL CALIBRATION USING TEST #1, EVENT 11 (1/16/96)

Project No.: 19540-489-01-09

Project Name: SSU Model Calibration

Hazen-Williams C Factor = 145

Booster Pump Speed = 1349 rpm (it is operating at 76% of full speed)

Location	Sub-System Monitored	Field Pressure (psi)	Model Pressure (psi)	Difference (psi)
Residual (West Deputy Drive)	Western	68	72.39	-4.39
North Princewood Drive	Eastern	75	72.11	2.89
North Buffalo Drive	Western	52	61.24	-9.24
Well #2	Western	60	67.99	-7.99
PRV #1 (upstream)		72	71.933	0.067
PRV #2 (upstream)		74	72.887	1.113
PRV #2 (downstream)		54	54.002	-0.002
PRV #3 (upstream)		60	61.239	-1.239
PRV #3 (downstream)		48	47.307	0.693
Booster Station (suction side)	Western	66	72.6	-6.6
Booster Station (discharge side)		105	101.01	3.99

Hydrant Flow = 0 GPM

System Demand = 180 GPM

ATTACHMENT 3

OBSTRUCTION TEST (2/28/96) - [Before Air Purging]

Project No.: 19540-489-01-09
 Project Name: SSU Model Calibration

Hazen-Williams C Factor = 145

Assumed Booster Pump Speed = 1384.5 rpm (it is operating at 78% of full speed)

Location	Sub-System Monitored	Field Pressure (psi)	Model Pressure (psi)	Difference (psi)
Carnation Hydrant	Eastern	56	56.85	-0.85
Perry Hydrant	Western	39	51.48	-12.48

Stressed Hydrant @ West Pine Ridge Boulevard & West Cavalry Lane @ 350 GPM.

System Demand Without Fire Flow = 278 GPM

Total Demand = 628 GPM

EXHIBIT (2CE-1)

PAGE 37 OF 48

ATTACHMENT 4

Air Binding in Pipes

Robert C. Edmunds

A survey of current research and recent case histories on the phenomenon of air binding suggests that while there is no generally agreed-upon solution to this problem, the adoption of some simple procedures can minimize its occurrence.

Air trapped in pipes can reduce pipeline carrying capacity, cause unexpected pressure surges, and produce objectionable "white water." This article summarizes state-of-the-art research and background data on the air binding phenomenon, compares case histories with theories developed to predict the occurrence of air binding, and describes a procedure that will assist pipeline designers in preventing air binding.

The Phenomenon

Two typical cases of air binding in pipelines demonstrate how this phenomenon occurs (Fig. 1). As flow begins in a pipe with mild slope, the normal depth—i.e., the depth associated with uniform flow—is greater than the critical depth for that flow and no hydraulic jump occurs. If the volume of the stagnant air pocket is not sufficient to fill the descending leg and if additional air reaches this zone in the pipeline, the air bubble grows in a downstream direction and maintains the same height at all points because of the fluid's uniform depth. The trapped air can be removed hydraulically either by generation of small air bubbles at the turbulent downstream end of the pocket, and entrainment into and transport by the fluid, or by sweeping the total air pocket down the pipeline. If an air pocket with low or no air velocity is assumed, the air pressure in the pocket must be everywhere the same. Calculating the general energy equation between the two sections of pipe (Fig. 1) will show that the head loss due to the trapped air pocket is equal to the vertical component of the length of the air pocket. Since in uniform flow the water surface is parallel to the channel invert, the energy loss is equal to the difference in invert elevation between the high and low points in the descending leg, assuming that the air pocket extends to the bottom of the slope. This point can be useful in locating unexplained head losses in pipelines by comparing the amount of unexplained head loss to the elevation differences in the pipeline profile.

In a pipe with steep slope (Fig. 2) the normal depth is less than the critical depth, and hydraulic jump is possible. (At mild slopes, special upstream control

sections such as a partially opened gate or a rapid change in slope can also cause hydraulic jump to form.) The jump is the interface between upstream supercritical and downstream subcritical backwater curves or between upstream supercritical normal depth and the downstream subcritical backwater curve. If the hydraulic jump seals the line, air is pumped into the water downstream of the jump. At low flow the air hydraulically removed is a function of the flow

conditions downstream of the jump. At some finite flow the entrained air is not carried downstream at all, but occasionally blows out through the jump, causing the jump to move temporarily downstream. At high flow the air, once entrained, is easily carried below the jump and the amount of air removed is a function of the hydraulic jump's ability to entrain air from the upstream pocket. As before, the entrapped air pocket can be hydraulically removed either by generation and entrainment of bubbles or by sweeping the air pocket down the pipeline.

To better demonstrate the hydraulic conditions within a closed pipeline




Fig. 1. Air Pocket in Pipe With Mild Slope
Normal Depth (d_0) > Critical Depth (d_{cr})

containing air, Kennison' developed a useful diagram that illustrates the following relationships (Fig. 3):

1. The critical discharge as a function of the depth of flow; that is, the depth at which the Froude number equals 1.0 (giving unstable water surfaces). The critical depth of flow can also be found if the discharge is given.

2. The normal discharge for any depth and slope. Introduction of additional air increases the bubble length, not the depth. (This relationship is plotted by assuming a C of 100 in the Chezy equation. It is useful because the units are the same as those for the critical discharge, thus permitting an immediate comparison of normal depth vs critical depth.)

3. Given the slope and the depth, the minimum flow required for the hydraulic jump to just fill the pipe and thus possibly pump air downstream. This was plotted using data developed by Kalinske and Robertson.²

4. Assuming uniform flow, the limit of the ability of the hydraulic jump to fill the pipe. These curves result from the intercepts of the curves for uniform flow and the curves giving the discharge necessary for the jump to fill the pipe.

5. The value of the Froude number for uniform flow at any depth and slope. If this number is greater than or equal to 1.0, hydraulic jump is possible.

Summary of Research on Air Removal by Hydraulic Means

Air pockets can be removed hydraulically by bubble generation and entrainment or by sweeping the pockets from the line. Should hydraulic jump occur within the line, the air removal capacity may be limited by hydraulic conditions downstream of the jump at low flows and by the air entraining limitations of the hydraulic jump at high flows. Kalinske and Robertson² correlated the air removal capacity resulting only from the air entraining limitations of the hydraulic jump and developed the relationship

$$Q_a = Q_w \cdot 0.0066 (F - 1)^{1.4} \quad (1)$$

where Q_a is the air removal capacity, Q_w is the water discharge, and F is the Froude number of the approaching flow, defined as $V/\sqrt{gY_e}$ (where V is the approach velocity, g is the acceleration due to gravity and Y_e the effective depth—i.e., the water cross-sectional area upstream of the jump divided by the surface width). This equation was found to be valid for conditions in which the fluid carried away all of the air the jump entrained. For any value of approach depth divided by pipe diameter there was a critical Froude number below which the pipeline would carry only part of the air pumped into the water by the jump (Fig. 4). The family of curves in Fig. 4 defines the point at which the air




Fig. 2. Air Pocket in Pipe With Steep Slope
Normal Depth (d_n) < Critical Depth (d_c)




Fig. 3. Hydraulic Jump Inside a Pipe—F-P-S System (After Kennison¹)

entraining capacity of the jump and air transporting capacity of the pipe downstream of the jump were found to be equal. These experiments were performed by inducing a hydraulic jump downstream of a partially open gate to easily manipulate the approach depth and effective depth. Experiments were performed in 4-in. and 6-in. acrylic pipes.

A number of researchers have examined the ability of the pipeline to transport discrete bubbles and pockets, where either no jump occurs or where the hydraulics downstream of the jump control air carrying capacity. Kalinske and Bliss³ equated the theoretical drag and displacement forces on an air pocket in equilibrium and developed an expression relating the pipe slope and equilibrium flow, defined as the minimum discharge necessary to start air moving down the pipe downstream of the hydraulic jump (Fig. 5). The deviation in data at low slopes resulted from the hydraulic jump not completely sealing the line, thus requiring higher flows to entrain and transport the air. Also plotted is the friction slope of the full pipeline, indicating that air movement was obtained with energy grade line (EGL) slopes much milder than the pipe slopes. Experiments were performed in a 6-in. acrylic pipe.

Kent⁴ also equated theoretical drag and displacement forces on an equilibrium air pocket. Experimental results were used to approximate the coefficient of drag, and the pocket equilibrium velocity was then correlated with pipeline slope as shown in Fig. 6. It was suggested that zeta (ζ), a shape factor, becomes constant for pockets whose length is greater than 1.5 times the pipe diameter. Kent also developed relationships for the loss-of-head vs percentage of air and pipe slope and the friction formula for flow with air pockets. Kent's experiments were performed in a 4-in. acrylic pipe.

Gandenberger⁵ experimented on the movement of air bubbles and pockets from the peaks of 10.5-mm, 26-mm and 45-mm glass tubes and 100-mm steel pipe with slopes varying from zero to 90 degrees and water flowing upward and downward. Based on these experiments, a graph subsequently converted to English units by Mechler was developed that shows the minimum clearing velocity as a function of bubble volume (Fig. 7). The term n is defined as the bubble volume divided by $\pi D^3/4$ where D is pipe diameter. These relationships were considered to be valid for pipes with a diameter greater than 4 in. Both Kalinske and Gandenberger noted a tendency for bubbles to stop and adhere at irregularities in the pipeline.

Wisner et al⁶ applied previous theories to several case histories and, noting




Fig. 8. Recommended Envelope Curve for Clearing of Aerated Pockets—F-P-S System
 Figures Beside Each Point Indicate Corresponding y/D : y = Approach Depth
 (After Wisner, Mohsen, & Kouwen⁶)




Fig. 9. Minimum Velocity vs Pipe Slope Recommended by Various Researchers—F-P-S System

and slope were identical. Slope of the EGL was 0.07 deg at 23.4 ML/day (6.2 mgd) or approximately 0.14 deg at 32.5 ML/day (8.6 mgd). Pipe slope is 0.20 deg.

Design of Pipelines to Prevent Air Binding

The following suggested design procedure incorporates other published recommendations along with the author's experience.

Step 1. Many unanticipated air pockets seem to be caused by the uncontrolled laying-to-cover of a pipeline. Typically the pipeline right of way is surveyed along a line offset from the centerline location. This profile is plotted on cross section sheets and air release valve locations determined by its use. A simple lay-to-cover specification permits the contractor to lay the pipeline at any depth so long as it is below the specified cover. Also, ground surface elevation differences may exist between the offset profile and the ground profile over the pipe centerline. It is suggested that if a lay-to-cover specification is preferred, the contract specify that the installed pipeline be profiled by the contractor as part of his work; as an alternative, cost permitting, the pipeline could be laid to a predetermined grade, particularly in hilly areas. This may permit the elimination of air release valves at intermediate high points (Fig. 10).

Step 2. Depending on the approach, the pipeline should be laid out to a trial profile. The design flow is then imposed on the pipeline to determine where air release valves are required for proper flow after the design flow is achieved.

Kennison⁹ reported that where the energy grade line of a pipe during flow has a slope steeper than the pipe slope, bubbles move along easily because of the decreasing pressure gradient. In other words, the reference for air propagation is not necessarily a level line, but rather the energy grade line.

Alternatively, or at higher flows, one of the previously discussed criteria for pipe slope vs clearing velocity may be used. Because of air binding occurrences which conflict with some researchers' recommendations, conservative judgment is urged. For example, Kennison⁹ placed air release valves at two obvious high points preceding steep descending legs—stations 25 + 50 and 46 + 64 (Fig. 11). Where air release valves are not yet placed but air binding is predicted, an energy loss equal to the vertical component of the descending leg should be included in the calculations.

Step 3. The pipeline should be analyzed for starting the flow. (With enough air-bound legs, the available head may not be able to start flow.) Assuming the worst case, the designer should total the vertical components of the remaining unvented descending legs and compare

that figure with the available head. If the available head is less than or equal to the sum of these energy losses, the flow may not start. Therefore, additional release valves must be added until the energy grade line permits a flow that will clear all remaining flow pockets. Note that in the Fig. 11 profile, even with the aforementioned air valves, the starting head was not sufficient to overcome the remaining air-bound descending legs. Therefore, additional air release valves were added at stations 9 + 20 and 31 + 00.

Where it is difficult to obtain a sufficiently flat downgrade, it is better to have the steepest part of the slope near the upstream end and the flattest part near the downstream end. If the water flow cannot remove the air pocket, the loss of head will then be confined to a relatively short length of pipe. If the steepest invert grade were located near the downstream end of the slope, the air pocket would extend back to the top of the descending leg, causing a much greater head loss. Furthermore, the shorter the descending leg, the steeper the slope that can safely be designed, since the worst that might happen would be binding over a short section.

Investigators have found that a positive pipe slope in the direction of flow can be installed at any slope without encountering air problems in the ascending line.

Whitsett and Christiansen⁹ report that the Metropolitan Water Dist. of Southern California experienced air problems caused by cascading; their experience indicates that the most severe problems occur with hydraulic jumps at vertical or horizontal bends in the pipeline. They recommend keeping the line and grade straight from the peak of the line to below the static water surface if cascading is necessary. Also, they have found that venting downstream of the hydraulic jump controls pressure surging but does not relieve white water.

In some circumstances it is desirable to obtain a sub-atmospheric siphon condition at knees above the operating energy grade line. Kennison has been successful in installing a combination air release and vacuum priming valve at such a point (station 47 + 00 of the Whitehall pipeline profile shown in Fig. 11). This valve releases air until the line approaches the normal depth for the flow resulting from the energy grade line with unprimed siphon. At this point it closes and remains closed as the water sweeps air pockets from the siphon knee. Kennison's data indicate that upon release of vacuum at this and other points, vacuum recovery occurs rapidly. Of course, the valve should always be installed below the minimum water surface of the upstream reservoir so that in case of air leakage into the pipe

upstream of this valve some flow would still be maintained.

Conclusions

Additional field data will confirm one or more of these recommendations for minimum velocity to clear air pockets. A simple technique is to close existing air release valves on lines known to receive air from vertical turbine pumps or gases from septic sewage. In each case studied, the following data should be reliably noted:

1. Pipe slope—preferably expressed as the sine of the descending angle
2. Type of pipe material, its age, and, if possible, roughness coefficient. This will permit future evaluation of the effect of wall roughness on air removal.
3. Pipe inside diameter
4. Maximum sustained flow or, if little variation, average flow
5. Whether or not air pockets were discovered downstream of the knee. These data can be organized and plotted as shown in Fig. 9. (The author would appreciate receiving any such data.)

References

1. KENNISON, K.R. The Design of Pipe Lines. *Jour. NEWWA*, 47:27 (1933).
2. KALINSKE, A.A. & ROBERTSON, J.M. Closed Conduit Flow. *Trans. ASCE*, 108:1435, Paper 2195 (1943).
3. KALINSKE, A.A. & BLISS, P.H. Removal of Air From Pipe Lines by Flowing Water. *Civ. Engrg., ASCE*, 13:10:480 (Oct. 1943).
4. KENT, JOSEPH C. The Entrapment of Air by Water Flowing in Circular Conduits With Downgrade Slopes. Doctoral thesis, Univ. of California, Berkeley, Calif. (1952).
5. GANDENBERGER, W. Design of Overland Water Supply Pipe Lines for Economy and Operational Reliability (In German). Munich, Germany (1957). A summary has been prepared by W.A. MECHLER, A Discussion of Factors Influencing Flow in Large Conduits. *Jour. Hydr. Div., ASCE*, 92:HY4:203, (Jul. 1966).
6. WISNER, P.E.; MOHSEN, F.N.; & KOUWEN, N. Removal of Air From Water Lines by Hydraulic Means. *Jour. Hydr. Div., ASCE*, 101:HY2:245, Proceedings Paper 11142 (Feb. 1975).
7. RICHARDS, R.T. Air Binding in Large Pipe Lines Flowing Under Vacuum. *Jour. Hydr. Div., ASCE*, 83:HY6:1454-1, Proceedings Paper 1454 (Dec. 1957).
8. BABB, A.F. & JOHNSON, W.K. Performance Characteristics of Siphon Outlets. *Jour. Hydr. Div., ASCE*, 94:HY6:1421, Proceedings Paper 6237 (Nov. 1968).
9. WHITSETT, A.M. & CHRISTIANSEN, L.E. Air In Transmission Mains. *Jour. AWWA*, 61:11:592 (Nov. 1969).

A paper contributed to and selected by the JOURNAL, authored by Robert C. Edmunds (Active Member, AWWA), exec. vice pres., Jones, Edmunds & Assoc., Inc., Gainesville, Fla.

EXHIBIT CRCE-1

PAGE 44 OF 48

ATTACHMENT 5

$V/(gD)^{0.5}$ vs. $(\sin\theta)^{0.5}$




FIGURE 1. Indication of potential air binding under normal network demand (Test 3, Event 2).

$V/(gD)^{0.5}$ vs. $(\sin\theta)^{0.5}$




FIGURE 2. Indication of potential for air binding with hydrant flow.

DOCKET 950495-WS

Ex. No. 99

EXHIBIT NO. 99

CASE NO. 96-04227

Company: SSU/FPSC Jurisd.-Conventional Treatment
Docket No. 950495-WS
Schedule Year Ended: 12/31/96
Interim [] Final [X]
Historical [] Projected [X]
FPSC Uniform [X] FPSC Non-Uniform [X]
Conventional Treatment [X] Reverse Osmosis []

Explanation: Provide calculations, analysis, and governmental requirements used to determine the used & useful percentages for the water distribution and wastewater collection systems for the historical and the projected test year (if applicable). The capacity should be in terms of ability to serve a designated number of connections. It should then be related to actual connected density for historical year calculations. Explain all assumptions for projected calculations. If the distribution and collection systems are entirely contributed or built out, this schedule is not required.

FPSC Schedules F-7(W)
Page 3 of 12
Preparer: Bliss
Recap Sched: A-5, A-9, B-13

Line No.	Description	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
			Citrus Park	Citrus Springs	Crystal River	Daetwyler Shores	Deltona Lakes	Dol Ray Manor	Druid Hills	East Lake Harris Est.	Fern Park

1	Transmission and Distribution										
2	CONNECTED LOTS 1996 w/ 1 Yr. MR	355	1,944	78	124	24,537	59	247	178	178	
3	NUMBER OF LOTS	335	11,667	91	138	34,940	77	335	214	208	
4	CALCULATED PERCENTAGE	100.00% [2]	16.66%	85.49%	89.52%	70.23%	76.39%	73.73%	83.41%	85.40%	
5	U&U PER ORDER	100.00%	21.00%	100.00%	100.00%	89.30%	100.00%	100.00%	100.00%	100.00%	
6	REQUESTED U & U [1]	100.00%	42.71% **	100.00%	100.00%	89.30%	100.00%	100.00%	100.00%	100.00%	

[1] Composite percentage based on gross plant balances for the NARUC accounts applicable to each component
[2] If calculated percentage exceeds 100% with MR, then 100% is requested

** Based on Cybernet Hydraulic Model Results

FLORIDA PUBLIC SERVICE COMMISSION
DOCKET NO. 950495 EXHIBIT NO 99
COMPANY/
WITNESS:
DATE: 4/29/96

USED AND USEFUL CALCULATIONS
WATER DISTRIBUTION SYSTEMS

Company: SSU/FPSC Jurisd.-Conventional Treatment
Docket No. 950495-WS
Schedule Year Ended: 12/31/96
Interim Final
Historical Projected
FPSC Uniform FPSC Non-Uniform
Conventional Treatment Reverse Osmosis

Explanation: Provide calculations, analysis, and governmental requirements used to determine the used & useful percentages for the water distribution and wastewater collection systems for the historical and the projected test year (if applicable). The capacity should be in terms of ability to serve a designated number of connections. It should then be related to actual connected density for historical year calculations. Explain all assumptions for projected calculations. If the distribution and collection systems are entirely contributed or built out, this schedule is not required.

FPSC
Schedules F-7(W)
Page 7 of 12
Preparer: Bliss
Recap Sched: A-5, A-9,
B-13

Line No.	(1) Description	(2) 1106 Marlon Oaks	(3) 330 Meredith Manor	(4) 562 Morningview	(5) 993 Oak Forest	(6) 1702 Oakwood	(7) 579 Palisades	(8) 440 Palm Port	(9) 1429 Palm Terrace	(10) 559 Palms Mobile Home Park
1	<u>Transmission and Distribution</u>									
2	CONNECTED LOTS 1996 w/ 1 Yr. MR	2,816	640	36	147	209	57	110	1,185	59
3	NUMBER OF LOTS	12,262	867	42	287	191	141	137	1,213	87
4	CALCULATED PERCENTAGE	22.98%	73.81%	85.90%	51.28%	100.00% [2]	40.08%	80.22%	97.65%	67.82%
5	U&U PER ORDER	34.40%	85.20%	100.00%	50.70%	100.00%	6.30%	67.50%	100.00%	69.00%
6	REQUESTED U & U [1]	66.83% **	85.20%	100.00%	51.28%	100.00%	40.08%	80.22%	100.00%	69.00%

[1] Composite percentage based on gross plant balances for the NARUC accounts applicable to each component
[2] If calculated percentage exceeds 100% with MR, then 100% is requested.

** Based on Cybernet Hydraulic Model Results

USED AND USEFUL CALCULATIONS
WATER DISTRIBUTION SYSTEMS

Company: SSU/FPSC Jurisd.-Conventional Treatment
Docket No. 950495-WS
Schedule Year Ended: 12/31/96
Interim [] Final [X]
Historical [] Projected [X]
FPSC Uniform [X] FPSC Non-Uniform [X]
Conventional Treatment [X] Reverse Osmosis []

Explanation: Provide calculations, analysis, and governmental requirements used to determine the used & useful percentages for the water distribution and wastewater collection systems for the historical and the projected test year (if applicable). The capacity should be in terms of ability to serve a designated number of connections. It should then be related to actual connected density for historical year calculations. Explain all assumptions for projected calculations. If the distribution and collection systems are entirely contributed or built out, this schedule is not required.

FPSC
Schedules F-7(W)
Page 8 of 12
Preparer: Bliss
Recap Sched: A-5, A-8,
B-13

Line No.	(1) Description	(2) Picciola Island	(3) Pine Ridge	(4) Pine Ridge Estates	(5) Piney Woods	(6) Point O'Woods	(7) Pomona Park	(8) Postmaster Village	(9) Quail Ridge	(10) River Grove
----------	--------------------	------------------------	-------------------	---------------------------	--------------------	----------------------	--------------------	---------------------------	--------------------	---------------------

1	Transmission and Distribution									
2	CONNECTED LOTS 1996 w/ 1 Yr. MR	140	892	227	171	375	175	165	30	104
3	NUMBER OF LOTS	213	3,828	292	215	415	535	345	114	119
4	CALCULATED PERCENTAGE	65.61%	23.30%	77.91%	79.44%	90.43%	32.72%	47.75%	26.20%	87.48%
5	U&U PER ORDER	100.00%	20.00%	100.00%	76.50%	83.50%	32.00%	44.70%	15.80%	100.00%
6	REQUESTED U & U [1]	100.00%	100.00% **	100.00%	79.44%	90.43%	32.72%	47.75%	26.20%	100.00%

[1] Composite percentage based on gross plant balances for the NARUC accounts applicable to each component

[2] If calculated percentage exceeds 100% with MR, then 100% is requested.

** Based on Cybemet Hydraulic Model Results

**USED AND USEFUL CALCULATIONS
WATER DISTRIBUTION SYSTEMS**

Company: SSU/FPSC Jurisd.-Conventional Treatment
 Docket No. 950495-WS
 Schedule Year Ended: 12/31/96
 Interim [] Final [X]
 Historical [] Projected [X]
 FPSC Uniform [X] FPSC Non-Uniform [X]
 Conventional Treatment [X] Reverse Osmosis []

Explanation: Provide calculations, analysis, and governmental requirements used to determine the used & useful percentages for the water distribution and wastewater collection systems for the historical and the projected test year (if applicable). The capacity should be in terms of ability to serve a designated number of connections. It should then be related to actual connected density for historical year calculations. Explain all assumptions for projected calculations. If the distribution and collection systems are entirely contributed or built out, this schedule is not required.

FPSC
 Schedules F-7(W)
 Page 10 of 12
 Preparer: Bliss
 Recap Sched: A-5, A-9,
 B-13

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	
Line No.	Description	Sugarmill Woods	Sunny Hills (Wells 1&4)	Sunny Hills (Well 5)	Sunshine Parkway	Tropical Park	University Shores	Venetian Village	Weiaka/Saratoga Harbor	Westmont
1	Transmission and Distribution									
2	CONNECTED LOTS 1996 w/ 1 Yr. MR	2,755	435	4	15	534	4,027	145	135	141
3	NUMBER OF LOTS	8,252	5,377	491	40	671	5,100	223	249	167
4	CALCULATED PERCENTAGE	33.39%	8.09%	0.81%	38.23%	79.58%	78.95%	65.13%	54.04%	84.19%
5	U&U PER ORDER	22.40%	11.00%	N/A	100.00%	81.40%	100.00%	61.70%	54.00%	100.00%
6	REQUESTED U & U [1]	33.39%	28.09% **	28.09% *	100.00%	81.40%	100.00%	65.13%	54.04%	100.00%

[1] Composite percentage based on gross plant balances for the NARUC accounts applicable to each component.
 [2] If calculated percentage exceeds 100% with MR, then 100% is requested

** Based on Cybernet Hydraulic Model Results