

Florida Power

HTC.

JAMES A. MCGEE SENIOR COUNSEL

FPSC-RECORDS/REPORTING

January 21, 1997

Ms. Blanca S. Bayó, Director Division of Records and Reporting Florida Public Service Commission 2540 Shumard Oak Boulevard Tallahassee, Florida 32399-0850

Re: Docket No. 970001-EI

Dear Ms. Bayó:

Enclosed for filing in the subject docket are an original and fifteen copies of the Preliminary List of Issues and Positions of Florida Power Corporation.

Please acknowledge your receipt of the above filing on the enclosed copy of this letter and return to the undersigned. Also enclosed is a 3.5 inch diskette containing the above-referenced document in WordPerfect format. Thank you for

A Florida Progress Company

	our assistance in this matter.		•
ACK		Very truly yours,	2
CAF		James A. McGee	,
A 700 400	AM/kp Enclosures		
- 11	c: Parties of record		
LEG			
LIN 3	RECEIVED & FILLO		
OPC	.41		
RCH	EDGG FUND		DOCUMENT NUMBER-DATE
SEC _	FPSC-BUREAU OF RECORD	GENERAL OFFICE	
WAS _2201 Thirty-	fourth Street South • Post Office Box 14042	• St. Petersburg, Florida 33733-4042 • (813) 86 DEA DEBE (1918) 866-4931
2	A 51	adda Desarrage Company	

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Fuel and Purchased Power
Cost Recovery Clause with
Generating Performance Incentive
Factor.

Docket No. 970001-EI

Submitted for filing: January 22, 1997

PRELIMINARY LIST OF ISSUES AND POSITIONS OF FLORIDA POWER CORPORATION

Florida Power Corporation (FPC), hereby submits its Preliminary List of Issues and Positions with respect to its levelized fuel and capacity cost recovery factors and its Generating Performance Incentive Factor (GPIF) for the period of April through September, 1997, and states as follows:

Generic Fuel Adjustment Issues

 ISSUE: What are the appropriate final fuel adjustment true-up amounts for the period of April through September 1996?

FPC: \$59,049,902 under-recovery. (Scardino)

ISSUE: What are the estimated fuel adjustment true-up amounts for the period of October 1996 through March 1997?

FPC: \$43,124,413 under-recovery. (Wieland)

 ISSUE: What are the total fuel adjustment true-up amounts to be collected during the period of April through September 1997?

FPC: \$102,174,315 under-recovery. However, FPC proposes to collect \$54,288,997 of the under-recovery during the April - September 1997 period (see company-specific issue __ below). (Wieland)

4. <u>ISSUE</u>: What are the appropriate levelized fuel cost recovery factors for the period of April through September 1997?

FPC: 2.385 cents per kWh (adjusted for jurisdictional losses). (Wieland)

5. <u>ISSUE</u>: What should be the effective date of the new fuel cost recovery factors and oil backout factors, if any, for billing purposes?

FPC: The new factors should be effective beginning with the first billing cycle for April, 1997, and thereafter through the last billing cycle for September, 1997. The first billing cycle may start before April 1, 1997, and the last billing cycle may end after September 30, 1997, so long as each customer is billed for six months regardless of when the factors became effective.

6. <u>ISSUE</u>: What are the appropriate fuel recovery loss multipliers to be used in calculating the fuel cost recovery factors charged to each rate/delivery voltage level group?

FPC:	Delivery	Line Loss	
Group	Voltage Level	Multiplier	
A.	Transmission	0.9800	
В.	Distribution Primary	0.9900	
C.	Distribution Secondary	1.0000	
D.	Lighting Service	1.0000	(Wieland)

7. <u>ISSUE</u>: What are the appropriate fuel cost recovery factors for each rate/delivery voltage level group, adjusted for line losses?

FPC:		Fuel Cost	Factors (cents/kWh)			
	Delivery	Time Of Use				
Group	Voltage Level	Standard	On-Peak	Off-Peak		
Α.	Transmission	2.342	3.031	1.967		
B.	Distribution Primary	2.366	3.062	i.987		
C.	Distribution Secondary	2.390	3.093	2.008		
D.	Lighting Service	2.210				
				(Wieland)		

 ISSUE: What is the appropriate revenue tax factor to be applied in calculating the levelized fuel factor for the projection period of April through September, 1997?

FPC: 1.00083 (Wieland)

Company-Specific Fuel Adjustment Issues

 ISSUE: Should the Commission approve FPC's request to recover the cost of converting 4 additional combustion turbine units at Debary(1), Suwannee(1), and Bartow(2) to burn natural gas?

FPC: Yes. FPC is requesting the same treatment for these units as the Commission approved in prior hearings for Intercession City units 7 - 10. The cost of conversion (\$7.5 million) is not included in FPC's base rates and will enable FPC to achieve fuel savings in excess of \$22 million over the next five years. (Wieland)

 ISSUE: Should the Commission approve FPC's proposal to collect the March-ending true-up under-recovery over a 12-month period beginning in April 1997?

FPC: Yes. Spreading the collection of the true-up under-recovery over a 12-month period will lessen the rate impact on customers. (Wieland)

Generic Generating Performance Incentive Factor Issues

11. <u>ISSUE</u>: What is the appropriate GPIF reward or penalty for performance achieved during the period of April through September, 1996?

FPC: \$431,674 reward. (Zuloaga)

12. <u>ISSUE</u>: What should the GPIF targets/ranges be for the period of April through September, 1997?

FPC: See Attachment A. (Zuloaga)

Generic Capacity Cost Recovery Issues

13. <u>ISSUE</u>: What is the appropriate final capacity cost recovery true-up amount for the period of April through September 1996?

FPC: \$3,700,279 over-recovery. (Scardino)

14. <u>ISSUE</u>: What is the estimated capacity cost recovery true-up amount for the period of October 1996 through March 1997?

FPC: \$8,476,789 under-recovery. (Wieland)

15. ISSUE: What is the total capacity cost recovery true-up amount to be collected during the period of April through September 1997?

FPC: \$4,776,510 under-recovery. (Wieland)

16. <u>ISSUE</u>: What is the appropriate projected net purchase power capacity cost recovery amount to be included in the recovery factor for the period April through September 1997?

FPC: \$146,689,671 (Wieland)

17. <u>ISSUE</u>: What are the projected capacity cost recovery factors for the period of April through September 1997?

FPC:	Rate Class	CCR Factor
1000	Residential	1.068 cents/kWh
	General Service Non-Demand	.845 cents/kWh
	@ Primary Voltage	.837 cents/kWh
	@ Transmission Voltage	.829 cents/kWh
	General Service 100% Load Factor	.583 cents/kWh
	General Service Demand	.704 cents/kWh
	@ Primary Voltage	.697 cents/kWh
	@ Transmission Voltage	.689 cents/kWh
	Curtailable	.590 cents/kWh
	@ Primary Voltage	.585 cents/kWh
	@ Transmission Voltage	.579 cents/kWh
	Interruptible	.553 cents/kWh
	@ Primary Voltage	.547 cents/kWh
	Primary Voltage Transmission Voltage	.542 cents/kWh
	Lighting	.204 cents/kWh (Wieland)

Respectfully submitted,

OFFICE OF THE GENERAL COUNSEL FLORIDA POWER CORPORATION

James A. McGee

Post Office Box 14042

St. Petersburg, FL 33733-4042

Telephone: (813) 866-5184 Facsimile: (813) 866-4931

GPIF TARGET AND RANGE SURBIARY

Company: Florida Power Corporation Period of: Apr. 1997 - Sep. 1997

	Weighting	EAF	EAF	RANGE	Max. Fuel	Max. Fuel
	Factor	Target	Max.	Min.	Savings	Loss
Plant/Unit	(%)	(%)	(%)	(2)	(8000)	(\$000)
				•••••		
ANC. 1	1.20	92.60	94.28	89.20	198.7	432.7
ANC. 2	1.74	96.57	98.19	93.24	287.8	667.9
C.R. 1	6.79	88.73	92.96	80.28	1125.9	130.4
C.R. 2	16.35	83.52	90.07	71.01	2710.0	-1470.9
C.R. 3	35.19	91.17	95.06	83.26	5833.6	0.0
C.R. 4	5.04	94.08	96.87	88.37	836.2	1766.9
C.R. 5	2.01	75.53	77.02	72.48	334.0	763.5
GPIF System	68.32				11326.2	2290.5

1	Weighting	ANOHR Tar	get	ANOHR	RANGE	Max. Fuel	necessipea.imimimimi
	Factor			Min.	Max.	Savinga	Loss
Plant/Unit	(%)	(BTU/KMI)	NOF	(%)	(%)	(\$000)	(\$000)
		• ••••••	•••	•••••			
ANC. 1	5.99	9745	77.2	9400	10090	993.3	993.3
ANC. 2	4.23	9741	71.8	9481	10001	701.3	701.3
C.R. 1	1.87	9946	80.6	9796	10096	309.9	309.9
C.R. 2	2.58	9788	94.3	9638	9938	428.0	428.0
C.R. 3	7.93	10473	99.3	10304	10642	1315.4	1315.4
C.R. 4	4.80	9370	87.5	9220	9520	795.0	796.0
C.R. 5	4.27	9270	99.0	9120	9420	707.1	707.1
GPIF System	31.68					5251.0	5251.0

Issued by: FPC

Filed: Suspended: Effective: Docket No.: Order No.:

ATTACHMENT A