

REQUEST TO ESTABLISH DOCKET
(PLEASE TYPE)

Date 2-7-00

Docket No. 000154-54

1. Division Name/Staff Name Appeals/C. Moore *CM*
2. OPR C. Moore (APP)
3. OCR B. Crouch (WAW), M. Willis (WAW), C. Hewitt/AFA
4. Suggested Docket Title Proposed Rule 25-30.432, F.A.C., Flows to be Used for Wastewater Treatment Plant Used and Useful Calculations

5. Suggested Docket Mailing List (attach separate sheet if necessary)

- A. Provide NAMES ONLY for regulated companies or ACRONYMS ONLY regulated industries, as shown in Rule 25-22.104, F.A.C.
- B. Provide COMPLETE name and address for all others. (Match representatives to clients.)
 1. Parties and their representatives (if any)

<u>SU</u>	
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

2. Interested Persons and their representatives (if any)

_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

6. Check one:
- Documentation is attached.
- Documentation will be provided with the recommendation.

1 25-30.432 Flows to be Used for Wastewater Treatment Plant
2 Used and Useful Calculations. The used and useful percentage of
3 a wastewater treatment plant shall be calculated using a ratio of
4 actual flows, plus the amount calculated pursuant to Rule 25-
5 30.431 and minus excess infiltration and inflow, to the permitted
6 plant capacity. The denominator shall be the plant capacity as
7 stated on the permit issued by the Department of Environmental
8 Protection for the utility's treatment plant. The flows in the
9 numerator shall be the flow data stated in the same unit of
10 measurement as the denominator.

11 Specific Authority: 350.167(2), 367.121(1)(f), FS.

12 Law Implemented: 367.081(2), FS.

13 History: New _____.

14 I:\amend\30-432.ctm

15

16

17

18

19

20

21

22

23

24

25

CODING: Words underlined are additions; words in
~~struck through~~ type are deletions from existing law.