



**Maria J. Moncada**  
Senior Attorney  
Florida Power & Light Company  
700 Universe Boulevard  
Juno Beach, FL 33408-0420  
(561) 304-5795  
(561) 691-7135 (Facsimile)  
E-mail: maria.moncada@fpl.com

April 20, 2018

**-VIA ELECTRONIC FILING -**

Ms. Carlotta S. Stauffer  
Commission Clerk  
Florida Public Service Commission  
2540 Shumard Oak Blvd.  
Tallahassee, FL 32399-0850

**Re: Docket No. 20180001-EI**

Dear Ms. Stauffer:

I enclose for electronic filing in the above docket Florida Power & Light Company's ("FPL") GPIF Actual Unit Performance Data Schedules covering the month of March 2018. These schedules are being filed at the same time but separately from its monthly filing of the A Schedules.

If there are any questions regarding this transmittal, please contact me at (561) 304-5795.

Sincerely,

*s/ Maria J. Moncada*  
Maria J. Moncada

Enclosures

cc: Counsel for Parties of Record (w/encl.)

**CERTIFICATE OF SERVICE**

**Docket No. 20180001-EI**

**I HEREBY CERTIFY** that a true and correct copy of the foregoing has been furnished

by electronic service on this 20th day of April 2018 to the following:

Suzanne Brownless, Esq.  
Danijela Janjic, Esq.  
**Division of Legal Services**  
**Florida Public Service Commission**  
2540 Shumard Oak Blvd.  
Tallahassee, Florida 32399-0850  
sbrownle@psc.state.fl.us  
djanjic@psc.state.fl.us

J.R. Kelly, Esq.  
Patricia Christensen, Esq.  
Charles Rehwinkel, Esq.  
Erik L. Sayler, Esq.  
**Office of Public Counsel**  
c/o The Florida Legislature  
111 West Madison Street, Room 812  
Tallahassee, Florida 32399  
kelly.jr@leg.state.fl.us  
christensen.patty@leg.state.fl.us  
rehwinkel.charles@leg.state.fl.us  
sayler.erik@leg.state.fl.us

Paula K. Brown, Manager  
**Tampa Electric Company**  
Regulatory Coordinator  
Post Office Box 111  
Tampa, Florida 33601-0111  
regdept@tecoenergy.com

James D. Beasley, Esq.  
J. Jeffrey Wahlen, Esq.  
Ausley & McMullen  
P.O. Box 391  
Tallahassee, Florida 32302  
jbeasley@ausley.com  
jwahlen@ausley.com  
**Attorneys for Tampa Electric Company**

Andrew Maurey  
Michael Barrett  
**Division of Accounting and Finance**  
**Florida Public Service Commission**  
2540 Shumard Oak Blvd.  
Tallahassee, Florida 32399-0850  
amaurey@psc.state.fl.us  
mbarrett@psc.state.fl.us

Matthew R. Bernier, Esq.  
106 East College Avenue, Suite 800  
Tallahassee, Florida 32301  
matthew.bernier@duke-energy.com

Dianne M. Triplett, Esq.  
299 First Avenue North  
St. Petersburg, Florida 33701  
dianne.triplett@duke-energy.com  
**Attorneys for Duke Energy Florida**

Jeffrey A. Stone  
Rhonda J. Alexander  
**Gulf Power Company**  
One Energy Place  
Pensacola, Florida 32520-0780  
jastone@southernco.com  
rjalexad@southernco.com

Russell A. Badders, Esq.  
Steven R. Griffin, Esq.  
Beggs & Lane  
P.O. Box 12950  
Pensacola, Florida 32591-2950  
rab@beggslane.com  
srg@beggslane.com  
**Attorneys for Gulf Power Company**

Mike Cassel  
Director, Regulatory and Governmental  
Affairs

**Florida Public Utilities Company**  
1750 S.W. 14th Street, Suite 200  
Fernandina Beach, Florida 32034  
mcassel@fpuc.com

Beth Keating, Esq.  
Gunster Law Firm  
215 South Monroe St., Suite 601  
Tallahassee, Florida 32301-1804  
bkeating@gunster.com

**Attorneys for Florida  
Public Utilities Company**

Robert Scheffel Wright, Esq.  
John T. LaVia, III, Esq.  
Gardner, Bist, Wiener, et al  
1300 Thomaswood Drive  
Tallahassee, Florida 32308  
schef@gbwlegal.com  
jlavia@gbwlegal.com  
**Attorneys for Florida Retail Federation**

James W. Brew, Esq.  
Laura A. Wynn, Esq.  
Stone Mattheis Xenopoulos & Brew, PC  
1025 Thomas Jefferson Street, NW  
Eighth Floor, West Tower  
Washington, DC 20007-5201  
jbrew@smxblaw.com  
law@smxblaw.com  
**Attorneys for PCS Phosphate -  
White Springs**

Jon C. Moyle, Esq.  
Moyle Law Firm, P.A.  
118 N. Gadsden St.  
Tallahassee, Florida 32301  
jmoyle@moylelaw.com  
**Attorneys for Florida Industrial Power  
Users Group**

By: s/ Maria J. Moncada  
Maria J. Moncada  
Florida Bar No. 0773301

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

FROM: Jan-2018 TO: Dec-2018

		PLANT / UNIT: CAPE CANAVERAL 03											PCC 03	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	99.4	99.7	97.9	0	0	0	0	0	0	0	0	0	99
2.	PH	744	672	743	0	0	0	0	0	0	0	0	0	2159
3.	SH	744	672	743	0	0	0	0	0	0	0	0	0	2159
4.	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5.	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10.	LR PP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11.	PFOH	358.58	260.47	296.75	0	0	0	0	0	0	0	0	0	915.8
12.	LR PF (MW)	16.56	9.05	15.18	0	0	0	0	0	0	0	0	0	13.98
13.	PMOH	0	0	37.73	0	0	0	0	0	0	0	0	0	37.73
14.	LR PM (MW)	0	0	412.69	0	0	0	0	0	0	0	0	0	412.69
15.	NSC	1268	1268	1268	0	0	0	0	0	0	0	0	0	1268
16.	OPER BTU (MBTU)	4800432	3582593	4251424	0	0	0	0	0	0	0	0	0	12634449
17.	NET GEN	734720	544496	645782	0	0	0	0	0	0	0	0	0	1924998
18.	ANOHR (BTU/KWH)	6534	6580	6583	0	0	0	0	0	0	0	0	0	6563
19.	NOF (%)	77.9	63.9	68.5	0	0	0	0	0	0	0	0	0	70.3
20.	NPC (MW)	1275	1275	1275	0	0	0	0	0	0	0	0	0	1275

21.	ANOHR EQUATION	ANOHR = A + B (N.O.F.) A = 0                      B = 0											
-----	----------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 FROM: Jan-2018 TO: Dec-2018

		PLANT / UNIT: RIVIERA 05						PRV 05						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	84.9	91.5	92.2	0	0	0	0	0	0	0	0	0	89.5
2.	PH	744	672	743	0	0	0	0	0	0	0	0	0	2159
3.	SH	709.65	672	743	0	0	0	0	0	0	0	0	0	2124.65
4.	RSH	18.78	0	0	0	0	0	0	0	0	0	0	0	18.78
5.	UH	15.57	0	0	0	0	0	0	0	0	0	0	0	15.57
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0.08	0	0	0	0	0	0	0	0	0	0	0	0.08
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10.	LR PP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11.	PFOH	31.77	31.27	4.67	0	0	0	0	0	0	0	0	0	67.7
12.	LR PF (MW)	742.02	409.27	404.37	0	0	0	0	0	0	0	0	0	565.14
13.	PMOH	180.02	140.5	111.03	0	0	0	0	0	0	0	0	0	431.55
14.	LR PM (MW)	624.94	404.65	613.79	0	0	0	0	0	0	0	0	0	550.35
15.	NSC	1214	1214	1214	0	0	0	0	0	0	0	0	0	1214
16.	OPER BTU (MBTU)	2930873	3425668	3776192	0	0	0	0	0	0	0	0	0	10132733
17.	NET GEN	438762	520298	568913	0	0	0	0	0	0	0	0	0	1527973
18.	ANOHR (BTU/KWH)	6680	6584	6638	0	0	0	0	0	0	0	0	0	6631
19.	NOF (%)	50.9	63.8	63.1	0	0	0	0	0	0	0	0	0	59.2
20.	NPC (MW)	1253	1253	1253	0	0	0	0	0	0	0	0	0	1253

21.	ANOHR EQUATION	ANOHR = A + B (N.O.F.) A = 0                      B = 0											
-----	----------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 FROM: Jan-2018 TO: Dec-2018

		PLANT / UNIT: WEST COUNTY ENER 03											PWC 03	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	59.2	69.1	64.1	0	0	0	0	0	0	0	0	0	64
2.	PH	744	672	743	0	0	0	0	0	0	0	0	0	2159
3.	SH	513.55	672	743	0	0	0	0	0	0	0	0	0	1928.55
4.	RSH	2.4	0	0	0	0	0	0	0	0	0	0	0	2.4
5.	UH	228.05	0	0	0	0	0	0	0	0	0	0	0	228.05
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	225.7	0	0	0	0	0	0	0	0	0	0	0	225.7
9.	PPOH	0	240	743	0	0	0	0	0	0	0	0	0	983
10.	LR PP (MW)	0	385.03	385.03	0	0	0	0	0	0	0	0	0	385.03
11.	PFOH	5.13	7.6	4.73	0	0	0	0	0	0	0	0	0	17.47
12.	LR PF (MW)	228.15	635.81	385.25	0	0	0	0	0	0	0	0	0	447.9
13.	PMOH	208.82	372.5	52.5	0	0	0	0	0	0	0	0	0	633.82
14.	LR PM (MW)	425.6	381.83	384.98	0	0	0	0	0	0	0	0	0	396.51
15.	NSC	1155	1155	1155	0	0	0	0	0	0	0	0	0	1155
16.	OPER BTU (MBTU)	2557520	2904273	3075622	0	0	0	0	0	0	0	0	0	8537414
17.	NET GEN	356147	410656	439919	0	0	0	0	0	0	0	0	0	1206722
18.	ANOHR (BTU/KWH)	7181	7072	6991	0	0	0	0	0	0	0	0	0	7075
19.	NOF (%)	60	52.9	51.3	0	0	0	0	0	0	0	0	0	54.2
20.	NPC (MW)	1215	1215	1215	0	0	0	0	0	0	0	0	0	1215

21.	ANOHR EQUATION	ANOHR = A + B (N.O.F.) A = 0                      B = 0											
-----	----------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

FROM: Jan-2018 TO: Dec-2018

		PLANT / UNIT: FORT MYERS 02						PFM 02						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	99.2	85.8	46.7	0	0	0	0	0	0	0	0	0	77
2.	PH	744	672	743	0	0	0	0	0	0	0	0	0	2159
3.	SH	744	672	402.5	0	0	0	0	0	0	0	0	0	1818.5
4.	RSH	0	0	340.5	0	0	0	0	0	0	0	0	0	340.5
5.	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	338.02	743	0	0	0	0	0	0	0	0	0	1081.02
10.	LR PP (MW)	0	370.32	640.41	0	0	0	0	0	0	0	0	0	555.96
11.	PFOH	152.05	65.23	0	0	0	0	0	0	0	0	0	0	217.28
12.	LR PF (MW)	61.62	247.82	0	0	0	0	0	0	0	0	0	0	117.52
13.	PMOH	0	0	331.88	0	0	0	0	0	0	0	0	0	331.88
14.	LR PM (MW)	0	0	339.98	0	0	0	0	0	0	0	0	0	339.98
15.	NSC	1486	1486	1486	0	0	0	0	0	0	0	0	0	1486
16.	OPER BTU (MBTU)	5046880	4706402	2405177	0	0	0	0	0	0	0	0	0	12158459
17.	NET GEN	686615	660856	332939	0	0	0	0	0	0	0	0	0	1680410
18.	ANOHR (BTU/KWH)	7350	7122	7224	0	0	0	0	0	0	0	0	0	7235
19.	NOF (%)	62.1	66.2	55.7	0	0	0	0	0	0	0	0	0	62.2
20.	NPC (MW)	1681	1681	1681	0	0	0	0	0	0	0	0	0	1681

21.	ANOHR EQUATION	ANOHR = A + B (N.O.F.) A = 0                      B = 0											
-----	----------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THE SYSTEM

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 FROM: Jan-2018 TO: Dec-2018

		PLANT / UNIT: ST LUCIE 01 PSL 01												
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	100	100	34.3	0	0	0	0	0	0	0	0	0	77.4
2.	PH	744	672	743	0	0	0	0	0	0	0	0	0	2159
3.	SH	744	672	263.02	0	0	0	0	0	0	0	0	0	1679.02
4.	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5.	UH	0	0	479.98	0	0	0	0	0	0	0	0	0	479.98
6.	POH	0	0	479.98	0	0	0	0	0	0	0	0	0	479.98
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	25.05	0	0	0	0	0	0	0	0	0	25.05
10.	LR PP (MW)	0	0	308.2	0	0	0	0	0	0	0	0	0	308.2
11.	PFOH	0	0	0	0	0	0	0	0	0	0	0	0	0
12.	LR PF (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
13.	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	0
14.	LR PM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
15.	NSC	981	981	981	0	0	0	0	0	0	0	0	0	981
16.	OPER BTU (MBTU)	7661898	6920566	2621364	0	0	0	0	0	0	0	0	0	17203828
17.	NET GEN	750977	674061	254996	0	0	0	0	0	0	0	0	0	1680034
18.	ANOHR (BTU/KWH)	10203	10267	10280	0	0	0	0	0	0	0	0	0	10240
19.	NOF (%)	102.9	102.2	98.8	0	0	0	0	0	0	0	0	0	102
20.	NPC (MW)	981	981	981	0	0	0	0	0	0	0	0	0	981

21.	ANOHR EQUATION	ANOHR = A + B (N.O.F.) A = 0 B = 0											
-----	----------------	---------------------------------------	--	--	--	--	--	--	--	--	--	--	--

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:



ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 FROM: Jan-2018 TO: Dec-2018

		PLANT / UNIT: ST LUCIE						PSL 02						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	100	100	100	0	0	0	0	0	0	0	0	0	100
2.	PH	744	672	743	0	0	0	0	0	0	0	0	0	2159
3.	SH	744	672	743	0	0	0	0	0	0	0	0	0	2159
4.	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5.	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10.	LR PP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11.	PFOH	0	0	0	0	0	0	0	0	0	0	0	0	0
12.	LR PF (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
13.	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	0
14.	LR PM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
15.	NSC	987	987	987	0	0	0	0	0	0	0	0	0	987
16.	OPER BTU (MBTU)	7663209	6921259	7652217	0	0	0	0	0	0	0	0	0	22236684
17.	NET GEN	760443	682139	756838	0	0	0	0	0	0	0	0	0	2199420
18.	ANOHR (BTU/KWH)	10077	10146	10111	0	0	0	0	0	0	0	0	0	10110
19.	NOF (%)	103.6	102.8	103.2	0	0	0	0	0	0	0	0	0	103.2
20.	NPC (MW)	987	987	987	0	0	0	0	0	0	0	0	0	987

21.	ANOHR EQUATION	ANOHR = A + B (N.O.F.) A = 0                      B = 0											
-----	----------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 FROM: Jan-2018 TO: Dec-2018

		PLANT / UNIT: TURKEY POINT 03											PTN 03	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	100	100	100	0	0	0	0	0	0	0	0	0	100
2.	PH	744	672	743	0	0	0	0	0	0	0	0	0	2159
3.	SH	744	672	743	0	0	0	0	0	0	0	0	0	2159
4.	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5.	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10.	LR PP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11.	PFOH	0	0	0	0	0	0	0	0	0	0	0	0	0
12.	LR PF (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
13.	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	0
14.	LR PM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
15.	NSC	811	811	811	0	0	0	0	0	0	0	0	0	811
16.	OPER BTU (MBTU)	6706472	6056789	6697889	0	0	0	0	0	0	0	0	0	19461149
17.	NET GEN	627593	561056	622898	0	0	0	0	0	0	0	0	0	1811548
18.	ANOHR (BTU/KWH)	10686	10795	10753	0	0	0	0	0	0	0	0	0	10743
19.	NOF (%)	104	102.9	103.4	0	0	0	0	0	0	0	0	0	103.5
20.	NPC (MW)	811	811	811	0	0	0	0	0	0	0	0	0	811

21.	ANOHR EQUATION	ANOHR = A + B (N.O.F.) A = 0                      B = 0											
-----	----------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 FROM: Jan-2018 TO: Dec-2018

		PLANT / UNIT: TURKEY POINT 04											PTN 04	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	100	100	100	0	0	0	0	0	0	0	0	0	100
2.	PH	744	672	743	0	0	0	0	0	0	0	0	0	2159
3.	SH	744	672	743	0	0	0	0	0	0	0	0	0	2159
4.	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5.	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10.	LR PP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11.	PFOH	0	0	0	0	0	0	0	0	0	0	0	0	0
12.	LR PF (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
13.	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	0
14.	LR PM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
15.	NSC	821	821	821	0	0	0	0	0	0	0	0	0	821
16.	OPER BTU (MBTU)	6706970	6054688	6697826	0	0	0	0	0	0	0	0	0	19459483
17.	NET GEN	632854	565919	628472	0	0	0	0	0	0	0	0	0	1827245
18.	ANOHR (BTU/KWH)	10598	10699	10657	0	0	0	0	0	0	0	0	0	10650
19.	NOF (%)	103.6	102.6	103	0	0	0	0	0	0	0	0	0	103.1
20.	NPC (MW)	821	821	821	0	0	0	0	0	0	0	0	0	821

21.	ANOHR EQUATION	ANOHR = A + B (N.O.F.) A = 0 B = 0											
-----	----------------	---------------------------------------	--	--	--	--	--	--	--	--	--	--	--

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 FROM: Jan-2018 TO: Dec-2018

		PLANT / UNIT: WEST COUNTY ENER 01											PWC 01	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	99.8	85.6	98.5	0	0	0	0	0	0	0	0	0	94.9
2.	PH	744	672	743	0	0	0	0	0	0	0	0	0	2159
3.	SH	744	577.48	735.92	0	0	0	0	0	0	0	0	0	2057.4
4.	RSH	0	0	0.17	0	0	0	0	0	0	0	0	0	0.17
5.	UH	0	94.52	6.91	0	0	0	0	0	0	0	0	0	101.43
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	94.52	5.42	0	0	0	0	0	0	0	0	0	99.93
9.	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10.	LR PP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11.	PFOH	2.52	2.93	3	0	0	0	0	0	0	0	0	0	8.45
12.	LR PF (MW)	542.31	385.46	306.52	0	0	0	0	0	0	0	0	0	404.21
13.	PMOH	0	3.8	9	0	0	0	0	0	0	0	0	0	12.8
14.	LR PM (MW)	0	428.06	640.04	0	0	0	0	0	0	0	0	0	578.01
15.	NSC	1155	1155	1155	0	0	0	0	0	0	0	0	0	1155
16.	OPER BTU (MBTU)	4104795	3285872	4437092	0	0	0	0	0	0	0	0	0	11827758
17.	NET GEN	579798	461476	622615	0	0	0	0	0	0	0	0	0	1663889
18.	ANOHR (BTU/KWH)	7080	7120	7127	0	0	0	0	0	0	0	0	0	7109
19.	NOF (%)	67.5	69.2	73.2	0	0	0	0	0	0	0	0	0	70
20.	NPC (MW)	1205	1205	1205	0	0	0	0	0	0	0	0	0	1205

21.	ANOHR EQUATION	ANOHR = A + B (N.O.F.) A = 0 B = 0											
-----	----------------	---------------------------------------	--	--	--	--	--	--	--	--	--	--	--

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 FROM: Jan-2018 TO: Dec-2018

		PLANT / UNIT: WEST COUNTY ENER 02											PWC 02	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	87.5	100	67.6	0	0	0	0	0	0	0	0	0	84.5
2.	PH	744	672	743	0	0	0	0	0	0	0	0	0	2159
3.	SH	738.97	650.97	575.35	0	0	0	0	0	0	0	0	0	1965.28
4.	RSH	5.03	21.03	0	0	0	0	0	0	0	0	0	0	26.07
5.	UH	0	0	167.65	0	0	0	0	0	0	0	0	0	167.65
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	167.65	0	0	0	0	0	0	0	0	0	167.65
9.	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10.	LR PP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11.	PFOH	3.95	0	0	0	0	0	0	0	0	0	0	0	3.95
12.	LR PF (MW)	388.36	0	0	0	0	0	0	0	0	0	0	0	388.36
13.	PMOH	274.45	0	145.18	0	0	0	0	0	0	0	0	0	419.63
14.	LR PM (MW)	388.31	0	586.95	0	0	0	0	0	0	0	0	0	457.03
15.	NSC	1165	1165	1165	0	0	0	0	0	0	0	0	0	1165
16.	OPER BTU (MBTU)	3636507	3631084	3004909	0	0	0	0	0	0	0	0	0	10272500
17.	NET GEN	506385	509534	428344	0	0	0	0	0	0	0	0	0	1444263
18.	ANOHR (BTU/KWH)	7181	7126	7015	0	0	0	0	0	0	0	0	0	7113
19.	NOF (%)	58.8	67.2	63.9	0	0	0	0	0	0	0	0	0	63.1
20.	NPC (MW)	1215	1215	1215	0	0	0	0	0	0	0	0	0	1215

21.	ANOHR EQUATION	ANOHR = A + B (N.O.F.) A = 0                      B = 0											
-----	----------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 FROM: Jan-2018 TO: Dec-2018

		PLANT / UNIT: MANATEE UNIT 3 CC 03											PM3	03
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	90.5	62.8	86.5	0	0	0	0	0	0	0	0	0	80.5
2.	PH	744	672	743	0	0	0	0	0	0	0	0	0	2159
3.	SH	668.55	496.58	743	0	0	0	0	0	0	0	0	0	1908.13
4.	RSH	6.52	5.48	0	0	0	0	0	0	0	0	0	0	12
5.	UH	68.93	169.94	0	0	0	0	0	0	0	0	0	0	238.87
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	68.93	169.93	0	0	0	0	0	0	0	0	0	0	238.87
9.	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10.	LR PP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11.	PFOH	0.47	8.48	19.17	0	0	0	0	0	0	0	0	0	28.12
12.	LR PF (MW)	292.41	294.62	294.45	0	0	0	0	0	0	0	0	0	294.47
13.	PMOH	4.92	310.88	382.25	0	0	0	0	0	0	0	0	0	698.05
14.	LR PM (MW)	421.25	295.97	294.5	0	0	0	0	0	0	0	0	0	296.03
15.	NSC	1178	1178	1178	0	0	0	0	0	0	0	0	0	1178
16.	OPER BTU (MBTU)	3889312	2680861	4522180	0	0	0	0	0	0	0	0	0	11092353
17.	NET GEN	566352	395189	665173	0	0	0	0	0	0	0	0	0	1626714
18.	ANOHR (BTU/KWH)	6867	6784	6799	0	0	0	0	0	0	0	0	0	6819
19.	NOF (%)	71.9	67.6	76	0	0	0	0	0	0	0	0	0	72.4
20.	NPC (MW)	1178	1178	1178	0	0	0	0	0	0	0	0	0	1178

21.	ANOHR EQUATION	ANOHR = A + B (N.O.F.) A = 0                      B = 0											
-----	----------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 FROM: Jan-2018 TO: Dec-2018

		PLANT / UNIT: MARTIN-UNIT 8 08							PM8 08					
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1.	EAF (%)	95.6	79	94.9	0	0	0	0	0	0	0	0	0	90.2
2.	PH	744	672	743	0	0	0	0	0	0	0	0	0	2159
3.	SH	744	672	743	0	0	0	0	0	0	0	0	0	2159
4.	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5.	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6.	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7.	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8.	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9.	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10.	LR PP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11.	PFOH	0	0	0	0	0	0	0	0	0	0	0	0	0
12.	LR PF (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
13.	PMOH	130.93	565.47	152.25	0	0	0	0	0	0	0	0	0	848.65
14.	LR PM (MW)	277.51	277.5	277.5	0	0	0	0	0	0	0	0	0	277.5
15.	NSC	1110	1110	1110	0	0	0	0	0	0	0	0	0	1110
16.	OPER BTU (MBTU)	3937618	3273855	4123534	0	0	0	0	0	0	0	0	0	11335008
17.	NET GEN	551375	470580	592207	0	0	0	0	0	0	0	0	0	1614162
18.	ANOHR (BTU/KWH)	7141	6957	6963	0	0	0	0	0	0	0	0	0	7022
19.	NOF (%)	66.8	63.1	71.8	0	0	0	0	0	0	0	0	0	67.4
20.	NPC (MW)	1195	1195	1195	0	0	0	0	0	0	0	0	0	1195
21.	ANOHR EQUATION	ANOHR = A + B (N.O.F.) A = 0 B = 0												

NOTE: LINE 17 IS DATA WHEN THE UNIT IS SYNCRONIZED TO THE SYSTEM

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: CAPE CANAVERAL 03

PCC 03

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/01/2018	PF	2.3	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/02/2018	PF	14.2	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/04/2018	PF	26.6	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/05/2018	PF	5.0	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/05/2018	PF	54.7	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/08/2018	PF	15.9	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/09/2018	PF	3.4	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/10/2018	PF	6.3	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/11/2018	PF	17.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/12/2018	PF	12.5	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/13/2018	PF	15.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/14/2018	PF	3.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/15/2018	PF	5.3	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/15/2018	PF	3.3	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/16/2018	PF	6.8	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/17/2018	PF	2.9	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/17/2018	PF	6.6	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/18/2018	PF	5.2	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/18/2018	PF	20.4	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/19/2018	PF	28.7	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/20/2018	PF	4.3	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/21/2018	PF	14.4	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/22/2018	PF	18.7	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/23/2018	PF	13.4	8	PCC - 31 CT Partial EFOR - VGV3 Issue

- (1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:



## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: CAPE CANAVERAL 03

PCC 03

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/24/2018	PF	13.7	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/25/2018	PF	3.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/26/2018	PF	3.5	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/27/2018	PF	2.6	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/28/2018	FF	2.8	263	PCC 3-2 Missed RFC
01/28/2018	PF	2.8	164.64	Impact loss due to curtailment on 32
01/28/2018	PF	5.8	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/29/2018	PF	10.8	164.64	Impact loss due to curtailment on 31
01/29/2018	PF	10.8	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/30/2018	PF	6.4	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/30/2018	PF	4.2	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/31/2018	PF	4.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue
01/31/2018	FF	0.2	263	PCC 3-3 Fire Protection System
01/31/2018	PF	0.2	164.7	Impact loss due to curtailment on 33
02/03/2018	PF	13.0	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/04/2018	PF	7.3	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/07/2018	PF	11.5	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/08/2018	PF	12.6	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/09/2018	PF	14.2	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/10/2018	PF	10.3	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/11/2018	PF	9.6	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/12/2018	PF	12.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/13/2018	PF	11.6	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/14/2018	PF	9.4	8	PCC - 31 CT Partial EFOR - VGV3 Issue

(1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:

ISSUED BY: FLORIDA POWER &amp; LIGHT CO.

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: CAPE CANAVERAL 03

PCC 03

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
02/16/2018	PF	12.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/17/2018	PF	10.8	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/18/2018	PF	10.8	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/19/2018	PF	13.9	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/20/2018	PF	1.1	93	3-3 FW Regulator
02/20/2018	PF	1.1	164.7	Impact loss due to curtailment on 33
02/20/2018	PF	10.7	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/21/2018	PF	10.5	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/22/2018	PF	11.5	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/23/2018	PF	6.7	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/24/2018	PF	10.0	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/25/2018	PF	9.4	8	PCC - 31 CT Partial EFOR - VGV3 Issue
02/26/2018	PF	13.6	8	PCC 31 CT PARTIAL EFOR VGV3 ISSUE
02/27/2018	PF	13.1	8	PCC 31 CT PARTIAL EFOR VGV3 ISSUE
02/28/2018	PF	14.9	8	PCC 31 PARTIAL EFOR VGV3 ISSUE
03/01/2018	PF	8.9	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/02/2018	PF	7.8	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/03/2018	PF	7.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/04/2018	PF	8.3	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/05/2018	PF	4.6	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/06/2018	PF	11.7	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/07/2018	FM	37.7	248	PCC 3-1 Event MOF - Feedwater Valve Repair
03/07/2018	PM	37.7	164.65	Impact loss due to curtailment on 31
03/09/2018	PF	4.9	8	PCC - 31 CT Partial EFOR - VGV3 Issue

(1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:

ISSUED BY: FLORIDA POWER &amp; LIGHT CO.

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: CAPE CANAVERAL 03

PCC 03

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
03/10/2018	PF	13.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/12/2018	PF	15.5	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/13/2018	PF	2.9	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/14/2018	PF	15.0	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/15/2018	PF	2.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/15/2018	PF	4.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/16/2018	PF	11.5	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/17/2018	PF	16.6	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/18/2018	PF	9.9	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/19/2018	PF	10.5	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/20/2018	PF	12.7	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/21/2018	PF	10.9	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/22/2018	PF	5.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/23/2018	PF	3.4	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/23/2018	PF	3.6	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/24/2018	PF	12.9	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/24/2018	PF	12.9	164.65	Impact loss due to curtailment on 31
03/25/2018	PF	11.9	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/26/2018	PF	14.7	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/27/2018	PF	11.6	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/28/2018	PF	14.0	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/29/2018	PF	14.6	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/30/2018	PF	14.8	8	PCC - 31 CT Partial EFOR - VGV3 Issue
03/31/2018	PF	12.1	8	PCC - 31 CT Partial EFOR - VGV3 Issue

(1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:

ISSUED BY: FLORIDA POWER &amp; LIGHT CO.

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: RIVIERA

05

PRV 05

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/15/2018	FM	129.4	247	PRV 52 CT Event MOF - HRSG Tube Leak
01/15/2018	PM	129.4	157.65	Impact loss due to curtailment on 52
01/16/2018	PM	116.6	157.65	Impact loss due to curtailment on 51
01/16/2018	FM	132.4	247	PRV 51 CT Event MOF - HRSG Tube Leak
01/21/2018	FF	2.1	247	CT 52 Start Up Failure Due to GV2 valve failing to open
01/21/2018	PF	2.1	157.65	Impact loss due to curtailment on 52
01/21/2018	PF	0.4	157.65	Impact loss due to curtailment on 52
01/21/2018	FF	16.3	247	PRV 52 CT EFOR/Full Forced: Poor HRSG chemistry
01/21/2018	FF	15.9	473	PRV ST EFOR/Full Forced: Poor Chem from Condensor Tube
01/21/2018	FF	19.7	247	PRV 53 CT EFOR/Full Forced: Poor HRSG chemistry
01/22/2018	FF	0.1	247	PRV 51 CT EFOR/Full Forced: Poor HRSG chemistry
01/22/2018	PF	4.1	237	PRV ST EOFR/Partial Forced: Poor Chem from Condenser Tu
01/22/2018	PF	4.1	123	PRV 52 CT EFOR/Partial Forced: Poor HRSG chemistry
01/22/2018	PF	4.1	157.69	Impact loss due to curtailment on 53
01/23/2018	FF	4.9	473	PRV ST EFOR/Full Forced: Missed RFC due to Bad Chemistr
01/23/2018	PF	0.7	151	PRV CT EFOR/Partial Forced: Missed RFC
01/25/2018	FM	20.7	247	PRV 52 CT Event MOF - Main Steam to Cold Reheat Drain Lir
01/25/2018	PM	20.7	157.65	Impact loss due to curtailment on 52
01/29/2018	FF	4.4	247	PRV CT 53 EFOR/Full Forced: VGV 3 signal mismatch
01/29/2018	PF	4.4	157.69	Impact loss due to curtailment on 53
01/31/2018	FM	1.7	247	PRV 52 CT Event MOF - Lift Oil Pump Maintenance
01/31/2018	PM	1.7	157.65	Impact loss due to curtailment on 52
02/01/2018	FM	100.9	247	PRV 52 CT Event MOF - Lift Oil Pump Leak
02/01/2018	PM	100.9	157.65	Impact loss due to curtailment on 52

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 From: Jan-2018 To: Dec-2018

PLANT / UNIT: RIVIERA 05 PRV 05

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
02/12/2018	FF	2.1	473	PRV ST EFOR/Full Forced: Low Condenser Vacuum
02/14/2018	FF	0.6	247	CT 53 Trip: Turbine Temperature Outlet Spread
02/14/2018	PF	0.6	157.69	Impact loss due to curtailment on 53
02/16/2018	FM	39.6	247	PRV 51 CT Event MOF- LP Preheater #2 Drain Leak
02/16/2018	PM	39.6	157.65	Impact loss due to curtailment on 51
02/18/2018	FF	26.2	247	PRV HRSG 52 EFOR/Full Forced: MS to CRH drain steam lea
02/18/2018	PF	26.2	157.65	Impact loss due to curtailment on 52
02/20/2018	FF	2.4	247	CT 52 Start-up Failure Human Performance, HP to CRH Byp v
02/20/2018	PF	2.4	157.65	Impact loss due to curtailment on 52
03/02/2018	FM	111.0	247	PRV 53 Event MOF - HP Drum Level Control Valve Vibration
03/02/2018	PM	111.0	157.7	Impact loss due to curtailment on 53
03/02/2018	FM	57.4	247	PRV 52 HRSG Event MOF - Blowdown Sample Pipe Leak
03/02/2018	PM	57.4	157.65	Impact loss due to curtailment on 52
03/05/2018	FF	3.4	247	CT 52 EFOR, HP DSH Flow Sensing Line Rupture
03/05/2018	PF	3.4	157.65	Impact loss due to curtailment on 52
03/09/2018	FF	0.7	247	PRV CT 52 Failed Start, HRSG Protection Trip
03/09/2018	PF	0.7	157.65	Impact loss due to curtailment on 52
03/26/2018	FF	0.6	247	CT 53 Trip: Turbine Temperature Outlet Spread
03/26/2018	PF	0.6	157.7	Impact loss due to curtailment on 53

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: WEST COUNTY ENERGY 03

PWC 03

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/06/2018	PM	11.1	156.98	Impact loss due to curtailment on 3A
01/06/2018	FM	237.1	228	PWC 3A Event MOF - ST Reheat Valve Leak
01/06/2018	PM	9.2	156.98	Impact loss due to curtailment on 3B
01/06/2018	FM	239.0	228	PWC 3B Event MOF - ST Reheat Valve Leak
01/06/2018	FM	238.4	471	PWC 3ST Event MOF - ST Reheat Valve Leak
01/06/2018	FM	270.3	228	PWC 3C Event MOF - ST Reheat Valve Leak
01/16/2018	FF	5.1	228	PWC 3A EFOR / Full Forced - Blade Path Temp Deviation
01/16/2018	PM	32.2	157.03	Impact loss due to curtailment on 3C
01/21/2018	FM	152.8	228	PWC 3C Event MOF - HRH Isolation Valve Fails to Operate
01/21/2018	PM	152.8	157.03	Impact loss due to curtailment on 3C
02/03/2018	FM	372.5	228	PWC 3C Task MOF - Condition Assessment
02/03/2018	PM	364.9	157.03	Impact loss due to curtailment on 3C
02/08/2018	PF	0.0	156.98	Impact loss due to curtailment on 3A
02/08/2018	FF	5.5	228	PWC 3A EFOR / Full Forced - Switchyard Relay Trip
02/08/2018	FF	7.6	471	PWC 3ST EFOR / Full Forced - Switchyard Relay Trip
02/19/2018	FP	983.0	228	PWC 3C POF - CT Major Overhaul & Kai Upgrade
02/19/2018	PP	983.0	157.03	Impact loss due to curtailment on 3C
03/03/2018	FM	52.5	228	PWC 3B Event MOF - Cooling Steam Leak
03/03/2018	PM	52.5	156.98	Impact loss due to curtailment on 3B
03/22/2018	FF	4.7	228	PWC 3B EFOR / Full Forced - Fuel Gas Tophat Valve Deviatio
03/22/2018	PF	4.7	156.98	Impact loss due to curtailment on 3B

- (1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:

ACTUAL PERFORMANCE DATA  
 COMPANY: FLORIDA POWER AND LIGHT  
 From: Jan-2018 To: Dec-2018

PLANT / UNIT: FORT MYERS 02 PFM 02

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/01/2018	PF	96.1	22	PFM ST1 Partail EFOR - Grounded CWP Motor
01/05/2018	FF	39.3	57	PFM ST1 EFOR - Hydraulic Line Break CV2
01/18/2018	FF	16.6	170	PFM 2D EFOR 89SS Failure
01/18/2018	PF	16.6	68.3	Impact loss due to curtailment on 2D
01/18/2018	PF	16.6	9.51	Impact loss due to curtailment on 2D
01/18/2018	FF	3.6	170	PFM 2E EFOR 89SS Failure (2D)
01/18/2018	PF	3.6	68.3	Impact loss due to curtailment on 2E
01/18/2018	PF	3.6	9.51	Impact loss due to curtailment on 2E
02/05/2018	FF	26.2	170	PFM 2E EFOR Generator breaker would not close
02/05/2018	PF	26.2	68.3	Impact loss due to curtailment on 2E
02/05/2018	PF	26.2	9.51	Impact loss due to curtailment on 2E
02/08/2018	FF	8.6	170	PFM 2D EFOR 89ND Failure
02/08/2018	PF	8.6	68.3	Impact loss due to curtailment on 2D
02/08/2018	PF	8.6	9.51	Impact loss due to curtailment on 2D
02/14/2018	FP	1081.0	170	PFM 2D Planned Outage - 3SAR Upgrade
02/14/2018	PP	732.7	68.3	Impact loss due to curtailment on 2D
02/14/2018	PP	746.8	9.51	Impact loss due to curtailment on 2D
02/17/2018	FF	26.5	170	2C CT EFOR - 89ND breaker faulty
02/17/2018	PF	26.5	68.3	Impact loss due to curtailment on 2C
02/17/2018	PF	26.5	9.51	Impact loss due to curtailment on 2C
02/19/2018	FF	4.0	170	2C CT EFOR - 41AC-2 failed to operate
02/19/2018	PF	4.0	68.3	Impact loss due to curtailment on 2C
02/19/2018	PF	4.0	9.51	Impact loss due to curtailment on 2C
02/22/2018	FP	910.1	170	PFM 2B Planned Outage - 3SAR Upgrade

(1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

ISSUED BY: FLORIDA POWER & LIGHT CO.

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: FORT MYERS 02

PFM 02

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
02/22/2018	PP	561.8	68.3	Impact loss due to curtailment on 2B
02/22/2018	PP	575.9	9.51	Impact loss due to curtailment on 2B
03/04/2018	FP	334.2	57	PFM ST1 - Planned Outage - Generator Minor
03/05/2018	FP	332.0	409	PFM ST2 - Planned Outage - Generator Minor
03/05/2018	FM	163.9	170	PFM 2A Task MOF - Reliability Outage.
03/05/2018	FM	163.8	170	PFM 2F Task MOF - Reliability Outage
03/11/2018	FM	168.0	170	PFM 2E Task MOF - Reliability Outage.
03/11/2018	FM	168.0	170	PFM 2C Task MOF - Reliability Outage.
03/18/2018	FP	16.4	409	PFM ST2 Planned Outage Extension - Generator Minor

- (1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:



## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: ST LUCIE 01

PSL 01

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
03/10/2018	PP	6.9	173.26	U1 PEL SL1-28 Down Power Part 1
03/11/2018	PP	14.2	313.62	U1 PEL MSSV Testing/SL1-28 down power 03112018
03/11/2018	PP	4.0	519.78	U1 PEL SL1-28 Down Power part 2 to breaker open 031118
03/12/2018	FP	480.0	981	U1 PEL SL1-28 Refueling and Maintenance

- (1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: WEST COUNTY ENERGY 01

PWC 01

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/12/2018	FF	1.3	471	PWC 1 ST EFOR / Full Forced - MS MOV/High drum level logi
01/12/2018	FF	1.5	228	PWC 1A EFOR / Full Forced - HRSG MCC Water Intrusion
01/12/2018	PF	0.2	156.98	Impact loss due to curtailment on 1A
01/22/2018	FF	1.1	228	PWC 1B EFOR / Full Forced - BFP Low Flow Trip
01/22/2018	PF	1.1	156.98	Impact loss due to curtailment on 1B
02/14/2018	FF	2.9	228	PWC 1C EFOR / Full Forced - Low Combustor Differential Pre
02/14/2018	PF	2.9	157.02	Impact loss due to curtailment on 1C
02/24/2018	PM	3.4	157.02	Impact loss due to curtailment on 1C
02/24/2018	FM	37.8	228	PWC 1C Event MOF - U1 HP to Aux Steam Control Valve Rep
02/25/2018	FM	31.4	471	PWC 1ST Event MOF - U1 HP to Aux Steam Control Valve Re
02/25/2018	FM	31.2	228	PWC 1B Event MOF - U1 HP to Aux Steam Control Valve Rep
02/25/2018	FM	31.0	228	PWC 1A Event MOF - U1 HP to Aux Steam Control Valve Rep:
02/26/2018	FM	68.9	228	PWC 1A Event MOF Extension - U1 HP to Aux Steam Control
02/26/2018	FM	70.6	228	PWC 1B Event MOF Extension - U1 HP to Aux Steam Control
02/26/2018	FM	75.0	471	PWC 1ST Event MOF Extention - U1 HP to Aux Steam Contro
02/26/2018	FM	73.7	228	PWC 1C Event MOF Extension - U1 HP to Aux Steam Control
03/01/2018	FF	1.5	228	PWC 1A EFOR / Start-up Failure - Large Blade Path Temp Var
03/01/2018	PM	1.7	157.02	Impact loss due to curtailment on 1C
03/17/2018	FF	1.5	228	PWC 1C EFOR / Full Forced - Inadvertent Shut off of BFP
03/17/2018	PF	1.5	157.03	Impact loss due to curtailment on 1C
03/31/2018	FM	1.2	228	PWC 1A Event MOF - SCR Cleaning
03/31/2018	PM	1.2	156.98	Impact loss due to curtailment on 1A

- (1) FFO - FULL FORCED OUTAGE  
 PPO - PARTIAL PLANNED OUTAGE  
 PMO - PARTIAL MAINTENANCE OUTAGE  
 PO - PLANNED OUTAGE  
 PFO - PARTIAL FORCED OUTAGE  
 FMO - FULL MAINTENANCE OUTAGE

FILED:  
 SUSPENDED:  
 EFFECTIVE:  
 DOCKET NO.:  
 ORDER NO.:

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: WEST COUNTY ENERGY 02

PWC 02

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/04/2018	FF	4.0	230	PWC 2C EFOR / Start-up Failure - Gen Breaker Relay Trouble
01/04/2018	PF	4.0	158.36	Impact loss due to curtailment on 2C
01/05/2018	FM	210.0	230	PWC 2B Event MOF - BFP Mechanical Seal Repair
01/05/2018	PM	210.0	158.31	Impact loss due to curtailment on 2B
01/19/2018	FM	64.5	230	PWC 2A Event MOF - HRH Bypass Relief Valve Leaking
01/19/2018	PM	64.5	158.31	Impact loss due to curtailment on 2A
03/18/2018	PM	145.0	158.32	Impact loss due to curtailment on 2B
03/18/2018	FM	312.8	230	PWC 2B Task MOF - 2018 Reliability Outage
03/21/2018	PM	74.0	158.37	Impact loss due to curtailment on 2C
03/21/2018	FM	241.8	230	PWC 2C Task MOF - 2018 Reliability Outage
03/25/2018	FM	167.9	475	PWC 2ST Task MOF - 2018 Reliability Outage
03/25/2018	FM	167.7	230	PWC 2A Task MOF - 2018 Reliability Outage

(1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:

ISSUED BY: FLORIDA POWER &amp; LIGHT CO.

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: MANATEE UNIT 3 CC 03

PM3 03

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/02/2018	FF	0.5	175	3A EFOR - Unit tripped on haz gas alarm
01/02/2018	PF	0.5	119.5	Impact loss due to curtailment on 3A
01/19/2018	PM	4.4	119.5	Impact loss due to curtailment on 3A
01/19/2018	FM	73.9	175	PMT 3A Event MOF - Main Header Isolation Valve Failure
01/20/2018	PM	1.1	119.5	Impact loss due to curtailment on 3B
01/20/2018	FM	70.5	175	PMT 3B Event MOF - Main Header Isolation Valve Failure
01/20/2018	FM	69.4	478	PMT 3ST Event MOF - Main Header Isolation Valve Failure
01/20/2018	FM	69.2	175	PMT 3C Event MOF - Main Header Isolation Valve Failure
01/20/2018	FM	68.9	175	PMT 3D Event MOF - Main Header Isolation Valve Failure
02/08/2018	FF	2.2	175	PMT 3A EFOR - Failed to synchronize
02/08/2018	PF	2.2	119.5	Impact loss due to curtailment on 3A
02/08/2018	PM	165.6	119.5	Impact loss due to curtailment on 3B
02/08/2018	FM	167.8	175	PMT 3B Task MOF - HRSG Cleaning
02/12/2018	FF	5.1	175	PMT 3C EFOR - Operator closed HP LCV inadvertently
02/12/2018	PF	5.1	119.5	Impact loss due to curtailment on 3C
02/15/2018	PM	1.0	119.5	Impact loss due to curtailment on 3C
02/15/2018	FM	171.2	175	PMT 3C Task MOF - Scheduled Reliability Outage
02/15/2018	FM	170.2	478	PMT 3ST Task MOF - Scheduled Reliability Outage
02/15/2018	FM	170.1	175	PMT 3A Task MOF - Scheduled Reliability Outage
02/15/2018	FM	169.9	175	PMT 3D Task MOF - Scheduled Reliability Outage
02/15/2018	FM	168.0	175	PMT 3B Task MOF - Scheduled Reliability Outage
02/22/2018	FM	168.0	175	PMT 3A Task MOF - Scheduled Reliability Outage
02/22/2018	PM	168.0	119.5	Impact loss due to curtailment on 3A
02/24/2018	FF	1.2	175	PMT3B EFOR - Operator closed bfp recirc inadvertently

(1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: MANATEE UNIT 3 CC 03

PM3 03

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
02/24/2018	PF	1.2	119.5	Impact loss due to curtailment on 3B
03/02/2018	FM	166.7	175	PMT 3D Task MOF - Scheduled Reliability Outage
03/02/2018	PM	166.7	119.5	Impact loss due to curtailment on 3D
03/06/2018	FF	19.2	175	PMT 3B EFOR - FW Regulating Valve Failed
03/06/2018	PF	19.2	119.5	Impact loss due to curtailment on 3B
03/21/2018	FM	165.5	175	PMT 3B Task MOF - For Scheduled HRSG Cleaning
03/21/2018	PM	165.5	119.5	Impact loss due to curtailment on 3C
03/30/2018	FM	27.1	175	PMT 3D Task MOF - For Scheduled HRSG Cleaning
03/30/2018	PM	27.1	119.5	Impact loss due to curtailment on 3D

(1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:

ISSUED BY: FLORIDA POWER &amp; LIGHT CO.

## ACTUAL PERFORMANCE DATA

COMPANY: FLORIDA POWER AND LIGHT

From: Jan-2018

To: Dec-2018

PLANT / UNIT: MARTIN-UNIT 8 08

PM8 08

DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
01/23/2018	FM	130.9	165	PMR 8A Event MOF - 8A Superheat 2 Tube Leak Repair
01/23/2018	PM	130.9	112.5	Impact loss due to curtailment on 8A
02/04/2018	FM	167.7	165	PMR 8C Task MOF - 8C Planned Reliability Outage (7 Day)
02/04/2018	PM	167.7	112.5	Impact loss due to curtailment on 8C
02/11/2018	FM	163.3	165	PMR 8D Task MOF - 8D Planned Reliability Outage (7 Day)
02/11/2018	PM	163.3	112.5	Impact loss due to curtailment on 8D
02/19/2018	FM	162.1	165	PMR 8A Task MOF - 8A Planned Reliability Outage (7 Day)
02/19/2018	PM	162.1	112.5	Impact loss due to curtailment on 8A
02/25/2018	FM	163.5	165	PMR 8B Task MOF - 8B Planned Reliability Outage (7 Day)
02/25/2018	PM	163.5	112.5	Impact loss due to curtailment on 8B
03/08/2018	FM	32.6	165	PMR 8C Event MOF - Liquid Fuel Leak Repairs in CT Compar
03/08/2018	PM	32.6	112.5	Impact loss due to curtailment on 8C
03/27/2018	FM	28.7	165	PMR 8D Event MOF - Liquid Fuel Leak Repair on Supply Line
03/27/2018	PM	28.7	112.5	Impact loss due to curtailment on 8D

(1) FFO - FULL FORCED OUTAGE  
PPO - PARTIAL PLANNED OUTAGE  
PMO - PARTIAL MAINTENANCE OUTAGE  
PO - PLANNED OUTAGE  
PFO - PARTIAL FORCED OUTAGE  
FMO - FULL MAINTENANCE OUTAGE

FILED:  
SUSPENDED:  
EFFECTIVE:  
DOCKET NO.:  
ORDER NO.:

ISSUED BY: FLORIDA POWER &amp; LIGHT CO.

**GPIF Units**  
**Actual Performance Data (ACRONYMS) for 2018**

ACRONYMS	DESCRIPTION
"R"	Mark VI "R" Processor
1A2	Unit 1 Pump A2
1B	Unit 1 Pump B
2B1	Unit 2 Pump B1
2A	Unit 2 Combustion Turbine (sub unit A)
2A CT - 2A 230	Combustion Turbine (sub unit A) - 2A Collector Bus
2A HDP	2 Alpha High Differential Pressure
2B	Unit 2 Combustion Turbine (sub unit B)
2B CT - 2A 230	Combustion Turbine (sub unit B) - 2A Collector Bus
2B MSR	2 Bravo Moisture Separator Reheater
2C	Unit 2 Combustion Turbine (sub unit C)
2C CT - 2A 230	Combustion Turbine (sub unit C) - 2A Collector Bus
2D	Unit 2 Combustion Turbine (sub unit D)
2E	Unit 2 Combustion Turbine (sub unit E)
2F	Unit 2 Combustion Turbine (sub unit F)
3 CTB	Unit 3 Combustion Turbine (sub unit B)
3A	Unit 3 Combustion Turbine (sub unit A)
3B	Unit 3 Combustion Turbine (sub unit B)
3C	Unit 3 Combustion Turbine (sub unit C)
3D	Unit 3 Combustion Turbine (sub unit D)
3ST	Unit 3 Steam Turbine
41AC-1	Breaker 1 for Power Supply to Exciter
41AC-2	Breaker 2 for Power Supply to Exciter
4A	Unit 4 Combustion Turbine (sub unit A)
4A SGFP	4A Steam Generator Feedwater Pump
4B	Unit 4 Combustion Turbine (sub unit B)
4C	Unit 4 Combustion Turbine (sub unit C)
4D	Unit 4 Combustion Turbine (sub unit D)
4KV	4 Thousand Volts
5A	Unit 5 Combustion Turbine (sub unit A)
5B	Unit 5 Combustion Turbine (sub unit B)
5C	Unit 5 Combustion Turbine (sub unit C)
5D	Unit 5 Combustion Turbine (sub unit D)
5ST	Unit 5 Steam Turbine
8A	Unit 8 Combustion Turbine (sub unit A)
8B	Unit 8 Combustion Turbine (sub unit B)
8C	Unit 8 Combustion Turbine (sub unit C)
8D	Unit 8 Combustion Turbine (sub unit D)
8X	Unit 8 Steam Turbine
89SS	Static Start Switch
89ND	Neutral disconnect switch on the generator
AA	Anhydrous Ammonia
AA HX	Atomizing Air Heat Exchanger
ABV	Air Block Valve
ACV-3	Automatic Control Valve # 3
ACV-408	Air Control Valve Tag 408
AFW	Auxiliary Feed Water
AIG	Ammonia Injection Grid
ANOHR	AVERAGE Net Operating Heat Rate
ASGJ-BV-27ED	A (unit 2A) SGJ (hot reheat to condenser) BV ( block valve) 27 (#) ED ( valve bypass)
AUX	Auxiliary
AVR	Automatic Voltage Regulator
BAB36	European designation for foundation mounted cabinet. 36 is the switch # located in that cabinet

**GPIF Units  
Actual Performance Data (ACRONYMS) for 2018**

ACRONYMS	DESCRIPTION
BBLs	Barrels
BFP	Boiler Feed Pump
BFPT	Boiler Feed Pump Turbine
BRG	Bearing
BRK	Breaker
BSGG	Unit B, main steam section of HRSG
BTU	British Thermal Units
CF	Capacity Factor
CBV	Compressor Bleed Valve
CEA	Control Element Assembly
CEA 38	Control Element Assembly Number 38
CEA 65	Control Element Assembly Number 65
CED	Compressor Exit Diffuser
CEDM	Control Element Drive Mechanism
Circ	Circulating (water pump)
com	Communication
comm	Communication
CPFM	Combustor Pressure Fluctuation Monitor
Cpk	Process Capability Index – or process variability considering specs; 'C <sub>pk</sub> should be 1.33 [4 sigma] or higher to satisfy most customers.'
CRH	Cold Reheat
CT	Combustion Turbine
CT C	Combustion Turbine (sub unit C)
CTG SRV	Speed Ratio Valve on Combustion Turbine (gas system)
CV-4-1510	Control Valve Number 4-1510
CVA	Cyber (security) Vulnerability Assessment
CW	Circulating Water
CWP	Circulating Water Pump
DCS	Distributed Control System
DEH	Digital Electro Hydraulic
DFS	Debris Filtration System
diff	Differential
DLN	Dry Low Nox
DP	Differential Pressure
DSH	DeSuperHeater
DWATT	Term used by General Electric as Auxiliary Megawatt Transducer
DWATT XDUCER	Megawatt transducer
DX	DeXcitation
EAF	Equivalent Availability Factor
ECCS	Emergency Core Cooling System
EFOR	Equivalent Forced Outage Rate
EFPD	Effective Full Power Days
EHC	Hydraulic
EJ	Expansion Joint
EOC	End of cycle
EPU	Extended Power Uprate
ESGA	System code for Ft. Myers 2E HRSG
EXP	Expansion
Fa	Failed
FCBBS	Florida Cost Based Broker System
FENA	Future Enterprise Network A
FGT	Florida Gas Transmission
FME	Foreign Material Exclusion



**GPIF Units  
Actual Performance Data (ACRONYMS) for 2018**

ACRONYMS	DESCRIPTION
FMPA	Florida Municipal Power Agency
FPI	Fluorescent penetrant inspection
FPSC	Florida Public Service Commission
FSGJ	F is the unit (2F) SGJ is the system designator
FSNL	Full Speed No Load
FRV	Feedwater Regulating Valve
FTEs	Full Time Equivalent Employees including: Headcount, O.T. i.e. Overtime, & Contractors
FW	Feedwater
FWA	Boiler Feedwater
FWC	Feedwater Control
GCV	Gas Control Valve
GE	General Electric
GPIF	Generating Performance Incentive Factor
GSU	Generator Step Up
GTE	Generator Terminal Enclose
Haz	Hazardous
HC	Headcount
HDP	Heater Drain Pump
HI	High
HMI	Human Machine Interface
HP	High Pressure
HRH	Hot Reheat
HRSG	Heat Recovery Steam Generator
HTF	Heat Transfer Fluid
I/O	Input / Output
IBH	Inlet Bleed Heat Valve
ID	Induced Draft
IGV	Inlet guide vanes
Instr.	Instrumentation
IP	Intermediate Pressure
IRP	Integrated Resource Plan
ISO	Isolation
kWh	Kilowatt Hour
LEFM	Leading Edge Flow Meter
LOI	Letter of Instruction
LCI	Load Commutating Inverter
LCO	Limiting Conditions for Operation
LF	Liquid Fuel
LL	Low Low
LO	Low
LP	Low Pressure
MAJOR	Major Overhaul
MCC	Motor Control Center
MCF	Million cubic feet
PMG	Martin
MS	Main Steam
PMT	Manatee
MFIV	Main Feed Isolation Valve
MF PP	Main Feed Pump
MFW	Main Feed Water
MG	Motor Generator
MMBTU	Million British Thermal Units
MOF	Maintenance Outage Factor

**GPIF Units  
Actual Performance Data (ACRONYMS) for 2018**

<b>ACRONYMS</b>	<b>DESCRIPTION</b>
MOF/AA	Maintenance Outage Factor / Atomizing Air
MOV	Motorized Operating Valve
MRE	Manuel Reject
MSR	Moisture Separator Reheater
MS	Main Steam
MSSV	Main Steam Safety Valve
MSIV	Main Steam Isolation Valves
MTC	Moderator Temperature Coefficient
MW	Megawatt
MUV	Motor actuated <u>U</u> nidirectional <u>V</u> alve
MTC	Moderator Temperature Coefficient
MW	Megawatt
MWh	Megawatt Hour
NEE	NEXtera Energy
NEL	Net Energy for Load
ND	Neutral Disconnect
NHR	Net Heat Rate
NO	No
NSC	Net Summer Continuous Capacity
O/H	Overhaul
OLWW	Off-Line Water Wash
OMC	Outside Management Control
OS	Off-system Sales
OUC	Orlando Utilities Commission
P&C	Protect and Control
POF	Planned Outage Factor
PEL	Planned Energy Loss
PFM	Ft. Myers
PM1	Gas Valve Number 1
PM3	Gas Valve Number 3
PDM	Power Delivery Module
Pmp	Pump
PPA	Purchased Power Agreement
PSE	Cooling Steam Supply
PSF	Cooling Steam Return
PSL	St Lucie
PSR	Sanford
PT	Potential transformer
PWR	Power
QF	Qualifying Facilities
RAP	Resource Assessment & Planning Dept.
R	Repair
R0	Row 0 blades on steam turbine
R1	Row 1 blades on steam turbine
RCP	Reactor Coolant Pump
RCS	Reactor Coolant System
RFC	Ready For Control
RFO	Refueling Outage
RH	Reheat
RPS	Reactor Protection System
RSD	Reserve Shutdown

**GPIF Units  
Actual Performance Data (ACRONYMS) for 2018**

ACRONYMS	DESCRIPTION
RSV	Reheat Stop Valve
RSV1	Reheat Stop Valve Number 1
RV	Release Valve
RW	Repetitive Work
S/U	Startup
SGFP	Steam Generator Feed Pump
SGG	Main Steam - High Pressure
SGJ-ACV-10	System Designator Air Control Valve
SH	Super heat
SIT	Safety Injection Tank
SL1-23	St Lucie Unit 1 cycle 23 refueling outage
SL2-19	St Lucie Unit 2 cycle 19 refueling outage
SNO	Short Notice Outage
SNOW	Short Notice Outage Work
SRV	Speed Ratio Valve
STARS	Strategic Anti Rotation Stall Surge testing
ST	Steam Turbine
ST1	Steam Turbine Number 1
ST2	Steam Turbine Number 2
STG or SG	Steam Generator
STM 1	Steam Turbine Number 1
STM 2	Steam Turbine Number 2
TYSP	Ten Year Site Plan
T-Ave	Temperature Average
TC or T/Cs	Thermal/Couples
TCW HX	Turbine Cooling Water Heat Exchanger
TMOF	Task MOF
TVT	Turbine Valve Testing
U1	Unit 1
U2	Unit 2
UEL	Unplanned Energy Loss
ULPM1	Ultra Lean Pre-Mix Valve # 1
UPS	Unit Power Sales Agreement
VCMI	Communication interface board for Mark 6 ovation system
Vi	Roman Numeral 6
VGW	Variable Guide Vane
VLV	Valve
VSV	Variable Stator Vanes
VTUR	"V" stands for speed and "TUR" is for turbine
WI	Water Injection
Wobbee	Water warms up gas fired units to 35 MWs. After that, permissive Wobbee takes it to base load.
WO	Work
WW	Water wash
XFMR	Transformer