

FILED 2/18/2020
DOCUMENT NO. 00978-2020
FPSC - COMMISSION CLERK

FLORIDA PUBLIC SERVICE COMMISSION
OFFICE OF COMMISSION CLERK



DOCUMENT NUMBER ASSIGNMENT*

FILED DATE: 2/18/2020
DOCKET NO.: 20200001-EI
DOCUMENT NO.: 00978-2020
DOCUMENT DESCRIPTION:

CONFIDENTIAL

(CONFIDENTIAL) Hearing Exhibit No. 112 from 2/5/20 DOAH Hearing. [CLK Note: See DN 10935-2019 for Exh Nos. 1, 68-75, 80, 82, 100]

DD 4/1/2026
DECLASSIFIED

*This document number has been assigned to a confidential document.
For further information, contact the Office of Commission Clerk.
E-MAIL: CLERK@PSC.STATE.FL.US PHONE NO. (850) 413-6770 FAX NO. (850) 717-0114

EXHIBIT NO. 112

DOCKET NO: 20190001-EI

WITNESS: Jeffrey Swartz

DECLASSIFIED

PARTY: DUKE ENERGY FLORIDA

DESCRIPTION:

DEF's Response to Citizens' Third Set of Interrogatories (Nos. 16-17)

PROFFERED BY: White Spring Agricultural Chemicals, Inc. d/b/a
PCS Phosphate


AFFIDAVIT


STATE OF FLORIDA


COUNTY OF PINELLAS

I hereby certify that on this 31st day of July, 2019, before me, an officer duly authorized in the State and County aforesaid to take acknowledgments, personally appeared JEFFREY SWARTZ, who is personally known to me, and has acknowledged before me that he provided the answers to interrogatory numbers 16 and 17 of CITIZENS' THIRD SET OF INTERROGATORIES TO DUKE ENERGY FLORIDA, LLC (Nos. 16-17) in Docket No. 20190001-EI, and that the responses are true and correct based on his personal knowledge.

In Witness Whereof, I have hereunto set my hand and seal in the State and County aforesaid as of this 31st day of JULY, 2019.


Jeffrey Swartz




Notary Public
State of Florida, at Large

My Commission Expires: July 18, 2022

DECLASSIFIED

DECLASSIFIED


CONFIDENTIAL

Bartow Steam Turbine Path Forward Recommendation

Bartow ST Project Team Summary

WORKING DRAFT – SUBJECT TO CHANGE

May 29, 2018



CONFIDENTIAL

DEF-19FL-FUEL-001602



CONFIDENTIAL Evaluation Overview & Agenda

- **Team evaluated 4 possible solutions for Bartow ST**
 - GE – LP retrofit
 - Siemens – LP retrofit
 - MHPS – Redesigned L-0 blade
 - Continue with the MHPS - Pressure Plate
- **Recommended solution for Bartow ST**
- **Details on our process and the selection**
 - Technical Evaluation
 - Performance Evaluation
 - Commercial Evaluation
- **Team Leaders:**
 - Dave Burney – Project Lead
 - Analytics Team – Mike Rib
 - Technical Team – Jake English
 - Total Cost of Ownership Analysis – Black & Veatch
 - Supply Chain – Jeremy Holton

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001603

DECLASSIFIED



CONFIDENTIAL

Executive Summary

Considering all elements of the evaluation (technical, cost, risk), the recommended path forward is to proceed with the new MHPS L-0 blade solution

- With GE being a close second from a business and technical perspective
- Siemens would be the less technically preferred solution to GE for an LP retrofit

Key elements of the evaluation that support the MHPS recommendation:

- All vendors have limited operating experience at the required steam flow rates, but MHPS appears to have the best understanding of the equipment, the historic L-0 issues, and the CC intricacies at Bartow. This understanding was built into their design changes.
- Their solution can be delivered before others – fuels/efficiency benefits realized earlier.
- Costs: MHPS credit of \$1.5M would be lost.
- All of upgrade proposals, including the MHPS option, offer capacity and performance upgrade potential over remaining with the pressure plate
- The MHPS blade solution allows us to retain the pressure plate as a contingency plan. MHPS pressure plate is not compatible with GE or Siemens.

DECLASSIFIED
CONFIDENTIAL

DEF-19FL-FUEL-001604



DECLASSIFIED

CONFIDENTIAL

Commercial Negotiations

Commercial Negotiation Goals:

- Keep MHPS accountable to resolve any design issues that may come up
- LD's to create proper response and to support our reliability goals
- Warranty provisions to limit our financial exposure (open/close, blade replacement, etc.)

To minimize financial risk, the following items need to be negotiated with MHPS:

- Material cost challenge: Previous sets of L-0 cost ~\$3.5 (both ends). Proposal is \$2M more with credits applied
- 10 year warranty requires active BVM monitoring at \$200k per year. This cost needs to be eliminated, or significantly reduced.
- Warranty needs to be clear and LD levels need to be evaluated/adjusted
- Tie LD's to 'unknown' operating restrictions (blending limitations, exclusion zones)
- Design deficiencies, if identified, in operation (at their first commercial site in Nov '18 and/or at Bartow) need to be resolved by MHPS to eliminate any operating restrictions at Bartow

Do not inform GE of selection (contingency). Inform Siemens is cut from short list.

CONFIDENTIAL

DEF-19FL-FUEL-001605

DECLASSIFIED



CONFIDENTIAL Technical Evaluation: Criteria

- Technical Evaluation approached using a KT-style analysis
- Main & Sub-categories were developed based on key KPI's
- Scoring criteria were defined to ensure technical solutions were evaluated consistently & fairly
 - Note: Scoring was rated on a scale of 1 to 5, with 5 being the best possible score.
- Weighting was applied separately by the Station, RS, and TGS

%Wt.	Categories and Weighting Factors
Impact to Future Maintenance (20%)	
25%	Maintenance Interval
20%	Major Overhaul Scope \$\$\$/Neg. Impacts
10%	Emergent Outage Scope if L-0 Blades Require Replacement
15%	Additional Support Infrastructure (e.g. Lift Oil System)
5%	Replacement Interval of L-0 blades (As Proposed)
5%	Rotor Life Extension Evaluation
15%	Tech Support -- Responsiveness, Ownership of Issues
5%	L-0 Erosion Susceptibility
Impact to Future Operations (20%)	
20%	Restrictions to Blending
40%	Restrictions on Condenser (Back Pressure / Bathtub Curves)
35%	Max Flow Limitations
5%	Low Load Limitations
Unit Performance (10%)	
30%	MW Output
70%	Heat Rate
Unit Reliability (50%)	
50%	OEM Operating Experience (At >= to Bartow Exhaust Flow)
20%	Experience with OEM ST Equipment (Fleet Experience)
30%	Ability to Detect Adverse Operations (Real Time)

CONFIDENTIAL

DEF-19FL-FUEL-001606



CONFIDENTIAL Technical Evaluation: Results

- Met with all 3 bidders and technically challenged their respective proposed solutions
- The technical assessment identified operational and performance deficiencies associated with continuing with the pressure plate as a long term solution
- Preferred technical selection is with MHPS and GE.

Overall Weighted Score			
MHPS	GE	Siemens	Press Plate
2.91	3.04	2.81	1.87

Ops/Maint Impact ONLY

MHPS	GE	Siemens	Press Plate
1.25	1.53	1.30	1.32

Performance/Reliability ONLY

MHPS	GE	Siemens	Press Plate
1.66	1.51	1.51	0.55

DECLASSIFIED

For ALL solutions ➔ operational experience for the proposed designs is limited

CONFIDENTIAL


DEF-19FL-FUEL-001607



Technical Evaluation: Original vs. Proposed L-0 Blade Design

CONFIDENTIAL

- Improvements to mid-span stub design...
 - Increased length and thickness of the stub (by 1.4 times, each) to improve fretting fatigue strength.
 - The stub interface angle was increased to reduce tip bending by distributing fretting over a greater area.
- Improvements to shroud design...
 - Increased the shroud length by 1.6 times to improve fretting fatigue strength.
 - Adjusted the angle of shroud contact face to increase contact area as well as mechanical damping.
- Overall blade design improvements...
 - Geometry upgrades result in up to 80% less vibratory stress at the stub and shroud for same blade displacement.
 - Optimum stub and shroud gaps are designed to control contact speed and reaction force – i.e. better cold offset to get more hot/running contact face area.
 - No welding stellite (after machining) to distort contact faces as was seen on the Type 3 design.
 - 100% optic scanning of faces for acceptance testing vs. 4-point measurement to a blade fixture.



Original 40" L-0

Proposed 40" L-0

CONFIDENTIAL

DECLASSIFIED

DEF 19FL-FUEL-001608



DECLASSIFIED

CONFIDENTIAL

Technical Evaluation: November 2018

- November 2018 marks a critical milestone for MHPS in validating their upgraded blade design.

	Napanee	vs.	Takasago
L-0 Blade Type	Type 5		Type Proposed Redesign
Relative to Duke Fleet	Blade design set to go in-service at Citrus		Blade design proposed for Bartow
2018 Testing	Scheduled 4Q 2018 COD – ~457 MW Testing at higher LP steam flows comparable to Bartow (using BVM to monitor)		Scheduled November 2018 air excitation and electromagnetic excitation testing (using telemetry testing and BVM to monitor)
What Results of Testing Means for Each	<ul style="list-style-type: none"> GOOD – Napanee moves forward POOR – Replace Napanee L-0s with Proposed Redesign, or impose operational limitations. POOR – Duke must know of possible Bartow limitations and "why". 		<ul style="list-style-type: none"> GOOD – Bartow project moves forward with MHPS L-0 Proposed Redesign option POOR – MHPS must provide an acceptable remedy plan to Duke, or Bartow Project moves to an alternate contingency plan.

- With either test case, Duke will have a vested interest in understanding the results and how they impact the long-term decision for Bartow.

CONFIDENTIAL

DEF-19FL-FUEL-001609



~~CONFIDENTIAL~~ **Evaluation: Results Summary**

Why we believe the MHPS L-0 solution is a viable technical solution...

- Best understanding of equipment and impacts of operation on ST.
- Previous L-0 event “fixes” were not based on an understanding of the cause.
 - Previous “fixes” were not design changes but application of coatings as an attempt to address a perceived symptom.
- Proposed L-0 design changes are significant in the new blade design.
- Initial rig testing (vibratory stress) indicates promising results. November 2018 test data to provide further validation.
- Long-term BVM during operation will provide Duke the ability to detect issues and keep track of the reliability of the upgraded L-0s.
- LP retrofits (like the GE and Siemens options) carry greater unknown risks due to lack of operating experience and experience in a 4x1 application

~~CONFIDENTIAL~~

DEF-19FL-FUEL-001610

DECLASSIFIED

DECLASSIFIED



CONFIDENTIAL **Analytics: Scenarios and Cases**

Black & Veatch and Performance Services worked together to establish the new heat balance cases needed to support analysis of the upgrade options.

- Original base design (matching Bibb cases) and pressure-plate model (matching actual data)
- A design model for each vendor using LP turbine data from their submitted heat balances.
- The case matrix for each vendor design and pressure-plate model established vendor-specific and pressure-plate dispatch curves:
 - 12 operating configurations from 1x70% to 4x1 PAG/duct-fired/evaporative cooling
 - 3 ambient temperature conditions (35, 74 and 95 deg F)
 - Included ALLTD cases at 2x1, 3x1 and 4x1x40%
 - 4 layers – GE, Siemens, Mitsubishi and pressure-plate
- The case matrix for alternative configuration screening included CT upgrades and chiller evaluations
 - 2 layers – one typical vendor design and pressure-plate conditions
- Total number of cases run = 238

CONFIDENTIAL

DEF-19FL-FUEL-001611

DECLASSIFIED

DECLASSIFIED



CONFIDENTIAL

Analytics: Operating Limits

Operational limits used as limiting conditions in all of the heat balance cases:

- ST HP admission pressure = 2389.7 psia
- ST IP admission pressure = 583.7 psia
- ST IP exhaust pressure = 125.7 psia (for pressure-plate cases only)
- ST generator output limit at PF 1.0 = 468 gross MW after generator losses (468 MVA)
- Duct burner fuel flow per HRSG = 10,000 lb/hr
- PAG steam flow per CT = 121,910 lb/hr
- Achieve maximum duct burner fuel flow first before bringing in any PAG steam flow for the most efficient ST operation in the ST maximum output cases
- CT maximum torque limit of 230,000 KW

CONFIDENTIAL

DEF-19FL-FUEL-001612







DECLASSIFIED

CONFIDENTIAL

ST Performance Comparisons

- Performance for the three OEM's is similar. With GE being slightly better than MHPs and Siemens



CONFIDENTIAL

DEF-19FL-FUEL-001613

DECLASSIFIED



CONFIDENTIAL Analytics: Summary of Results

- Developed design models for each vendor to validate heat balance and determined if there were any equipment limitations
- CC normalized performance comparison (Winter, 4x1 (100%) + Duct/PAG):

	GE	MHPS	Siemens	Pressure Plate
Net Load (MW)	1,309	1,309	1,308	1,252
NUHR (btu/Kwh)	7,040	7,042	7,045	7,361

- CC normalized performance comparison (Summer, 4x1 (100%) + EC/Duct/PAG):

	GE	MHPS	Siemens	Pressure Plate
Net Load (MW)	1,172	1,169	1,169	1,121
NUHR (btu/Kwh)	7,069	7,089	7,085	7,388

- *Note: CT Upgrades and Chiller options were also evaluated and are summarized in the Appendix*

CONFIDENTIAL

DEF-19FL-FUEL-001614

DECLASSIFIED



DECLASSIFIED


CONFIDENTIAL

Analytics: CC Performance Overview

CC upgrade performance results – Pressure plate is outlier, others comparable

Comparison of Performance Curves

Comparison of Annual Operating Hours
(Annual %'s Projected for 2023)



Notes:

- Bartow CC is modeled as a must run unit on the DEF system
- System production cost studies reflect positive CPVRR savings, pending finalization of the costs and timing for the upgrade projects
- Preliminary results are subject to change as the assessment progresses


CONFIDENTIAL

DEF-19FL-FUEL-001615

DECLASSIFIED



CONFIDENTIAL Fleet Generation Comparisons



CONFIDENTIAL

DEF-19FL-FUEL-001616



DECLASSIFIED ~~CONFIDENTIAL~~ Analytics System Economics Summary

Results of the comparison of alternatives performed by Integrated Resource Planning

- Reflects impacts of performance upgrades on total DEF system costs over the planning period
- Includes the projected capital cost impacts for the upgrades
- Results in Cumulative PV of Revenue Requirements (\$CPVRR) reflect customer cost perspective

Comparison of Alternatives CPVRR \$M	P Plate	MHPS	Siemens	GE	P Plate vs	P Plate vs	P Plate vs
					MHPS ISD Fall 2019	Siemens ISD Spring 2022	GE ISD Fall 2019
System Fixed Costs	8,077	8,077	8,077	8,077	0	0	0
System Fuel Cost	15,202	15,116	15,126	15,113	86	76	89
System VOM Cost + Start Up Costs	2,210	2,204	2,205	2,203	6	5	6
System Environmental	2,508	2,488	2,488	2,488	20	20	20
Total Production Costs	27,997	27,885	27,896	27,881	111	101	115
Incremental Capital RR's	-	11	11	14	(11)	(11)	(14)
Total Costs	27,997	27,896	27,906	27,896	100	90	101

- As noted in the summary, resulting improvements for either the MHPS or GE options are comparable
- Given these results and the commercial and technical evaluations performed, the recommendation to proceed with negotiations and risk review with MHPS is supported.

CONFIDENTIAL

DEF-19FL-FUEL-001617

DECLASSIFIED



DECLASSIFIED

CONFIDENTIAL

Project Summary

Project Cost to Install Solution (LP Section Only, in \$MM)

	GE	MHPS	Siemens
Materials	\$8.38	\$6.94	\$9.19
Labor	\$1.87	\$1.59	\$1.76
Crane	\$0.66	\$0.46	\$0.66
Grand Total	\$10.91	\$8.99	\$11.61

- Assumptions: OEM Turn Key labor, materials for LP only, crane cost for outage (project burdens not included)
- MHPS: Install in 2019 MJR with HPIP. Not included - \$1M pressure plate storage inventory increase
- GE and Siemens Install – LP Only MJR in 2020
- Does not include cost of any potential foundation modifications to accommodate added rotor weight (if needed for GE/Siemens)*

BVM System and Monitoring Costs (in \$K)

	GE	MHPS	Siemens
System Cost	\$850	Included in Base	Included in Base*
Annual Monitoring	\$TBD**	\$200	\$44

- * Siemens base package BVM offering was for 1-year installed. Siemens addendum for permanent install was "Base + \$50k"
- ** GE is purchasing/providing a 3rd Party BVM product and leaving the long-term monitoring responsibilities for Duke to manage.

CONFIDENTIAL

DEF-19FL-FUEL-001618



Bartow CC Steam Turbine Optimization Project - Alternative Configurations

CONFIDENTIAL

In addition to review of the ST L-0 vendor proposals, the project team also performed a screening evaluation of several additional upgrade configurations.

Alternative Configuration* Cases:

- Combustion Turbine Upgrades
- Chiller Upgrades
- Both Combustion Turbine and Chiller Upgrades

**Note: Considered configurations both with and without the ST L-0 Upgrades*

Modeling & Analytics:

- B&V developed full load and partial heat balance model cases for the upgrades and determined the performance and full output capabilities with the limiting conditions assumed for the study.
- The alternative configurations were then studied by IRP to assess the savings potential in system production cost and capacity deferral.

Results

- The observed benefits offer limited potential for these investments at this time.

CONFIDENTIAL

DEF-19FL-FUEL-001619

DECLASSIFIED

DECLASSIFIED



Bartow CC Steam Turbine Optimization Project - Alternative Configurations

CONFIDENTIAL

Overview of Limits Observed:

Ambient	Mode	Configuration	Rate	Evap. Cooler	Duct Firing	PAG	Fuel	L-O Upgrade Only	GT Upgrade	Chiller	GT Upgrade and Chiller
35 F	2x1	2x100%	Max	-	-	-	Gas				
95 F	2x1	2x100%	Max	On	-	-	Gas				
35 F	3x1	3x100%	Max	-	-	-	Gas				
35 F	3x1	3x100%	Max	-	Fired	-	Gas		HPT		
74 F	3x1	3x100%	Max	-	-	-	Gas				
74 F	3x1	3x100%	Max	-	Fired	-	Gas		HPT		HPT
74 F	3x1	3x100% PAG	Max	-	Fired	PAG	Gas				HPT
95 F	3x1	3x100%	Max	On	-	-	Gas				
95 F	3x1	3x100%	Max	On	Fired	-	Gas		HPT		HPT
35 F	4x1	4x100%	Max	-	-	-	Gas				
35 F	4x1	4x100% Max DF	Max	-	Fired	-	Gas	IPT	IPT		
35 F	4x1	4x100% PAG	Max	-	Fired	PAG	Gas		IPT		
74 F	4x1	4x100%	Max	-	-	-	Gas				
74 F	4x1	4x100% Max DF	Max	-	Fired	-	Gas	IPT	IPT		IPT
74 F	4x1	4x100% PAG	Max	-	Fired	PAG	Gas				HPT
95 F	4x1	4x100%	Max	On	-	-	Gas				
95 F	4x1	4x100% PAG	Max	On	Fired	PAG	Gas		HPT		HPT
95 F	4x1	4x100% Max DF	Max	On	Fired	-	Gas	IPT	IPT	IPT	IPT

	No limit
	Limited by IPT inlet pressure
	Limited by HPT inlet pressure
	Not achievable

CONFIDENTIAL

- Includes L-0 Upgrades
- 4x1x100% cases with max duct-firing limited by IPT inlet pressure
- 3x1x100% cases with duct-firing/PAG limited by HPT inlet pressure
- 4x1x100% cases with duct-firing limited by IPT inlet pressure
- 4x1x100% cases with duct-firing/PAG limited by HPT inlet pressure

DEF-19FL-FUEL-001620




Bartow CC Steam Turbine Optimization Project - Alternative Configurations

CONFIDENTIAL

Performance Improvements:

4X100% NUHR vs Net Load - Summer with L-0 Upgrade



- Includes L-0 Upgrades
- Duct-firing case
Limiting condition = IP admission pressure
- PAG case
Limiting condition = HP admission pressure

CONFIDENTIAL

DEF-19FL-FUEL-001621

DECLASSIFIED

DECLASSIFIED



Bartow CC Steam Turbine Optimization Project - Alternative Configurations

CONFIDENTIAL

Economic Study Results:

DECLASSIFIED

Comparison to Ref Case (with the ST L-0 Upgrade) 20 Yr Cumulative PV of Revenue Requirements (\$M)	CT Upgrades	Chiller Additions	CT Upgrades & Chiller Additions
Fuel & Other Production Cost Savings	63	18	74
Environmental Savings	16	3	20
Upgrade Capital (CT, Chillers)	(89)	(57)	(146)
CPVRR System Savings (Costs)	(10)	(37)	(53)
Deferred Planned Additions Savings	17	17	89
GPVRR Total Savings (Costs)	7	(20)	36
MW and HR* Improvements (Summer)	126 / (100)	79 / 49	175 / (142)

* HR Improvements in Btu/kWh

CONFIDENTIAL

DEF-19FL-FUEL-001622



CONFIDENTIAL

Next Steps...

Any Questions?

- T&C negotiation with MHPS
- Communicate direction with Legal to get input
- Begin building a project execution plan and budget

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001623

DECLASSIFIED

CONFIDENTIAL



CONFIDENTIAL

DEF-19FL-FUEL-001624



CONFIDENTIAL

DECLASSIFIED



Backup Slides – Additional Detail & Analysis...

CONFIDENTIAL

DEF-19FL-FUEL-001625

DECLASSIFIED



CONFIDENTIAL Technical Evaluation: Criteria Details

■ Sub Category rating criteria and definitions

%Wt	Criteria and Weighting Factors	Rating Criteria		
		1	3	5
Impact to Future Maintenance (20%)				
25%	Maintenance Interval	Worse Than Current	Same As Current (64k Hrs)	Better Than Current
20%	Major Overhaul Scope \$\$\$/Neg. Impacts	Templates Will Require Adjustment	No Adjustment to Templates	Template Cost Reduced
10%	Emergent Outage Scope if L-0 Blades Require Replacement	Requires Rotor Removal	NA	Does Not Require Rotor Removal
15%	Additional Support Infrastructure (e.g. Lift Oil System)	Mods/Maint Adders Req'd (Additional Maint. Impact)	Mods/Maint Adders Req'd (No Additional Maint. Impact)	No Mods/Maint. Equipment Adders
5%	Replacement Interval of L-0 blades (As Proposed)	< 1 Maintenance Interval	1 Maintenance Interval (64k Hrs)	> 1 Maintenance Interval
5%	Rotor Life Extension Evaluation	< (200k Hours / 5k Starts) before RLE	(200k Hours / 5k Starts) before RLE	> (200k Hours / 5k Starts) before RLE
15%	Tech Support -- Responsiveness, Ownership of Issues	Multi-OEM ST Config -- Higher Likelihood of Having Difficulty w Problem Solving	NA	No Conflict or Difficulty Resolving Issues
5%	L-0 Erosion Susceptibility	No Erosion Protection, Erosion Likely w Design -- Increased Reliability Risk	Likely to Have Erosion (Regardless of Protection Scheme) -- Not Likely to Cause Issues	Proven Experience with Mitigating Erosion
Impact to Future Operations (20%)				
20%	Restrictions to Blending	Restrictons / Unknown Until Ops Data Collected	Known / Acceptable Restrictions	No Restrictions
40%	Restrictions on Condenser (Back Pressure / Bathtub Curves)	Restrictons / Unknown Until Ops Data Collected	Known / Acceptable Restrictions	No Restrictions
35%	Max Flow Limitations	(< 2.38 MPPH / 420 MW) / Min Margin Available	(= 2.38 MPPH / 420 MW) / Min Margin Available	(2.7 MPPH / 450+ MW) / Margin Available
5%	Low Load Limitations	ST Output of > ~65 MW Indefinitely (1x1 or 2x1)	ST Output of ~65 MW Indefinitely w/o Sprays (1x1)	ST Output of < ~65 MW Indefinitely w/o Sprays (1x1)
Unit Performance (10%)				
30%	MW Output	Today w/ PressPlate	Nameplate (420 MW)	Bid Spec Guarantee (450MW)
70%	Heat Rate	Appreciable Increase in HR	Same as Kiewit 2009 Value	Appreciable Decrease in HR
Unit Reliability (50%)				
50%	OEM Operating Experience (At >= to Bartow Exhaust Flow)	Test Rig Only	Operation Experience < 64k Hrs	Operational Experience > 64k Hrs
20%	Experience with OEM ST Equipment (Fleet Experience)	Several Operational/Historical Design Deficiencies	Some Issues but Responds Quickly and Responsibly	Few Operational/Historical Design Deficiencies
30%	Ability to Detect Adverse Operations (Real Time)	No Telemetry Test / No BVM	Telemetry Test at Stm Conditions	BVM

CONFIDENTIAL

DEF-19FL-FUEL-001626

DECLASSIFIED

DECLASSIFIED



Technical Evaluation: KT Assessment Details

Scoring Results by Category (unweighted and weighted)

Criteria and Weighting Factors	Criteria Based Scoring (Unweighted)				Criteria Based Scoring (Weighted)			
	MHPS	GE	Siemens	Press Plate	MHPS	GE	Siemens	Press Plate
Impact to Future Maintenance (20%)					3.50	3.70	2.95	3.10
Maintenance Interval	3	5	5	2	0.75	1.25	1.25	0.5
Major Overhaul Scope \$\$\$/Neg. Impacts	3	2	1	2	0.6	0.4	0.2	0.4
Emergent Outage Scope If L-O Blades Require Replacement	1	5	5	5	0.1	0.5	0.5	0.5
Additional Support Infrastructure (e.g. Lift Oil System)	5	5	1	2	0.75	0.75	0.15	0.3
Replacement Interval of L-O blades (As Proposed)	5	5	5	5	0.25	0.25	0.25	0.25
Rotor Life Extension Evaluation	3	3	3	3	0.15	0.15	0.15	0.15
Tech Support -- Responsiveness, Ownership of Issues	5	2	2	5	0.75	0.3	0.3	0.75
L-O Erosion Susceptibility	3	2	3	5	0.15	0.1	0.15	0.25
Impact to Future Operations (20%)					2.75	3.95	3.55	3.50
Restrictions to Blending	4	4	4	5	0.8	0.8	0.8	1
Restrictions on Condenser (Back Pressure / Bathtub Curves)	1	4	3	5	0.4	1.6	1.2	2
Max Flow Limitations	4	4	4	1	1.4	1.4	1.4	0.35
Low Load Limitations	3	3	3	3	0.15	0.15	0.15	0.15
Unit Performance (10%)					3.60	3.60	3.60	1.00
MW Output	5	5	5	1	1.5	1.5	1.5	0.3
Heat Rate	3	3	3	1	2.1	2.1	2.1	0.7
Unit Reliability (50%)					2.60	2.30	2.30	0.90
OEM Operating Experience (At >= to Bartow Exhaust Flow)	1	1	1	0	0.5	0.5	0.5	0
Experience with OEM ST Equipment (Fleet Experience)	3	3	3	3	0.6	0.6	0.6	0.6
Ability to Detect Adverse Operations (Real Time)	5	4	4	1	1.5	1.2	1.2	0.3

Overall Weighted Score			
MHPS	GE	Siemens	Press Plate
2.91	3.04	2.81	1.87

Ops/Maint Impact ONLY

MHPS	GE	Siemens	Press Plate
1.25	1.53	1.30	1.32

Performance/Reliability ONLY

MHPS	GE	Siemens	Press Plate
1.66	1.51	1.51	0.55

CONFIDENTIAL

DEF-19FL-FUEL-001627



~~CONFIDENTIAL~~ Technical Evaluation: Siemens Summary

- Of the three viable options this is the least preferred option
 - Requires a lift oil system to manage rotor weight
 - Complexity added with major maintenance requiring potential 1000T crane to lift rotor
 - Torsional testing is required (nothing in the proposal covers discovery)
 - Limited operating experience at the flow rate required at Bartow
 - Similar design as what is in the Osprey ST.
-
- No engineering has been performed to determine if there are any system impacts (equipment modifications) or foundation modification due to the heavy rotor. High potential for project cost creep

DECLASSIFIED

~~CONFIDENTIAL~~

DEF-19FL-FUEL-001628



~~CONFIDENTIAL~~ **Technical Evaluation: GE Summary**

- Of the three viable options this is the first preferred for an LP retro-fit option
 - Rotor weight is heavier but GE indicated some additional engineering could take place to reduce weight
 - No lift system required
 - Torsional testing is not required , but the technical team may require detailed reviews to ensure this is not needed (nothing in the proposal covers discovery)
 - Limited operating experience at the flow rate. Installed in two (2) Texas units with <10k hrs of operation
-
- No engineering has been performed to determine if there are any system impacts (equipment modifications) or foundation modification due to the heavy rotor. High potential for project cost creep

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001629



CONFIDENTIAL Technical Evaluation: Pressure Plate Summary

- The pressure plate option was a low-scoring outlier in the technical evaluation.
- Recent inspections have shown the presence of the pressure plate causes damage to neighboring and downstream infrastructure due in part to increased steam velocities generated because of the pressure plate.
- Continued operation with the pressure plate and its effects on future recommended maintenance intervals can not yet be determined.

DECLASSIFIED

- IF Duke proceeds with the recommended MHPS technical offering, the pressure plate (and associated hardware) will need to be removed, blast cleaned, NDE'd and placed into Bartow inventory for short-term contingency (3-5 years).
- IF Duke proceeds with either the GE or Siemens technical offerings, the existing pressure plate will not be able to be reused in those rotor configurations.

CONFIDENTIAL

DEF-19FL-FUEL-001630



CONFIDENTIAL

DECLASSIFIED



Performance team evaluation details

CONFIDENTIAL

DEF-19FL-FUEL-001631



CONFIDENTIAL

DECLASSIFIED

Performance evaluation details

Bartow CC -LP Turbine Upgrade Study 2018

Becky McClintock
Thermal Performance M&D Center

CONFIDENTIAL

DEF-19FL-FUEL-001632

DECLASSIFIED



DECLASSIFIED

CONFIDENTIAL

Overview

- Load Cases Requested from Vendors
- Black & Veatch Modeling and Analysis
 - Case Matrix
 - Operational Limits
- Model Results
 - Steam turbine performance by vendor
 - Net unit heat rate
 - GT Upgrade and Chiller Operating Limitations

CONFIDENTIAL

DEF-19FL-FUEL-001633

Load Cases Requested from Vendors

- Four full-load cases and one low-load case
 - 1) 455.7 Gross MW - Maximum load on steam turbine below its operational limits and matching December 2014 steam turbine test conditions at 2.5"Hg condenser back pressure
 - 2) 449.9 Gross MW - Maximum load on steam turbine below its operational limits and matching December 2014 steam turbine test conditions at 4.5"Hg condenser back pressure
 - 3) 419.6 Gross MW - Guarantee load from Bibb Heat Balances for fired conditions
 - 4) 385.7 Gross MW - Guarantee load from Bibb Heat Balances for unfired conditions
 - 5) 59.5 Gross MW - Low load from Bibb Heat Balances (1x1x70% CT Load at 95 deg F ambient)


DECLASSIFIED

CONFIDENTIAL

DECLASSIFIED

455.7 Gross MW

Valves Wide Open (IP Inlet Pressure at Namplate - Before Control Valve) - 4x1 Fired Natural Gas, Ambient Temp 74.4 deg F, Circulating Water Inlet Temperature 66 deg F, 72% Condenser Cleanliness (to match 12/22/2014 15:16 actual data)




CONFIDENTIAL

DEF-19FL-FUEL-001635

449.9 Gross MW

Valves Wide Open (IP Inlet Pressure at Nameplate - Before Control Valve) - 4x1 Fired Natural Gas, Ambient Temp 79 deg F, Circulating Water Inlet Temperature 66 deg F, 46% Condenser Cleanliness (to match 12/23/2014 14:20 actual data)






DECLASSIFIED

CONFIDENTIAL

DECLASSIFIED


419.6 Gross MW

419.6 MW - 4x1 Fired Natural Gas, Ambient Temp 74 deg F, Circulating Water Inlet Temperature 85 deg F, 90% Condenser Cleanliness



CONFIDENTIAL

DEF-19FL-FUEL-001637



DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001639



DECLASSIFIED

CONFIDENTIAL

DECLASSIFIED

DEF-19FL-FUEL-001640

Black & Veatch Modeling and Analysis

- Developed original base design (matching Bibb cases) and pressure-plate model (matching actual data)
- Developed a design model for each vendor using LP turbine data from their submitted heat balances
- Ran case matrix for each vendor design and pressure-plate model to develop vendor-specific and pressure-plate dispatch curves
 - 12 operating configurations from 1x70% to 4x1 PAG/duct-fired/evaporative cooling
 - 3 ambient temperature conditions (35, 74 and 95 deg F)
 - Included ALLTD cases at 2x1, 3x1 and 4x1x40%
 - 4 layers – GE, Siemens, Mitsubishi and pressure-plate
- Ran another case matrix for CT upgrade and chiller evaluation
 - 2 layers – one typical vendor design and pressure-plate conditions
- Total number of cases run = 238

CONFIDENTIAL

DEF-19FL-FUEL-001640



CONFIDENTIAL

Operational Limits

- Used operational limits as limiting conditions in all cases
 - ST HP admission pressure = 2389.7 psia
 - ST IP admission pressure = 583.7 psia
 - ST IP exhaust pressure = 125.7 psia (for pressure-plate cases only)
 - ST generator output limit at PF 1.0 = 468 gross MW after generator losses (468 MVA)
 - Duct burner fuel flow per HRSG = 10,000 lb/hr
 - PAG steam flow per CT = 121,910 lb/hr
 - Achieve maximum duct burner fuel flow first before bringing in any PAG steam flow for the most efficient ST operation in the ST maximum output cases
- CT maximum torque limit of 230,000 KW

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001641




DECLASSIFIED

CONFIDENTIAL

DECLASSIFIED

Model Results – ST Performance

- At ST maximum load, GE's upgrade had 1% higher LP turbine efficiency, 5 more gross MW's, and 2% lower turbine cycle heat rate than Mitsubishi upgrade




CONFIDENTIAL

DEF-19FL-FUEL-001642

Model Results – Net Unit Heat Rate


- L-O Upgrade
- Duct-firing case limiting condition = IP admission pressure
- PAG case limiting condition = HP admission pressure

4X100% NUHR vs Net Load - Summer with L-O Upgrade



Model Results – Pressure Plate

- According to Black and Veatch, "if steam turbine is kept as-is with the pressure plate, and the CT's are upgraded, then the IPT exit pressure limit would be exceeded in many operational scenarios"
- Only the chiller operation in the summer was an available option for 4x1, yielding an additional ~75 net unit MW





CONFIDENTIAL

Model Results – GT Upgrade & Chiller Limitations with L-0 Upgrade

- 3x1x100% cases with duct-firing/PAG limited by HPT inlet pressure
- 4x1x100% cases with duct-firing limited by IPT inlet pressure
- 4x1x100% cases with duct-firing/PAG limited by HPT inlet pressure

Ambient	Mode	Configuration	Rate	Evap. Cooler	Duct Firing	PAG	Fuel	GT Upgrade	Chiller	GT Upgrade and Chiller
35 F	2x1	2x100%	Max	-	-	-	Gas			
95 F	2x1	2x100%	Max	On	-	-	Gas			
35 F	3x1	3x100%	Max	-	-	-	Gas			
35 F	3x1	3x100%	Max	-	Fired	-	Gas	HPT		
74 F	3x1	3x100%	Max	-	-	-	Gas			
74 F	3x1	3x100%	Max	-	Fired	-	Gas	HPT		HPT
74 F	3x1	3x100% PAG	Max	-	Fired	PAG	Gas			HPT
95 F	3x1	3x100%	Max	On	-	-	Gas			
95 F	3x1	3x100%	Max	On	Fired	-	Gas	HPT		HPT
35 F	4x1	4x100%	Max	-	-	-	Gas			
35 F	4x1	4x100%	Max	-	Fired	-	Gas	IPT		
35 F	4x1	4x100% PAG	Max	-	Fired	PAG	Gas	IPT		
74 F	4x1	4x100%	Max	-	-	-	Gas			
74 F	4x1	4x100%	Max	-	Fired	-	Gas	IPT		IPT
74 F	4x1	4x100% PAG	Max	-	Fired	PAG	Gas			HPT
95 F	4x1	4x100%	Max	On	-	-	Gas			
95 F	4x1	4x100%	Max	On	Fired	-	Gas	IPT		IPT
95 F	4x1	4x100% PAG	Max	On	Fired	PAG	Gas	HPT		HPT
95 F	4x1	4x100% ST Max	Max	On	Fired	-	Gas	IPT	IPT	IPT

No limit
 Limited by IPT inlet pressure
 Limited by HPT inlet pressure
 Not achievable

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001645

Model Results – GT Upgrade & Chiller Limitations with Pressure-Plate

- 3x1x100% cases with duct-firing limited by IPT exhaust pressure
- 4x1x100% cases cannot be achieved with GT Upgrade
- Only chiller cases limited by IPT exhaust pressure are at 4x1x100% with duct-firing

Ambient	Mode	Configuration	Rate	Evap. Cooler	Duct Firing	PAG	Fuel	GT Upgrade	Chiller	GT Upgrade and Chiller
35 F	3x1	3x100%	Max	-	-	-	Gas			
35 F	3x1	3x100%	Max	-	Fired	-	Gas			
35 F	4x1	4x100%	Max	-	-	-	Gas			
35 F	4x1	4x100%	Max	-	Fired	-	Gas			
35 F	4x1	4x100% ST Max	Max	-	Fired	-	Gas			
74 F	3x1	3x100%	Max	-	-	-	Gas			
74 F	3x1	3x100%	Max	-	Fired	-	Gas			
74 F	4x1	4x100%	Max	-	-	-	Gas			
74 F	4x1	4x100%	Max	-	Fired	-	Gas			
74 F	4x1	4x100%	Max	-	Fired	-	Gas			
95 F	3x1	3x100%	Max	On	-	-	Gas			
95 F	3x1	3x100%	Max	On	Fired	-	Gas			
95 F	4x1	4x100%	Max	On	-	-	Gas			
95 F	4x1	4x100%	Max	On	Fired	-	Gas			
95 F	4x1	4x100% PAG	Max	On	Fired	PAG	Gas			
95 F	4x1	4x100% ST Max	Max	On	Fired	-	Gas			

No limit
 Limited by IPT exhaust pressure
 Not achievable



CONFIDENTIAL



Integrated Resource Planning evaluations

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001647



Bartow CC Steam Turbine ~~CONFIDENTIAL~~ Project - Modeling Assumptions

Reference Case vs Current Configuration: Pressure Plate

- Bid # 1: Mitsubishi L-Zero Blades Replacement ISD: May 1st 2019
- Bid # 2: Siemens Rotor Replacement ISD: May 1st 2022
- Bid # 3: GE Rotor Replacement ISD: May 1st 2022

DECLASSIFIED

Pressure Plate Case Outage Schedule for years 2018 – 2023 based on GMS.

L-Zero, Siemens and GE cases are variations from the GMS assuming 12 week outage for the Blades / Rotor Replacement.

Pressure Plate			L-Zero			Siemens & GE		
Start Date	Duration (Days)	MW Out	Start Date	Duration (Days)	MW Out	Start Date	Duration (Days)	MW Out
3/10/2018 0:00	8	700	3/10/2018 0:00	8	700	3/10/2018 0:00	8	700
3/18/2018 0:00	7	520	3/18/2018 0:00	7	520	3/18/2018 0:00	7	520
3/2/2019 0:00	35	500	2/6/2019 0:00	25	300	3/2/2019 0:00	35	500
4/6/2019 0:00	7	300	3/2/2019 0:00	34	500	4/6/2019 0:00	7	300
9/28/2019 0:00	35	220	3/3/2019 0:00	25	300	9/28/2019 0:00	35	220
3/7/2020 0:00	8	700	9/28/2019 0:00	35	220	3/7/2020 0:00	8	700
3/15/2020 0:00	7	520	3/7/2020 0:00	8	700	3/15/2020 0:00	7	520
3/6/2021 0:00	8	700	3/15/2020 0:00	7	520	3/15/2020 0:00	7	520
3/14/2021 0:00	7	520	3/6/2021 0:00	8	700	3/6/2021 0:00	8	700
3/5/2022 0:00	42	500	3/14/2021 0:00	7	520	3/14/2021 0:00	7	520
3/4/2023 0:00	42	500	3/5/2022 0:00	42	500	2/6/2022 0:00	26	300
						3/5/2022 0:00	42	500
						4/16/2022 0:00	16	300
						3/4/2023 0:00	42	500

CONFIDENTIAL

DEF19FL-FUEL-001648



Bartow CC Steam Turbine Optimization Project - Modeling Assumptions

CONFIDENTIAL

Bartow CC

- Must Run Unit
- Min Capacity 2x1 @ 40%
- Maintenance Rates (Turbine and Generator Services):

2024	4.10%
2025	4.10%
2026	8.20%
2027	4.10%
2028	4.10%
2029	5.80%
2030	4.10%
2031	4.10%
2032	4.10%
2033	8.20%
2034	4.10%
2035	4.10%
2036	5.70%
2037	4.10%
2038	4.10%

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001649

DECLASSIFIED



Bartow CC Steam Turbine Optimization Project - Assumptions

Winter Heat Rates and Capacities values provided by Dario Zuloaga / Becky McClintock

<u>Winter</u>	<u>Net Load</u>	<u>NUHR</u>	<u>Net Load</u>	<u>NUHR</u>	<u>Net Load</u>	<u>NUHR</u>	<u>Net Load</u>	<u>NUHR</u>
	<u>Pressure Plate</u>		<u>L-Zero</u>		<u>Siemens</u>		<u>GE</u>	
4x40%	505	9,233	547	8,520	546	8,526	547.10	8,515
4x100%	1,150	7,248	1,209	6,892	1,209	6,896	1,209.69	6,890
4x100% DF	1,158	7,264	1,262	6,957	1,260	6,960	1,261.25	6,953
4x100% DF, PAG	1,252	7,361	1,309	7,042	1,308	7,045	1,309.27	7,040
3x40%	378	9,248	409	8,535	409	8,544	409.19	8,538
3x100%	865	7,229	909	6,876	909	6,879	909.46	6,873
3x100% DF	972	7,506	1,030	7,077	1,030	7,082	1,030.74	7,074
2x40%	249	9,368	268	8,685	268	8,686	269.01	8,658
2x100%	573	7,267	603	6,912	602	6,918	602.75	6,914
1x70%	200	7,898	207	7,611	208	7,592	207.93	7,581
1x100%	278	7,489	290	7,187	290	7,180	290.85	7,164

CONFIDENTIAL

DEF-19FL-FUEL-001650



Bartow CC Steam Turbine Optimization Project - Assumptions

Summer Heat Rates and Capacities values provided by Dario Zuloaga / Becky McClintock

<u>Summer</u>	<u>Net Load</u>	<u>NUHR</u>	<u>Net Load</u>	<u>NUHR</u>	<u>Net Load</u>	<u>NUHR</u>	<u>Net Load</u>	<u>NUHR</u>
	<u>Pressure Plate</u>		<u>L-Zero</u>		<u>Siemens</u>		<u>GE</u>	
4x40%	561	8,624	597	8,105	597.22	8,096	599.24	8,068
4x100%, EC	1,025	7,259	1,074	6,928	1,074.70	6,925	1,077.39	6,907
4x100%, EC, DF	1,049	7,296	1,138	7,001	1,138.03	6,998	1,140.70	6,978
4x100%, EC, PAG, DF	1,121	7,388	1,169	7,089	1,169.11	7,085	1,171.71	7,069
3x40%	420	8,632	444	8,159	445.33	8,143	446.65	8,119
3x100%, EC	770	7,248	805	6,935	805.48	6,929	807.45	6,912
3x100%, EC, DF	884	7,534	933	7,134	933.65	7,131	936.38	7,110
2x40%	277	8,731	289	8,358	290.37	8,325	290.66	8,317
2x100%, EC	510	7,302	529	7,031	530.20	7,018	531.20	7,005
1x70%	165	8,161	168	8,044	168.75	7,987	165.76	8,131
1x100%, EC	246	7,576	249	7,469	250.44	7,429	248.43	7,489

CONFIDENTIAL

DEF-19FL-FUEL-001651

DECLASSIFIED

DECLASSIFIED



Bartow CC Steam Turbine ~~CONFIDENTIAL~~ Project - Modeling Assumptions

Modeled	Pressure Plate		L-Zero		Siemens		GE	
	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
Winter								
2x40%	249	9,368	268	8,685	268	8,686	269	8,658
2x100%	573	7,267	603	6,912	602	6,918	603	6,914
3x100%	865	7,229	909	6,876	909	6,879	909	6,873
4x100%	1,150	7,248	1,209	6,892	1,209	6,896	1,210	6,890
4x100% DF	1,158	7,264	1,262	6,957	1,260	6,960	1,261	6,953
4x100% DF, PAG	1,252	7,361	1,309	7,042	1,308	7,045	1,309	7,040

Modeled	Pressure Plate		L-Zero		Siemens		GE	
	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
Summer								
2x40%	277	8,731	289	8,358	290	8,325	291	8,317
2x100%, EC	510	7,302	529	7,031	530	7,018	531	7,005
3x100%, EC	770	7,248	805	6,935	805	6,929	807	6,912
4x100%, EC	1,025	7,259	1,074	6,928	1,075	6,925	1,077	6,907
4x100%, EC, DF	1,049	7,296	1,138	7,001	1,138	6,998	1,141	6,978
4x100%, EC, PAG, DF	1,121	7,388	1,169	7,089	1,169	7,085	1,172	7,069


CONFIDENTIAL

DEF-19FL-FUEL-001652



Bartow CC Steam Turbine Optimization Project - Modeling Assumptions

CONFIDENTIAL



DECLASSIFIED

CONFIDENTIAL


DEF-19FL-FUEL-001653

DECLASSIFIED



Bartow CC Steam Turbine Optimization Project - Modeling Assumptions

CONFIDENTIAL







CONFIDENTIAL

DEF-19FL-FUEL-001654



Bartow CC Steam Turbine Optimization Project - Hours of Operation Year 2023

CONFIDENTIAL



CONFIDENTIAL

DEF-19FL-FUEL-001655





DECLASSIFIED

DECLASSIFIED



Bartow CC Steam Turbine Optimization Project - Hours of Operation Year 2025

CONFIDENTIAL




CONFIDENTIAL

DEF-19FL-FUEL-001656



Dispatch ~~CONFIDENTIAL~~ – Generation Gwh




DEF-19EL-FUEL-001657

DECLASSIFIED

DECLASSIFIED



Dispatch Comparison – Generation %



CONFIDENTIAL

DEF-19FL-FUEL-001658



Dispatch Comparison – Capacity Factors

CONFIDENTIAL

Pressure Plate Case

Mitsubishi L-Zero Case

CF	2018	2019	2020	2021	2022	2023
Anclote.1	21%	11%	7%	8%	9%	9%
Anclote.2	14%	9%	8%	8%	9%	9%
Bartow CC.1.0	68%	58%	60%	60%	61%	61%
Bartow CC.1.DUCT	27%	12%	9%	8%	6%	6%
Bartow CC.1.PAG	19%	8%	5%	5%	4%	4%
Citrus.CC.1	93%	86%	87%	87%	89%	89%
Citrus.CC.1.Duct	19%	15%	14%	11%	13%	19%
Citrus.CC.2	72%	80%	81%	81%	84%	84%
Citrus.CC.2.Duct	3%	15%	12%	9%	11%	17%
Crystal.4	81%	77%	58%	65%	47%	37%
Crystal.5	88%	66%	72%	64%	54%	42%
Hines.CC.1	66%	46%	46%	44%	51%	50%
Hines.CC.2	51%	35%	35%	36%	39%	45%
Hines.CC.3	63%	46%	45%	47%	50%	56%
Hines.CC.4	79%	67%	69%	69%	66%	64%
Osprey Up to 245Mws	37%	21%	25%	25%	42%	47%
Osprey Above 245MWs	16%	11%	12%	8%	9%	33%
Osprey DF	2%	1%	0%	0%	0%	1%
Tigerbay.1	56%	58%	53%	60%	66%	61%
Solar.3rdParty.Block.1	20%	23%	23%	24%	24%	24%
Solar.DEF.Block.1	24%	24%	24%	24%	24%	24%
Solar.DEF.Block.3	0%	30%	29%	29%	30%	30%

CF	2018	2019	2020	2021	2022	2023
Anclote.1	21%	11%	7%	8%	8%	9%
Anclote.2	14%	9%	8%	8%	9%	9%
Bartow CC.1.0	68%	62%	68%	68%	69%	69%
Bartow CC.1.DUCT	27%	14%	9%	8%	6%	7%
Bartow CC.1.PAG	19%	2%	1%	2%	2%	2%
Citrus.CC.1	93%	86%	87%	87%	88%	89%
Citrus.CC.1.Duct	19%	15%	13%	11%	12%	18%
Citrus.CC.2	72%	81%	81%	80%	83%	85%
Citrus.CC.2.Duct	3%	14%	11%	10%	11%	17%
Crystal.4	81%	76%	56%	62%	43%	35%
Crystal.5	88%	66%	69%	61%	52%	40%
Hines.CC.1	66%	42%	40%	39%	46%	46%
Hines.CC.2	51%	34%	32%	33%	38%	42%
Hines.CC.3	63%	43%	39%	41%	46%	50%
Hines.CC.4	79%	65%	70%	69%	66%	64%
Osprey Up to 245Mws	37%	21%	24%	23%	37%	44%
Osprey Above 245MWs	16%	11%	12%	8%	9%	31%
Osprey DF	2%	1%	0%	0%	0%	1%
Tigerbay.1	56%	55%	50%	62%	69%	61%
Solar.3rdParty.Block.1	20%	23%	23%	24%	24%	24%
Solar.DEF.Block.1	24%	24%	24%	24%	24%	24%
Solar.DEF.Block.4	0%	0%	32%	38%	38%	30%

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001659



Dispatch Comparison – Capacity Factors

DECLASSIFIED

Pressure Plate Case

GE Case

CF	2018	2019	2020	2021	2022	2023
Anclote.1	21%	11%	7%	8%	9%	9%
Anclote.2	14%	9%	8%	8%	9%	9%
Bartow CC.1.0	68%	58%	60%	60%	61%	61%
Bartow CC.1.DUCT	27%	12%	9%	8%	6%	6%
Bartow CC.1.PAG	19%	8%	5%	5%	4%	4%
Citrus.CC.1	93%	86%	87%	87%	89%	89%
Citrus.CC.1.Duct	19%	15%	14%	11%	13%	19%
Citrus.CC.2	72%	80%	81%	81%	84%	84%
Citrus.CC.2.Duct	3%	15%	12%	9%	11%	17%
Crystal.4	81%	77%	58%	65%	47%	37%
Crystal.5	88%	66%	72%	64%	54%	42%
Hines.CC.1	66%	46%	46%	44%	51%	50%
Hines.CC.2	51%	35%	35%	36%	39%	45%
Hines.CC.3	63%	46%	45%	47%	50%	56%
Hines.CC.4	79%	67%	69%	69%	66%	64%
Osprey Up to 245Mws	37%	21%	25%	25%	42%	47%
Osprey Above 245MWs	16%	11%	12%	8%	9%	33%
Osprey DF	2%	1%	0%	0%	0%	1%
Tigerbay.1	56%	58%	53%	60%	66%	61%
Solar.3rdParty.Block.1	20%	23%	23%	24%	24%	24%
Solar.DEF.Block.1	24%	24%	24%	24%	24%	24%
Solar.DEF.Block.3	0%	30%	29%	29%	28%	30%

CF	2018	2019	2020	2021	2022	2023
Anclote.1	21%	11%	7%	8%	8%	9%
Anclote.2	14%	9%	8%	8%	9%	9%
Bartow CC.1.0	68%	58%	60%	60%	65%	69%
Bartow CC.1.DUCT	27%	12%	9%	8%	7%	7%
Bartow CC.1.PAG	19%	8%	5%	5%	2%	2%
Citrus.CC.1	93%	86%	87%	87%	89%	89%
Citrus.CC.1.Duct	19%	15%	14%	11%	12%	18%
Citrus.CC.2	72%	80%	81%	81%	84%	85%
Citrus.CC.2.Duct	3%	15%	12%	9%	11%	17%
Crystal.4	81%	77%	58%	65%	43%	35%
Crystal.5	88%	66%	72%	64%	52%	39%
Hines.CC.1	66%	46%	46%	44%	48%	46%
Hines.CC.2	51%	35%	35%	36%	38%	42%
Hines.CC.3	63%	46%	45%	47%	47%	49%
Hines.CC.4	79%	67%	69%	69%	66%	64%
Osprey Up to 245Mws	37%	21%	25%	25%	38%	44%
Osprey Above 245MWs	16%	11%	12%	8%	10%	31%
Osprey DF	2%	1%	0%	0%	0%	1%
Tigerbay.1	56%	58%	53%	60%	73%	61%
Solar.3rdParty.Block.1	20%	23%	23%	24%	24%	24%
Solar.DEF.Block.1	24%	24%	24%	24%	24%	24%
Solar.DEF.Block.3	0%	30%	29%	29%	28%	30%

CONFIDENTIAL

DEF-19FL-FUEL-001660



Results – ~~CONFIDENTIAL~~ Operation Year 2023

Winter 2023	P-Plate	L-Zero	Siemens	GE
Min Cap 2x1 (40%)	-	-	-	-
2x1 (41%-100%)	1,040	785	785	918
3x1 (0%-100%)	2,081	1,364	1,729	1,215
Max Cap 4x1 (0%-100%)	316	1,294	928	1,310
4x1 (100%) + Duct	55	57	58	56
4x1 (100%) + PAG	51	43	43	44
Total Hours of Generation	3,543	3,543	3,543	3,543
No Generation	801	801	801	801
Total	4,344	4,344	4,344	4,344

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
249	9,368	268	8,685	268	8,686	269	8,658
573	7,267	603	6,912	602	6,918	603	6,914
865	7,229	909	6,876	909	6,879	909	6,873
1,150	7,248	1,209	6,892	1,209	6,896	1,210	6,890
1,158	7,264	1,262	6,957	1,260	6,960	1,261	6,953
1,252	7,361	1,309	7,042	1,308	7,045	1,309	7,040

Summer 2023	P-Plate	L-Zero	Siemens	GE
Min Cap 2x1 (40%)	-	-	-	-
2x1 (41%-100%)	545	-	-	262
3x1 (0%-100%)	903	896	898	639
Max Cap 4x1 (0%-100%)	2,040	2,663	2,665	2,631
4x1 (100%) + DUCT	332	433	425	454
4x1 (100%) + PAG	320	148	152	154
Total Hours of Generation	4,140	4,140	4,140	4,140
No Generation	276	276	276	276
Total	4,416	4,416	4,416	4,416

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
277	8,731	289	8,358	290	8,325	291	8,317
510	7,302	529	7,031	530	7,018	531	7,005
770	7,248	805	6,935	805	6,929	807	6,912
1,025	7,259	1,074	6,928	1,075	6,925	1,077	6,907
1,049	7,296	1,138	7,001	1,138	6,998	1,141	6,978
1,121	7,388	1,169	7,089	1,169	7,085	1,172	7,069

~~CONFIDENTIAL~~

DEF-19FL-FUEL-001661

DECLASSIFIED

DECLASSIFIED

DECLASSIFIED



Results – Hours of Operation Year 2023

CONFIDENTIAL

Winter 2023		P-Plate	L-Zero	Siemens	GE
Min Cap	2x1 (40%)	0%	0%	0%	0%
	2x1 (41%-100%)	24%	18%	18%	21%
	3x1 (0%-100%)	48%	31%	40%	28%
	4x1 (0%-100%)	7%	30%	21%	30%
	4x1 (100%) + Duct	1%	1%	1%	1%
	4x1 (100%) + PAG	1%	1%	1%	1%
Total Hours of Generation		82%	82%	82%	82%
No Generation		18%	18%	18%	18%
Total		100%	100%	100%	100%

Summer 2023		P-Plate	L-Zero	Siemens	GE
Min Cap	2x1 (40%)	0%	0%	0%	0%
	2x1 (41%-100%)	12%	0%	0%	6%
	3x1 (0%-100%)	20%	20%	20%	14%
	4x1 (0%-100%)	46%	60%	60%	60%
	4x1 (100%) + DUCT	8%	10%	10%	10%
	4x1 (100%) + PAG	7%	3%	3%	3%
Total Hours of Generation		94%	94%	94%	94%
No Generation		6%	6%	6%	6%
Total		100%	100%	100%	100%

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
249	9,368	268	8,685	268	8,686	269	8,658
573	7,267	603	6,912	602	6,918	603	6,914
865	7,229	909	6,876	909	6,879	909	6,873
1,150	7,248	1,209	6,892	1,209	6,896	1,210	6,890
1,158	7,264	1,262	6,957	1,260	6,960	1,261	6,953
1,252	7,361	1,309	7,042	1,308	7,045	1,309	7,040

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
277	8,731	289	8,358	290	8,325	291	8,317
510	7,302	529	7,031	530	7,018	531	7,005
770	7,248	805	6,935	805	6,929	807	6,912
1,025	7,259	1,074	6,928	1,075	6,925	1,077	6,907
1,049	7,296	1,138	7,001	1,138	6,998	1,141	6,978
1,121	7,388	1,169	7,089	1,169	7,085	1,172	7,069

CONFIDENTIAL

DEF-19FL-FUEL-001662



Results – ~~CONFIDENTIAL~~ Operation Year 2025

Winter 2025	P-Plate	L-Zero	Siemens	GE
Min Cap 2x1 (40%)	-	-	-	-
2x1 (41%-100%)	1,094	653	659	671
3x1 (0%-100%)	2,246	1,779	1,981	1,759
Max Cap 4x1 (0%-100%)	487	1,367	1,159	1,368
4x1 (100%) + Duct	60	96	95	98
4x1 (100%) + PAG	57	50	51	49
Total Hours of Generation	3,944	3,945	3,945	3,945
No Generation	400	399	399	399
Total	4,344	4,344	4,344	4,344

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
249	9,368	268	8,685	268	8,686	269	8,658
573	7,267	603	6,912	602	6,918	603	6,914
865	7,229	909	6,876	909	6,879	909	6,873
1,150	7,248	1,209	6,892	1,209	6,896	1,210	6,890
1,158	7,264	1,262	6,957	1,260	6,960	1,261	6,953
1,252	7,361	1,309	7,042	1,308	7,045	1,309	7,040

Summer 2025	P-Plate	L-Zero	Siemens	GE
Min Cap 2x1 (40%)	-	-	-	-
2x1 (41%-100%)	524	-	-	250
3x1 (0%-100%)	1,396	892	892	633
Max Cap 4x1 (0%-100%)	1,154	2,150	2,150	2,073
4x1 (100%) + DUCT	539	839	837	915
4x1 (100%) + PAG	526	259	261	269
Total Hours of Generation	4,139	4,140	4,140	4,140
No Generation	277	276	276	276
Total	4,416	4,416	4,416	4,416

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
277	8,731	289	8,358	290	8,325	291	8,317
510	7,302	529	7,031	530	7,018	531	7,005
770	7,248	805	6,935	805	6,929	807	6,912
1,025	7,259	1,074	6,928	1,075	6,925	1,077	6,907
1,049	7,296	1,138	7,001	1,138	6,998	1,141	6,978
1,121	7,388	1,169	7,089	1,169	7,085	1,172	7,069

~~CONFIDENTIAL~~

DEF-19FL-FUEL-001663

DECLASSIFIED

DECLASSIFIED



Results – Hours of Operation Year 2025

CONFIDENTIAL

Winter 2025		P-Plate	L-Zero	Siemens	GE
Min Cap	2x1 (40%)	0%	0%	0%	0%
	2x1 (41%-100%)	25%	15%	15%	15%
	3x1 (0%-100%)	52%	41%	46%	40%
	4x1 (0%-100%)	11%	31%	27%	31%
	4x1 (100%) + Duct	1%	2%	2%	2%
	4x1 (100%) + PAG	1%	1%	1%	1%
Total Hours of Generation		91%	91%	91%	91%
No Generation		9%	9%	9%	9%
Total		100%	100%	100%	100%

Summer 2025		P-Plate	L-Zero	Siemens	GE
Min Cap	2x1 (40%)	0%	0%	0%	0%
	2x1 (41%-100%)	12%	0%	0%	6%
	3x1 (0%-100%)	32%	20%	20%	14%
	4x1 (0%-100%)	26%	49%	49%	47%
	4x1 (100%) + DUCT	12%	19%	19%	21%
	4x1 (100%) + PAG	12%	6%	6%	6%
Total Hours of Generation		94%	94%	94%	94%
No Generation		6%	6%	6%	6%
Total		100%	100%	100%	100%

CONFIDENTIAL

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
249	9,368	268	8,685	268	8,686	269	8,658
573	7,267	603	6,912	602	6,918	603	6,914
865	7,229	909	6,876	909	6,879	909	6,873
1,150	7,248	1,209	6,892	1,209	6,896	1,210	6,890
1,158	7,264	1,262	6,957	1,260	6,960	1,261	6,953
1,252	7,361	1,309	7,042	1,308	7,045	1,309	7,040

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
277	8,731	289	8,358	290	8,325	291	8,317
510	7,302	529	7,031	530	7,018	531	7,005
770	7,248	805	6,935	805	6,929	807	6,912
1,025	7,259	1,074	6,928	1,075	6,925	1,077	6,907
1,049	7,296	1,138	7,001	1,138	6,998	1,141	6,978
1,121	7,388	1,169	7,089	1,169	7,085	1,172	7,069

DEF-19FL-FUEL-001664



~~CONFIDENTIAL~~
Capital Costs

	<u>L-Zero</u>	<u>Siemens</u>	<u>GE</u>
Total Direct and Indirect \$M	\$ 7.39	\$ 12.38	\$ 11.00

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001665

DECLASSIFIED

DECLASSIFIED



CPVRR \$M (Production Costs and Capital) Comparison

CONFIDENTIAL

CPVRR \$M - Spring Outages	P-Plate	L-Zero	Siemens	GE	P-Plate - L-Zero	P-Plate - Siemens	P-Plate - GE
Fixed Costs	\$8,077	\$8,077	\$8,077	\$8,077	\$0	\$0	\$0
Fuel Cost	\$15,202	\$15,108	\$15,126	\$15,124	\$94	\$76	\$78
VOM Cost + Start Up Costs	\$2,210	\$2,203	\$2,205	\$2,204	\$7	\$5	\$6
Environmental	\$2,508	\$2,488	\$2,488	\$2,488	\$20	\$20	\$20
Total Production Costs	\$27,997	\$27,875	\$27,896	\$27,893	\$121	\$101	\$104
Capital Investment	0	\$ 8	\$ 11	\$ 10	(\$8)	(\$11)	(\$10)
Total Costs	\$27,997	\$27,883	\$27,907	\$27,903	\$113	\$90	\$94

Bid # 1: Mitsubishi L-Zero Blades Replacement

ISD: May 1st 2019

Bid # 2: Siemens Rotor Replacement

ISD: May 1st 2022

Bid # 3: GE Rotor Replacement


ISD: May 1st 2022

CONFIDENTIAL

DEF-19FL-FUEL-001666



Production Costs ~~CONFIDENTIAL~~ (\$M) Comparison



DECLASSIFIED

DECLASSIFIED



Bartow CC Steam Turbine Optimization Project - Fall'19 Outages

Additional Scenario – Moving the Major Outage from the 2019 Spring to the 2019 Fall

- Bid # 1: Mitsubishi L-Zero Blades Replacement ISD: Dec 1st 2019
- Bid # 3: GE Rotor Replacement ISD: Dec 1st 2019

CONFIDENTIAL

DEF-19FL-FUEL-001668



CPVRR \$M (Production Costs and Capital) Comparison

CONFIDENTIAL

CPVRR \$M - Spring Outages for Steam Turbine Upgrades	P-Plate	L-Zero - Year 2019	GE - Year 2022
Fixed Costs	\$8,077	\$8,077	\$8,077
Fuel Cost	\$15,202	\$15,108	\$15,124
VOM Cost + Start Up Costs	\$2,210	\$2,203	\$2,204
Environmental	\$2,508	\$2,488	\$2,488
Total Production Costs	\$27,997	\$27,875	\$27,893
Capital Investment	0	\$ 8	\$ 10
Total Costs	\$27,997	\$27,883	\$27,903

P-Plate - L-Zero	P-Plate - GE
\$0	\$0
\$94	\$78
\$7	\$6
\$20	\$20
\$121	\$104
(\$8)	(\$10)
\$113	\$94

CPVRR \$M - Fall Outages for Steam Turbine Upgrades	P-Plate	L-Zero - Year 2019	GE - Year 2019
Fixed Costs	\$8,077	\$8,077	\$8,077
Fuel Cost	\$15,202	\$15,116	\$15,113
VOM Cost + Start Up Costs	\$2,210	\$2,204	\$2,203
Environmental	\$2,508	\$2,488	\$2,488
Total Production Costs	\$27,997	\$27,885	\$27,881
Capital Investment	0	\$ 8	\$ 12
Total Costs	\$27,997	\$27,893	\$27,893

P-Plate - L-Zero	P-Plate - GE
\$0	\$0
\$86	\$89
\$6	\$6
\$20	\$20
\$111	\$115
(\$8)	(\$12)
\$103	\$103

CONFIDENTIAL

DEF-19FL-FUEL-001669


DECLASSIFIED

DECLASSIFIED



Production Costs CPVRR (\$M) Comparison – Fall Outages

CPVRR Differentials Chart \$M



(20)

CONFIDENTIAL

DEF-19FL-FUEL-001670



CONFIDENTIAL

Alternatives Configuration Cases:

- Combustion Turbine Upgrades
- Chiller Upgrades
- Both Combustion Turbine and Chiller Upgrades

Constraints:

- The B&V model cases for upgrades with the LP pressure plate indicated that the Bartow combined cycle can't operate in a 4x1 configuration because it violates the pressure limits set by MHI on the IP/LP turbines. Therefore, the CT upgrades for 4x1 configuration are not applicable.
- However, the 3x1 and 2x1 configurations were evaluated and met the pressure limits set by MHI in the HP/IP/LP turbines.

CONFIDENTIAL

DEF-19FL-FUEL-001671

DECLASSIFIED

DECLASSIFIED

DECLASSIFIED



CPVRR (\$M) Comparison - Pressure Plate w/ Upgrades

CONFIDENTIAL

CPVRR \$M	<u>P-Plate Ref Case</u>	<u>P-Plate with CT Upgrade Case</u>	<u>P-Plate with Chillers Upgrade Case</u>	<u>P-Plate with CT and Chillers Upgrade Case</u>	<u>P-Plate Ref Case - P-Plate with CT Upgrade Case</u>	<u>P-Plate Ref Case - P-Plate with Chillers Upgrade Case</u>	<u>P-Plate Ref Case - P-Plate with CT and Chillers Upgrade Case</u>
Fixed Costs	\$8,077	\$8,077	\$8,077	\$8,077	\$0	\$0	\$0
Fuel Cost	\$15,202	\$15,266	\$15,187	\$15,254	(\$64)	\$16	(\$51)
VOM Cost + Start Up Costs	\$2,210	\$2,213	\$2,208	\$2,212	(\$3)	\$1	(\$2)
Environmental	\$2,508	\$2,528	\$2,505	\$2,526	(\$20)	\$3	(\$18)
CT Upgrade Capital	\$0	\$89	\$0	\$89	(\$89)	\$0	(\$89)
Chillers Upgrade Capital	\$0	\$0	\$57	\$57	\$0	(\$57)	(\$57)
Total Cost	\$27,997	\$28,173	\$28,033	\$28,214	(\$177)	(\$37)	(\$217)

CONFIDENTIAL

DEF-19FL-FUEL-001672



CPVRR (\$M) Comparison - L-Zero w/ Upgrades

CONFIDENTIAL

CPVRR \$M	L-Zero Ref Case	L-Zero with CT Upgrade Case	L-Zero with Chillers Upgrade Case	L-Zero with CT and Chillers Upgrade Case	L-Zero Ref Case - L-Zero with CT Upgrade Case	L-Zero Ref Case - L-Zero with Chillers Upgrade Case	L-Zero Ref Case - L-Zero with CT and Chillers Upgrade Case
Fixed Costs	\$8,077	\$8,077	\$8,077	\$8,077	\$0	\$0	\$0
Fuel Cost	\$15,108	\$15,048	\$15,092	\$15,038	\$60	\$16	\$70
VOM Cost + Start Up Costs	\$2,203	\$2,200	\$2,201	\$2,199	\$3	\$2	\$4
Environmental	\$2,488	\$2,471	\$2,485	\$2,468	\$16	\$3	\$20
CT Upgrade Capital ¹	\$0	\$89	\$0	\$89	(\$89)	\$0	(\$89)
Chillers Upgrade Capital ²	\$0	\$0	\$57	\$57	\$0	(\$57)	(\$57)
Total Cost	\$27,875	\$27,885	\$27,912	\$27,928	(\$10)	(\$37)	(\$53)
Gen CT Capital ³	\$0	(\$16)	(\$16)	(\$85)	\$16	\$16	\$85
Gen CT FOM ¹³	\$0	(\$1)	(\$1)	(\$4)	\$1	\$1	\$4
	\$27,875	\$27,868	\$27,895	\$27,839	\$7	(\$20)	\$36

¹ CTs Upgrade Capital Investment \$100M 2018\$ over a 1 year period (2022 May-2023 Apr / 70% 2022 - 30% 2023)
Insurance Costs have been included. No Property Taxes have been included. Book Life assumed as the 21 Yr Remaining Life. Tax Life assumption 20 Yr.

² Chillers Upgrade Capital Investment \$64M 2018\$ over a 1 year period (2022 May-2023 Apr / 70% 2022 - 30% 2023)
Insurance Costs have been included. No Property Taxes have been included. Book Life assumed as the 21 Yr Remaining Life. Tax Life assumption 20 Yr.

³ One of the 2027 New CTs is delayed to 2029 in the CT Upgrade Cases and the Ch Upgrades Cases
One of the 2027 is avoided in the CT and Chiller (both happening simultaneously) Upgrade Cases

CONFIDENTIAL

DEF-19FL-FUEL-001673

DECLASSIFIED



CONFIDENTIAL

DECLASSIFIED



Commercial "TCO" evaluation details

CONFIDENTIAL

DEF-19FL-FUEL-001674



CONFIDENTIAL

Duke Energy - Bartow Combined Cycle Facility STG
LPT/L0 Upgrade
Bid Analysis April 20,

INTRODUCTION/SCOPE OF WORK					
LP Turbine L0/steam path upgrades					
TABLE 1: BID ANALYSIS SUMMARY					
	Press Plate	MHPS	GE	SIEMENS	Comments
SCHEDULE:					
Delivery		12 months	13 months	20 months	
Outage duration		43 days	35 days	35 days	
a. BASE BID PRICE (From Table 2)	\$0	\$6,931,284	\$9,091,000	\$10,398,000	
COST ADJUSTMENTS					
b. Technical Cost Adjustment (From Table 3)	\$0	\$100,000	\$235,806	\$295,806	
c. Commercial Cost Adjustment (From Table 4)	\$0	\$0	\$0	\$0	
EXPECTED / FINAL CONTRACT PRICE (a+b+c)	\$0	\$7,031,284	\$9,326,806	\$10,693,806	
		BASE	\$2,205,522	\$3,662,522	
		BASE	33%	52%	
EVALUATING FACTORS					
d. Technical Evaluation (From Table 3)	\$0	\$0	\$50,000	\$250,000	Not complete evaluation cost
e. Construction Evaluation (From Table 3)	\$0	\$0	\$0	\$0	Not complete evaluation cost
g. Commercial Evaluation (From Table 4)	\$0	\$0	\$0	\$0	
EVALUATED FACTORS SUBTOTAL (d+e+g)	\$0	\$0	\$50,000	\$250,000	
TOTAL EVALUATED COST(a+b+c+d+e+f+g)	\$0	\$7,031,284	\$9,376,806	\$10,943,806	Crane not included
Minus Installation	\$0	\$5,442,814	\$7,533,806	\$9,193,806	Crane not included
		\$1,588,470	\$1,843,000	\$1,750,000	
Evaluated Cost Difference (Evaluated Cost - Low Evaluated Cost)		BASE	\$2,345,522	\$3,912,522	
Percentage Difference vs. Evaluated Base (Evaluated Cost / Low Evaluated Cost)		BASE	33%	56%	

CONFIDENTIAL

DEF-19FL-FUEL-001675

DECLASSIFIED

DECLASSIFIED

DECLASSIFIED



CONFIDENTIAL

Duke Energy - Bartow Combined Cycle Facility STG
LPT/L0 Upgrade
Bid Analysis April
20, 2018

TABLE 2: PRICE BREAKDOWN					
Bidders:	Press Plate	MHPS	GE	SIEMENS	Comments
Base Bid Price	\$0	\$6,931,284	\$9,091,000	\$10,398,000	
Price Breakdown:					
Fully Bladed LP Rotor with integral coupling, high speed balanced and overspeed tested			\$7,248,000	\$8,430,000	
LP Inner Cylinder Complete With Attached Stationary Components (Blade Carriers, one per opposing flow, with stationary blading, integral exhaust tip diffusers and all associated half joint bolting,)			included	included	
Cooling spray nozzles and pipes connected to existing spray water system			included	included	
Pilgrim hydraulic coupling bolts and sleeves for the HP/IP-			included	included	
LP and LP-Generator couplings			included	included	
Sets of keys, shims, and packers for blade carrier alignment and adjustment;			included	included	
Casing guide pillars, eyebolts and bolt tensioning			included	included	
Transportation to site			included	\$218,000	SIEMENS shipping costs are estimated only, not firm
Supply L0 blades only		\$5,342,814	not offered	not offered	Past blade sets cost \$3.5M (both ends) - significant difference
Removal of existing LPT			included		
Installation for items above		\$1,588,470	\$1,843,000	\$1,750,000	SIEMENS cost includes T&M basis scope which needs further definition
Base Bid Price (Should Equal Base Bid Price Above)	\$0	\$6,931,284	\$9,091,000	\$10,398,000	

CONFIDENTIAL

DEF-19FL-FUEL-001676



CONFIDENTIAL

Duke Energy - Bartow Combined Cycle Facility STG
LPT/L0 Upgrade
Bid Analysis April
20, 2018

TABLE 3: TECHNICAL EVALUATION					
Description	Press Plate	MHPS	GE	SIEMENS	Comments
Technical Cost Adjustments to Base Bid					
1. Blade Vibration Monitoring		Included	To be Provided	One year only	MHPS \$200k/yr monitoring fee
2. Steel Blade Carrier			Not provided	Included	
3. High speed Lube Oil flush			\$90,806	\$90,806	Based on budgetary pricing
4. LP rotor and outer casing disposal			\$45,000	\$45,000	Estimated
5. Training		Not required	Not provided	Included	SIEMENS included 4 days
6. Torsional Testing		Not required	Not required	\$60,000	Pre+Post Tests Supervised jointly
7. Performance Testing		\$100,000	\$100,000	\$100,000	Estimated
Subtotal Technical Cost Adjustments (Subtotal Forwarded to Table 1)	\$0	\$100,000	\$235,806	\$295,806	
Technical Evaluation Factors					
Differential Balance of Plant Costs:					
1. Jacking Oil Pump Installation	Not required	Not required	Not required	\$200,000	2 AC Pumps, 75 kW estimated
Differential Engineering Costs:					
1. Foundation analysis study	Not required	Not required	\$50,000	\$50,000	Provided by Duke; GE may not need FA study
Differential Operating & Maintenance Costs:					
1. Fuel costs, 2018-2037 (\$k)	\$3,707,733	\$4,240,626	\$4,190,766	\$4,195,075	NOT USED Provided by Duke
2. O&M costs (k)	\$38,040	\$44,971	\$40,231	\$41,320	Using information received from Duke, bidder proposals and supplemented with EPRI SOAPP cost estimating model
Other Technical Evaluation Factors:					
1. Crane upgrades			Not evaluated	Not evaluated	Could be none or significant
2. Foundation upgrade costs			Not evaluated	Not evaluated	Could be none or significant
3. Journal bearing rebarbbit costs			Not evaluated	Not evaluated	Minimal impact if needed
Subtotal Technical Evaluation Factors (Subtotal Forwarded to Table 1)	\$0	\$0	\$50,000	\$250,000	
Construction Evaluation Factors					
1. Foundation Modification			Not evaluated	Not evaluated	Could be none or significant (100-500K)
Subtotal Constructability Factors (Subtotals Forwarded to Table 1)	\$0	\$0	\$0	\$0	

CONFIDENTIAL

DEF-19FL-FUEL-001677

DECLASSIFIED



CONFIDENTIAL

DECLASSIFIED

CONFIDENTIAL

Operations and Maintenance Analysis Assumptions

- 1) Must Run All the Time @ 2x1 at 40%
- 2) Assumptions for the L-Zero Case (Mitsubishi proposal): Outage: 12 weeks
ISD: May 1st 2019.
- 3) For GE and Siemens proposals: Outage: 12 weeks
ISD: May 1st 2022.

2024	4.10%
2025	4.10%
2026	8.20%
2027	4.10%
2028	4.10%
2029	5.80%
2030	4.10%
2031	4.10%
2032	4.10%
2033	8.20%
2034	4.10%
2035	4.10%
2036	5.70%
2037	4.10%
2038	4.10%

- 4) Outage from Connie Bruce

Taken from the ST Templates that TGS Provided to RS/FHO Stations

Current	
Full Major Template \$	Inc \$1.3M for Crane
5,612,640	
Full Major Template \$	
(Bartow) 4,492,640	
HPIP \$	
Only 2,336,320	
\$	
LP Only 2,336,320	

From Dave Burney
Crane (650T) \$180,000 2 weeks
Crane (1000T) - GE and Siemens adder to template \$384,000 2 weeks
adder for GE and Siemens if combined with HPIP \$204,000
From Chris Holland
\$3,500,00
0
1 Set of TE and GE L-0 Blades 0

OPTIM Current	Z3/Z4 Due
HPIP 64,000 Hrs	2019
LP 64,000 Hrs	2022
Valves 24,000 Hrs	2019

	Assumes
	8k Hrs / Yr
	Next
	OPTIM
	Outage
OPTIM w/ GE LP Rotor	
HPIP 64,000 Hrs	2027
LP 100,000 Hrs	2031
Valves 24,000 Hrs	2021

Assumes 2019 Install

	Assumes
	8k Hrs / Yr
	Next
	OPTIM
	Outage
OPTIM w/ Siemens LP Rotor	
HPIP 64,000 Hrs	2027
LP 100,000 Hrs	2034
Valves 24,000 Hrs	2022

Assumes 2022 Install

CONFIDENTIAL

DEF-19FL-FUEL-001678



Fuel and Non-Fuel Operational and Maintenance Cost Estimate

Option 1: Pressure Plate	NPV (2018)	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	Total Cost	Desc.	\$/MWh	
Fuel Cost \$k	\$1,921,964	\$156,370	\$121,424	\$123,732	\$123,409	\$124,647	\$132,406	\$144,958	\$164,587	\$169,324	\$192,644	\$201,359	\$211,191	\$223,575	\$219,224	\$216,227	\$217,228	\$233,502	\$239,074	\$248,003	\$244,851	\$3,707,735	Fuel Total		
Interval Hours			7,855	16,125	24,372	32,365	40,048	48,158	56,243	63,983	72,068	80,178	88,125	96,210	104,295	112,405	120,145	128,230	136,315	144,286	152,371				
Operating Hours		8,247	7,855	8,270	8,247	7,993	7,683	8,110	8,085	7,740	8,085	8,110	7,947	8,085	8,085	8,110	7,740	8,085	8,085	7,971	8,085				
LP Inspection Interval			Minor	Minor	Minor	Major	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Major				
Cost \$k	\$3,466	0	0.05	0.05	0.05	\$2,335	0.05	0.05	0.05	0.05	0.05	0.05	0.05	\$2,335	0.05	0.05	0.05	0.05	0.05	0.05	\$2,335	\$7,010	LP Total		
HP/IP Inspection Interval			Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major				
Cost \$k	\$4,194	0	\$7,335	0	0	0	0	0	0	0	\$2,335	0	0	0	0	0	0	0	0	0	\$2,335	\$7,009	HP/IP Total		
sum	\$1,929,634	\$156,370	\$123,760	\$123,732	\$123,409	\$126,983	\$132,406	\$144,958	\$164,587	\$169,324	\$194,980	\$201,359	\$211,191	\$225,911	\$219,224	\$216,227	\$217,228	\$233,502	\$241,410	\$248,003	\$247,187	\$3,721,754	Fuel/O&M Total	\$33.15	104.21%

Option 2: MHPs LSB Upgrade		2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	Total Cost	Desc.	\$/MWh	
Fuel Cost \$k	\$2,180,824.69	\$156,370	\$129,412	\$140,663	\$139,078	\$141,679	\$148,409	\$173,025	\$190,456	\$196,894	\$225,442	\$233,848	\$243,787	\$261,738	\$251,300	\$245,858	\$247,611	\$269,620	\$278,384	\$287,218	\$279,834	\$4,240,626	Fuel Total		
Interval Hours		8,247	7,762	8,270	8,247	7,993	7,683	8,110	8,085	7,740	8,085	8,110	7,947	8,085	8,085	8,110	7,740	8,085	8,085	7,971	8,085				
Operating Hours		8,247	7,762	8,270	8,247	7,993	7,683	8,110	8,085	7,740	8,085	8,110	7,947	8,085	8,085	8,110	7,740	8,085	8,085	7,971	8,085				
LP Inspection Interval			Minor	Minor	Minor	Major	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Major				
Cost \$k	\$9,119	0	\$7,489	0	0	0	0	0	0	0	\$2,248	0	0	0	0	0	0	0	0	0	\$2,248	\$12,182	LP Total		
HP/IP Inspection Interval			Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major				
Cost \$k	\$4,032	0	\$2,248	0	0	0	0	0	0	0	\$2,248	0	0	0	0	0	0	0	0	0	\$2,248	\$6,739	HP/IP Total		
sum	\$2,193,975	\$156,370	\$139,347	\$140,663	\$139,078	\$141,679	\$148,409	\$173,025	\$190,456	\$196,894	\$229,935	\$233,848	\$243,787	\$261,738	\$251,300	\$245,858	\$247,611	\$269,620	\$282,877	\$287,218	\$279,834	\$4,259,547	Fuel/O&M Total	\$31.81	100.00%

Option 3: GE LPT Upgrade		2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	Total Cost	Desc.	\$/MWh	
Fuel Cost \$k	\$2,138,848	\$156,370	\$121,424	\$123,732	\$123,409	\$133,380	\$148,403	\$173,008	\$190,426	\$196,831	\$224,698	\$233,351	\$243,871	\$261,264	\$251,897	\$245,824	\$247,712	\$269,558	\$278,297	\$287,291	\$280,019	\$4,190,765	Fuel Total		
Interval Hours			7,855	16,125	24,372	7,739	15,422	23,532	31,617	39,357	47,442	55,552	63,499	71,584	79,669	87,779	95,519	103,604	111,689	119,660	127,745				
Operating Hours		8,247	7,855	8,270	8,247	7,739	7,683	8,110	8,085	7,740	8,085	8,110	7,947	8,085	8,085	8,110	7,740	8,085	8,085	7,971	8,085				
LP Inspection Interval				LP Replace		LP Replace (OPTIM due)										Major									
Cost \$k	\$9,580	0	0	\$9,761	0	0	0	0	0	0	0	0	0	0	0	\$2,720	0	0	0	0	\$12,481	LP Total			
HP/IP Inspection Interval			Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major				
Cost \$k	\$4,194	0	\$2,335	0	0	0	0	0	0	0	\$2,335	0	0	0	0	0	0	0	0	0	\$2,335	\$7,009	HP/IP Total		
All in TCO	\$2,160,066.59	\$156,370	\$123,760	\$133,493	\$123,409	\$143,141	\$148,403	\$173,008	\$190,426	\$196,831	\$227,034	\$233,351	\$243,871	\$261,264	\$251,897	\$248,544	\$247,712	\$269,558	\$280,633	\$287,291	\$280,019	\$4,210,255	Fuel/O&M Total	\$32.19	101.19%

Option 4: Siemens LPT Upgrade		2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	Total Cost	Desc.	\$/MWh	
Fuel Cost \$k	\$2,140,888	\$156,370	\$121,424	\$123,732	\$123,409	\$133,346	\$148,424	\$173,609	\$190,753	\$195,930	\$225,658	\$234,965	\$243,804	\$261,714	\$251,208	\$245,781	\$247,590	\$269,554	\$278,180	\$287,709	\$281,915	\$4,195,075	Fuel Total		
Interval Hours		8,247	7,855	8,270	8,247	7,739	7,683	8,110	8,085	7,740	8,085	8,110	7,947	8,085	8,085	8,110	7,740	8,085	8,085	7,971	8,085				
Operating Hours		8,247	7,855	8,270	8,247	7,739	7,683	8,110	8,085	7,740	8,085	8,110	7,947	8,085	8,085	8,110	7,740	8,085	8,085	7,971	8,085				
LP Inspection Interval				LP Replace		LP Replace (OPTIM due)										Major									
Cost \$k	\$10,949	0	0	\$11,328	0	0	0	0	0	0	0	0	0	0	0	\$2,720	0	0	0	0	\$14,048	LP Total			
HP/IP Inspection Interval			Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major				
Cost \$k	\$4,194	0	\$2,335	0	0	0	0	0	0	0	\$2,335	0	0	0	0	0	0	0	0	0	\$2,335	\$7,009	HP/IP Total		
sum	\$2,164,473	\$156,370	\$123,760	\$135,060	\$123,409	\$144,674	\$148,424	\$173,609	\$190,753	\$195,930	\$227,994	\$234,965	\$243,804	\$261,714	\$251,208	\$248,501	\$247,590	\$269,554	\$280,516	\$287,709	\$281,915	\$4,216,132	Fuel/O&M Total	\$32.15	101.07%

DECLASSIFIED

CONFIDENTIAL

DEF-19-FL-FUEL-001678

EXHIBIT NO. _____

DOCKET NO: 20190001-EI

WITNESS: Jeffrey Swartz

DECLASSIFIED

PARTY: DUKE ENERGY FLORIDA

DESCRIPTION:

DEF's Response to Citizens' Third Set of Interrogatories (Nos. 16-17)

PROFFERED BY: White Spring Agricultural Chemicals, Inc. d/b/a
PCS Phosphate

AFFIDAVIT

STATE OF FLORIDA

COUNTY OF PINELLAS

I hereby certify that on this 31st day of July, 2019, before me, an officer duly authorized in the State and County aforesaid to take acknowledgments, personally appeared JEFFREY SWARTZ, who is personally known to me, and has acknowledged before me that he provided the answers to interrogatory numbers 16 and 17 of CITIZENS' THIRD SET OF INTERROGATORIES TO DUKE ENERGY FLORIDA, LLC (Nos. 16-17) in Docket No. 20190001-EI, and that the responses are true and correct based on his personal knowledge.

In Witness Whereof, I have hereunto set my hand and seal in the State and County aforesaid as of this 31st day of JULY, 2019.

[Signature]
Jeffrey Swartz

[Signature]
Notary Public
State of Florida, at Large



My Commission Expires: July 18, 2022

DECLASSIFIED

DECLASSIFIED

CONFIDENTIAL


Bartow Steam Turbine Path Forward Recommendation

Bartow ST Project Team Summary

May 29, 2018



WORKING DRAFT – SUBJECT TO CHANGE



CONFIDENTIAL

DEF-19FL-FUEL-001602



CONFIDENTIAL Evaluation Overview & Agenda

- **Team evaluated 4 possible solutions for Bartow ST**
 - GE – LP retrofit
 - Siemens – LP retrofit
 - MHPS – Redesigned L-0 blade
 - Continue with the MHPS - Pressure Plate
- **Recommended solution for Bartow ST**
- **Details on our process and the selection**
 - Technical Evaluation
 - Performance Evaluation
 - Commercial Evaluation
- **Team Leaders:**
 - Dave Burney – Project Lead
 - Analytics Team – Mike Rib
 - Technical Team – Jake English
 - Total Cost of Ownership Analysis – Black & Veatch
 - Supply Chain – Jeremy Holton

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001603

DECLASSIFIED



CONFIDENTIAL

Executive Summary

Considering all elements of the evaluation (technical, cost, risk), the recommended path forward is to proceed with the new MHPS L-0 blade solution

- With GE being a close second from a business and technical perspective
- Siemens would be the less technically preferred solution to GE for an LP retrofit

Key elements of the evaluation that support the MHPS recommendation:

- All vendors have limited operating experience at the required steam flow rates, but MHPS appears to have the best understanding of the equipment, the historic L-0 issues, and the CC intricacies at Bartow. This understanding was built into their design changes.
- Their solution can be delivered before others – fuels/efficiency benefits realized earlier.
- Costs: MHPS credit of \$1.5M would be lost.
- All of upgrade proposals, including the MHPS option, offer capacity and performance upgrade potential over remaining with the pressure plate
- The MHPS blade solution allows us to retain the pressure plate as a contingency plan. MHPS pressure plate is not compatible with GE or Siemens.

CONFIDENTIAL

DEF-19FL-FUEL-001604



CONFIDENTIAL

Commercial Negotiations

Commercial Negotiation Goals:

- Keep MHPS accountable to resolve any design issues that may come up
- LD's to create proper response and to support our reliability goals
- Warranty provisions to limit our financial exposure (open/close, blade replacement, etc.)

To minimize financial risk, the following items need to be negotiated with MHPS:

- Material cost challenge: Previous sets of L-0 cost ~\$3.5 (both ends). Proposal is \$2M more with credits applied
- 10 year warranty requires active BVM monitoring at \$200k per year. This cost needs to be eliminated, or significantly reduced.
- Warranty needs to be clear and LD levels need to be evaluated/adjusted
- Tie LD's to 'unknown' operating restrictions (blending limitations, exclusion zones)
- Design deficiencies, if identified, in operation (at their first commercial site in Nov '18 and/or at Bartow) need to be resolved by MHPS to eliminate any operating restrictions at Bartow

Do not inform GE of selection (contingency). Inform Siemens is cut from short list.

CONFIDENTIAL

DEF-19FL-FUEL-001605

DECLASSIFIED



CONFIDENTIAL Technical Evaluation: Criteria

- Technical Evaluation approached using a KT-style analysis
- Main & Sub-categories were developed based on key KPI's
- Scoring criteria were defined to ensure technical solutions were evaluated consistently & fairly
 - Note: Scoring was rated on a scale of 1 to 5, with 5 being the best possible score.
- Weighting was applied separately by the Station, RS, and TGS

%Wt.	Categories and Weighting Factors
Impact to Future Maintenance (20%)	
25%	Maintenance Interval
20%	Major Overhaul Scope \$\$\$/Neg. Impacts
10%	Emergent Outage Scope if L-0 Blades Require Replacement
15%	Additional Support Infrastructure (e.g. Lift Oil System)
5%	Replacement Interval of L-0 blades (As Proposed)
5%	Rotor Life Extension Evaluation
15%	Tech Support -- Responsiveness, Ownership of Issues
5%	L-0 Erosion Susceptibility
Impact to Future Operations (20%)	
20%	Restrictions to Blending
40%	Restrictions on Condenser (Back Pressure / Bathtub Curves)
35%	Max Flow Limitations
5%	Low Load Limitations
Unit Performance (10%)	
30%	MW Output
70%	Heat Rate
Unit Reliability (50%)	
50%	OEM Operating Experience (At >= to Bartow Exhaust Flow)
20%	Experience with OEM ST Equipment (Fleet Experience)
30%	Ability to Detect Adverse Operations (Real Time)



CONFIDENTIAL Technical Evaluation: Results

- Met with all 3 bidders and technically challenged their respective proposed solutions
- The technical assessment identified operational and performance deficiencies associated with continuing with the pressure plate as a long term solution
- Preferred technical selection is with MHPS and GE.

Overall Weighted Score			
MHPS	GE	Siemens	Press Plate
2.91	3.04	2.81	1.87

Ops/Maint Impact ONLY

MHPS	GE	Siemens	Press Plate
1.25	1.53	1.30	1.32

Performance/Reliability ONLY

MHPS	GE	Siemens	Press Plate
1.66	1.51	1.51	0.55

For ALL solutions ➔ operational experience for the proposed designs is limited

CONFIDENTIAL

DEF-19FL-FUEL-001607

DECLASSIFIED


DECLASSIFIED

DECLASSIFIED



Technical Evaluation: ~~CONFIDENTIAL~~ Original vs. Proposed L-0 Blade Design

- Improvements to mid-span stub design...
 - Increased length and thickness of the stub (by 1.4 times, each) to improve fretting fatigue strength.
 - The stub interface angle was increased to reduce tip bending by distributing fretting over a greater area.
- Improvements to shroud design...
 - Increased the shroud length by 1.6 times to improve fretting fatigue strength.
 - Adjusted the angle of shroud contact face to increase contact area as well as mechanical damping.
- Overall blade design improvements...
 - Geometry upgrades result in up to 80% less vibratory stress at the stub and shroud for same blade displacement.
 - Optimum stub and shroud gaps are designed to control contact speed and reaction force – i.e. better cold offset to get more hot/running contact face area.
 - No welding stellite (after machining) to distort contact faces as was seen on the Type 3 design.
 - 100% optic scanning of faces for acceptance testing vs. 4-point measurement to a blade fixture.



CONFIDENTIAL

Proposed 40" L-0 DEF 19FL-FUEL-001608



CONFIDENTIAL Technical Evaluation: November 2018

- November 2018 marks a critical milestone for MHPS in validating their upgraded blade design.

	Napanee	vs.	Takasago
L-0 Blade Type	Type 5		Type Proposed Redesign
Relative to Duke Fleet	Blade design set to go in-service at Citrus		Blade design proposed for Bartow
2018 Testing	Scheduled 4Q 2018 COD – ~457 MW Testing at higher LP steam flows comparable to Bartow (using BVM to monitor)		Scheduled November 2018 air excitation and electromagnetic excitation testing (using telemetry testing and BVM to monitor)
What Results of Testing Means for Each	<ul style="list-style-type: none"> GOOD – Napanee moves forward POOR – Replace Napanee L-0s with Proposed Redesign, or impose operational limitations. POOR – Duke must know of possible Bartow limitations and “why”. 		<ul style="list-style-type: none"> GOOD – Bartow project moves forward with MHPS L-0 Proposed Redesign option POOR – MHPS must provide an acceptable remedy plan to Duke, or Bartow Project moves to an alternate contingency plan.

- With either test case, Duke will have a vested interest in understanding the results and how they impact the long-term decision for Bartow.

CONFIDENTIAL

DEF-19FL-FUEL-001609

DECLASSIFIED

DECLASSIFIED



~~CONFIDENTIAL~~ **Technical Evaluation: Results Summary**

Why we believe the MHPS L-0 solution is a viable technical solution...

- Best understanding of equipment and impacts of operation on ST.
- Previous L-0 event “fixes” were not based on an understanding of the cause.
 - Previous “fixes” were not design changes but application of coatings as an attempt to address a perceived symptom.
- Proposed L-0 design changes are significant in the new blade design.
- Initial rig testing (vibratory stress) indicates promising results. November 2018 test data to provide further validation.
- Long-term BVM during operation will provide Duke the ability to detect issues and keep track of the reliability of the upgraded L-0s.
- LP retrofits (like the GE and Siemens options) carry greater unknown risks due to lack of operating experience and experience in a 4x1 application

CONFIDENTIAL

DEF-19FL-FUEL-001610



CONFIDENTIAL Analytics: Scenarios and Cases

Black & Veatch and Performance Services worked together to establish the new heat balance cases needed to support analysis of the upgrade options.

- Original base design (matching Bibb cases) and pressure-plate model (matching actual data)
- A design model for each vendor using LP turbine data from their submitted heat balances.
- The case matrix for each vendor design and pressure-plate model established vendor-specific and pressure-plate dispatch curves:
 - 12 operating configurations from 1x70% to 4x1 PAG/duct-fired/evaporative cooling
 - 3 ambient temperature conditions (35, 74 and 95 deg F)
 - Included ALLTD cases at 2x1, 3x1 and 4x1x40%
 - 4 layers – GE, Siemens, Mitsubishi and pressure-plate
- The case matrix for alternative configuration screening included CT upgrades and chiller evaluations
 - 2 layers – one typical vendor design and pressure-plate conditions
- Total number of cases run = 238

CONFIDENTIAL

DEF-19FL-FUEL-001611

DECLASSIFIED

DECLASSIFIED

DECLASSIFIED



CONFIDENTIAL

Analytics: Operating Limits

Operational limits used as limiting conditions in all of the heat balance cases:

- ST HP admission pressure = 2389.7 psia
- ST IP admission pressure = 583.7 psia
- ST IP exhaust pressure = 125.7 psia (for pressure-plate cases only)
- ST generator output limit at PF 1.0 = 468 gross MW after generator losses (468 MVA)
- Duct burner fuel flow per HRSG = 10,000 lb/hr
- PAG steam flow per CT = 121,910 lb/hr
- Achieve maximum duct burner fuel flow first before bringing in any PAG steam flow for the most efficient ST operation in the ST maximum output cases
- CT maximum torque limit of 230,000 KW





CONFIDENTIAL

DEF-19FL-FUEL-001612



Analytics AST Performance Comparisons

- Performance for the three OEM's is similar. With GE being slightly better than MHPS and Siemens



CONFIDENTIAL

DEF-19-FUEL-FUEL-001613

DECLASSIFIED

DECLASSIFIED



CONFIDENTIAL Analytics: Summary of Results

- Developed design models for each vendor to validate heat balance and determined if there were any equipment limitations
- CC normalized performance comparison (Winter, 4x1 (100%) + Duct/PAG):

	GE	MHPS	Siemens	Pressure Plate
Net Load (MW)	1,309	1,309	1,308	1,252
NUHR (btu/Kwh)	7,040	7,042	7,045	7,361

- CC normalized performance comparison (Summer, 4x1 (100%) + EC/Duct/PAG):

	GE	MHPS	Siemens	Pressure Plate
Net Load (MW)	1,172	1,169	1,169	1,121
NUHR (btu/Kwh)	7,069	7,089	7,085	7,388

- *Note: CT Upgrades and Chiller options were also evaluated and are summarized in the Appendix*

CONFIDENTIAL

DEF-19FL-FUEL-001614




CONFIDENTIAL: CC Performance Overview

CC upgrade performance results – Pressure plate is outlier, others comparable

Comparison of Performance Curves

Comparison of Annual Operating Hours
(Annual %'s Projected for 2023)



Notes:

- Bartow CC is modeled as a must run unit on the DEF system
- System production cost studies reflect positive CPVRR savings, pending finalization of the costs and timing for the upgrade projects
- Preliminary results are subject to change as the assessment progresses


CONFIDENTIAL

DEF-19FL-FUEL-001615

DECLASSIFIED

DECLASSIFIED

CONFIDENTIAL Fleet Generation Comparisons



CONFIDENTIAL

DEF-19FL-FUEL-001616



CONFIDENTIAL System Economics Summary

Results of the comparison of alternatives performed by Integrated Resource Planning

- Reflects impacts of performance upgrades on total DEF system costs over the planning period
- Includes the projected capital cost impacts for the upgrades
- Results in Cumulative PV of Revenue Requirements (\$CPVRR) reflect customer cost perspective

Comparison of Alternatives CPVRR \$M	P Plate	MHPS	Siemens	GE	P Plate vs	P Plate vs	P Plate vs
					MHPS ISD Fall 2019	Siemens ISD Spring 2022	GE ISD Fall 2019
System Fixed Costs	8,077	8,077	8,077	8,077	0	0	0
System Fuel Cost	15,202	15,116	15,126	15,113	86	76	89
System VOM Cost + Start Up Costs	2,210	2,204	2,205	2,203	6	5	6
System Environmental	2,508	2,488	2,488	2,488	20	20	20
Total Production Costs	27,997	27,885	27,896	27,881	111	101	115
Incremental Capital RR's	-	11	11	14	(11)	(11)	(14)
Total Costs	27,997	27,896	27,906	27,896	100	90	101

- As noted in the summary, resulting improvements for either the MHPS or GE options are comparable
- Given these results and the commercial and technical evaluations performed, the recommendation to proceed with negotiations and risk review with MHPS is supported.

CONFIDENTIAL

DEF-19FL-FUEL-001617

DECLASSIFIED



CONFIDENTIAL

Project Summary

- Project Cost to Install Solution (LP Section Only, in \$MM)

	GE	MHPS	Siemens
Materials	\$8.38	\$6.94	\$9.19
Labor	\$1.87	\$1.59	\$1.76
Crane	\$0.66	\$0.46	\$0.66
Grand Total	\$10.91	\$8.99	\$11.61

- Assumptions: OEM Turn Key labor, materials for LP only, crane cost for outage (project burdens not included)
- MHPS: Install in 2019 MJR with HPIP. Not included - \$1M pressure plate storage inventory increase
- GE and Siemens Install – LP Only MJR in 2020
- Does not include cost of any potential foundation modifications to accommodate added rotor weight (if needed for GE/Siemens)*

- BVM System and Monitoring Costs (in \$K)

	GE	MHPS	Siemens
System Cost	\$850	Included in Base	Included in Base*
Annual Monitoring	\$TBD**	\$200	\$44

* Siemens base package BVM offering was for 1-year installed. Siemens addendum for permanent install was "Base + \$50k"

** GE is purchasing/providing a 3rd Party BVM product and leaving the long-term monitoring responsibilities for Duke to manage.

CONFIDENTIAL

DEF-19FL-FUEL-001618



Bartow CC Steam Turbine ~~CONFIDENTIAL~~ Project - Alternative Configurations

In addition to review of the ST L-0 vendor proposals, the project team also performed a screening evaluation of several additional upgrade configurations.

Alternative Configuration* Cases:

- Combustion Turbine Upgrades
- Chiller Upgrades
- Both Combustion Turbine and Chiller Upgrades

**Note: Considered configurations both with and without the ST L-0 Upgrades*

Modeling & Analytics:

- B&V developed full load and partial heat balance model cases for the upgrades and determined the performance and full output capabilities with the limiting conditions assumed for the study.
- The alternative configurations were then studied by IRP to assess the savings potential in system production cost and capacity deferral.

Results

- The observed benefits offer limited potential for these investments at this time.

~~CONFIDENTIAL~~

DEF-19FL-FUEL-001619

DECLASSIFIED

DECLASSIFIED



Bartow CC Steam Turbine Optimization Project - Alternative Configurations

CONFIDENTIAL

Overview of Limits Observed:

Ambient	Mode	Configuration	Rate	Evap. Cooler	Duct Firing	PAG	Fuel	L-O Upgrade Only	GT Upgrade	Chiller	GT Upgrade and Chiller
35 F	2x1	2x100%	Max	-	-	-	Gas				
95 F	2x1	2x100%	Max	On	-	-	Gas				
35 F	3x1	3x100%	Max	-	-	-	Gas				
35 F	3x1	3x100%	Max	-	Fired	-	Gas		HPT		
74 F	3x1	3x100%	Max	-	-	-	Gas				
74 F	3x1	3x100%	Max	-	Fired	-	Gas		HPT		HPT
74 F	3x1	3x100% PAG	Max	-	Fired	PAG	Gas				HPT
95 F	3x1	3x100%	Max	On	-	-	Gas				
95 F	3x1	3x100%	Max	On	Fired	-	Gas		HPT		HPT
35 F	4x1	4x100%	Max	-	-	-	Gas				
35 F	4x1	4x100% Max DF	Max	-	Fired	-	Gas	IPT	IPT		
35 F	4x1	4x100% PAG	Max	-	Fired	PAG	Gas		IPT		
74 F	4x1	4x100%	Max	-	-	-	Gas				
74 F	4x1	4x100% Max DF	Max	-	Fired	-	Gas	IPT	IPT		IPT
74 F	4x1	4x100% PAG	Max	-	Fired	PAG	Gas				HPT
95 F	4x1	4x100%	Max	On	-	-	Gas				
95 F	4x1	4x100% PAG	Max	On	Fired	PAG	Gas		HPT		HPT
95 F	4x1	4x100% Max DF	Max	On	Fired	-	Gas	IPT	IPT	IPT	IPT

- No limit
- Limited by IPT inlet pressure
- Limited by HPT inlet pressure
- Not achievable

- Includes L-O Upgrades
- 4x1x100% cases with max duct-firing limited by IPT inlet pressure
- 3x1x100% cases with duct-firing/PAG limited by HPT inlet pressure
- 4x1x100% cases with duct-firing limited by IPT inlet pressure
- 4x1x100% cases with duct-firing/PAG limited by HPT inlet pressure

CONFIDENTIAL


DEF-19FL-FUEL-001620



CONFIDENTIAL

Performance Improvements:

4X100% NUHR vs Net Load - Summer with L-O Upgrade



- Includes L-O Upgrades
- Duct-firing case
Limiting condition = IP admission pressure
- PAG case
Limiting condition = HP admission pressure

CONFIDENTIAL

DEF-19FL-FUEL-001621

DECLASSIFIED

DECLASSIFIED



Bartow CC Steam Turbine Optimization Project - Alternative Configurations

CONFIDENTIAL

Economic Study Results:

Comparison to Ref Case (with the ST L-0 Upgrade) 20 Yr Cumulative PV of Revenue Requirements (\$M)	CT Upgrades	Chiller Additions	CT Upgrades & Chiller Additions
Fuel & Other Production Cost Savings	63	18	74
Environmental Savings	16	3	20
Upgrade Capital (CT, Chillers)	(89)	(57)	(146)
CPVRR System Savings (Costs)	(10)	(37)	(53)
Deferred Planned Additions Savings	17	17	89
CPVRR Total Savings (Costs)	7	(20)	36
MW and HR* Improvements (Summer)	126 / (100)	79 / 49	175 / (142)

* HR Improvements in Btu/kWh

CONFIDENTIAL

DEF-19FL-FUEL-001622



CONFIDENTIAL

Next Steps...

Any Questions?

- T&C negotiation with MHPS
- Communicate direction with Legal to get input
- Begin building a project execution plan and budget

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001623

DECLASSIFIED

CONFIDENTIAL



CONFIDENTIAL

DEF-19FL-FUEL-001624



CONFIDENTIAL



Backup Slides – Additional Detail & Analysis...

DECLASSIFIED CONFIDENTIAL

DEF-19FL-FUEL-001625



DECLASSIFIED

CONFIDENTIAL Technical Evaluation: Criteria Details

■ Sub Category rating criteria and definitions

%Wt	Criteria and Weighting Factors	Rating Criteria		
		1	3	5
Impact to Future Maintenance (20%)				
25%	Maintenance Interval	Worse Than Current	Same As Current (64k Hrs)	Better Than Current
20%	Major Overhaul Scope \$\$\$/Neg. Impacts	Templates Will Require Adjustment	No Adjustment to Templates	Template Cost Reduced
10%	Emergent Outage Scope if L-0 Blades Require Replacement	Requires Rotor Removal	NA	Does Not Require Rotor Removal
15%	Additional Support Infrastructure (e.g. Lift Oil System)	Mods/Maint Adders Req'd (Additional Maint. Impact)	Mods/Maint Adders Req'd (No Additional Maint. Impact)	No Mods/Maint. Equipment Adders
5%	Replacement Interval of L-0 blades (As Proposed)	< 1 Maintenance Interval	1 Maintenance Interval (64k Hrs)	> 1 Maintenance Interval
5%	Rotor Life Extension Evaluation	< (200k Hours / 5k Starts) before RLE	(200k Hours / 5k Starts) before RLE	> (200k Hours / 5k Starts) before RLE
15%	Tech Support -- Responsiveness, Ownership of Issues	Multi-OEM ST Config -- Higher Likelihood of Having Difficulty w Problem Solving	NA	No Conflict or Difficulty Resolving Issues
5%	L-0 Erosion Susceptibility	No Erosion Protection, Erosion Likely w Design -- Increased Reliability Risk	Likely to Have Erosion (Regardless of Protection Scheme) -- Not Likely to Cause Issues	Proven Experience with Mitigating Erosion
Impact to Future Operations (20%)				
20%	Restrictions to Blending	Restrictons / Unknown Until Ops Data Collected	Known / Acceptable Restrictions	No Restrictions
40%	Restrictions on Condenser (Back Pressure / Bathtub Curves)	Restrictons / Unknown Until Ops Data Collected	Known / Acceptable Restrictions	No Restrictions
35%	Max Flow Limitations	(< 2.38 MPPH / 420 MW) / Min Margin Available	(= 2.38 MPPH / 420 MW) / Min Margin Available	(2.7 MPPH / 450+ MW) / Margin Available
5%	Low Load Limitations	ST Output of > ~65 MW Indefinitely (1x1 or 2x1)	ST Output of ~65 MW Indefinitely w/o Sprays (1x1)	ST Output of < ~65 MW Indefinitely w/o Sprays (1x1)
Unit Performance (10%)				
30%	MW Output	Today w/ PressPlate	Nameplate (420 MW)	Bid Spec Guarantee (450MW)
70%	Heat Rate	Appreciable Increase in HR	Same as Kiewit 2009 Value	Appreciable Decrease in HR
Unit Reliability (50%)				
50%	OEM Operating Experience (At >= to Bartow Exhaust Flow)	Test Rig Only	Operation Experience < 64k Hrs	Operational Experience > 64k Hrs
20%	Experience with OEM ST Equipment (Fleet Experience)	Several Operational/Historical Design Deficiencies	Some Issues but Responds Quickly and Responsibly	Few Operational/Historical Design Deficiencies
30%	Ability to Detect Adverse Operations (Real Time)	No Telemetry Test / No BVM	Telemetry Test at Strm Conditions	BVM



CONFIDENTIAL Technical Evaluation: KT Assessment Details

■ Scoring Results by Category (unweighted and weighted)

Criteria and Weighting Factors	Criteria Based Scoring (Unweighted)				Criteria Based Scoring (Weighted)			
	MHPS	GE	Siemens	Press Plate	MHPS	GE	Siemens	Press Plate
Impact to Future Maintenance (20%)					3.50	3.70	2.95	3.10
Maintenance Interval	3	5	5	2	0.75	1.25	1.25	0.5
Major Overhaul Scope \$\$\$/Neg. Impacts	3	2	1	2	0.6	0.4	0.2	0.4
Emergent Outage Scope if L-0 Blades Require Replacement	1	5	5	5	0.1	0.5	0.5	0.5
Additional Support Infrastructure (e.g. Lift Oil System)	5	5	1	2	0.75	0.75	0.15	0.3
Replacement Interval of L-0 blades (As Proposed)	5	5	5	5	0.25	0.25	0.25	0.25
Rotor Life Extension Evaluation	3	3	3	3	0.15	0.15	0.15	0.15
Tech Support -- Responsiveness, Ownership of Issues	5	2	2	5	0.75	0.3	0.3	0.75
L-0 Erosion Susceptibility	3	2	3	5	0.15	0.1	0.15	0.25
Impact to Future Operations (20%)					2.75	3.95	3.55	3.50
Restrictions to Blending	4	4	4	5	0.8	0.8	0.8	1
Restrictions on Condenser (Back Pressure / Bathtub Curves)	1	4	3	5	0.4	1.6	1.2	2
Max Flow Limitations	4	4	4	1	1.4	1.4	1.4	0.35
Low Load Limitations	3	3	3	3	0.15	0.15	0.15	0.15
Unit Performance (10%)					3.60	3.60	3.60	1.00
MW Output	5	5	5	1	1.5	1.5	1.5	0.3
Heat Rate	3	3	3	1	2.1	2.1	2.1	0.7
Unit Reliability (50%)					2.60	2.30	2.30	0.90
OEM Operating Experience (At >= to Bartow Exhaust Flow)	1	1	1	0	0.5	0.5	0.5	0
Experience with OEM ST Equipment (Fleet Experience)	3	3	3	3	0.6	0.6	0.6	0.6
Ability to Detect Adverse Operations (Real Time)	5	4	4	1	1.5	1.2	1.2	0.3

Overall Weighted Score			
MHPS	GE	Siemens	Press Plate
2.91	3.04	2.81	1.87

Ops/Maint Impact ONLY

MHPS	GE	Siemens	Press Plate
1.25	1.53	1.30	1.32

Performance/Reliability ONLY

MHPS	GE	Siemens	Press Plate
1.66	1.51	1.51	0.55

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001627

DECLASSIFIED



CONFIDENTIAL Technical Evaluation: Siemens Summary

- Of the three viable options this is the least preferred option
 - Requires a lift oil system to manage rotor weight
 - Complexity added with major maintenance requiring potential 1000T crane to lift rotor
 - Torsional testing is required (nothing in the proposal covers discovery)
 - Limited operating experience at the flow rate required at Bartow
 - Similar design as what is in the Osprey ST.
-
- No engineering has been performed to determine if there are any system impacts (equipment modifications) or foundation modification due to the heavy rotor. High potential for project cost creep

CONFIDENTIAL

DEF-19FL-FUEL-001628



CONFIDENTIAL

Technical Evaluation: GE Summary

- Of the three viable options this is the first preferred for an LP retro-fit option
 - Rotor weight is heavier but GE indicated some additional engineering could take place to reduce weight
 - No lift system required
 - Torsional testing is not required , but the technical team may require detailed reviews to ensure this is not needed (nothing in the proposal covers discovery)
 - Limited operating experience at the flow rate. Installed in two (2) Texas units with <10k hrs of operation
-
- No engineering has been performed to determine if there are any system impacts (equipment modifications) or foundation modification due to the heavy rotor. High potential for project cost creep

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001629

DECLASSIFIED



CONFIDENTIAL Technical Evaluation: Pressure Plate Summary

- The pressure plate option was a low-scoring outlier in the technical evaluation.
- Recent inspections have shown the presence of the pressure plate causes damage to neighboring and downstream infrastructure due in part to increased steam velocities generated because of the pressure plate.
- Continued operation with the pressure plate and its effects on future recommended maintenance intervals can not yet be determined.

- IF Duke proceeds with the recommended MHPs technical offering, the pressure plate (and associated hardware) will need to be removed, blast cleaned, NDE'd and placed into Bartow inventory for short-term contingency (3-5 years).
- IF Duke proceeds with either the GE or Siemens technical offerings, the existing pressure plate will not be able to be reused in those rotor configurations.

CONFIDENTIAL

DEF-19FL-FUEL-001630



CONFIDENTIAL



Performance team evaluation details

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001631



DECLASSIFIED

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001632

Performance evaluation details

Bartow CC -LP Turbine Upgrade Study 2018

Becky McClintock
Thermal Performance M&D Center

CONFIDENTIAL

DEF-19FL-FUEL-001632



CONFIDENTIAL

Overview

- Load Cases Requested from Vendors
- Black & Veatch Modeling and Analysis
 - Case Matrix
 - Operational Limits
- Model Results
 - Steam turbine performance by vendor
 - Net unit heat rate
 - GT Upgrade and Chiller Operating Limitations

CONFIDENTIAL

DEF-19FL-FUEL-001633

DECLASSIFIED

DECLASSIFIED



CONFIDENTIAL

Load Cases Requested from Vendors

- Four full-load cases and one low-load case
 - 1) 455.7 Gross MW - Maximum load on steam turbine below its operational limits and matching December 2014 steam turbine test conditions at 2.5"Hg condenser back pressure
 - 2) 449.9 Gross MW - Maximum load on steam turbine below its operational limits and matching December 2014 steam turbine test conditions at 4.5"Hg condenser back pressure
 - 3) 419.6 Gross MW - Guarantee load from Bibb Heat Balances for fired conditions
 - 4) 385.7 Gross MW - Guarantee load from Bibb Heat Balances for unfired conditions
 - 5) 59.5 Gross MW - Low load from Bibb Heat Balances (1x1x70% CT Load at 95 deg F ambient)


CONFIDENTIAL

DEF-19FL-FUEL-001634

CONFIDENTIAL

455.7 Gross MW

Valves Wide Open (IP Inlet Pressure at Nameplate - Before Control Valve) - 4x1 Fired Natural Gas, Ambient Temp 74.4 deg F, Circulating Water Inlet Temperature 66 deg F, 72% Condenser Cleanliness (to match 12/22/2014 15:16 actual data)



CONFIDENTIAL

DEF-19FL-FUEL-001635

DECLASSIFIED




DECLASSIFIED

CONFIDENTIAL

DECLASSIFIED

449.9 Gross MW

Valves Wide Open (IP Inlet Pressure at Nameplate - Before Control Valve) - 4x1 Fired Natural Gas, Ambient Temp 79 deg F, Circulating Water Inlet Temperature 66 deg F, 46% Condenser Cleanliness [to match 12/23/2014 14:20 actual data]




CONFIDENTIAL

DEF-19FL-FUEL-001636

419.6 Gross MW

419.6 MW - 4x1 Fired Natural Gas, Ambient Temp 74 deg F, Circulating Water Inlet Temperature 85 deg F, 90% Condenser Cleanliness



DECLASSIFIED

DECLASSIFIED




CONFIDENTIAL

DEF-19FL-FUEL-001638


385.7 Gross MW

Rated Conditions - 4x1 Unfired Natural Gas, Ambient Temp 74 deg F, Circulating Water Inlet Temperature 85 deg F, 90% Condenser Cleanliness



CONFIDENTIAL

DEF-19FL-FUEL-001638



DECLASSIFIED



DECLASSIFIED

CONFIDENTIAL

DECLASSIFIED

DEF-19FL-FUEL-001640

Black & Veatch Modeling and Analysis

- Developed original base design (matching Bibb cases) and pressure-plate model (matching actual data)
- Developed a design model for each vendor using LP turbine data from their submitted heat balances
- Ran case matrix for each vendor design and pressure-plate model to develop vendor-specific and pressure-plate dispatch curves
 - 12 operating configurations from 1x70% to 4x1 PAG/duct-fired/evaporative cooling
 - 3 ambient temperature conditions (35, 74 and 95 deg F)
 - Included ALLTD cases at 2x1, 3x1 and 4x1x40%
 - 4 layers - GE, Siemens, Mitsubishi and pressure-plate
- Ran another case matrix for CT upgrade and chiller evaluation
 - 2 layers - one typical vendor design and pressure-plate conditions
- Total number of cases run = 238

CONFIDENTIAL

DEF-19FL-FUEL-001640

CONFIDENTIAL

Operational Limits

- Used operational limits as limiting conditions in all cases
 - ST HP admission pressure = 2389.7 psia
 - ST IP admission pressure = 583.7 psia
 - ST IP exhaust pressure = 125.7 psia (for pressure-plate cases only)
 - ST generator output limit at PF 1.0 = 468 gross MW after generator losses (468 MVA)
 - Duct burner fuel flow per HRSG = 10,000 lb/hr
 - PAG steam flow per CT = 121,910 lb/hr
 - Achieve maximum duct burner fuel flow first before bringing in any PAG steam flow for the most efficient ST operation in the ST maximum output cases
- CT maximum torque limit of 230,000 KW

CONFIDENTIAL

DEF-19FL-FUEL-001641

DECLASSIFIED

DECLASSIFIED


CONFIDENTIAL

DECLASSIFIED

DEF-19FL-FUEL-001642

Model Results – ST Performance

- At ST maximum load, GE's upgrade had 1% higher LP turbine efficiency, 5 more gross MW's, and 2% lower turbine cycle heat rate than Mitsubishi upgrade




CONFIDENTIAL

DEF-19FL-FUEL-001642

Model Results – Net Unit Heat Rate


- L-O Upgrade
- Duct-firing case limiting condition = IP admission pressure
- PAG case limiting condition = HP admission pressure



DECLASSIFIED

Model Results – Pressure Plate

- According to Black and Veatch, "if steam turbine is kept as-is with the pressure plate, and the CT's are upgraded, then the IPT exit pressure limit would be exceeded in many operational scenarios"
- Only the chiller operation in the summer was an available option for 4x1, yielding an additional ~75 net unit MW



Model Results – GT Upgrade & Chiller Limitations with L-0 Upgrade

- 3x1x100% cases with duct-firing/PAG limited by HPT inlet pressure
- 4x1x100% cases with duct-firing limited by IPT inlet pressure
- 4x1x100% cases with duct-firing/PAG limited by HPT inlet pressure

Ambient	Mode	Configuration	Rate	Evap. Cooler	Duct Firing	PAG	Fuel	GT Upgrade	Chiller	GT Upgrade and Chiller
35 F	2x1	2x100%	Max	-	-	-	Gas			
95 F	2x1	2x100%	Max	On	-	-	Gas			
35 F	3x1	3x100%	Max	-	-	-	Gas			
35 F	3x1	3x100%	Max	-	Fired	-	Gas	HPT		
74 F	3x1	3x100%	Max	-	-	-	Gas			
74 F	3x1	3x100%	Max	-	Fired	-	Gas	HPT		HPT
74 F	3x1	3x100% PAG	Max	-	Fired	PAG	Gas			HPT
95 F	3x1	3x100%	Max	On	-	-	Gas			
95 F	3x1	3x100%	Max	On	Fired	-	Gas	HPT		HPT
35 F	4x1	4x100%	Max	-	-	-	Gas			
35 F	4x1	4x100%	Max	-	Fired	-	Gas	IPT		
35 F	4x1	4x100% PAG	Max	-	Fired	PAG	Gas	IPT		
74 F	4x1	4x100%	Max	-	-	-	Gas			
74 F	4x1	4x100%	Max	-	Fired	-	Gas	IPT		IPT
74 F	4x1	4x100% PAG	Max	-	Fired	PAG	Gas			HPT
95 F	4x1	4x100%	Max	On	-	-	Gas			
95 F	4x1	4x100% PAG	Max	On	Fired	-	Gas	IPT		IPT
95 F	4x1	4x100% PAG	Max	On	Fired	PAG	Gas	HPT		HPT
95 F	4x1	4x100% ST Max	Max	On	Fired	-	Gas	IPT	IPT	IPT

No limit
 Limited by IPT inlet pressure
 Limited by HPT inlet pressure
 Not achievable



DECLASSIFIED

CONFIDENTIAL

DECLASSIFIED

DEF-19FL-FUEL-001646

Model Results – GT Upgrade & Chiller Limitations with Pressure-Plate

- 3x1x100% cases with duct-firing limited by IPT exhaust pressure
- 4x1x100% cases cannot be achieved with GT Upgrade
- Only chiller cases limited by IPT exhaust pressure are at 4x1x100% with duct-firing

Ambient	Mode	Configuration	Rate	Evap. Cooler	Duct Firing	PAG	Fuel	GT Upgrade	Chiller	GT Upgrade and Chiller
35 F	3x1	3x100%	Max	-	-	-	Gas			
35 F	3x1	3x100%	Max	-	Fired	-	Gas			
35 F	4x1	4x100%	Max	-	-	-	Gas			
35 F	4x1	4x100%	Max	-	Fired	-	Gas			
35 F	4x1	4x100% ST Max	Max	-	Fired	-	Gas			
74 F	3x1	3x100%	Max	-	-	-	Gas			
74 F	3x1	3x100%	Max	-	Fired	-	Gas			
74 F	4x1	4x100%	Max	-	-	-	Gas			
74 F	4x1	4x100%	Max	-	Fired	-	Gas			
74 F	4x1	4x100%	Max	-	Fired	-	Gas			
95 F	3x1	3x100%	Max	On	-	-	Gas			
95 F	3x1	3x100%	Max	On	Fired	-	Gas			
95 F	4x1	4x100%	Max	On	-	-	Gas			
95 F	4x1	4x100%	Max	On	Fired	-	Gas			
95 F	4x1	4x100% PAG	Max	On	Fired	PAG	Gas			
95 F	4x1	4x100% ST Max	Max	On	Fired	-	Gas			

No limit
 Limited by IPT exhaust pressure
 Not achievable

CONFIDENTIAL

DEF-19FL-FUEL-001646



CONFIDENTIAL



Integrated Resource Planning evaluations

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001647



Bartow CC Steam Turbine Optimization Project - Modeling Assumptions

CONFIDENTIAL

Bartow CC

- Must Run Unit
- Min Capacity 2x1 @ 40%
- Maintenance Rates (Turbine and Generator Services):

2024	4.10%
2025	4.10%
2026	8.20%
2027	4.10%
2028	4.10%
2029	5.80%
2030	4.10%
2031	4.10%
2032	4.10%
2033	8.20%
2034	4.10%
2035	4.10%
2036	5.70%
2037	4.10%
2038	4.10%

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001649

DECLASSIFIED

DECLASSIFIED



Bartow CC Steam Turbine Optimization Project - Assumptions

Winter Heat Rates and Capacities values provided by Dario Zuloaga / Becky McClintock

<u>Winter</u>	<u>Net Load</u>	<u>NUHR</u>	<u>Net Load</u>	<u>NUHR</u>	<u>Net Load</u>	<u>NUHR</u>	<u>Net Load</u>	<u>NUHR</u>
	<u>Pressure Plate</u>		<u>L-Zero</u>		<u>Siemens</u>		<u>GE</u>	
4x40%	505	9,233	547	8,520	546	8,526	547.10	8,515
4x100%	1,150	7,248	1,209	6,892	1,209	6,896	1,209.69	6,890
4x100% DF	1,158	7,264	1,262	6,957	1,260	6,960	1,261.25	6,953
4x100% DF, PAG	1,252	7,361	1,309	7,042	1,308	7,045	1,309.27	7,040
3x40%	378	9,248	409	8,535	409	8,544	409.19	8,538
3x100%	865	7,229	909	6,876	909	6,879	909.46	6,873
3x100% DF	972	7,506	1,030	7,077	1,030	7,082	1,030.74	7,074
2x40%	249	9,368	268	8,685	268	8,686	269.01	8,658
2x100%	573	7,267	603	6,912	602	6,918	602.75	6,914
1x70%	200	7,898	207	7,611	208	7,592	207.93	7,581
1x100%	278	7,489	290	7,187	290	7,180	290.85	7,164

CONFIDENTIAL

DEF-19FL-FUEL-001650



Bartow CC Steam Turbine Optimization Project - Assumptions

Summer Heat Rates and Capacities values provided by Dario Zuloaga / Becky McClintock

<u>Summer</u>	<u>Net Load</u>	<u>NUHR</u>	<u>Net Load</u>	<u>NUHR</u>	<u>Net Load</u>	<u>NUHR</u>	<u>Net Load</u>	<u>NUHR</u>
	<u>Pressure Plate</u>		<u>L-Zero</u>		<u>Siemens</u>		<u>GE</u>	
4x40%	561	8,624	597	8,105	597.22	8,096	599.24	8,068
4x100%, EC	1,025	7,259	1,074	6,928	1,074.70	6,925	1,077.39	6,907
4x100%, EC, DF	1,049	7,296	1,138	7,001	1,138.03	6,998	1,140.70	6,978
4x100%, EC, PAG, DF	1,121	7,388	1,169	7,089	1,169.11	7,085	1,171.71	7,069
3x40%	420	8,632	444	8,159	445.33	8,143	446.65	8,119
3x100%, EC	770	7,248	805	6,935	805.48	6,929	807.45	6,912
3x100%, EC, DF	884	7,534	933	7,134	933.65	7,131	936.38	7,110
2x40%	277	8,731	289	8,358	290.37	8,325	290.66	8,317
2x100%, EC	510	7,302	529	7,031	530.20	7,018	531.20	7,005
1x70%	165	8,161	168	8,044	168.75	7,987	165.76	8,131
1x100%, EC	246	7,576	249	7,469	250.44	7,429	248.43	7,489

CONFIDENTIAL

DEF-19FL-FUEL-001651

DECLASSIFIED

DECLASSIFIED



Bartow CC Steam Turbine Optimization Project - Modeling Assumptions

Modeled	Pressure Plate		L-Zero		Siemens		GE	
	Winter	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load
2x40%	249	9,368	268	8,685	268	8,686	269	8,658
2x100%	573	7,267	603	6,912	602	6,918	603	6,914
3x100%	865	7,229	909	6,876	909	6,879	909	6,873
4x100%	1,150	7,248	1,209	6,892	1,209	6,896	1,210	6,890
4x100% DF	1,158	7,264	1,262	6,957	1,260	6,960	1,261	6,953
4x100% DF, PAG	1,252	7,361	1,309	7,042	1,308	7,045	1,309	7,040

Modeled	Pressure Plate		L-Zero		Siemens		GE	
	Summer	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load
2x40%	277	8,731	289	8,358	290	8,325	291	8,317
2x100%, EC	510	7,302	529	7,031	530	7,018	531	7,005
3x100%, EC	770	7,248	805	6,935	805	6,929	807	6,912
4x100%, EC	1,025	7,259	1,074	6,928	1,075	6,925	1,077	6,907
4x100%, EC, DF	1,049	7,296	1,138	7,001	1,138	6,998	1,141	6,978
4x100%, EC, PAG, DF	1,121	7,388	1,169	7,089	1,169	7,085	1,172	7,069


CONFIDENTIAL

DEF-19FL-FUEL-001652



Bartow CC Steam Turbine Optimization Project - Modeling Assumptions

CONFIDENTIAL



CONFIDENTIAL

DEF-19FL-FUEL-001653


DECLASSIFIED

DECLASSIFIED



Bartow CC Steam Turbine Optimization Project - Modeling Assumptions

CONFIDENTIAL







CONFIDENTIAL

DEF-19FL-FUEL-001654



Bartow CC Steam Turbine Optimization Project - Hours of Operation Year 2023

CONFIDENTIAL



CONFIDENTIAL

DEF-19FL-FUEL-001655





DECLASSIFIED

DECLASSIFIED



Bartow CC Steam Turbine Optimization Project - Hours of Operation Year 2025

CONFIDENTIAL




CONFIDENTIAL

DEF-19FL-FUEL-001656



Dispatch ~~CONFIDENTIAL~~ – Generation Gwh




DECLASSIFIED

DECLASSIFIED

DECLASSIFIED



Dispatch Comparison – Generation %



CONFIDENTIAL

DEF-19FL-FUEL-001658



Dispatch Comparison – Capacity Factors

Pressure Plate Case

CF	2018	2019	2020	2021	2022	2023
Anclote.1	21%	11%	7%	8%	9%	9%
Anclote.2	14%	9%	8%	8%	9%	9%
Bartow CC.1.0	68%	58%	60%	60%	61%	61%
Bartow CC.1.DUCT	27%	12%	9%	8%	6%	6%
Bartow CC.1.PAG	19%	8%	5%	5%	4%	4%
Citrus.CC.1	93%	86%	87%	87%	89%	89%
Citrus.CC.1.Duct	19%	15%	14%	11%	13%	19%
Citrus.CC.2	72%	80%	81%	81%	84%	84%
Citrus.CC.2.Duct	3%	15%	12%	9%	11%	17%
Crystal.4	81%	77%	58%	65%	47%	37%
Crystal.5	88%	66%	72%	64%	54%	42%
Hines.CC.1	66%	46%	46%	44%	51%	50%
Hines.CC.2	51%	35%	35%	36%	39%	45%
Hines.CC.3	63%	46%	45%	47%	50%	56%
Hines.CC.4	79%	67%	69%	69%	66%	64%
Osprey Up to 245Mws	37%	21%	25%	25%	42%	47%
Osprey Above 245MWs	16%	11%	12%	8%	9%	33%
Osprey DF	2%	1%	0%	0%	0%	1%
Tigerbay.1	56%	58%	53%	60%	66%	61%
Solar.3rdParty.Block.1	20%	23%	23%	24%	24%	24%
Solar.DEF.Block.1	24%	24%	24%	24%	24%	24%
Solar.DEF.Block.3	0%	30%	29%	29%	33%	30%

Mitsubishi L-Zero Case

CF	2018	2019	2020	2021	2022	2023
Anclote.1	21%	11%	7%	8%	8%	9%
Anclote.2	14%	9%	8%	8%	9%	9%
Bartow CC.1.0	68%	62%	68%	68%	69%	69%
Bartow CC.1.DUCT	27%	14%	9%	8%	6%	7%
Bartow CC.1.PAG	19%	2%	1%	2%	2%	2%
Citrus.CC.1	93%	86%	87%	87%	88%	89%
Citrus.CC.1.Duct	19%	15%	13%	11%	12%	18%
Citrus.CC.2	72%	81%	81%	80%	83%	85%
Citrus.CC.2.Duct	3%	14%	11%	10%	11%	17%
Crystal.4	81%	76%	56%	62%	43%	35%
Crystal.5	88%	66%	69%	61%	52%	40%
Hines.CC.1	66%	42%	40%	39%	46%	46%
Hines.CC.2	51%	34%	32%	33%	38%	42%
Hines.CC.3	63%	43%	39%	41%	46%	50%
Hines.CC.4	79%	65%	70%	69%	66%	64%
Osprey Up to 245Mws	37%	21%	24%	23%	37%	44%
Osprey Above 245MWs	16%	11%	12%	8%	9%	31%
Osprey DF	2%	1%	0%	0%	0%	1%
Tigerbay.1	56%	55%	50%	62%	69%	61%
Solar.3rdParty.Block.1	20%	23%	23%	24%	24%	24%
Solar.DEF.Block.1	24%	24%	24%	24%	24%	24%
Solar.DEF.Block.4	0%	0%	32%	30%	38%	30%

DECLASSIFIED

DEF-19FL-FUEL-001659



Dispatch Comparison – Capacity Factors

Pressure Plate Case

CF	2018	2019	2020	2021	2022	2023
Anclote.1	21%	11%	7%	8%	9%	9%
Anclote.2	14%	9%	8%	8%	9%	9%
Bartow CC.1.0	68%	58%	60%	60%	61%	61%
Bartow CC.1.DUCT	27%	12%	9%	8%	6%	6%
Bartow CC.1.PAG	19%	8%	5%	5%	4%	4%
Citrus.CC.1	93%	86%	87%	87%	89%	89%
Citrus.CC.1.Duct	19%	15%	14%	11%	13%	19%
Citrus.CC.2	72%	80%	81%	81%	84%	84%
Citrus.CC.2.Duct	3%	15%	12%	9%	11%	17%
Crystal.4	81%	77%	58%	65%	47%	37%
Crystal.5	88%	66%	72%	64%	54%	42%
Hines.CC.1	66%	46%	46%	44%	51%	50%
Hines.CC.2	51%	35%	35%	36%	39%	45%
Hines.CC.3	63%	46%	45%	47%	50%	56%
Hines.CC.4	79%	67%	69%	69%	66%	64%
Osprey Up to 245Mws	37%	21%	25%	25%	42%	47%
Osprey Above 245MWs	16%	11%	12%	8%	9%	33%
Osprey DF	2%	1%	0%	0%	0%	1%
Tigerbay.1	56%	58%	53%	60%	66%	61%
Solar.3rdParty.Block.1	20%	23%	23%	24%	24%	24%
Solar.DEF.Block.1	24%	24%	24%	24%	24%	24%
Solar.DEF.Block.3	0%	30%	29%	29%	28%	30%

GE Case

CF	2018	2019	2020	2021	2022	2023
Anclote.1	21%	11%	7%	8%	8%	9%
Anclote.2	14%	9%	8%	8%	9%	9%
Bartow CC.1.0	68%	58%	60%	60%	65%	69%
Bartow CC.1.DUCT	27%	12%	9%	8%	7%	7%
Bartow CC.1.PAG	19%	8%	5%	5%	2%	2%
Citrus.CC.1	93%	86%	87%	87%	89%	89%
Citrus.CC.1.Duct	19%	15%	14%	11%	12%	18%
Citrus.CC.2	72%	80%	81%	81%	84%	85%
Citrus.CC.2.Duct	3%	15%	12%	9%	11%	17%
Crystal.4	81%	77%	58%	65%	43%	35%
Crystal.5	88%	66%	72%	64%	52%	39%
Hines.CC.1	66%	46%	46%	44%	48%	46%
Hines.CC.2	51%	35%	35%	36%	38%	42%
Hines.CC.3	63%	46%	45%	47%	47%	49%
Hines.CC.4	79%	67%	69%	69%	66%	64%
Osprey Up to 245Mws	37%	21%	25%	25%	38%	44%
Osprey Above 245MWs	16%	11%	12%	8%	10%	31%
Osprey DF	2%	1%	0%	0%	0%	1%
Tigerbay.1	56%	58%	53%	60%	73%	61%
Solar.3rdParty.Block.1	20%	23%	23%	24%	24%	24%
Solar.DEF.Block.1	24%	24%	24%	24%	24%	24%
Solar.DEF.Block.3	0%	30%	29%	29%	28%	30%



Results – Hours of Operation Year 2023

CONFIDENTIAL

Winter 2023	P-Plate	L-Zero	Siemens	GE
Min Cap 2x1 (40%)	-	-	-	-
2x1 (41%-100%)	1,040	785	785	918
3x1 (0%-100%)	2,081	1,364	1,729	1,215
Max Cap 4x1 (0%-100%)	316	1,294	928	1,310
4x1 (100%) + Duct	55	57	58	56
4x1 (100%) + PAG	51	43	43	44
Total Hours of Generation	3,543	3,543	3,543	3,543
No Generation	801	801	801	801
Total	4,344	4,344	4,344	4,344

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
249	9,368	268	8,685	268	8,686	269	8,658
573	7,267	603	6,912	602	6,918	603	6,914
865	7,229	909	6,876	909	6,879	909	6,873
1,150	7,248	1,209	6,892	1,209	6,896	1,210	6,890
1,158	7,264	1,262	6,957	1,260	6,960	1,261	6,953
1,252	7,361	1,309	7,042	1,308	7,045	1,309	7,040

Summer 2023	P-Plate	L-Zero	Siemens	GE
Min Cap 2x1 (40%)	-	-	-	-
2x1 (41%-100%)	545	-	-	262
3x1 (0%-100%)	903	896	898	639
Max Cap 4x1 (0%-100%)	2,040	2,663	2,665	2,631
4x1 (100%) + DUCT	332	433	425	454
4x1 (100%) + PAG	320	148	152	154
Total Hours of Generation	4,140	4,140	4,140	4,140
No Generation	276	276	276	276
Total	4,416	4,416	4,416	4,416

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
277	8,731	289	8,358	290	8,325	291	8,317
510	7,302	529	7,031	530	7,018	531	7,005
770	7,248	805	6,935	805	6,929	807	6,912
1,025	7,259	1,074	6,928	1,075	6,925	1,077	6,907
1,049	7,296	1,138	7,001	1,138	6,998	1,141	6,978
1,121	7,388	1,169	7,089	1,169	7,085	1,172	7,069

CONFIDENTIAL

DEF-19FL-FUEL-001661

DECLASSIFIED

DECLASSIFIED



Results – Hours of Operation Year 2023

Winter 2023		P-Plate	L-Zero	Siemens	GE
Min Cap	2x1 (40%)	0%	0%	0%	0%
	2x1 (41%-100%)	24%	18%	18%	21%
	3x1 (0%-100%)	48%	31%	40%	28%
	4x1 (0%-100%)	7%	30%	21%	30%
	4x1 (100%) + Duct	1%	1%	1%	1%
	4x1 (100%) + PAG	1%	1%	1%	1%
Total Hours of Generation		82%	82%	82%	82%
No Generation		18%	18%	18%	18%
Total		100%	100%	100%	100%

Summer 2023		P-Plate	L-Zero	Siemens	GE
Min Cap	2x1 (40%)	0%	0%	0%	0%
	2x1 (41%-100%)	12%	0%	0%	6%
	3x1 (0%-100%)	20%	20%	20%	14%
	4x1 (0%-100%)	46%	60%	60%	60%
	4x1 (100%) + DUCT	8%	10%	10%	10%
	4x1 (100%) + PAG	7%	3%	3%	3%
Total Hours of Generation		94%	94%	94%	94%
No Generation		6%	6%	6%	6%
Total		100%	100%	100%	100%

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
249	9,368	268	8,685	268	8,686	269	8,658
573	7,267	603	6,912	602	6,918	603	6,914
865	7,229	909	6,876	909	6,879	909	6,873
1,150	7,248	1,209	6,892	1,209	6,896	1,210	6,890
1,158	7,264	1,262	6,957	1,260	6,960	1,261	6,953
1,252	7,361	1,309	7,042	1,308	7,045	1,309	7,040

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
277	8,731	289	8,358	290	8,325	291	8,317
510	7,302	529	7,031	530	7,018	531	7,005
770	7,248	805	6,935	805	6,929	807	6,912
1,025	7,259	1,074	6,928	1,075	6,925	1,077	6,907
1,049	7,296	1,138	7,001	1,138	6,998	1,141	6,978
1,121	7,388	1,169	7,089	1,169	7,085	1,172	7,069

CONFIDENTIAL

DEF-19FL-FUEL-001662



Results – ~~CONFIDENTIAL~~ of Operation Year 2025

Winter 2025	P-Plate	L-Zero	Siemens	GE
Min Cap 2x1 (40%)	-	-	-	-
2x1 (41%-100%)	1,094	653	659	671
3x1 (0%-100%)	2,246	1,779	1,981	1,759
Max Cap 4x1 (0%-100%)	487	1,367	1,159	1,368
4x1 (100%) + Duct	60	96	95	98
4x1 (100%) + PAG	57	50	51	49
Total Hours of Generation	3,944	3,945	3,945	3,945
No Generation	400	399	399	399
Total	4,344	4,344	4,344	4,344

Summer 2025	P-Plate	L-Zero	Siemens	GE
Min Cap 2x1 (40%)	-	-	-	-
2x1 (41%-100%)	524	-	-	250
3x1 (0%-100%)	1,396	892	892	633
Max Cap 4x1 (0%-100%)	1,154	2,150	2,150	2,073
4x1 (100%) + DUCT	539	839	837	915
4x1 (100%) + PAG	526	259	261	269
Total Hours of Generation	4,139	4,140	4,140	4,140
No Generation	277	276	276	276
Total	4,416	4,416	4,416	4,416

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
249	9,368	268	8,685	268	8,686	269	8,658
573	7,267	603	6,912	602	6,918	603	6,914
865	7,229	909	6,876	909	6,879	909	6,873
1,150	7,248	1,209	6,892	1,209	6,896	1,210	6,890
1,158	7,264	1,262	6,957	1,260	6,960	1,261	6,953
1,252	7,361	1,309	7,042	1,308	7,045	1,309	7,040

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
277	8,731	289	8,358	290	8,325	291	8,317
510	7,302	529	7,031	530	7,018	531	7,005
770	7,248	805	6,935	805	6,929	807	6,912
1,025	7,259	1,074	6,928	1,075	6,925	1,077	6,907
1,049	7,296	1,138	7,001	1,138	6,998	1,141	6,978
1,121	7,388	1,169	7,089	1,169	7,085	1,172	7,069

~~CONFIDENTIAL~~

DEF-19FL-FUEL-001663

DECLASSIFIED

DECLASSIFIED



Results – Hours of Operation Year 2025

Winter 2025		P-Plate	L-Zero	Siemens	GE
Min Cap	2x1 (40%)	0%	0%	0%	0%
	2x1 (41%-100%)	25%	15%	15%	15%
	3x1 (0%-100%)	52%	41%	46%	40%
	4x1 (0%-100%)	11%	31%	27%	31%
	4x1 (100%) + Duct	1%	2%	2%	2%
	4x1 (100%) + PAG	1%	1%	1%	1%
Total Hours of Generation		91%	91%	91%	91%
No Generation		9%	9%	9%	9%
Total		100%	100%	100%	100%

Summer 2025		P-Plate	L-Zero	Siemens	GE
Min Cap	2x1 (40%)	0%	0%	0%	0%
	2x1 (41%-100%)	12%	0%	0%	6%
	3x1 (0%-100%)	32%	20%	20%	14%
	4x1 (0%-100%)	26%	49%	49%	47%
	4x1 (100%) + DUCT	12%	19%	19%	21%
	4x1 (100%) + PAG	12%	6%	6%	6%
Total Hours of Generation		94%	94%	94%	94%
No Generation		6%	6%	6%	6%
Total		100%	100%	100%	100%

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
249	9,368	268	8,685	268	8,686	269	8,658
573	7,267	603	6,912	602	6,918	603	6,914
865	7,229	909	6,876	909	6,879	909	6,873
1,150	7,248	1,209	6,892	1,209	6,896	1,210	6,890
1,158	7,264	1,262	6,957	1,260	6,960	1,261	6,953
1,252	7,361	1,309	7,042	1,308	7,045	1,309	7,040

P-Plate		L-Zero		Siemens		GE	
Net Load	NUHR	Net Load	NUHR	Net Load	NUHR	Net Load	NUHR
277	8,731	289	8,358	290	8,325	291	8,317
510	7,302	529	7,031	530	7,018	531	7,005
770	7,248	805	6,935	805	6,929	807	6,912
1,025	7,259	1,074	6,928	1,075	6,925	1,077	6,907
1,049	7,296	1,138	7,001	1,138	6,998	1,141	6,978
1,121	7,388	1,169	7,089	1,169	7,085	1,172	7,069

CONFIDENTIAL

DEF-19FL-FUEL-001664



~~CONFIDENTIAL~~
Capital Costs

	<u>L-Zero</u>	<u>Siemens</u>	<u>GE</u>
Total Direct and Indirect \$M	\$ 7.39	\$ 12.38	\$ 11.00

DECLASSIFIED

CONFIDENTIAL

DEF-19FL-FUEL-001665

DECLASSIFIED



CPVRR \$M (Production Costs and Capital) Comparison

CONFIDENTIAL

CPVRR \$M - Spring Outages	P-Plate	L-Zero	Siemens	GE	P-Plate - L-Zero	P-Plate - Siemens	P-Plate - GE
Fixed Costs	\$8,077	\$8,077	\$8,077	\$8,077	\$0	\$0	\$0
Fuel Cost	\$15,202	\$15,108	\$15,126	\$15,124	\$94	\$76	\$78
VOM Cost + Start Up Costs	\$2,210	\$2,203	\$2,205	\$2,204	\$7	\$5	\$6
Environmental	\$2,508	\$2,488	\$2,488	\$2,488	\$20	\$20	\$20
Total Production Costs	\$27,997	\$27,875	\$27,896	\$27,893	\$121	\$101	\$104
Capital Investment	0	\$ 8	\$ 11	\$ 10	(\$8)	(\$11)	(\$10)
Total Costs	\$27,997	\$27,883	\$27,907	\$27,903	\$113	\$90	\$94

Bid # 1: Mitsubishi L-Zero Blades Replacement

ISD: May 1st 2019

Bid # 2: Siemens Rotor Replacement

ISD: May 1st 2022

Bid # 3: GE Rotor Replacement

ISD: May 1st 2022


CONFIDENTIAL

DEF-19FL-FUEL-001666

DECLASSIFIED



Production Costs ~~CONFIDENTIAL~~ (\$M) Comparison





CPVRR \$M (Production Costs and Capital) Comparison

CONFIDENTIAL

CPVRR \$M - Spring Outages for Steam Turbine Upgrades	P-Plate	L-Zero - Year 2019	GE - Year 2022
Fixed Costs	\$8,077	\$8,077	\$8,077
Fuel Cost	\$15,202	\$15,108	\$15,124
VOM Cost + Start Up Costs	\$2,210	\$2,203	\$2,204
Environmental	\$2,508	\$2,488	\$2,488
Total Production Costs	\$27,997	\$27,875	\$27,893
Capital Investment	0	\$ 8	\$ 10
Total Costs	\$27,997	\$27,883	\$27,903

P-Plate - L-Zero	P-Plate - GE
\$0	\$0
\$94	\$78
\$7	\$6
\$20	\$20
\$121	\$104
(\$8)	(\$10)
\$113	\$94

CPVRR \$M - Fall Outages for Steam Turbine Upgrades	P-Plate	L-Zero - Year 2019	GE - Year 2019
Fixed Costs	\$8,077	\$8,077	\$8,077
Fuel Cost	\$15,202	\$15,116	\$15,113
VOM Cost + Start Up Costs	\$2,210	\$2,204	\$2,203
Environmental	\$2,508	\$2,488	\$2,488
Total Production Costs	\$27,997	\$27,885	\$27,881
Capital Investment	0	\$ 8	\$ 12
Total Costs	\$27,997	\$27,893	\$27,893

P-Plate - L-Zero	P-Plate - GE
\$0	\$0
\$86	\$89
\$6	\$6
\$20	\$20
\$111	\$115
(\$8)	(\$12)
\$103	\$103

CONFIDENTIAL


DEF-19FL-FUEL-001669

DECLASSIFIED

DECLASSIFIED



Production Costs CPVRR (\$M) Comparison – Fall Outages





Alternatives Configuration Cases:

- Combustion Turbine Upgrades
- Chiller Upgrades
- Both Combustion Turbine and Chiller Upgrades

Constraints:

- The B&V model cases for upgrades with the LP pressure plate indicated that the Bartow combined cycle can't operate in a 4x1 configuration because it violates the pressure limits set by MHI on the IP/LP turbines. Therefore, the CT upgrades for 4x1 configuration are not applicable.
- However, the 3x1 and 2x1 configurations were evaluated and met the pressure limits set by MHI in the HP/IP/LP turbines.

CONFIDENTIAL

DEF-19FL-FUEL-001671

DECLASSIFIED

DECLASSIFIED



CPVRR (\$M) Comparison - Pressure Plate w/ Upgrades

CONFIDENTIAL

CPVRR \$M	<u>P-Plate Ref Case</u>	<u>P-Plate with CT Upgrade Case</u>	<u>P-Plate with Chillers Upgrade Case</u>	<u>P-Plate with CT and Chillers Upgrade Case</u>	<u>P-Plate Ref Case - P-Plate with CT Upgrade Case</u>	<u>P-Plate Ref Case - P-Plate with Chillers Upgrade Case</u>	<u>P-Plate Ref Case - P-Plate with CT and Chillers Upgrade Case</u>
Fixed Costs	\$8,077	\$8,077	\$8,077	\$8,077	\$0	\$0	\$0
Fuel Cost	\$15,202	\$15,266	\$15,187	\$15,254	(\$64)	\$16	(\$51)
VOM Cost + Start Up Costs	\$2,210	\$2,213	\$2,208	\$2,212	(\$3)	\$1	(\$2)
Environmental	\$2,508	\$2,528	\$2,505	\$2,526	(\$20)	\$3	(\$18)
CT Upgrade Capital	\$0	\$89	\$0	\$89	(\$89)	\$0	(\$89)
Chillers Upgrade Capital	\$0	\$0	\$57	\$57	\$0	(\$57)	(\$57)
Total Cost	\$27,997	\$28,173	\$28,033	\$28,214	(\$177)	(\$37)	(\$217)

CONFIDENTIAL

DEF-19FL-FUEL-001672



CPVRR (\$M) Comparison – L-Zero w/ Upgrades

CONFIDENTIAL

CPVRR \$M	L-Zero Ref Case	L-Zero with CT Upgrade Case	L-Zero with Chillers Upgrade Case	L-Zero with CT and Chillers Upgrade Case	L-Zero Ref Case - L-Zero with CT Upgrade Case	L-Zero Ref Case - L-Zero with Chillers Upgrade Case	L-Zero Ref Case - L-Zero with CT and Chillers Upgrade Case
Fixed Costs	\$8,077	\$8,077	\$8,077	\$8,077	\$0	\$0	\$0
Fuel Cost	\$15,108	\$15,048	\$15,092	\$15,038	\$60	\$16	\$70
VOM Cost + Start Up Costs	\$2,203	\$2,200	\$2,201	\$2,199	\$3	\$2	\$4
Environmental	\$2,488	\$2,471	\$2,485	\$2,468	\$16	\$3	\$20
CT Upgrade Capital ¹	\$0	\$89	\$0	\$89	(\$89)	\$0	(\$89)
Chillers Upgrade Capital ²	\$0	\$0	\$57	\$57	\$0	(\$57)	(\$57)
Total Cost	\$27,875	\$27,885	\$27,912	\$27,928	(\$10)	(\$37)	(\$53)
Gen CT Capital ³	\$0	(\$16)	(\$16)	(\$85)	\$16	\$16	\$85
Gen CT FOM ¹³	\$0	(\$1)	(\$1)	(\$4)	\$1	\$1	\$4
	\$27,875	\$27,868	\$27,895	\$27,839	\$7	(\$20)	\$36

¹ CTs Upgrade Capital Investment \$100M 2018\$ over a 1 year period (2022 May-2023 Apr / 70% 2022 - 30% 2023)
Insurance Costs have been included. No Property Taxes have been included. Book Life assumed as the 21 Yr Remaining Life. Tax Life assumption 20 Yr.

² Chillers Upgrade Capital Investment \$64M 2018\$ over a 1 year period (2022 May-2023 Apr / 70% 2022 - 30% 2023)
Insurance Costs have been included. No Property Taxes have been included. Book Life assumed as the 21 Yr Remaining Life. Tax Life assumption 20 Yr.

³ One of the 2027 New CTs is delayed to 2029 in the CT Upgrade Cases and the Ch Upgrades Cases
One of the 2027 is avoided in the CT and Chiller (both happening simultaneously) Upgrade Cases

CONFIDENTIAL

DEF-19FL-FUEL-001673

DECLASSIFIED

DECLASSIFIED



CONFIDENTIAL



Commercial "TCO" evaluation details

CONFIDENTIAL

DEF-19FL-FUEL-001674



CONFIDENTIAL

Duke Energy - Bartow Combined Cycle Facility STG
LPT/LO Upgrade
Bid Analysis April 20,

INTRODUCTION/SCOPE OF WORK					
L.P. Turbine LO/steam path upgrades					
TABLE 1: BID ANALYSIS SUMMARY					
	Press Plate	MHPS	GE	SIEMENS	Comments
SCHEDULE:					
Delivery		12 months	13 months	20 months	
Outage duration		43 days	35 days	35 days	
a. BASE BID PRICE (From Table 2)	\$0	\$6,931,284	\$9,091,000	\$10,398,000	
COST ADJUSTMENTS					
b. Technical Cost Adjustment (From Table 3)	\$0	\$100,000	\$235,806	\$295,806	
c. Commercial Cost Adjustment (From Table 4)	\$0	\$0	\$0	\$0	
EXPECTED / FINAL CONTRACT PRICE (a+b+c)	\$0	\$7,031,284	\$9,326,806	\$10,693,806	
		BASE	\$2,295,522	\$3,662,522	
		BASE	33%	52%	
EVALUATING FACTORS					
d. Technical Evaluation (From Table 3)	\$0	\$0	\$50,000	\$250,000	Not complete evaluation cost
e. Construction Evaluation (From Table 3)	\$0	\$0	\$0	\$0	Not complete evaluation cost
g. Commercial Evaluation (From Table 4)	\$0	\$0	\$0	\$0	
EVALUATED FACTORS SUBTOTAL (d+e+g)	\$0	\$0	\$50,000	\$250,000	
TOTAL EVALUATED COST(a+b+c+d+e+f+g)	\$0	\$7,031,284	\$9,376,806	\$10,943,806	Crane not included
Minus Installation	\$0	\$5,442,814	\$7,533,808	\$9,193,806	Crane not included
Evaluated Cost Difference (Evaluated Cost - Low Evaluated Cost)		\$1,588,470	\$1,843,000	\$1,750,000	
		BASE	\$2,345,522	\$3,912,522	
Percentage Difference vs. Evaluated Base (Evaluated Cost / Low Evaluated Cost)		BASE	33%	56%	

CONFIDENTIAL

DEF-19FL-FUEL-001675

DECLASSIFIED

DECLASSIFIED



CONFIDENTIAL

Duke Energy - Bartow Combined Cycle Facility STG
LPT/L0 Upgrade
Bid Analysis April
20, 2018

TABLE 2: PRICE BREAKDOWN					
Bidders:	Press Plate	MHPS	GE	SIEMENS	Comments
Base Bid Price	\$0	\$6,931,284	\$9,091,000	\$10,398,000	
Price Breakdown:					
Fully Bladed LP Rotor with integral coupling, high speed balanced and overspeed tested			\$7,248,000	\$8,430,000	
LP Inner Cylinder Complete With Attached Stationary Components (Blade Carriers, one per opposing flow, with stationary blading, integral exhaust tip diffusers and all associated half joint bolting;)			included	included	
Cooling spray nozzles and pipes connected to existing spray water system			included	included	
Pilgrim hydraulic coupling bolts and sleeves for the HP/IP-LP and LP-Generator couplings			included	included	
Sets of keys, shims, and packers for blade carrier alignment and adjustment;			included	included	
Casing guide pillars, eyebolts and bolt tensioning			included	included	
Transportation to site			included	\$218,000	SIEMENS shipping costs are estimated only, not firm
Supply L0 blades only		\$5,342,814	not offered	not offered	Past blade sets cost \$3.5M (both ends) - significant difference
Removal of existing LPT			included		
Installation for items above		\$1,588,470	\$1,843,000	\$1,750,000	SIEMENS cost includes T&M basis scope which needs further definition
Base Bid Price (Should Equal Base Bid Price Above)	\$0	\$6,931,284	\$9,091,000	\$10,398,000	

CONFIDENTIAL

DEF-19FL-FUEL-001676



CONFIDENTIAL

Duke Energy - Bartow Combined Cycle Facility STG
 LP7/L0 Upgrade
 Bid Analysis April
 20, 2018

TABLE 3: TECHNICAL EVALUATION					
Description	Press Plate	MHPS	GE	SIEMENS	Comments
Technical Cost Adjustments to Base Bid					
1 Blade Vibration Monitoring		Included	To be Provided	One year only	MHPS \$200k/yr monitoring fee
2 Steel Blade Carrier			Not provided	Included	
3 High speed Lube Oil flush			\$90,806	\$90,806	Based on budgetary pricing
4 LP rotor and outer casing disposal			\$45,000	\$45,000	Estimated
5 Training		Not required	Not provided	Included	SIEMENS included 4 days
6 Torsional Testing		Not required	Not required	\$60,000	Pre+Post Tests Supervised jointly
7 Performance Testing		\$100,000	\$100,000	\$100,000	Estimated
Subtotal Technical Cost Adjustments (Subtotal Forwarded to Table 1)	\$0	\$100,000	\$235,806	\$295,806	
Technical Evaluation Factors					
Differential Balance of Plant Costs:					
1. Jacking Oil Pump Installation	Not required	Not required	Not required	\$200,000	2 AC Pumps, 75 kW estimated
Differential Engineering Costs:					
1. Foundation analysis study	Not required	Not required	\$50,000	\$50,000	Provided by Duke; GE may not need F A study
Differential Operating & Maintenance Costs:					
1. Fuel costs, 2018-2037 (\$k)	\$3,707,733	\$4,240,628	\$4,190,766	\$4,195,075	NOT USED Provided by Duke
2. O&M costs (k)	\$38,040	\$44,971	\$40,231	\$41,320	Using information received from Duke, bidder proposals and supplemented with EPRI SOAPP cost estimating model
Other Technical Evaluation Factors:					
1. Crane upgrades			Not evaluated	Not evaluated	Could be none or significant
2. Foundation upgrade costs			Not evaluated	Not evaluated	Could be none or significant
3. Journal bearing rebabbit costs			Not evaluated	Not evaluated	Minimal impact if needed
Subtotal Technical Evaluation Factors (Subtotal Forwarded to Table 1)	\$0	\$0	\$50,000	\$250,000	
Construction Evaluation Factors					
1. Foundation Modification			Not evaluated	Not evaluated	Could be none or significant (100-500K)
Subtotal Constructability Factors (Subtotals Forwarded to Table 1)	\$0	\$0	\$0	\$0	

CONFIDENTIAL

DEF-19FL-FUEL-001677

DECLASSIFIED

DECLASSIFIED



CONFIDENTIAL

Operations and Maintenance Analysis Assumptions

1) Must Run All the Time @ 2x1 at 40%

2) Assumptions for the L-Zero Case (Mitsubishi proposal): Outage: 12 weeks
ISD: May 1st 2019.

3) For GE and Siemens proposals: Outage: 12 weeks
ISD: May 1st 2022.

4) Outage from Connie Bruce

2024	4.10%
2025	4.10%
2026	8.20%
2027	4.10%
2028	4.10%
2029	5.80%
2030	4.10%
2031	4.10%
2032	4.10%
2033	8.20%
2034	4.10%
2035	4.10%
2036	5.70%
2037	4.10%
2038	4.10%

Taken from the ST Templates that TGS Provided to RS/FHO Stations

Current	
Full Major Template	\$ 5,612,640 Inc \$1.3M for Crane
Full Major Template (Bartow)	\$ 4,492,640
HPIP Only	\$ 2,336,320
LP Only	\$ 2,336,320

From Dave Burney

Crane (650T) \$180,000 2 weeks

Crane (1000T) - GE and Siemens adder to template \$384,000 2 weeks

adder for GE and Siemens if combined with HPIP **\$204,000**

From Chris Holland

\$3,500.00

1 Set of TE and GE L-0 Blades 0

OPTIM Current		Z3/Z4 Due
HPIP	64,000 Hrs	2019
LP	64,000 Hrs	2022
Valves	24,000 Hrs	2019

	Assumes 8k Hrs / Yr
	Next
	OPTIM Outage
OPTIM w/ GE LP Rotor	
HPIP	64,000 Hrs 2027
LP	100,000 Hrs 2031
Valves	24,000 Hrs 2021

Assumes 2019 Install

	Assumes 8k Hrs / Yr
	Next
	OPTIM Outage
OPTIM w/ Siemens LP Rotor	
HPIP	64,000 Hrs 2027
LP	100,000 Hrs 2034
Valves	24,000 Hrs 2022

Assumes 2022 Install

CONFIDENTIAL

DEF-19FL-FUEL-001678



Fuel and Non-Fuel OPERATIONAL and Maintenance Cost Estimate

Option 1: Pressure Plate	NPV (2018)	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	Total Cost	Desc.	\$/MWh	
Fuel Cost \$k	\$1,921,964	\$156,370	\$121,424	\$123,732	\$123,409	\$124,647	\$132,406	\$144,958	\$164,587	\$169,324	\$192,644	\$201,359	\$211,191	\$223,575	\$219,224	\$216,227	\$217,228	\$233,502	\$239,074	\$248,003	\$244,851	\$3,707,735	Fuel Total		
Interval Hours			7,855	16,125	24,372		40,048	48,158	56,243	63,983	72,068	80,178	88,125	96,210				104,295	112,405	120,145	128,230	136,315	144,286	152,371	
Operating Hours		8,247	7,855	8,270	8,247	7,993	7,683	8,110	8,085	7,740	8,085	8,110	7,947	8,085	8,085	8,110	7,740	8,085	8,085	7,971	8,085				
LP Inspection Interval			Minor	Minor	Minor	Major	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Minor	Major			
Cost \$k	\$3,486	0	0.05	0.05	0.05	\$2,336	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	\$7,010	LP Total	
HP/IP Inspection Interval			Major								Major											Major			
Cost \$k	\$4,194	0	\$2,335	0	0	0	0	0	0	0	\$2,335	0	0	0	0	0	0	0	0	0	0	\$7,009	HP/IP Total		
sum	\$1,929,624	\$156,370	\$123,760	\$123,732	\$123,409	\$126,983	\$132,406	\$144,958	\$164,587	\$169,324	\$194,980	\$201,359	\$211,191	\$225,911	\$219,224	\$216,227	\$217,228	\$233,502	\$241,410	\$248,003	\$247,187	\$3,721,754	Fuel/O&M Total	\$33.15	104.21%

Option 2: MHPS LSB Upgrade		2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	Total Cost	Desc.	\$/MWh	
Fuel Cost \$k	\$2,180,824.69	\$156,370	\$129,412	\$140,663	\$139,078	\$141,679	\$148,409	\$173,025	\$190,456	\$196,894	\$225,442	\$233,848	\$243,787	\$261,738	\$251,300	\$245,858	\$247,611	\$269,620	\$278,384	\$287,218	\$279,834	\$4,240,626	Fuel Total		
Interval Hours		8,247	7,762	8,270	8,247	7,993	7,683	8,110	8,085	7,740	8,085	8,110	7,947	8,085	8,085	8,110	7,740	8,085	8,085	7,971	8,085				
LP Inspection Interval			Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major	Major			
Cost \$k	\$9,118	0	\$7,688	0	0	0	0	0	0	0	\$2,248	0	0	0	0	0	0	0	0	0	0	\$12,182	LP Total		
HP/IP Inspection Interval			Major								Major											Major			
Cost \$k	\$4,032	0	\$2,246	0	0	0	0	0	0	0	\$2,246	0	0	0	0	0	0	0	0	0	0	\$6,739	HP/IP Total		
sum	\$2,193,976	\$156,370	\$139,347	\$140,663	\$139,078	\$141,679	\$148,409	\$173,025	\$190,456	\$196,894	\$229,935	\$233,848	\$243,787	\$261,738	\$251,300	\$245,858	\$247,611	\$269,620	\$282,877	\$287,218	\$279,834	\$4,259,547	Fuel/O&M Total	\$31.81	100.00%

Option 3: GE LPT Upgrade		2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	Total Cost	Desc.	\$/MWh	
Fuel Cost \$k	\$2,138,846	\$156,370	\$121,424	\$123,732	\$123,409	\$133,380	\$148,403	\$173,008	\$190,426	\$196,831	\$224,698	\$233,351	\$243,871	\$261,264	\$251,897	\$245,824	\$247,712	\$269,558	\$278,297	\$287,291	\$280,019	\$4,190,765	Fuel Total		
Interval Hours			7,855	16,125	24,372		15,422	23,532	31,617	39,357	47,442	55,552	63,499	71,584	79,669	87,779	95,519	103,604	111,689	119,560	127,745				
Operating Hours		8,247	7,855	8,270	8,247	7,739	7,633	8,110	8,085	7,740	8,085	8,110	7,947	8,085	8,085	8,110	7,740	8,085	8,085	7,971	8,085				
LP Inspection Interval				LP Replace		LP Replace (OPTIM read)										Major									
Cost \$k	\$9,580	0	0	\$4,761	0	0	0	0	0	0	0	0	0	0	0	\$2,720	0	0	0	0	0	\$12,481	LP Total		
HP/IP Inspection Interval			Major								Major											Major			
Cost \$k	\$4,194	0	\$2,335	0	0	0	0	0	0	0	\$2,335	0	0	0	0	0	0	0	0	0	0	\$7,009	HP/IP Total		
All in TCO	\$2,160,066.59	\$156,370	\$123,760	\$133,493	\$123,409	\$143,141	\$148,403	\$173,008	\$190,426	\$196,831	\$227,034	\$233,351	\$243,871	\$261,264	\$251,897	\$248,544	\$247,712	\$269,558	\$280,633	\$287,291	\$280,019	\$4,210,255	Fuel/O&M Total	\$32.19	101.19%

Option 4: Siemens LPT Upgrade		2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	Total Cost	Desc.	\$/MWh	
Fuel Cost \$k	\$2,140,688	\$156,370	\$121,424	\$123,732	\$123,409	\$133,346	\$148,424	\$173,609	\$190,753	\$195,930	\$225,658	\$234,965	\$243,804	\$261,714	\$251,208	\$245,781	\$247,590	\$269,554	\$278,180	\$287,709	\$281,915	\$4,195,075	Fuel Total		
Interval Hours		8,247	7,855	8,270	8,247	7,739	7,683	8,110	8,085	7,740	8,085	8,110	7,947	8,085	8,085	8,110	7,740	8,085	8,085	7,971	8,085				
LP Inspection Interval				LP Replace		LP Replace (OPTIM read)										Major									
Cost \$k	\$10,949	0	0	\$11,328	0	0	0	0	0	0	0	0	0	0	0	\$2,720	0	0	0	0	0	\$14,048	LP Total		
HP/IP Inspection Interval			Major								Major											Major			
Cost \$k	\$4,194	0	\$2,335	0	0	0	0	0	0	0	\$2,335	0	0	0	0	0	0	0	0	0	0	\$7,009	HP/IP Total		
sum	\$2,164,473	\$156,370	\$123,760	\$135,060	\$123,409	\$144,674	\$148,424	\$173,609	\$190,753	\$195,930	\$227,994	\$234,965	\$243,804	\$261,714	\$251,208	\$248,501	\$247,590	\$269,554	\$280,516	\$287,709	\$281,915	\$4,216,132	Fuel/O&M Total	\$32.15	101.07%

DECLASSIFIED

CONFIDENTIAL

DEF-19PL-FUEL-001678