

THE WOODS UTILITY COMPANY

May 20, 2021

Office of Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850

Re: Docket No. 20190125-WS - Application for staff-assisted rate case in Sumter County by The Woods Utility Company – Third Status Report.

Dear Commission Clerk:

The Woods Utility Company (The Woods) hereby submits its third status report pursuant to Order No. PSC-2020-0087-PAA-WS, issued on March 25, 2020.

In reference to the Lead & Copper testing, The Woods is now on Semi annual lead and copper testing. The 1st half of 2021 samples were collected earlier in May, we are awaiting results from the laboratory.


The following are additional updates and steps currently completed or in progress:

1. Lead and Copper samples collected January - June 2020 - yielded an exceedance at the 90% for Lead of a 0.0195 (MCL 0.0015). There were two lead exceedances at the customers' homes which triggered the 90%
2. A public notice was issued due to the 90% exceedance, the notice was hand delivered to all residents on September 18, 2020
3. Sampling was performed again in July - December 2020 - **all** locations sampled were **below** the MCL's for lead and copper. Both lead and copper passed at the 90% for the sampling event.
4. The system lead and copper monitoring plan was revised and approved by FDEP
5. (4) qtrs of WQP samples were collected in 2020 as requested by the FDEP
6. Ten samples were collected on May 3 – 5, 2021. Waiting on results. The test results will be sent in the next status report.

The Woods Utility Company
Third Status Report

If you have any questions, please do not hesitate to contact me at (727) 848-8292, ext. 245.

Respectfully,

A handwritten signature in blue ink, appearing to read "T. Rendell". The signature is fluid and cursive, with a large initial "T" and a stylized "R".

Troy Rendell
Vice President

Investor Owned Utilities

// for The Woods Utility Company