



Maria Jose Moncada
Assistant General Counsel
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408
(561) 304-5795
(561) 691-7135 (facsimile)
maria.moncada@fpl.com

November 17, 2023

-VIA ELECTRONIC FILING-

Adam Teitzman
Division of Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Re: Docket No. 20230001-EI

Dear Mr. Teitzman:

Attached for electronic filing in the above docket are Florida Power & Light Company's GPIF Actual Unit Performance Data Schedules covering the month of October 2023. These schedules are being filed at the same time but separately from the monthly A-Schedules.

If there are any questions regarding this transmittal, please contact me at (561) 304-5795.

Sincerely,

s/ Maria Jose Moncada

Maria Jose Moncada

Attachments

cc: Counsel for Parties of Record (w/ attachment)

Florida Power & Light Company

700 Universe Boulevard, Juno Beach, FL 33408

:21697935

CERTIFICATE OF SERVICE
Docket No. 20230001-EI

I **HEREBY CERTIFY** that a true and correct copy of the foregoing has been furnished by electronic service on this 17th day of November 2023 to the following:

Suzanne Brownless
Ryan Sandy
Office of General Counsel
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850
sbrownle@psc.state.fl.us
rsandy@psc.state.fl.us

J. Jeffry Wahlen
Malcolm N. Means
Virginia Ponder
Ausley McMullen
123 S. Calhoun Street
Post Office Box 391
Tallahassee, Florida 32302
jwahlen@ausley.com
mmeans@ausley.com
vponder@ausley.com
Attorneys for Tampa Electric Company

Paula K. Brown
Tampa Electric Company
P.O. Box 111
Tampa, Florida 33601-0111
regdept@tecoenergy.com

Mike Cassel
Vice President, Regulatory Affairs
Florida Public Utilities Company
208 Wildlight Avenue
Yulee, Florida 32097
mcassel@fpuc.com

Michelle D. Napier
Director, Regulatory Affairs
Florida Public Utilities Company
1635 Meathe Drive
West Palm Beach, Florida 33411
mnapier@fpuc.com

Walt Trierweiler
Charles J. Rehwinkel
Mary A. Wessling
Patricia A. Christensen
Office of Public Counsel
The Florida Legislature
111 W. Madison Street, Room 812
Tallahassee, Florida 32399
trierweiler.walt@leg.state.fl.us
rehwinkel.charles@leg.state.fl.us
christensen.patty@leg.state.fl.us
wessling.mary@leg.state.fl.us

Dianne M. Triplett
299 First Avenue North
St. Petersburg, Florida 33701
dianne.triplett@duke-energy.com

Matthew R. Bernier
Stephanie A. Cuello
106 East College Avenue, Suite 800
Tallahassee, Florida 32301
matthew.bernier@duke-energy.com
stephanie.cuello@duke-energy.com
Attorneys for Duke Energy Florida

Robert L. Pickels
Duke Energy Florida
106 East College Avenue, Suite 800
Tallahassee, Florida 32301
robert.pickels@duke-energy.com
FLRegulatoryLegal@duke-energy.com

Beth Keating
Gunster Law Firm
215 South Monroe Street, Suite 601
Tallahassee, Florida 32301-1804
bkeating@gunster.com
Attorneys for Florida Public Utilities Company

Robert Scheffel Wright
John Thomas LaVia, III
Gardner, Bist, Bowden, Dee, LaVia,
Wright, Perry & Harper, P.A.
1300 Thomaswood Drive
Tallahassee, FL 32308
schef@gbwlegal.com
jlavia@gbwlegal.com
Attorneys for Florida Retail Federation

Jon C. Moyle, Jr.
Moyle Law Firm, P.A.
118 North Gadsden Street
Tallahassee, Florida 32301
jmoyle@moylelaw.com
mqualls@moylelaw.com
**Attorneys for Florida Industrial Power
Users Group**

William C. Garner, Esq.
Law Office of William C. Garner, PLLC
3425 Bannerman Road
Unit 105, No. 414
Tallahassee, Florida 32312
bgarner@wcglawoffice.com
**Attorney for Southern Alliance for Clean
Energy**

Peter J. Mattheis
Michael K. Lavanga
Joseph R. Briscar
Stone Mattheis Xenopoulos & Brew, PC
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, DC 20007
pjm@smxblaw.com
mkl@smxblaw.com
jrb@smxblaw.com
Attorneys for Nucor Steel Florida, Inc.

James W. Brew
Laura Wynn Baker
Stone Mattheis Xenopoulos & Brew, P.C.
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, D.C. 20007
jbrew@smxblaw.com
lwb@smxblaw.com
**Attorneys for White Springs
Agricultural Chemicals, Inc. d/b/a PCS
Phosphate – White Springs**

By: s/ Maria Jose Moncada
Maria Jose Moncada
Florida Bar No. 0773301

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

		PLANT/UNIT: Cape Canaveral - PCC											PCC-03	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	96.2	98.8	95	99.5	89.6	97.8	97.5	94.2	94.1	82	0	0	94.4
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	744	672	743	720	744	720	744	744	720	738.48	0	0	7289.48
4	RSH	0	0	0	0	0	0	0	0	0	5.52	0	0	5.52
5	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9	PPOH	0	0	0	0	0	0	0	0.27	0	0	0	0	0.27
10	LRPP (MW)	0	0	0	0	0	0	0	426	0	0	0	0	426
11	PFOH	0	0.5	2.17	1.25	0	0	55.55	15.67	6.87	0	0	0	82
12	LRPF (MW)	0	206	441	387	0	0	426.12	426	426	0	0	0	424.54
13	PMOH	135.93	38.57	171.8	16.72	208.25	48.57	0	114.18	104.65	265.2	0	0	1103.87
14	LRPM (MW)	269	269	269	269	475.7	426	0	426	494.17	645.75	0	0	443
15	NSC	1280	1280	1280	1280	1280	1280	1280	1280	1280	1280	0	0	1280
16	OPER BTU (MBTU)	3,941,524	3,963,216	4,103,789	4,201,371	3,801,536	4,167,706	4,896,973	4,597,055	4,165,717	2,615,859	0	0	40,454,747
17	OPER NET GEN (MWH)	593,012	595,674	615,286	626,834	565,220	627,492	731,488	681,240	610,168	382,739	0	0	6,029,153
18	ANOHR (BTU/KWH)	6,647	6,653	6,670	6,703	6,726	6,642	6,695	6,748	6,827	6,835	0	0	6,710
19	NOF (%)	62.3	69.3	64.7	68.0	59.4	68.1	76.8	71.5	66.2	40.5	0	0	64.6
20	NPC (MW)	1280	1280	1280	1280	1280	1280	1280	1280	1280	1280	0	0	1280

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0												
----	----------------	-------------------------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2023 TO: Dec-2023

		PLANT/UNIT: Fort Myers - PFM						PFM-02						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	88.1	69.9	97.9	86.1	91.5	98.3	94	98.3	85.4	82.3	0	0	89.3
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	744	546.65	743	720	744	720	744	744	720	744	0	0	7169.65
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	0	125.35	0	0	0	0	0	0	0	0	0	0	125.35
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	125.35	0	0	0	0	0	0	0	0	0	0	125.35
9	PPOH	0	0	0	524.32	98.73	0	0	0	431.4	489.52	0	0	1543.97
10	LRPP (MW)	0	0	0	285.5	228.17	0	0	0	375.67	410.54	0	0	346.67
11	PFOH	0	97.93	15.7	49.78	4.62	1.07	173.52	53.77	12.78	0	0	0	409.17
12	LRPF (MW)	0	400.8	284.86	51.2	188	280.8	250.93	283.5	188	0	0	0	265.48
13	PMOH	744	237.57	76.52	83.67	300.32	114.88	139.33	22.75	67.97	73.68	0	0	1860.68
14	LRPM (MW)	200.94	381.58	285.94	188	276.64	179.06	229.35	280.8	187.17	280.8	0	0	243.55
15	NSC	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	0	0	1682
16	OPER BTU (MBTU)	5,450,944	4,071,133	6,853,520	5,877,636	6,371,253	6,437,605	6,842,411	7,346,242	6,117,200	6,207,419	0	0	61,575,363
17	OPER NET GEN (MWH)	714,336	531,742	961,459	819,651	893,151	906,366	953,992	1,028,845	855,520	873,578	0	0	8,538,640
18	ANOHR (BTU/KWH)	7,631	7,656	7,128	7,171	7,133	7,103	7,172	7,140	7,150	7,106	0	0	7,211
19	NOF (%)	57.1	57.8	76.9	67.7	71.4	74.8	76.2	82.2	70.6	69.8	0	0	70.8
20	NPC (MW)	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	0	0	1682

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0												
----	----------------	-------------------------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

		PLANT/UNIT: Manatee - PM3						PM3-03						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	93.7	88.3	96.8	98.7	94.5	98	97.2	95.6	97.5	99.7	0	0	96.1
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	744	600.23	743	720	744	720	739.38	741.57	720	744	0	0	7216.18
4	RSH	0	0	0	0	0	0	1.22	2.43	0	0	0	0	3.65
5	UH	0	71.77	0	0	0	0	3.4	0	0	0	0	0	75.17
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	71.77	0	0	0	0	3.4	0	0	0	0	0	75.17
9	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10	LRPP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11	PFOH	0	4.15	0	0	93.02	19.75	27.55	3.17	11.03	4.43	0	0	163.1
12	LRPF (MW)	0	295.22	0	0	287.04	540.59	618.36	539	538.17	537	0	0	402.59
13	PMOH	241.43	12.83	154.75	58.27	77.78	15.6	9.02	73.43	30.17	0	0	0	673.28
14	LRPM (MW)	237.34	529.17	189.89	191	296.98	418.6	502.74	523.81	537	0	0	0	287.3
15	NSC	1222	1222	1222	1222	1222	1222	1222	1222	1222	1222	0	0	1222
16	OPER BTU (MBTU)	3,421,533	3,407,422	4,210,148	4,474,886	4,293,530	4,467,770	4,840,842	4,955,682	4,736,093	4,797,039	0	0	43,604,945
17	OPER NET GEN (MWH)	493,392	499,407	610,543	651,480	626,862	652,198	706,150	729,975	695,551	702,676	0	0	6,368,234
18	ANOHR (BTU/KWH)	6,935	6,823	6,896	6,869	6,849	6,850	6,855	6,789	6,809	6,827	0	0	6,847
19	NOF (%)	54.3	68.1	67.2	74.0	68.9	74.1	78.2	80.6	79.1	77.3	0	0	72.2
20	NPC (MW)	1222	1222	1222	1222	1222	1222	1222	1222	1222	1222	0	0	1222

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0												
----	----------------	-------------------------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

		PLANT/UNIT: Martin - PM8						PM8-08						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	92.7	99.5	98.4	86.9	83.3	89.6	93.2	99.1	94.4	69.6	0	0	90.6
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	663.07	561.63	737.65	720	731.85	720	744	744	715.98	634.92	0	0	6973.1
4	RSH	32.93	110.37	5.35	0	12.15	0	0	0	4.02	62.58	0	0	227.4
5	UH	48	0	0	0	0	0	0	0	0	46.5	0	0	94.5
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	48	0	0	0	0	0	0	0	0	46.5	0	0	94.5
9	PPOH	0	0	0	337.22	255.88	0	0	0	0	313.5	0	0	906.6
10	LRPP (MW)	0	0	0	303.5	303.5	0	0	0	0	651.43	0	0	423.81
11	PFOH	3.27	21.05	0	3.82	75.7	72.98	74.83	0.35	0	0.72	0	0	252.72
12	LRPF (MW)	232.49	187.31	0	188.83	402.64	593.24	318.78	303	0	260.39	0	0	408.95
13	PMOH	30.55	0	77.4	61.27	143.05	103.73	125.6	26.75	165.9	49.5	0	0	783.75
14	LRPM (MW)	237.6	0	188.47	187	303.5	463.82	303	303	295.19	286.44	0	0	298.75
15	NSC	1216	1216	1216	1216	1216	1216	1216	1216	1216	1216	0	0	1216
16	OPER BTU (MBTU)	3,242,448	2,245,129	4,005,994	3,771,073	3,492,239	3,571,448	3,964,677	4,083,392	3,569,275	2,717,030	0	0	34,662,705
17	OPER NET GEN (MWH)	455,682	306,129	574,546	541,683	513,502	531,908	559,049	587,368	505,979	362,615	0	0	4,938,460
18	ANOHR (BTU/KWH)	7,116	7,334	6,972	6,962	6,801	6,714	7,092	6,952	7,054	7,493	0	0	7,019
19	NOF (%)	56.5	44.8	64.1	61.9	57.7	60.8	61.8	64.9	58.1	47.0	0	0	58.2
20	NPC (MW)	1216	1216	1216	1216	1216	1216	1216	1216	1216	1216	0	0	1216

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Okeechobee Energy Center - POK													
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	95.6	98.8	65.2	63.2	100	98.6	92.8	95.6	86.7	86.2	0	0	88.2
2	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	744	672	696.65	499.73	744	720	744	744	720	744	0	0	7028.38
4	0	0	46.35	92.63	0	0	0	0	0	0	0	0	138.98
5	0	0	0	127.64	0	0	0	0	0	0	0	0	127.64
6	0	0	0	0	0	0	0	0	0	0	0	0	0
7	0	0	0	0	0	0	0	0	0	0	0	0	0
8	0	0	0	127.63	0	0	0	0	0	0	0	0	127.63
9	0	24.23	743	30	0	0	0	0	0	0	0	0	797.23
10	0	513	501.65	342	0	0	0	0	0	0	0	0	495.99
11	24.15	0	0	0.92	0	12.03	162.53	1.45	46.87	7.15	0	0	255.1
12	414.06	0	0	342	0	342	506	342	498.94	342	0	0	482.14
13	118.92	0	49.32	336	0	31.98	0	99.67	246.32	306.68	0	0	1188.88
14	342	0	514	599.22	0	342	0	507	504.29	509	0	0	512.36
15	1540	1540	1540	1540	1540	1540	1540	1540	1540	1540	0	0	1540
16	5,799,230	5,520,081	4,483,986	3,804,939	7,014,167	6,497,511	6,446,206	6,759,100	5,980,955	6,194,483	0	0	58,500,658
17	904,010	867,316	706,268	590,342	1,117,777	1,030,952	1,021,091	1,078,906	946,211	979,970	0	0	9,242,842
18	6,415	6,365	6,349	6,445	6,275	6,302	6,313	6,265	6,321	6,321	0	0	6,329
19	78.9	83.8	65.8	76.7	97.6	93.0	89.1	94.2	85.3	85.5	0	0	85.4
20	1540	1540	1540	1540	1540	1540	1540	1540	1540	1540	0	0	1540

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

		PLANT/UNIT: Port Everglades - PPE										PPE-05		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	90.4	98.2	37.5	90.6	99.7	97.8	99.5	95.5	95.9	99.5	0	0	90.3
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	744	672	419.85	720	744	720	744	744	720	744	0	0	6971.85
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	0	0	323.15	0	0	0	0	0	0	0	0	0	323.15
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	323.15	0	0	0	0	0	0	0	0	0	323.15
9	PPOH	0	0	321.32	179.22	0	0	0	0	0	0	0	0	500.53
10	LRPP (MW)	0	0	406.59	410	0	0	0	0	0	0	0	0	407.81
11	PFOH	17.82	9.97	2	0.83	9.18	5.62	12.63	0.97	6.28	11.67	0	0	76.97
12	LRPF (MW)	320.9	371.88	381	269	307.48	267.03	364	252	559.94	387	0	0	358.71
13	PMOH	212.95	43.08	125.38	25.48	0.53	69.72	0.03	99.4	79.83	0	0	0	656.42
14	LRPM (MW)	369.76	252	277.09	252	269	252	252	395.17	387	0	0	0	333.11
15	NSC	1178	1178	1178	1178	1178	1178	1178	1178	1178	1178	0	0	1178
16	OPER BTU (MBTU)	2,988,310	3,591,374	1,748,852	3,364,595	4,236,218	3,827,231	4,512,105	4,235,228	3,981,826	4,193,793	0	0	36,679,531
17	OPER NET GEN (MWH)	434,393	527,133	254,886	477,045	623,655	560,166	665,373	626,863	584,154	611,305	0	0	5,364,973
18	ANOHR (BTU/KWH)	6,879	6,813	6,861	7,053	6,793	6,832	6,781	6,756	6,816	6,860	0	0	6,837
19	NOF (%)	49.6	66.6	51.5	56.2	71.2	66.0	75.9	71.5	68.9	69.7	0	0	65.3
20	NPC (MW)	1178	1178	1178	1178	1178	1178	1178	1178	1178	1178	0	0	1178

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0												
----	----------------	-------------------------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

		PLANT/UNIT: Riviera - PRV						PRV-05						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	93.4	97.4	95.5	95.2	83.8	92.7	99.9	97.2	97.7	99.6	0	0	95.2
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	744	672	743	720	744	678.2	744	744	720	744	0	0	7253.2
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	0	0	0	0	0	41.8	0	0	0	0	0	0	41.8
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	0	41.8	0	0	0	0	0	0	41.8
9	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10	LRPP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11	PFOH	19.42	2.88	12.98	16.25	2.08	1.53	0	0	0	7.42	0	0	62.57
12	LRPF (MW)	430	145.04	426.04	426	408	430	0	0	0	431	0	0	414.39
13	PMOH	115.72	47.08	86.9	86.23	374.77	23.03	2.35	62.82	49.68	1.2	0	0	849.78
14	LRPM (MW)	469.25	470.53	426	426	408	574.23	412	420.03	431	413	0	0	430.23
15	NSC	1275	1275	1275	1275	1275	1275	1275	1275	1275	1275	0	0	1275
16	OPER BTU (MBTU)	2,968,322	2,928,748	3,936,125	4,012,162	3,405,980	4,363,927	5,197,502	4,817,331	4,621,786	4,670,735	0	0	40,922,619
17	OPER NET GEN (MWH)	438,583	444,639	591,777	605,690	506,941	663,119	793,198	731,362	698,758	706,158	0	0	6,180,225
18	ANOHR (BTU/KWH)	6,768	6,587	6,651	6,624	6,719	6,581	6,553	6,587	6,614	6,614	0	0	6,622
19	NOF (%)	46.2	51.9	62.5	66.0	53.4	76.7	83.6	77.1	76.1	74.4	0	0	66.8
20	NPC (MW)	1275	1275	1275	1275	1275	1275	1275	1275	1275	1275	0	0	1275

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0											
----	----------------	-------------------------------	--	--	--	--	--	--	--	--	--	--	--

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: St. Lucie Nuclear - PSL														
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd	
1	EAF (%)	100	100	100	100	100	100	96.8	100	100	100	0	0	99.7
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	744	672	743	720	744	720	744	744	720	744	0	0	7295
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9	PPOH	0	0	0	0	0	0	86.42	0	0	0	0	0	86.42
10	LRPP (MW)	0	0	0	0	0	0	232.03	0	0	0	0	0	232.03
11	PFOH	0	0	0	0	0	0	311.75	0	0	0	0	0	311.75
12	LRPF (MW)	0	0	0	0	0	0	9.85	0	0	0	0	0	9.85
13	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	0
14	LRPM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
15	NSC	981	981	981	981	981	981	981	981	981	981	0	0	981
16	OPER BTU (MBTU)	7,643,839	6,897,660	7,626,276	7,392,433	7,639,114	7,387,164	7,396,539	7,631,446	7,384,987	7,613,956	0	0	74,613,414
17	OPER NET GEN (MWH)	740,947	672,577	741,852	716,977	738,009	710,576	702,195	734,002	705,097	733,981	0	0	7,196,213
18	ANOHR (BTU/KWH)	10,316	10,256	10,280	10,311	10,351	10,396	10,533	10,397	10,474	10,374	0	0	10,368
19	NOF (%)	101.5	102.0	101.8	101.5	101.1	100.6	96.2	100.6	99.8	100.6	0	0	100.6
20	NPC (MW)	981	981	981	981	981	981	981	981	981	981	0	0	981

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

		PLANT/UNIT: St. Lucie Nuclear - PSL											PSL-02	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	100	59.4	39.8	100	100	99.8	100	100	100	100	0	0	90.1
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	744	408	315.12	720	744	720	744	744	720	744	0	0	6603.12
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	0	264	427.88	0	0	0	0	0	0	0	0	0	691.88
6	POH	0	264	427.88	0	0	0	0	0	0	0	0	0	691.88
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9	PPOH	0	27.08	91.87	0	0	0	0	0	0	0	0	0	118.95
10	LRPP (MW)	0	316.36	207.53	0	0	0	0	0	0	0	0	0	232.31
11	PFOH	0	0	0	0	0	7.37	0	0	0	0	0	0	7.37
12	LRPF (MW)	0	0	0	0	0	163.22	0	0	0	0	0	0	163.22
13	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	0
14	LRPM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
15	NSC	986	986	986	986	986	986	986	986	986	986	0	0	986
16	OPER BTU (MBTU)	7,661,502	4,111,434	3,054,627	7,413,658	7,660,982	7,400,126	7,660,166	7,661,428	7,413,979	7,660,784	0	0	67,698,686
17	OPER NET GEN (MWH)	754,116	402,558	296,328	727,530	747,548	719,406	743,088	744,481	715,399	746,497	0	0	6,596,951
18	ANOHR (BTU/KWH)	10,160	10,213	10,308	10,190	10,248	10,286	10,309	10,291	10,363	10,262	0	0	10,262
19	NOF (%)	102.8	100.1	95.4	102.5	101.9	101.3	101.3	101.5	100.8	101.8	0	0	101.3
20	NPC (MW)	986	986	986	986	986	986	986	986	986	986	0	0	986

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Turkey Point Nuclear - PTN														PTN-03
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd	
1	EAF (%)	100	100	100	21.2	72.7	100	100	93.5	95.3	96	0	0	87.9
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	744	672	743	168	581.75	720	744	702.13	690.97	719.08	0	0	6484.93
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	0	0	0	552	162.25	0	0	41.87	29.03	24.92	0	0	810.07
6	POH	0	0	0	552	162.25	0	0	0	0	0	0	0	714.25
7	FOH	0	0	0	0	0	0	0	41.87	29.03	24.92	0	0	95.82
8	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9	PPOH	0	0	0	27.57	99.93	0	0	0	0	0	0	0	127.5
10	LRPP (MW)	0	0	0	477.07	339.62	0	0	0	0	0	0	0	369.34
11	PFOH	0	0	0	0	0	0	0	15.27	10.22	22.1	0	0	47.58
12	LRPF (MW)	0	0	0	0	0	0	0	375.09	412.57	193.05	0	0	298.59
13	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	0
14	LRPM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
15	NSC	837	837	837	837	837	837	837	837	837	837	0	0	837
16	OPER BTU (MBTU)	6,706,970	6,058,023	6,698,114	1,387,273	4,900,407	6,490,676	6,706,493	6,274,469	6,186,886	6,435,341	0	0	57,844,651
17	OPER NET GEN (MWH)	645,923	581,002	644,083	130,477	465,776	622,113	637,870	596,977	591,045	620,095	0	0	5,535,360
18	ANOHR (BTU/KWH)	10,384	10,427	10,399	10,632	10,521	10,433	10,514	10,510	10,468	10,378	0	0	10,450
19	NOF (%)	103.7	103.3	103.6	92.8	95.7	103.2	102.4	101.6	102.2	103.0	0	0	102.0
20	NPC (MW)	837	837	837	837	837	837	837	837	837	837	0	0	837

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Turkey Point Nuclear - PTN														PTN-04
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd	
1	EAF (%)	100	100	100	100	100	99.7	98.9	100	94.4	0	0	0	89.1
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	744	672	743	720	744	720	744	744	696	0	0	0	6527
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	0	0	0	0	0	0	0	0	24	744	0	0	768
6	POH	0	0	0	0	0	0	0	0	24	744	0	0	768
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9	PPOH	0	0	0	0	0	0	0	0	28	0	0	0	28
10	LRPP (MW)	0	0	0	0	0	0	0	0	498.34	0	0	0	498.34
11	PFOH	0	0	0	0	0	8.08	37.57	0	0	0	0	0	45.65
12	LRPF (MW)	0	0	0	0	0	192.28	189.22	0	0	0	0	0	189.76
13	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	0
14	LRPM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
15	NSC	844	844	844	844	844	844	844	844	844	844	0	0	844
16	OPER BTU (MBTU)	6,707,251	6,058,587	6,698,429	6,491,369	6,706,147	6,471,033	6,652,155	6,706,580	6,076,562	0	0	0	58,568,112
17	OPER NET GEN (MWH)	652,201	588,956	652,212	630,286	647,410	618,322	631,115	641,296	578,061	0	0	0	5,639,860
18	ANOHR (BTU/KWH)	10,284	10,287	10,270	10,299	10,358	10,465	10,540	10,458	10,512	0	0	0	10,385
19	NOF (%)	103.9	103.8	104.0	103.7	103.1	101.8	100.5	102.1	98.4	0	0	0	102.4
20	NPC (MW)	844	844	844	844	844	844	844	844	844	844	0	0	844

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: West County Energy Center - PWC														PWC-01
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd	
1	EAF (%)	74.7	94.6	65.8	74.8	96.9	90.7	95.8	93	96.5	99.8	0	0	88.2
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	572.53	672	743	720	744	720	744	744	720	744	0	0	7123.53
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	171.47	0	0	0	0	0	0	0	0	0	0	0	171.47
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	171.47	0	0	0	0	0	0	0	0	0	0	0	171.47
9	PPOH	0	3.53	743	486.1	0	0	0	0	0	0	0	0	1232.63
10	LRPP (MW)	0	400	400	400	0	0	0	0	0	0	0	0	400
11	PFOH	29.52	14.85	0	4.13	7.25	19.85	36.58	3.85	2.68	4.4	0	0	123.12
12	LRPF (MW)	398	398	0	181.89	306.52	544.31	443.9	368.41	400	400	0	0	421.78
13	PMOH	14.65	89.28	32.17	56.82	61.37	157.95	53.7	134.73	73.22	0	0	0	673.88
14	LRPM (MW)	582.76	404	239	400	410.28	443.14	400	453.47	400	0	0	0	418.56
15	NSC	1201	1201	1201	1201	1201	1201	1201	1201	1201	1201	0	0	1201
16	OPER BTU (MBTU)	2,379,777	3,398,590	3,438,648	3,933,873	4,794,503	4,159,527	4,928,384	4,951,987	4,965,721	4,749,596	0	0	41,700,606
17	OPER NET GEN (MWH)	333,233	489,962	489,885	564,386	698,798	597,507	711,811	716,344	719,059	685,014	0	0	6,005,999
18	ANOHR (BTU/KWH)	7,141	6,936	7,019	6,970	6,861	6,961	6,924	6,913	6,906	6,934	0	0	6,943
19	NOF (%)	48.5	60.7	54.9	65.3	78.2	69.1	79.7	80.2	83.2	76.7	0	0	70.2
20	NPC (MW)	1201	1201	1201	1201	1201	1201	1201	1201	1201	1201	0	0	1201

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: West County Energy Center - PWC														
PWC-02														
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd	
1	EAF (%)	78.6	94.4	93	98.8	66.7	73.6	92.4	97.2	99.8	97.5	0	0	89.1
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	591.33	668.72	743	720	744	720	734.13	744	720	744	0	0	7129.18
4	RSH	0	3.28	0	0	0	0	9.87	0	0	0	0	0	13.15
5	UH	152.67	0	0	0	0	0	0	0	0	0	0	0	152.67
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	152.67	0	0	0	0	0	0	0	0	0	0	0	152.67
9	PPOH	0	0	0	26.32	744	450.07	0	0	0	0	0	0	1220.38
10	LRPP (MW)	0	0	0	400	400	397.13	0	0	0	0	0	0	398.94
11	PFOH	0	31.55	0	0	0	8.35	63.2	1.5	4.4	0	0	0	109
12	LRPF (MW)	0	476.26	0	0	0	406.95	469.38	400	400	0	0	0	462.83
13	PMOH	11.93	74.03	133.48	0	0	164.75	96.13	51.88	0	55.7	0	0	587.92
14	LRPM (MW)	682.29	404	469.82	0	0	278.91	400	470.79	0	400	0	0	394.4
15	NSC	1201	1201	1201	1201	1201	1201	1201	1201	1201	1201	0	0	1201
16	OPER BTU (MBTU)	2,646,326	3,311,800	4,438,110	4,867,767	3,658,361	3,247,212	4,728,932	5,099,118	5,041,124	4,511,251	0	0	41,550,000
17	OPER NET GEN (MWH)	379,276	485,260	641,387	710,554	523,984	451,767	685,096	746,334	739,122	654,905	0	0	6,017,685
18	ANOHR (BTU/KWH)	6,977	6,825	6,920	6,851	6,982	7,188	6,903	6,832	6,820	6,888	0	0	6,905
19	NOF (%)	53.4	60.4	71.9	82.2	58.6	52.2	77.7	83.5	85.5	73.3	0	0	70.3
20	NPC (MW)	1201	1201	1201	1201	1201	1201	1201	1201	1201	1201	0	0	1201

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: West County Energy Center - PWC														PWC-03
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd	
1	91.6	53.1	0	0	68.9	99.6	100	100	92.8	100	0	0	70.8	
2	744	672	743	720	744	720	744	744	720	744	0	0	7295	
3	744	455.3	0	0	582.65	720	744	744	688.95	744	0	0	5422.9	
4	0	0	0	0	0	0	0	0	0	0	0	0	0	
5	0	216.7	743	720	161.35	0	0	0	31.05	0	0	0	1872.1	
6	0	216.7	743	720	126.27	0	0	0	0	0	0	0	1805.97	
7	0	0	0	0	0	0	0	0	0	0	0	0	0	
8	0	0	0	0	35.08	0	0	0	31.05	0	0	0	66.13	
9	0	0.28	0	0	146.2	0	0	0	0	0	0	0	146.48	
10	0	484	0	0	431.17	0	0	0	0	0	0	0	431.28	
11	0	0	0	0	7.7	9.77	0	0	0	0.4	0	0	17.87	
12	0	0	0	0	402	402	0	0	0	241	0	0	398.4	
13	190.13	256.77	0	0	43.92	0	0	0	57.47	0	0	0	548.28	
14	398	460.96	0	0	419.66	0	0	0	430.64	0	0	0	432.64	
15	1207	1207	1207	1207	1207	1207	1207	1207	1207	1207	0	0	1207	
16	3,350,008	2,000,300	21,802	20,983	3,329,613	4,644,573	5,071,568	5,192,879	4,625,206	4,697,375	0	0	32,954,307	
17	465,513	274,424	-396.0	-1275.0	463,393	665,326	727,769	745,540	655,601	675,514	0	0	4,671,409	
18	7,196	7,289	0	0	7,185	6,981	6,969	6,965	7,055	6,954	0	0	7,054	
19	51.8	49.9	0	0	65.9	76.6	81.0	83.0	78.8	75.2	0	0	71.4	
20	1207	1207	1207	1207	1207	1207	1207	1207	1207	1207	0	0	1207	

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

		PLANT/UNIT: Turkey Point - TP5						TP5-05						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	95.6	80.6	75.6	98.6	83.9	68.4	97	98.4	95.4	98.3	0	0	89.3
2	PH	744	672	743	720	744	720	744	744	720	744	0	0	7295
3	SH	706.13	601.73	733.93	720	744	720	744	744	720	744	0	0	7177.8
4	RSH	37.87	70.27	9.07	0	0	0	0	0	0	0	0	0	117.2
5	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9	PPOH	0	435.45	636.08	38.83	312.72	549.03	0	0	0	0	0	0	1972.12
10	LRPP (MW)	0	316.5	316.5	316.5	365.08	487.78	0	0	0	0	0	0	371.89
11	PFOH	0	2.53	11.37	0.28	97.18	22.57	17.2	2.78	0	0	0	0	153.92
12	LRPF (MW)	0	336.5	316.5	316.5	151	194.36	316.5	316.5	0	0	0	0	194.43
13	PMOH	95.98	74.63	132.73	0	73.5	51.43	70.97	55.88	148	52.02	0	0	755.15
14	LRPM (MW)	428.39	348.67	188.5	0	316.5	316.5	316.5	247.21	283.29	316.5	0	0	299.77
15	NSC	1266	1266	1266	1266	1266	1266	1266	1266	1266	1266	0	0	1266
16	OPER BTU (MBTU)	2,762,237	2,333,031	3,217,536	4,294,836	3,934,592	3,164,854	4,480,408	4,840,434	4,325,155	4,434,910	0	0	37,787,992
17	OPER NET GEN (MWH)	375,049	318,249	453,204	609,068	558,777	448,730	638,530	694,679	615,747	634,164	0	0	5,346,196
18	ANOHR (BTU/KWH)	7,365	7,331	7,100	7,051	7,041	7,053	7,017	6,968	7,024	6,993	0	0	7,068
19	NOF (%)	42.0	41.8	48.8	66.8	59.3	49.2	67.8	73.8	67.6	67.3	0	0	58.8
20	NPC (MW)	1266	1266	1266	1266	1266	1266	1266	1266	1266	1266	0	0	1266

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0												
----	----------------	-------------------------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Cape Canaveral - PCC		PCC-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-01-06	PMO	72.6	269.00	32 SNOW
2023-01-19	PMO	23.6	269.00	31 SNOW
2023-01-20	PMO	12.2	269.00	31 SNOW
2023-01-21	PMO	27.4	269.00	32 SNOW
2023-02-08	PFO	0.5	206.00	PCC 32 GV2 Derating
2023-02-10	PMO	38.5	269.00	PCC 32 GV2 MO
2023-03-09	PMO	89.0	269.00	PCC 32 MO
2023-03-18	PMO	82.7	269.00	CT 32 MO
2023-03-29	PFO	2.1	269.00	PCC CT32 HRH bypass valve fail
2023-03-29	PFO	2.1	172.00	PCC CT32 HRH bypass valve fail
2023-04-05	PFO	1.2	269.00	PCC 32 HRH bypass valve
2023-04-05	PFO	1.2	118.00	PCC 32 HRH bypass valve
2023-04-13	PMO	16.7	269.00	PCC 32
2023-05-11	PMO	94.2	269.00	PCC 33 SNOW
2023-05-11	PMO	94.2	172.00	PCC 33 SNOW
2023-05-21	PMO	114.0	269.00	PCC 31 SNOW
2023-05-21	PMO	114.0	157.00	PCC 31 SNOW
2023-05-24	PMO	33.2	269.00	PCC 32 SNOW
2023-06-24	PMO	48.5	269.00	PCC 33 SNOW
2023-06-24	PMO	48.5	157.00	PCC 33 SNOW
2023-07-13	PFO	2.3	269.00	PCC31 Trip
2023-07-13	PFO	2.3	158.00	PCC31 Trip
2023-07-14	PFO	4.5	269.00	CT 31 TOT Failure
2023-07-14	PFO	4.5	158.00	CT 31 TOT Failure
2023-07-16	PFO	23.5	269.00	CT31 Breaker Open Unexpectedly
2023-07-16	PFO	23.5	157.00	CT31 Breaker Open Unexpectedly
2023-07-17	PFO	4.5	269.00	CT 31 Start-up Failure
2023-07-17	PFO	4.5	157.00	CT 31 Start-up Failure
2023-07-25	PFO	17.4	269.00	PCC 31 Trip - Breaker opened unexpectedly
2023-07-25	PFO	17.4	157.00	PCC 31 Trip - Breaker opened unexpectedly
2023-07-25	PFO	3.2	269.00	PCC 31 TOT failure
2023-07-25	PFO	3.2	157.00	PCC 31 TOT failure
2023-08-13	PFO	7.5	269.00	CT31 Breaker Open Unexpectedly
2023-08-13	PFO	7.5	157.00	CT31 Breaker Open Unexpectedly
2023-08-15	PPO	0.2	269.00	PCC 31 SNOW- Breaker Troubleshoot
2023-08-15	PPO	0.2	157.00	PCC 31 SNOW- Breaker Troubleshoot
2023-08-16	PMO	28.8	269.00	PCC31- SNOW- Breaker Troubleshooting
2023-08-16	PMO	28.8	157.00	PCC31- SNOW- Breaker Troubleshooting
2023-08-18	PFO	2.9	269.00	PCC31- SU Fail- Dyn Pres
2023-08-18	PFO	2.9	157.00	PCC31- SU Fail- Dyn Pres
2023-08-20	PMO	24.8	269.00	PCC31- SNOW- Breaker Troubleshooting
2023-08-20	PMO	24.8	157.00	PCC31- SNOW- Breaker Troubleshooting
2023-08-24	PMO	24.3	269.00	PCC CT32- SNOW- Secondary Exciter Breaker
2023-08-24	PMO	24.3	157.00	PCC CT32- SNOW- Secondary Exciter Breaker
2023-08-26	PFO	5.1	269.00	PCC CT32 Trip- BAB36
2023-08-26	PFO	5.1	157.00	PCC CT32 Trip- BAB36
2023-08-27	PMO	36.0	269.00	PCC CT31- SNOW
2023-08-27	PMO	36.0	157.00	PCC CT31- SNOW
2023-09-08	PFO	1.0	269.00	PCC 31 TOT Failure
2023-09-08	PFO	1.0	157.00	PCC 31 TOT Failure
2023-09-08	PFO	0.8	269.00	PCC31- SU Fail- Exc Trans Bkr
2023-09-08	PFO	0.8	157.00	PCC31- SU Fail- Exc Trans Bkr
2023-09-09	PMO	53.8	269.00	PCC 32 HRSG- HRH Bypass
2023-09-09	PMO	27.8	301.00	PCC ST- Waterbox Cleaning
2023-09-09	PMO	27.8	112.00	PCC ST- Waterbox Cleaning
2023-09-09	PMO	27.8	112.00	PCC ST- Waterbox Cleaning
2023-09-12	PFO	2.9	269.00	PCC CT32- SU Fail- Logic
2023-09-12	PFO	2.9	157.00	PCC CT32- SU Fail- Logic
2023-09-12	PFO	1.9	269.00	PCC CT32- SU Fail- Dyn Pres
2023-09-12	PFO	1.9	157.00	PCC CT32- SU Fail- Dyn Pres
2023-09-18	PMO	20.6	269.00	PCC31- SNOW
2023-09-18	PMO	20.6	157.00	PCC31- SNOW
2023-09-20	PMO	4.0	269.00	PCC31- SNOW
2023-09-20	PMO	4.0	157.00	PCC31- SNOW
2023-09-29	PMO	158.0	269.00	WaterBox Cleaning
2023-09-29	PMO	158.0	158.00	WaterBox Cleaning
2023-09-30	PMO	135.4	269.00	WaterBox Cleaning
2023-09-30	PMO	135.4	158.00	WaterBox Cleaning
2023-10-06	PMO	4.2	269.00	WaterBox Cleaning
2023-10-06	PMO	24.1	269.00	WaterBox Cleaning
2023-10-06	PMO	4.2	158.00	WaterBox Cleaning

2023-10-06	PMO	4.2	158.00	WaterBox Cleaning
2023-10-06	PMO	19.9	158.00	WaterBox Cleaning
2023-10-15	PMO	41.8	269.00	PCC33- SNOW- CEMS
2023-10-15	PMO	41.8	316.00	PCC33- SNOW- CEMS
2023-10-16	PMO	44.4	269.00	PCC32- SNOW- CEMS
2023-10-16	PMO	17.8	316.00	PCC32- SNOW- CEMS
2023-10-17	PMO	26.6	316.00	PCC32- SNOW- CEMS
2023-10-18	PMO	32.1	269.00	PCC31- SNOW- CEMS
2023-10-18	PMO	5.9	316.00	PCC31- SNOW- CEMS
2023-10-18	PMO	26.1	316.00	PCC31- SNOW- CEMS
2023-10-26	PMO	14.4	269.00	PCC32- SNOW- Turb Insp
2023-10-26	PMO	14.4	158.00	PCC32- SNOW- Turb Insp

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

- FILED:
- SUSPENDED:
- EFFECTIVE:
- DOCKET NO:
- ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Fort Myers - PFM		PFM-02		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-01-01	PMO	0.0	125.00	PFM ST 1 MOF Extension - Control Valve Issues
2023-01-01	PMO	743.9	125.00	PFM ST1 MOF Extension - LP Steam Control Valve Issues
2023-01-10	PMO	50.6	188.00	PFM 2D Task MOF - Remote Purge Test and Water Wash
2023-01-10	PMO	50.6	99.00	PFM 2D Task MOF - Remote Purge Test and Water Wash
2023-01-15	PMO	4.8	103.00	PFM 2D Task MOF - Tuning
2023-01-15	PMO	4.8	72.07	PFM 2D Task MOF - Tuning
2023-01-19	PMO	19.0	188.00	PFM 2D Event MOF - Refill transformer oil
2023-01-26	PMO	35.9	188.00	PFM 2B Event MOF - Repair IP Intermittent blowdown line
2023-01-26	PMO	35.9	98.69	PFM 2B Event MOF - Repair IP Intermittent blowdown line
2023-01-30	PMO	74.6	188.00	PFM 2E Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-01-30	PMO	74.6	202.00	PFM 2E Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-01-31	PMO	45.1	188.00	PFM 2D Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-01-31	PMO	45.1	202.00	PFM 2D Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-01-31	PMO	51.9	188.00	PFM 2F Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-01-31	PMO	48.2	32.00	PFM 2F Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-02-01	PMO	0.0	125.00	PFM ST1 MOF Extension - LP Steam Control Valves
2023-02-01	PMO	120.8	125.00	PFM ST1 MOF Extension - LP Steam Control Valve Issues
2023-02-02	PMO	44.9	185.00	PFM 2C Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-02-02	PMO	1.6	202.00	PFM 2C Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-02-02	PMO	3.7	32.00	PFM 2F Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-02-02	PMO	43.3	170.00	PFM 2C Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-02-02	PMO	40.3	188.00	PFM 2B Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-02-02	PMO	0.8	202.00	PFM 2B Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-02-02	PMO	39.5	32.00	PFM 2B Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-02-02	PMO	36.7	188.00	PFM 2A Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-02-02	PMO	36.7	202.00	PFM 2A Task MOF - PnC NERC collector bus 6 year compliance maintenance
2023-02-05	PMO	1.8	188.00	PFM 2E Event MOF - ST1 stop valve replacement
2023-02-06	PMO	0.5	188.00	PFM 2A Event MOF - ST1 stop valve replacement
2023-02-06	PMO	0.5	185.00	PFM 2C Event MOF - ST1 stop valve replacement
2023-02-06	PMO	0.5	432.00	PFM ST2 Event MOF - ST1 stop valve replacement
2023-02-06	PMO	0.2	188.00	PFM 2F Event MOF - ST1 stop valve replacement
2023-02-06	PMO	0.1	188.00	PFM 2D Event MOF - ST1 stop valve replacement
2023-02-06	FMO	125.3	1682.00	PFM 2B Event MOF - ST1 stop valve replacement
2023-02-11	PMO	0.7	188.00	PFM 2A Event MOF - ST1 stop valve replacement
2023-02-11	PMO	0.3	188.00	PFM 2B Event MOF - ST1 stop valve replacement
2023-02-11	PMO	0.3	185.00	PFM 2C Event MOF - ST1 stop valve replacement
2023-02-11	PMO	1.0	188.00	PFM 2E Event MOF - ST1 stop valve replacement
2023-02-11	PMO	4.5	432.00	PFM ST2 Event MOF - ST1 stop valve replacement
2023-02-11	PMO	0.3	188.00	PFM 2D Event MOF - ST1 stop valve replacement

2023-02-11	PMO	116.7	125.00	PFM ST1 MOF Extension - LP Steam Control Valve Issues
2023-02-11	PFO	84.9	432.00	PFM ST2 EFOR - Hydraulic leaks
2023-02-15	PFO	9.8	244.00	PFM ST2 Partial EFOR - Hydraulic leaks
2023-02-15	PMO	13.6	432.00	PFM ST2 Event MOF - Repair hydraulic line servo
2023-02-18	PFO	3.1	50.00	ST1 Partial Derate - Debris Filter Torque Nut loose
2023-03-02	PFO	1.5	185.00	PFM 2C EFOR - Exciter breaker unable to close
2023-03-02	PFO	1.5	15.79	PFM 2C EFOR - Exciter breaker unable to close
2023-03-02	PFO	1.5	82.00	PFM 2C EFOR - Exciter breaker unable to close
2023-03-08	PMO	23.7	188.00	PFM 2F Event MOF - Repair West Side Penetration Seal
2023-03-08	PMO	23.7	15.79	PFM 2F Event MOF - Repair West Side Penetration Seal
2023-03-08	PMO	23.7	82.00	PFM 2F Event MOF - Repair West Side Penetration Seal
2023-03-11	PFO	3.3	185.00	PFM 2C EFOR - Exciter Breaker Issues 41-AC-2
2023-03-11	PFO	3.3	15.79	PFM 2C EFOR - Exciter Breaker Issues 41-AC-2
2023-03-11	PFO	3.3	82.00	PFM 2C EFOR - Exciter Breaker Issues 41-AC-2
2023-03-15	PMO	52.7	188.00	PFM 2E Event MO - IP Riser Leak
2023-03-15	PMO	52.7	16.00	PFM 2E Event MO - IP Riser Leak
2023-03-15	PMO	52.7	82.00	PFM 2E Event MO - IP Riser Leak
2023-03-22	PFO	2.6	188.00	PFM 2A EFOR - Loss of flame trip on SRV going closed
2023-03-22	PFO	2.6	15.79	PFM 2A EFOR - Loss of flame trip on SRV going closed
2023-03-22	PFO	2.6	82.00	PFM 2A EFOR - Loss of flame trip on SRV going closed
2023-03-25	PFO	8.1	188.00	PFM 2E EFOR - VSV control cable failures
2023-03-25	PFO	8.1	15.79	PFM 2E EFOR - VSV control cable failures
2023-03-25	PFO	8.1	82.00	PFM 2E EFOR - VSV control cable failures
2023-04-03	PFO	0.7	188.00	PFM 2A EFOR - Exhaust Frame Blower
2023-04-03	PFO	0.7	5.79	PFM 2A EFOR - Exhaust Frame Blower
2023-04-03	PFO	0.7	82.00	PFM 2A EFOR - Exhaust Frame Blower
2023-04-07	PFO	3.3	188.00	PFM 2A EFOR - IBH Actuator Diaphragm failure
2023-04-07	PFO	3.3	15.79	PFM 2A EFOR - IBH Actuator Diaphragm failure
2023-04-07	PFO	3.3	82.00	PFM 2A EFOR - IBH Actuator Diaphragm failure
2023-04-09	PPO	524.3	188.00	PFM 2B PO - HGP Tech 2.0
2023-04-09	PPO	524.3	15.50	PFM 2B PO - HGP Tech 2.0
2023-04-09	PPO	524.3	82.00	PFM 2B PO - HGP Tech 2.0
2023-04-12	PMO	83.6	188.00	PFM 2A Event MO - BFP flex coupling and CT Exhaust issues
2023-04-12	PMO	83.6	15.00	PFM 2A Event MO - BFP flex coupling and CT Exhaust issues
2023-04-12	PMO	83.6	82.00	PFM 2A Event MO - BFP flex coupling and CT Exhaust issues
2023-04-17	PFO	28.2	34.50	PFM ST1 - Stop valve does not open
2023-04-18	PFO	17.5	24.50	PFM ST1 - Stop valve will not open past 50%
2023-05-01	PPO	66.3	188.00	PFM 2B PO - HGP Tech 2.0
2023-05-01	PPO	66.3	15.79	PFM 2B PO - HGP Tech 2.0
2023-05-01	PPO	66.3	82.00	PFM 2B PO - HGP Tech 2.0
2023-05-02	PMO	300.3	185.00	PFM 2C MO - Generator bearing replacement and BFP motor install
2023-05-02	PMO	18.9	15.79	PFM 2C MO - Generator bearing replacement and BFP motor install
2023-05-02	PMO	18.9	82.00	PFM 2C MO - Generator bearing replacement and BFP motor install
2023-05-03	PMO	281.4	15.79	PFM 2C MO - Generator bearing replacement and BFP motor install
2023-05-03	PMO	281.4	82.00	PFM 2C MO - Generator bearing replacement and BFP motor install
2023-05-04	PPO	10.6	21.59	PFM 2B - Post HGP Tech 2.0 Tuning
2023-05-06	PPO	6.4	88.56	PFM 2B - Post HGP Tech 2.0 Tuning
2023-05-07	PPO	13.7	188.00	PFM 2B PO - VSV servo failure
2023-05-07	PPO	13.7	6.20	PFM 2B PO - VSV servo failure
2023-05-07	PPO	13.7	74.00	PFM 2B PO - VSV servo failure
2023-05-07	PPO	1.6	65.02	PFM 2B - Post HGP Tech 2.0 Tuning

2023-05-14	PFO		4.6	188.00	PFM 2A EFOR - VSV fault
2023-05-14	PFO		4.6	15.79	PFM 2A EFOR - VSV fault
2023-05-14	PFO		4.6	82.00	PFM 2A EFOR - VSV fault
2023-06-01	PMO		2.1	42.80	PFM 2B Task MD - Tuning for low NOx operation
2023-06-02	PMO		1.9	37.69	PFM 2B Task MD - Tuning
2023-06-06	PMO		3.2	30.50	PFM 2D Task MD - Tuning
2023-06-19	PMO		92.5	188.00	PFM 2A MO - MS Isolation Valve Packing Repair
2023-06-26	PFO		1.0	188.00	PFM 2B EFOR - Missed RFC due to CRH bypass valve
2023-06-26	PFO		1.0	20.79	PFM 2B EFOR - Missed RFC due to CRH bypass valve
2023-06-26	PFO		1.0	72.00	PFM 2B EFOR - Missed RFC due to CRH bypass valve
2023-06-30	PMO		97.5	185.00	PFM 2C MO related to PFM ST1 Event Derate - Debris filter failed
2023-06-30	PMO		97.5	1.00	PFM ST1 Event MO - Debris filter failed
2023-06-30	PMO		97.5	1.00	PFM ST1 Event MO - Debris filter failed
2023-06-30	PMO		97.5	1.00	PFM ST1 Event MO - Debris filter failed
2023-06-30	PMO		97.5	1.00	PFM ST1 Event MO - Debris filter failed
2023-06-30	PMO		97.5	3.00	PFM ST1 Event MO - Debris filter failed
2023-06-30	PMO		97.5	2.00	PFM ST1 Event MO - Debris filter failed
2023-07-04	PFO		38.9	188.00	PFM 2F EFOR - Lube oil pump motor and load tunnel high temp
2023-07-04	PFO		38.9	20.79	PFM 2F EFOR - Lube oil pump motor and load tunnel high temp
2023-07-04	PFO		38.9	72.00	PFM 2F EFOR - Lube oil pump motor and load tunnel high temp
2023-07-05	PFO		9.5	185.00	PFM 2C EFOR - Faulty fire protection notifier module
2023-07-05	PFO		9.5	20.79	PFM 2C EFOR - Faulty fire protection notifier module
2023-07-05	PFO		9.5	72.00	PFM 2C EFOR - Faulty fire protection notifier module
2023-07-07	PMO		56.7	188.00	PFM 2F Event MO - Lube Oil Motor Replacement
2023-07-07	PMO		56.7	20.79	PFM 2F Event MO - Lube Oil Motor Replacement
2023-07-07	PMO		56.7	72.00	PFM 2F Event MO - Lube Oil Motor Replacement
2023-07-21	PFO		36.6	8.00	PFM 2A Partial EFOR - CRH blending valve would not open
2023-07-21	PFO		36.6	11.00	PFM 2A Partial EFOR - CRH blending valve would not open
2023-07-21	PFO		36.6	72.00	PFM 2A Partial EFOR - CRH blending valve would not open
2023-07-27	PFO		98.0	188.00	PFM 2E EFOR - T3 bearing oil leak
2023-07-27	PFO		98.0	20.79	PFM 2E EFOR - T3 bearing oil leak
2023-07-27	PFO		98.0	72.00	PFM 2E EFOR - T3 bearing oil leak
2023-08-01	PFO		0.0	185.00	PFM 2C EFOR - High Blade Path Spread Trip
2023-08-01	PFO		0.0	20.79	PFM 2C EFOR - High Blade Path Spread Trip
2023-08-01	PFO		0.0	72.00	PFM 2C EFOR - High Blade Path Spread Trip
2023-08-09	PFO		0.4	188.00	PFM 2B SF - 89ND Exciter Startup Fuse Blown
2023-08-09	PFO		0.4	20.79	PFM 2B SF - 89ND Exciter Startup Fuse Blown
2023-08-09	PFO		0.4	72.00	PFM 2B SF - 89ND Exciter Startup Fuse Blown
2023-08-25	PFO		7.5	188.00	PFM 2A EFOR - Tripped at 120 MW
2023-08-25	PFO		7.5	20.79	PFM 2A EFOR - Tripped at 120 MW
2023-08-25	PFO		7.5	72.00	PFM 2A EFOR - Tripped at 120 MW
2023-08-25	PFO		3.5	188.00	PFM 2F EFOR - IGV position feedback deviation
2023-08-25	PFO		0.3	20.79	PFM 2F EFOR - IGV position feedback deviation
2023-08-25	PFO		0.3	72.00	PFM 2F EFOR - IGV position feedback deviation
2023-08-25	PFO		3.2	20.79	PFM 2F EFOR - IGV position feedback deviation
2023-08-25	PFO		3.2	72.00	PFM 2F EFOR - IGV position feedback deviation
2023-08-25	PFO		8.5	188.00	PFM 2F EFOR - VSV position feedback deviation
2023-08-25	PFO		8.5	20.79	PFM 2F EFOR - VSV position feedback deviation
2023-08-25	PFO		8.5	72.00	PFM 2F EFOR - VSV position feedback deviation
2023-08-25	PFO		1.8	185.00	PFM 2C EFOR - PM2 Valve Stuck 43%

2023-08-25	PFO		1.8	20.79	PFM 2C EFOR - PM2 Valve Stuck 43%
2023-08-25	PFO		1.8	72.00	PFM 2C EFOR - PM2 Valve Stuck 43%
2023-08-27	PMO		22.7	188.00	PFM 2F MO - Replace IGV VSV Cables
2023-08-27	PMO		22.7	20.79	PFM 2F MO - Replace IGV VSV Cables
2023-08-27	PMO		22.7	72.00	PFM 2F MO - Replace IGV VSV Cables
2023-08-27	PFO		1.8	185.00	PFM 2C EFOR - PM2 Valve Stuck
2023-08-27	PFO		1.8	20.79	PFM 2C EFOR - PM2 Valve Stuck
2023-08-27	PFO		1.8	72.00	PFM 2C EFOR - PM2 Valve Stuck
2023-08-27	PFO		28.0	185.00	PFM 2C EFOR - PM2 Valve Stuck
2023-08-27	PFO		28.0	20.79	PFM 2C EFOR - PM2 Valve Stuck
2023-08-27	PFO		28.0	72.00	PFM 2C EFOR - PM2 Valve Stuck
2023-08-29	PFO		4.1	188.00	PFM 2E EFOR - IGV VSV Feedback
2023-08-29	PFO		4.1	20.79	PFM 2E EFOR - IGV VSV Feedback
2023-08-29	PFO		4.1	72.00	PFM 2E EFOR - IGV VSV Feedback
2023-09-01	PMO		49.2	188.00	PFM 2E Event MO - Replace IGV and VSV Cables
2023-09-06	PMO		18.7	185.00	PFM 2C MO - Replace Compressor Discharge TCs
2023-09-12	PFO		0.7	188.00	PFM 2A EFOR - PM GCV valve overshoot due to excessive leakage of SRV
2023-09-13	PPO		431.4	188.00	PFM 2A PO - HGP Tech 2.0 Bearing Replacement
2023-09-18	PPO		288.3	188.00	PFM 2F PO - HGP Tech 2.0
2023-09-18	PPO		288.3	20.79	PFM 2F PO - HGP Tech 2.0
2023-09-18	PPO		288.3	72.00	PFM 2F PO - HGP Tech 2.0
2023-09-30	PFO		12.0	188.00	PFM 2B - Trip due to
2023-10-01	PPO		168.0	188.00	PFM 2A PO - HGP Tech 2.0 Bearing Replacement
2023-10-01	PPO		264.0	188.00	PFM 2F PO - Tech 2.0 HGP
2023-10-01	PPO		168.0	20.79	PFM 2A PO - HGP Tech 2.0 Bearing Replacement
2023-10-01	PPO		168.0	20.79	PFM 2F PO - Tech 2.0 HGP
2023-10-01	PPO		168.0	72.00	PFM 2A PO - HGP Tech 2.0 Bearing Replacement
2023-10-01	PPO		168.0	72.00	PFM 2F PO - Tech 2.0 HGP
2023-10-08	PPO		291.0	188.00	PFM 2A POE - HGP Tech 2.0 Compressor Blade Replace And Blend
2023-10-08	PPO		96.0	20.79	PFM 2F PO - Tech 2.0 HGP
2023-10-08	PPO		96.0	20.79	PFM 2A POE - HGP Tech 2.0 Compressor Blade Replace And Blend
2023-10-08	PPO		96.0	72.00	PFM 2F PO - Tech 2.0 HGP
2023-10-08	PPO		96.0	72.00	PFM 2A POE - HGP Tech 2.0 Compressor Blade Replace And Blend
2023-10-12	PPO		47.2	188.00	PFM 2F POE - Tech 2.0 HGP extended by failed gen entry gasket
2023-10-12	PPO		195.0	20.79	PFM 2A POE - HGP Tech 2.0 Compressor Blade Replace And Blend
2023-10-12	PPO		47.2	20.79	PFM 2F POE - Tech 2.0 HGP extended by failed gen entry gasket
2023-10-12	PPO		195.0	72.00	PFM 2A POE - HGP Tech 2.0 Compressor Blade Replace And Blend
2023-10-12	PPO		47.2	72.00	PFM 2F POE - Tech 2.0 HGP extended by failed gen entry gasket
2023-10-13	PPO		46.6	43.50	PFM 2F PD - Tuning for performance testing
2023-10-13	PPO		46.6	4.79	PFM 2F PD - Tuning for performance testing
2023-10-13	PPO		46.6	16.69	PFM 2F PD - Tuning for performance testing
2023-10-15	PPO		0.0	188.00	PFM 2F POE - Tech 2.0 trip during tuning due to failed GCV breaker
2023-10-15	PPO		0.0	20.79	PFM 2F POE - Tech 2.0 trip during tuning due to failed GCV breaker
2023-10-15	PPO		0.0	72.00	PFM 2F POE - Tech 2.0 trip during tuning due to failed GCV breaker
2023-10-15	PPO		14.8	188.00	PFM 2F POE - Tech 2.0 trip during tuning due to failed GCV breaker
2023-10-15	PPO		14.8	20.79	PFM 2F POE - Tech 2.0 trip during tuning due to failed GCV breaker
2023-10-15	PPO		14.8	72.00	PFM 2F POE - Tech 2.0 trip during tuning due to failed GCV breaker
2023-10-16	PPO		0.0	188.00	PFM 2F POE - Calibrate OBB valve for GE
2023-10-16	PPO		19.8	188.00	PFM 2F POE - Calibrate OBB for GE
2023-10-16	PPO		19.8	20.79	PFM 2F POE - Calibrate OBB for GE
2023-10-16	PPO		19.8	72.00	PFM 2F POE - Calibrate OBB for GE
2023-10-20	PPO		15.0	50.00	PFM 2A PD - Tech 2.0 Test and Tune

2023-10-20	PPO		15.0	5.50	PFM 2A PD - Tech 2.0 Test and Tune
2023-10-20	PPO		15.0	19.10	PFM 2A PD - Tech 2.0 Test and Tune
2023-10-23	PPO		0.0	188.00	PFM 2A POE - Calibrate gas flow sensor for GE
2023-10-23	PPO		0.0	20.79	PFM 2A POE - Calibrate gas flow sensor for GE
2023-10-23	PPO		0.0	72.00	PFM 2A POE - Calibrate gas flow sensor for GE
2023-10-23	PPO		11.9	188.00	PFM 2A POE - Calibrate gas flow sensor for GE
2023-10-23	PPO		11.9	20.79	PFM 2A POE - Calibrate gas flow sensor for GE
2023-10-23	PPO		11.9	72.00	PFM 2A POE - Calibrate gas flow sensor for GE
2023-10-24	PPO		3.5	105.50	PFM 2A PD - Tech 2.0 performance testing
2023-10-24	PPO		3.5	9.09	PFM 2A PD - Tech 2.0 performance testing
2023-10-24	PPO		3.5	32.00	PFM 2A PD - Tech 2.0 performance testing
2023-10-28	PMO		73.6	188.00	PFM 2B MO - HP drum door steam cut
2023-10-28	PMO		73.6	20.79	PFM 2B MO - HP drum door steam cut
2023-10-28	PMO		73.6	72.00	PFM 2B MO - HP drum door steam cut

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Manatee - PM3		PM3-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-01-01	PMO	83.1	50.06	PMT U3 ST Maintenance Derating Extension - Traveling Screen
2023-01-01	PMO	83.1	48.06	PMT U3 ST Maintenance Derating Extension - Traveling Screen
2023-01-01	PMO	83.1	48.06	PMT U3 ST Maintenance Derating Extension - Traveling Screen
2023-01-01	PMO	83.1	133.00	PMT U3 ST Maintenance Derating Extension - Traveling Screen
2023-01-01	PMO	83.1	48.06	PMT U3 ST Maintenance Derating Extension - Traveling Screen
2023-01-06	PMO	70.5	189.00	PMT 3D SNOW - Repair HP Steam Leak
2023-01-12	PMO	87.8	191.00	PMT 3B SNOW - HP Valve Repack and 3B Balance Shot
2023-02-11	PMO	3.6	189.00	PMT U3D Block Snow - ST Seal Oil Valve Replacement
2023-02-11	PMO	2.3	189.00	PMT U3A SNOW - Block ST Seal Oil Valve Replacement
2023-02-12	PMO	0.3	464.00	PMT U3 Block SNOW - ST Seal Oil Valve Replacement
2023-02-12	PMO	0.2	189.00	PMT U3C Block Snow - ST Seal Oil Valve Replacement
2023-02-12	FMO	71.7	1222.00	PMT U3B Block Snow - ST Seal Oil Valve Replacement
2023-02-15	PMO	4.2	464.00	PMT U3 Block SNOW - ST Seal Oil Valve Replacement
2023-02-15	PMO	6.2	189.00	PMT U3A SNOW - Block ST Seal Oil Valve Replacement
2023-02-15	PMO	9.1	191.00	PMT U3B Block Snow - ST Seal Oil Valve Replacement
2023-02-15	PMO	2.8	189.00	PMT U3C Block Snow - ST Seal Oil Valve Replacement
2023-02-15	PFO	4.1	189.00	PMT 3D EFOR - IP Steam Backpressure Control Valve Controller
2023-02-15	PFO	0.9	464.00	PMT U3ST EFOR - 3D IP Steam Backpressure Control Valve controller
2023-03-07	PMO	85.9	189.00	PMT 3C SNOW - FG Transmitter Calibration
2023-03-21	PMO	68.8	191.00	PMT 3B SNOW - HP Relief Fuel Gas Cal
2023-04-11	PMO	58.2	191.00	PMT 3B SNOW - LP Economizer Relief Inlet Valve
2023-05-12	PMO	36.1	189.00	PMT 3A SNOW - FG Transmitter Cal
2023-05-12	PMO	36.1	116.00	PMT 3A SNOW - FG Transmitter Cal
2023-05-15	PFO	91.0	189.00	EFOR PMT 3A - BFP Motor and Seals
2023-05-15	PFO	91.0	101.00	EFOR PMT 3A - BFP Motor and Seals
2023-05-25	PMO	41.6	189.00	PMT 3D SNOW - FG Transmitter Calibration
2023-05-25	PMO	41.6	101.00	PMT 3D SNOW - FG Transmitter Calibration
2023-05-28	PFO	1.7	75.05	PMT 3A Forced Derating - Inlet Bleed Heat valve
2023-05-28	PFO	1.7	62.00	PMT 3A Forced Derating - Inlet Bleed Heat valve
2023-05-28	PFO	0.2	131.49	PMT 3A Forced Derating - Inlet Bleed Heat
2023-05-28	PFO	0.2	99.00	PMT 3A Forced Derating - Inlet Bleed Heat
2023-06-01	PFO	2.9	189.00	PMT 3A EFOR - Late RFC - Haz Gas Card Issue
2023-06-01	PFO	2.9	116.00	PMT 3A EFOR - Late RFC - Haz Gas Card Issue
2023-06-10	PMO	12.6	189.00	PMT 3C- Task MO - Steamer Hydraulic Recharge
2023-06-10	PMO	14.9	191.00	PMT 3B - Task MO - Steamer Hydraulic Recharge
2023-06-10	PMO	2.7	464.00	PMT 3ST Task MO - Hydraulic Recharge
2023-06-13	PFO	3.0	189.00	PMT Unti3A EFOR - HRSG SH Spray valve Failure
2023-06-13	PFO	3.0	116.00	PMT Unti3A EFOR - HRSG SH Spray valve Failure
2023-06-14	PFO	0.1	180.00	PMT 3C - Derating - HRSG Super Heater
2023-06-14	PFO	0.1	99.00	PMT 3C - Derating - IP Startup Drain Failure
2023-06-14	PFO	0.1	61.82	PMT 3C - Derating - IP Startup Drain Failure
2023-06-30	PFO	36.1	189.00	EFOR - PMT 3A- 1002 HRH ISO MOV Failure
2023-06-30	PFO	36.1	463.00	EFOR - PMT 3A- 1002 HRH ISO MOV Failure
2023-07-01	PMO	2.5	189.00	PMT - 3C - Task MO- 3A HRH Isolation Valve
2023-07-01	PFO	1.0	189.00	EFOR - PMT 3A- 1002 HRH ISO MOV Failure
2023-07-01	PMO	0.8	189.00	PMT - 3D - Task MO - 3A HRH Isolation Valve

2023-07-01	PMO		0.6	191.00	PMT - 3B - Task MO - 3A HRH Valve
2023-07-01	FMO		3.4	1222.00	PMT - ST - Task MO- 3A HRH Isolation Valve
2023-07-02	PMO		4.4	191.00	PMT - 3B - Task MO - 3A HRH Valve
2023-07-02	PMO		6.4	189.00	PMT - 3C - Task MO- 3A HRH Isolation Valve
2023-07-02	PMO		0.6	189.00	PMT - 3D - Task MO - 3A HRH Isolation Valve
2023-07-02	PMO		3.4	464.00	PMT - ST - Task MO- 3A HRH Isolation Valve
2023-07-22	PFO		3.9	189.00	PMT - 3A EFOR - Fire Protection System
2023-07-22	PFO		3.9	348.00	PMT - 3A EFOR - Fire Protection System
2023-08-05	PMO		7.9	189.00	PMT 3A MOF - Water Wash Drain
2023-08-05	PMO		7.9	348.00	PMT 3A MOF - Water Wash Drain
2023-08-05	PMO		2.7	189.00	PMT - 3A - MOF - Water Wash Drain
2023-08-18	PMO		62.7	189.00	PMT 3D - MOF - BFP Seals Strainer and IP SH Drain
2023-08-18	PMO		62.7	348.00	PMT 3D - MOF - BFP Seals Strainer and IP SH Drain
2023-08-25	PFO		3.1	191.00	EFOR - PMT 3B Trip due too GCV Deviation
2023-08-25	PFO		3.1	348.00	EFOR - PMT 3B Trip due too GCV Deviation
2023-09-02	PFO		4.7	191.00	EFOR- PMT 3B Trip due to High Vibration
2023-09-02	PFO		4.7	348.00	EFOR- PMT 3B Trip due to High Vibration
2023-09-10	PMO		30.1	189.00	MOF- PMT 3C SRV Replacement
2023-09-10	PMO		30.1	348.00	MOF- PMT 3C SRV Replacement
2023-09-22	PFO		1.7	191.00	PMT 3B- Late RFC due to Non-Deferable Maintenance
2023-09-22	PFO		1.7	348.00	PMT 3B- Late RFC due to Non-Deferable Maintenance
2023-09-25	PFO		3.1	189.00	PMT 3D - SF due to BFP Motor Trip
2023-09-25	PFO		3.1	348.00	PMT 3D - SF due to BFP Motor Trip
2023-09-26	PFO		0.0	189.00	PMT 3C EFOR due to Flame Scanner Fault
2023-09-26	PFO		0.0	348.00	PMT 3C EFOR due to Flame Scanner Fault
2023-09-28	PFO		1.4	189.00	PMT 3C - Late RFC due to Flame Scanner Replacement
2023-09-28	PFO		1.4	348.00	PMT 3C - Late RFC due to Flame Scanner Replacement
2023-10-01	PFO		0.9	189.00	PMT 3D- SF due to Haz Gas
2023-10-01	PFO		0.9	348.00	PMT 3D- SF due to Haz Gas
2023-10-02	PFO		1.3	189.00	PMT 3D - Late RFC due Haz Gas Sensor Replacement
2023-10-02	PFO		1.3	348.00	PMT 3D - Late RFC due Haz Gas Sensor Replacement
2023-10-06	PFO		1.2	189.00	PMT 3C- Late RFC due to HP Stop Check Valve Sticking
2023-10-06	PFO		1.2	348.00	PMT 3C- Late RFC due to HP Stop Check Valve Sticking
2023-10-08	PFO		0.9	189.00	PMT 3D- Late RFC Due to BFP Trip
2023-10-08	PFO		0.9	348.00	PMT 3D- Late RFC Due to BFP Trip

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Martin - PM8		PM8-08		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-01-14	PFO	2.7	189.00	EFOR 8D 89-ND Switch Fail to Close
2023-01-24	PFO	0.5	464.00	EFOR Unit 8 ST Trip
2023-01-26	PMO	22.2	187.00	SNOW: PMR Unit 8 Block Repair Motive Steam Valve
2023-01-27	FMO	48.0	1216.00	SNOW: 8ST HRB-ACV-0008 Motive Steam Valve
2023-01-29	PMO	8.2	187.00	SNOW: PMR Unit 8 Block Repair Motive Steam Valve
2023-01-29	PMO	8.3	187.00	SNOW: 8ST HRB-ACV-0008 Motive Steam Valve
2023-02-03	PFO	13.3	187.00	EFOR 8A IGV Trip
2023-02-09	PFO	0.0	183.00	EFOR 8D Runback high RH Temp
2023-02-10	PFO	0.6	187.00	EFOR 8A Trip Steam Pressure Low
2023-02-12	PFO	1.7	189.00	EFOR 8D Runback LF Testing
2023-02-21	PFO	1.6	189.00	EFOR PMR 8D BFP Recirc Valve
2023-02-22	PFO	3.5	187.00	EFOR PMR 8B SRV Leak-by
2023-03-10	PMO	20.5	187.00	SNOW: PMR 8B SRV Replacement
2023-03-15	PMO	56.8	189.00	SNOW: PMR 8D CT Exhaust and Lift Oil
2023-04-09	PFO	3.2	189.00	EFOR: PMR 8C Runback High Superheater 3 Temperatures
2023-04-16	PPO	337.2	189.00	PO: PMR 8C Reliability Outage
2023-04-16	PPO	337.2	114.50	PO: PMR 8C Reliability Outage
2023-04-20	PMO	61.2	187.00	SNOW: PMR 8A
2023-04-25	PFO	0.3	187.00	EFOR: 8A CT Trip During LF Testing Lo Lo Atomizing Air Alarm
2023-04-25	PFO	0.3	189.00	EFOR: 8D CT Trip During LF Testing Lo Lo Atomizing Air Alarm
2023-05-01	PPO	232.6	189.00	PO: PMR 8C Planned Outage
2023-05-01	PPO	232.6	114.50	PO: PMR 8C Planned Outage
2023-05-03	PFO	3.1	187.00	EFOR: PMR 8B BFP Lube Oil Intrusion
2023-05-03	PFO	3.1	114.50	EFOR: PMR 8B BFP Lube Oil Intrusion
2023-05-12	PPO	0.0	189.00	PO: PMR 8C Tuning
2023-05-12	PPO	0.0	114.50	PO: PMR 8C Tuning
2023-05-12	PPO	21.7	189.00	POE: PMR 8C Tuning
2023-05-12	PPO	21.7	114.50	POE: PMR 8C Tuning
2023-05-15	PPO	0.0	189.00	PO: PMR 8C Tuning
2023-05-15	PPO	0.0	114.50	PO: PMR 8C Tuning
2023-05-15	PPO	1.4	189.00	POE: PMR 8C Tuning
2023-05-15	PPO	1.4	114.50	POE: PMR 8C Tuning
2023-05-17	PFO	47.6	187.00	EFOR: PMR 8A Cracked HRH Header
2023-05-17	PFO	47.6	114.50	EFOR: PMR 8A Cracked HRH Header
2023-05-20	PFO	1.6	189.00	EFOR: PMR 8C VSV LVDT Cable
2023-05-20	PFO	1.6	114.50	EFOR: PMR 8C VSV LVDT Cable
2023-05-24	PMO	143.0	189.00	SNO: PMR 8D Reliability Outage
2023-05-24	PMO	143.0	114.50	SNO: PMR 8D Reliability Outage
2023-05-31	PFO	92.3	189.00	EFOR: PMR 8D Breaker Fire
2023-05-31	PFO	0.7	232.00	EFOR: PMR 8D Breaker Fire
2023-05-31	PFO	92.0	189.00	EFOR: PMR 8C Breaker Fire
2023-05-31	PFO	92.0	116.00	EFOR: PMR 8C Breaker Fire
2023-05-31	PFO	2.1	464.00	EFOR: PMR 8ST SU due to Breaker Fire
2023-05-31	PFO	2.1	232.00	EFOR: PMR 8D Breaker Fire
2023-05-31	PFO	1.9	187.00	EFOR: PMR 8A SU due to Breaker Fire
2023-05-31	PFO	89.4	232.00	EFOR: PMR 8D Breaker Fire
2023-06-03	PMO	87.1	189.00	MO: PMR 8C Switchgear 2
2023-06-03	PMO	87.1	189.00	MO: PMR 8D Switchgear 2
2023-06-03	PMO	87.1	116.00	MO: PMR 8C Switchgear 2
2023-06-03	PMO	87.1	116.00	MO: PMR 8D Switchgear 2
2023-06-13	PFO	3.9	187.00	EFOR: PMR 8A CT Fail to start due to low atomizing air purge pressure
2023-06-13	PFO	3.9	116.00	EFOR: PMR 8A CT Fail to start due to low atomizing air purge pressure
2023-06-22	PMO	16.5	189.00	MO: PMR 8C Exhaust Frame Blower Motors Replacement
2023-06-22	PMO	16.5	116.00	MO: PMR 8C Exhaust Frame Blower Motors Replacement
2023-07-01	PMO	24.0	187.00	MO: PMR 8A Reliability Outage

2023-07-01	PMO		24.0	116.00	MO: PMR 8A Reliability Outage
2023-07-04	PFO		2.2	187.00	EFOR: PMR 8A LF Failed Transfer AA Low DP Trip
2023-07-04	PFO		2.2	116.00	EFOR: PMR 8A LF Failed Transfer AA Low DP Trip
2023-07-06	PFO		1.5	464.00	EFOR: PMR 8ST Lightning Strike - Impacts: 8C and 8D
2023-07-06	PFO		1.5	92.50	EFOR: PMR 8ST Lightning Strike - Impacts: 8C and 8D
2023-07-06	PFO		1.5	92.50	EFOR: PMR 8ST Lightning Strike - Impacts: 8C and 8D
2023-07-06	PFO		1.5	94.50	EFOR: PMR 8ST Lightning Strike - Impacts: 8C and 8D
2023-07-06	PFO		1.5	94.50	EFOR: PMR 8ST Lightning Strike - Impacts: 8C and 8D
2023-07-12	PFO		0.9	187.00	EFOR: PMR 8A Atomizing Air low dP Trip
2023-07-12	PFO		0.9	116.00	EFOR: PMR 8A Atomizing Air low dP Trip
2023-07-13	PFO		0.6	187.00	EFOR: PMR 8A Atomizing Air
2023-07-13	PFO		0.6	116.00	EFOR: PMR 8A Atomizing Air
2023-07-19	PFO		69.0	187.00	EFOR: PMR 8A Atomizing Air Cooler Leak
2023-07-19	PFO		69.0	116.00	EFOR: PMR 8A Atomizing Air Cooler Leak
2023-07-19	PFO		1.8	187.00	EFOR: PMR 8B Manual shutdown loss of CCW
2023-07-19	PFO		1.8	116.00	EFOR: PMR 8B Manual shutdown loss of CCW
2023-07-26	PFO		0.5	187.00	EFOR: PMR 8A SU Failure Low A APR
2023-07-26	PFO		0.5	116.00	EFOR: PMR 8A SU Failure Low A APR
2023-07-26	PMO		101.6	187.00	MO: PMR 8A Atomizing Air Reliability Outage
2023-07-26	PMO		101.6	116.00	MO: PMR 8A Atomizing Air Reliability Outage
2023-08-15	PMO		26.7	187.00	MO: PMR 8A Atomizing Air Troubleshooting
2023-08-15	PMO		26.7	116.00	MO: PMR 8A Atomizing Air Troubleshooting
2023-08-17	PFO		0.3	187.00	EFOR: PMR 8B Trip on BFP minimum flow
2023-08-17	PFO		0.3	116.00	EFOR: PMR 8B Trip on BFP minimum flow
2023-09-15	PMO		85.0	187.00	MO: PMR 8B Reliability Outage
2023-09-15	PMO		85.0	116.00	MO: PMR 8B Reliability Outage
2023-09-18	PMO		8.9	187.00	MOF: PMR 8B HRH sky vent
2023-09-18	PMO		8.9	116.00	MOF: PMR 8B HRH sky vent
2023-09-21	PMO		72.0	189.00	MO: PMR 8D Lube Oil Heat Exchanger Plate Replacement
2023-09-21	PMO		72.0	96.00	MO: PMR 8D Lube Oil Heat Exchanger Plate Replacement
2023-10-05	PFO		0.3	187.00	EFOR: PMR 8A LF Testing
2023-10-05	PFO		0.3	116.00	EFOR: PMR 8A LF Testing
2023-10-07	PFO		0.1	189.00	EFOR: PMR 8C High NOx
2023-10-07	PFO		0.1	84.52	EFOR: PMR 8C High NOx
2023-10-15	PMO		48.0	189.00	MO: PMR 8D generator alignment
2023-10-15	PMO		48.0	96.00	MO: PMR 8D generator alignment
2023-10-17	PPO		313.5	189.00	PO: 8D HGP Fall 2023
2023-10-17	PPO		313.1	463.00	PO: 8D HGP Fall 2023
2023-10-24	PFO		0.2	187.00	EFOR: PMR 8A HRH Bypass valve
2023-10-24	PFO		0.2	116.00	EFOR: PMR 8A HRH Bypass valve
2023-10-30	PMO		1.5	189.00	MO: PMR Block 8. 8C. Reassign IP Addresses
2023-10-30	PMO		0.3	464.00	MO: PMR Block 8. 8ST. Reassign IP Addresses
2023-10-30	PPO		46.8	463.00	PO: 8D HGP Fall 2023
2023-10-30	PMO		0.2	187.00	MO: PMR Block 8. 8B. Reassign IP Addresses
2023-10-30	FMO		46.5	1216.00	MO: PMR Block 8. 8A. Reassign IP Addresses

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Okeechobee Energy Center - POK				
				POK-01
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-01-02	PFO	13.9	342.00	CT 1-3 Tripped on Hot Reheat Valve not Providing Feedback To DCS
2023-01-07	PMO	13.1	342.00	MOF - Unit 1-2 Planned Liquid Fuel Testing
2023-01-08	PMO	15.5	342.00	MOF - Unit 1-2 Planned Liquid Fuel Testing
2023-01-09	PFO	0.5	342.00	EFOR Unit 1-3 Auxiliaries Exhaust Frame Cooling Shutdown.
2023-01-09	PFO	0.5	157.00	EFOR Unit 1-3 Auxiliaries Exhaust Frame Cooling Shutdown.
2023-01-15	PFO	9.6	514.00	EFOR - failed thermocouple on the IP turbine system tripped the unit.
2023-01-19	PMO	90.2	342.00	SNOW: POK 1-2
2023-02-27	PPO	797.2	342.00	POK 11 HGP Planned Outage Coating of CT Compressor
2023-02-27	PPO	717.9	171.00	POK 11 HGP Planned Outage Coating of CT Compressor
2023-03-29	PMO	49.3	514.00	ST Maintenance Outage MOF Mad 11 Bearing inspection and repairs.
2023-03-29	PPO	131.3	171.00	POK 11 HGP Planned Outage Coating of CT Compressor
2023-04-01	PMO	30.0	514.00	ST Maintenance Outage MOF Mad 11 Bearing Inspection and Repairs
2023-04-02	FMO	52.0	1540.00	Unit 1-3 MOF Maintenance Outage
2023-04-04	FMO	75.6	1540.00	Unit 1-1 MOF Maintenance Outage
2023-04-07	PMO	91.9	342.00	Unit 1-3 MOF Maintenance Outage
2023-04-07	PMO	96.9	514.00	ST Maintenance Outage MOF Mad 11 Bearing Inspection and Repairs
2023-04-07	PMO	302.2	342.00	Unit 1-1 MOF Maintenance Outage
2023-04-11	PFO	0.9	342.00	EFOR POK-13 High HP attemperator temperature.
2023-04-20	PMO	3.7	342.00	Unit 1-1 MOF
2023-06-02	PFO	3.7	342.00	EFOR - High combustor temperature unit trip during liquid fuel testing.
2023-06-24	PMO	31.9	342.00	MOF Unit 1-1 Flame scanner D replacement.
2023-06-27	PFO	4.9	342.00	EFOR - Unit 1-2 Trip Boiler Feed Pump.
2023-06-30	PFO	3.3	342.00	EFOR - Unit 1-1 trip on High HP desuperheater temperature.
2023-07-14	PFO	162.5	342.00	EFOR Unit 1-2 Inlet Bleed Heat Flex Hose Liberation
2023-07-14	PFO	162.5	164.00	EFOR Unit 1-2 Inlet Bleed Heat Flex Hose Liberation
2023-08-01	PFO	1.4	342.00	EFOR - Unit 1-1 Trip due to HP WTR Drum LVL LOW
2023-08-22	PMO	99.6	342.00	SNOW CT 1-1 IBH flex hose replacement
2023-08-22	PMO	99.6	165.00	SNOW CT 1-1 IBH flex hose replacement
2023-09-01	PMO	84.4	342.00	SNOW CT 1-2 IBH flex hose replacement
2023-09-01	PMO	84.4	159.00	SNOW CT 1-2 IBH flex hose replacement
2023-09-07	PMO	161.8	342.00	SNOW CT 1-3 IBH flex hose replacement.
2023-09-07	PMO	161.8	164.00	SNOW CT 1-3 IBH flex hose replacement.
2023-09-25	PFO	1.0	49.00	Unplanned Derating Lightning strike in gas yard.
2023-09-25	PFO	1.0	42.00	Unplanned Derating Lightning strike in gas yard.
2023-09-25	PFO	1.0	42.00	Unplanned Derating Lightning strike in gas yard.
2023-09-25	PFO	1.0	42.00	Unplanned Derating Lightning strike in gas yard.
2023-09-25	PFO	21.1	342.00	EFOR CT 1-1 Gas Control Valve GCV-4 Position Error
2023-09-25	PFO	21.1	164.00	EFOR CT 1-1 Gas Control Valve GCV-4 Position Error
2023-09-29	PFO	24.7	342.00	EFOR Unit 1-1 Gas Control Valve GVC-4 Drive Current Fault.
2023-09-29	PFO	24.7	164.00	EFOR Unit 1-1 Gas Control Valve GVC-4 Drive Current Fault.
2023-10-14	PMO	306.6	342.00	SNOW Unit 1-1 Hydrogen Tie-In.
2023-10-14	PMO	306.6	167.00	SNOW Unit 1-1 Hydrogen Tie-In.
2023-10-27	PFO	7.1	342.00	EFOR Unit 1-1 Trip DSH Outlet Temp High

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Port Everglades - PPE			PPE-05	
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-01-01	PMO	23.5	269.00	53 MOF - HP Economizer Tube Leak Repairs
2023-01-01	PMO	23.5	112.00	53 MOF - HP Economizer Tube Leak Repairs
2023-01-06	PMO	46.0	269.00	53 MOF - Borescope Inspection
2023-01-06	PMO	46.0	113.00	53 MOF - Borescope Inspection
2023-01-11	PMO	140.1	252.00	51 MOF - Liquid Fuel Repairs and Tuning
2023-01-11	PMO	140.1	112.00	51 MOF - Liquid Fuel Repairs and Tuning
2023-01-15	PFO	6.8	252.00	52 Forced Outage - GV4 Cooling Air Low
2023-01-15	PFO	6.8	112.00	52 Forced Outage - GV4 Cooling Air Low
2023-01-15	PFO	1.4	252.00	52 SUF - GV4 Cooling Air Low
2023-01-15	PFO	1.4	112.00	52 SUF - GV4 Cooling Air Low
2023-01-18	PMO	2.5	252.00	51 MOF - Liquid Fuel Repairs and Tuning
2023-01-18	PMO	2.5	112.00	51 MOF - Liquid Fuel Repairs and Tuning
2023-01-18	PMO	0.8	252.00	51 MOF - Liquid Fuel Repairs and Tuning
2023-01-18	PMO	0.8	112.00	51 MOF - Liquid Fuel Repairs and Tuning
2023-01-30	PFO	3.2	269.00	53 Forced Outage - CEMS Analyzer Equipment Failure
2023-01-30	PFO	3.2	112.00	53 Forced Outage - CEMS Analyzer Equipment Failure
2023-01-30	PFO	6.3	269.00	53 SUF - TOT 10 Bad Quality
2023-01-30	PFO	6.3	112.00	53 SUF - TOT 10 Bad Quality
2023-02-01	PMO	43.0	252.00	51 MOF - HP Feedwater Stop Valve Repair
2023-02-16	PFO	1.4	252.00	51 SUF - SFC Trip
2023-02-16	PFO	1.4	112.00	51 SUF - SFC Trip
2023-02-24	PFO	6.6	252.00	51 Forced Outage - TOT 8 Failure
2023-02-24	PFO	6.6	112.00	51 Forced Outage - TOT 8 Failure
2023-02-28	PFO	1.9	405.00	50 Forced Outage - High IP Exhaust Temperature Unblended CRH HRH
2023-03-05	PFO	2.0	269.00	53 Forced Outage - HRH Bypass PCV Leakby
2023-03-05	PFO	2.0	112.00	53 Forced Outage - HRH Bypass PCV Leakby
2023-03-05	PPO	143.5	269.00	53 POF - Spring Outage
2023-03-05	PPO	141.7	141.00	53 POF - Spring Outage
2023-03-10	PMO	2.8	252.00	51 Block SNOW
2023-03-11	PMO	1.8	405.00	50 ST - Block SNOW
2023-03-11	PPO	330.9	141.00	53 POF - Spring Outage
2023-03-11	FMO	323.1	1178.00	52 Block SNOW
2023-03-24	PMO	5.9	405.00	50 ST - Block SNOW
2023-03-24	PMO	122.5	252.00	51 Block SNOW
2023-03-24	PPO	357.0	269.00	53 POF - Spring Outage
2023-03-24	PPO	351.0	141.00	53 POF - Spring Outage
2023-04-15	PFO	0.8	269.00	53 SUF - CT SGC Trip on SFC
2023-04-25	PMO	25.4	252.00	51 SNOW - Ammonia Blower
2023-05-03	PFO	3.0	252.00	52 SUF - BAB36 Position Indicator Failure
2023-05-03	PFO	0.3	269.00	53 EFOR - LLCO System Issue
2023-05-03	PFO	0.3	142.00	53 EFOR - LLCO System Issue
2023-05-11	PFO	2.9	405.00	50 ST EFOR - Trip On Low Vacuum HP
2023-05-22	PMO	0.5	269.00	53 - LF Testing Trip
2023-05-26	PFO	2.8	252.00	51 SUF - GV2 Solenoid Failure
2023-06-05	PMO	33.0	252.00	51 SNOW - Ammonia Blower Re-Alignment
2023-06-10	PFO	0.6	252.00	PPE 52 SUF - SFC failed to release
2023-06-19	PMO	36.6	252.00	PPE 52 SNOW - Control Oil Accumulator
2023-06-29	PFO	4.9	269.00	53 SUF - High Blade Path Spread
2023-07-02	PFO	3.6	252.00	52 SUF - ESV Not Open
2023-07-02	PFO	3.6	112.00	52 SUF - ESV Not Open
2023-07-05	PMO	0.0	252.00	51 LF Transfer
2023-07-06	PFO	9.0	252.00	51 SUF - TOT 8 Failure
2023-07-06	PFO	9.0	112.00	51 SUF - TOT 8 Failure
2023-08-18	PMO	47.7	269.00	53 SNOW - Aux Lube Oil Motor Replacement
2023-08-18	PMO	47.7	135.00	53 SNOW - Aux Lube Oil Motor Replacement
2023-08-23	PFO	0.9	252.00	51 - LF Swap Trip
2023-08-26	PMO	51.6	252.00	51 SNOW - Condenser Water box Leak
2023-08-26	PMO	51.6	135.00	51 SNOW - Condenser Water box Leak
2023-09-01	PMO	27.7	252.00	52 MOF - Condenser Water Box Leak
2023-09-01	PMO	27.7	135.00	52 MOF - Condenser Water Box Leak
2023-09-06	PFO	5.2	405.00	50 ST Trip - Loss of Vacuum
2023-09-06	PFO	5.2	269.00	53 Forced Outage - Due to ST Trip

2023-09-24	PMO	52.0	252.00	52 SNOW - R1 Borescope Inspection
2023-09-24	PMO	52.0	135.00	52 SNOW - R1 Borescope Inspection
2023-10-13	PFO	4.0	252.00	52 Forced Outage - VGV2 Failure
2023-10-13	PFO	4.0	135.00	52 Forced Outage - VGV2 Failure
2023-10-27	PFO	7.5	252.00	52 Runback - VGV2 Double Fault
2023-10-27	PFO	7.5	135.00	52 Runback - VGV2 Double Fault

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Riviera - PRV		PRV-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-01-02	PFO	2.0	269.00	PRV-Unit 53-Start up failure-Bleed off Valve
2023-01-02	PFO	2.0	161.00	PRV-Unit 53-Start up failure-Bleed off Valve
2023-01-05	PMO	115.7	269.00	PRV-53-Event MOF-Turning Gear
2023-01-05	PMO	115.7	161.00	PRV-53-Event MOF-Turning Gear
2023-01-07	PMO	16.8	269.00	prv-53-Event MOF-Flame Scanner
2023-01-07	PMO	16.8	161.00	prv-53-Event MOF-Flame Scanner
2023-01-27	PFO	17.3	269.00	PRV-Unit 52-Start up failure-blade path spread
2023-01-27	PFO	17.3	161.00	PRV-Unit 52-Start up failure-blade path spread
2023-02-14	PFO	2.8	53.04	PRV-51- HRH Blending Valve Failed To Open
2023-02-14	PFO	2.8	92.00	PRV-51- HRH Blending Valve Failed To Open
2023-02-17	PMO	35.0	269.00	PRV 53 - Event MOF -NG Pressure Transmitter
2023-02-17	PMO	35.0	153.00	PRV 53 - Event MOF -NG Pressure Transmitter
2023-02-18	PMO	22.0	251.00	PWC 3B - Event MOF - Test HRH Blending Valve
2023-02-18	PMO	22.0	83.00	PWC 3B - Event MOF - Test HRH Blending Valve
2023-03-04	PMO	86.9	269.00	PRV 53 - Event MOF -FG Filter replacement
2023-03-04	PMO	86.9	157.00	PRV 53 - Event MOF -FG Filter replacement
2023-03-29	PFO	0.5	269.00	PRV-53 Tripped on fuel oil startup testing
2023-03-29	PFO	0.5	158.00	PRV-53 Tripped on fuel oil startup testing
2023-03-31	PFO	27.8	269.00	PRV-53 CT Tripped from 1334 RPM during SU due to a combustor outlet d
2023-03-31	PFO	27.8	157.00	PRV-53 CT Tripped from 1334 RPM during SU due to a combustor outlet d
2023-04-20	PFO	0.8	269.00	PRV-53 -Start up failure during Fuel Oil testing
2023-04-20	PFO	0.8	157.00	PRV-53 -Start up failure during Fuel Oil testing
2023-04-25	PMO	86.2	269.00	PRV-52-MOF Event-FG FILTER
2023-04-25	PMO	86.2	157.00	PRV-52-MOF Event-FG FILTER
2023-05-04	PFO	2.0	251.00	PRV 51-Startup failure during purge and SFC did not pick up the unit
2023-05-04	PFO	2.0	157.00	PRV 51-Startup failure during purge and SFC did not pick up the unit
2023-05-04	PMO	300.8	251.00	PRV51-MAINTENANCE-ANNUAL-C5A122
2023-05-04	PMO	300.8	157.00	PRV51-MAINTENANCE-ANNUAL-C5A122
2023-05-17	PMO	73.9	251.00	PRV51-MAINTENANCE-ANNUAL-C5A122-Ext
2023-05-17	PMO	73.9	157.00	PRV51-MAINTENANCE-ANNUAL-C5A122-Ext
2023-06-23	PMO	2.1	269.00	PRV-53-Event MOF- HRH Block Valve packing leak
2023-06-23	PMO	0.9	251.00	PRV-51-Event MOF- HRH Block Valve packing leak
2023-06-23	PMO	0.3	486.00	PRV-50-Event MOF- 53 HRH Block Valve packing leak
2023-06-23	FMO	41.8	1275.00	PRV-52-Event MOF- HRH Block Valve packing leak
2023-06-25	PMO	16.6	269.00	PRV-52-Event MOF- HRH Block Valve packing leak
2023-06-25	PMO	4.4	486.00	PRV-50-Event MOF- 53 HRH Block Valve packing leak
2023-06-25	PMO	20.8	269.00	PRV-53-Event MOF- HRH Block Valve packing leak
2023-06-26	PFO	1.5	269.00	PRV-52-Startup Failure due to fuel line no purge prior starting
2023-06-26	PFO	1.5	161.00	PRV-52-Startup Failure due to fuel line no purge prior starting
2023-07-31	PMO	38.6	251.00	PRV-51-VGV2 FB1 Kubler Replacement
2023-07-31	PMO	38.6	161.00	PRV-51-VGV2 FB1 Kubler Replacement
2023-08-12	PMO	26.5	269.00	PRV-52-Event MOF-AIG and Vaporizer cleaning
2023-08-12	PMO	26.5	162.00	PRV-52-Event MOF-AIG and Vaporizer cleaning
2023-09-05	PMO	49.6	269.00	PRV-53-Repair blowdown tank piping and duct burner valve replacement
2023-09-05	PMO	49.6	162.00	PRV-53-Repair blowdown tank piping and duct burner valve replacement
2023-10-17	PFO	7.4	269.00	PRV-52-Forced Outage due to lift oil tubing damaged
2023-10-17	PFO	7.4	162.00	PRV-52-Forced Outage due to lift oil tubing damaged
2023-10-31	PMO	1.2	251.00	PRV 51 - Event MOF - HP to cooling steam line leaks.
2023-10-31	PMO	1.2	162.00	PRV 51 - Event MOF - HP to cooling steam line leaks.

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: St. Lucie Nuclear - PSL		PSL-01		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-07-13	PFO	311.7	9.85	UEL SL1-31 1B Drain Cooler Down Power
2023-07-26	PPO	86.4	232.02	PEL SL1-31 1B Drain Cooler Repair

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: St. Lucie Nuclear - PSL		PSL-02		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-02-16	PPO	6.9	171.58	U2 PEL Down Power to 67% MSSV Testing
2023-02-17	PPO	16.1	324.34	U2 PEL MSSV Testing
2023-02-17	PPO	4.0	534.45	U2 PEL Down Power to Start SL2-27
2023-02-18	PO	264.0	986.00	U2 PEL SL2-27 Feb
2023-03-01	PO	427.8	986.00	Unit 2 SL2-27 March
2023-03-18	PPO	91.8	207.52	U2 PEL SL2-27 Up Power
2023-06-30	PFO	7.3	163.22	UEL SL2-27 Seal Oil Cooler Valve SH22503

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Turkey Point Nuclear - PTN		PTN-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-04-06	PPO	27.5	477.07	PTN Unit 3 planned power reduction for cycle 33 refueling outage
2023-04-08	PO	552.0	837.00	PTN Unit 3 planned refueling outage for Cycle 33
2023-05-01	PO	162.2	837.00	PTN Unit 3 planned refueling outage for Cycle 33-finish
2023-05-07	PPO	99.9	339.62	PTN Unit 3 planned power ascension following refueling outage
2023-08-04	FFO	41.8	837.00	U3 Manual Reactor Trip for 3C FRV Failure
2023-08-06	PFO	15.2	375.09	U3 Power Ascension from 3C FRV FO
2023-09-22	FFO	29.0	837.00	PTN3 Unplanned Outage due to SWYD Lightning Strike
2023-09-23	PFO	10.2	412.57	PTN3 Power Ascension following Generator Lockout FO
2023-10-24	FFO	24.9	837.00	PTN3 Unplanned Outage due to RPS Event
2023-10-25	PFO	22.1	193.04	PTN3 Power Ascension following RPS Event FO

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Turkey Point Nuclear - PTN		PTN-04		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-06-30	PFO	8.0	192.27	PTN4 Unplanned Downpower for Heater Drain Repairs
2023-07-01	PFO	37.5	189.22	PTN4 Unplanned Downpower For Heater Drain Repairs July
2023-09-28	PPO	28.0	498.34	PTN4 Planned downpower for entry into refueling outage PT4-34
2023-09-30	PO	24.0	844.00	PTN4 planned refueling outage PT4-34
2023-10-01	PO	744.0	844.00	PTN4 Planned Refueling Outage PT4-34 October

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: West County Energy Center - PWC				
				PWC-01
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-01-02	PFO	1.4	238.00	PWC 1B CT- Tripped on Condenser protection
2023-01-02	PFO	1.4	160.00	PWC 1B CT- Tripped on Condenser protection
2023-01-03	PFO	5.7	238.00	PWC 1B-START UP FAILURE-BFP HP FLOW LOW LOW TRIP
2023-01-03	PFO	5.7	160.00	PWC 1B-START UP FAILURE-BFP HP FLOW LOW LOW TRIP
2023-01-04	PFO	14.6	238.00	PWC 1C SU Failure BFP Recirculation Valve
2023-01-04	PFO	14.6	160.00	PWC 1C SU Failure BFP Recirculation Valve
2023-01-14	PFO	2.4	238.00	PWC 1A-Force Outage-Cold Reheat Bypass Control Valve
2023-01-14	PFO	2.4	160.00	PWC 1A-Force Outage-Cold Reheat Bypass Control Valve
2023-01-14	PMO	6.3	88.00	PWC 1A - Event MOF - Liquid Fuel Transfer
2023-01-14	PMO	6.3	205.63	PWC 1A - Event MOF - Liquid Fuel Transfer
2023-01-15	PFO	1.8	238.00	PWC 1A-Force Outage-Cold Reheat Bypass Control Valve
2023-01-15	PFO	1.8	160.00	PWC 1A-Force Outage-Cold Reheat Bypass Control Valve
2023-01-16	PMO	1.9	238.00	PWC-1A- 1 and 2 Gas Yard Maintenance Outage
2023-01-16	PMO	1.7	160.00	PWC-1A- 1 and 2 Gas Yard Maintenance Outage
2023-01-16	PMO	1.2	238.00	PWC-1B- 1 and 2 Gas Yard Outage
2023-01-16	PMO	1.0	82.00	PWC-1B- 1 and 2 Gas Yard Outage
2023-01-16	PMO	0.2	487.00	PWC-1ST- 1 and 2 Gas Yard Outage
2023-01-16	PMO	176.6	160.00	PWC-1A- 1 and 2 Gas Yard Maintenance Outage
2023-01-16	PMO	176.6	82.00	PWC-1B- 1 and 2 Gas Yard Outage
2023-01-16	FMO	171.4	1201.00	PWC-1C- 1 and 2 Gas Yard Outage
2023-01-23	PMO	4.9	238.00	PWC-1A- 1 and 2 Gas Yard Maintenance Outage
2023-01-23	PMO	4.9	238.00	PWC-1B- 1 and 2 Gas Yard Outage
2023-01-23	PMO	6.3	487.00	PWC-1ST- 1 and 2 Gas Yard Outage
2023-01-31	PFO	3.4	238.00	PWC-1B-BFP RECIRC MALFUNCTION RESULTED IN CT TRIP
2023-01-31	PFO	3.4	160.00	PWC-1B-BFP RECIRC MALFUNCTION RESULTED IN CT TRIP
2023-02-03	PFO	14.8	238.00	PWC-1A-SU Failure-Generator NGR switch
2023-02-03	PFO	14.8	160.00	PWC-1A-SU Failure-Generator NGR switch
2023-02-04	PMO	89.2	238.00	PWC 1A-Maintenance Outage-Swinging LP Drum Level
2023-02-04	PMO	89.2	166.00	PWC 1A-Maintenance Outage-Swinging LP Drum Level
2023-02-28	PPO	1224.7	238.00	PWC-1B-ROTOR-GENERATOR MAJOR
2023-02-28	PPO	1224.7	162.00	PWC-1B-ROTOR-GENERATOR MAJOR
2023-03-16	PMO	32.1	238.00	PWC-1A-Troubleshoot Water Injection Valves
2023-03-16	PMO	32.1	1.00	PWC-1A-Troubleshoot Water Injection Valves
2023-04-02	PFO	2.9	58.00	PWC-1A- Derating Force Outage-HRH Blending Valve
2023-04-02	PFO	2.9	34.67	PWC-1A- Derating Force Outage-HRH Blending Valve
2023-04-22	PPO	7.8	238.00	PWC-1B-ROTOR-GENERATOR MAJOR
2023-04-22	PPO	7.8	162.00	PWC-1B-ROTOR-GENERATOR MAJOR
2023-04-24	PMO	56.8	238.00	PWC 1B-Event MOF Post Outage shakedown
2023-04-24	PMO	56.8	162.00	PWC 1B-Event MOF Post Outage shakedown
2023-04-27	PFO	1.2	238.00	PWC-1B-START UP FAILURE MP BLEED VALVE FAILED
2023-04-27	PFO	1.2	162.00	PWC-1B-START UP FAILURE MP BLEED VALVE FAILED
2023-05-23	PFO	3.0	238.00	PWC-1B-SU Failure-MP Bleed Valve Abnormal
2023-05-23	PFO	3.0	162.00	PWC-1B-SU Failure-MP Bleed Valve Abnormal
2023-05-26	PMO	36.2	238.00	PWC-1B-Event MOF-Spin cool and install Dial Indicators
2023-05-26	PMO	36.2	162.00	PWC-1B-Event MOF-Spin cool and install Dial Indicators
2023-05-30	PMO	149.8	238.00	PWC-1B-Repair BFP Seal and Mitsubishi Cooldown Measurements

2023-05-30	PMO	149.8	162.00	PWC-1B-Repair BFP Seal and Mitsubishi Cooldown Measurements
2023-05-31	PFO	4.1	238.00	PWC-1C-IGV actuator cables were loose
2023-05-31	PFO	4.1	162.00	PWC-1C-IGV actuator cables were loose
2023-05-31	PMO	31.2	238.00	PWC-1C-Inspect IGV Actuator Cables and Seal Tight
2023-05-31	PMO	31.2	162.00	PWC-1C-Inspect IGV Actuator Cables and Seal Tight
2023-06-12	PFO	7.9	238.00	PWC-1A-Force Outage-Aux Transformer Yard Breaker trip
2023-06-12	PFO	4.8	487.00	PWC-1ST-Force Outage-Aux Transformer Yard Breaker trip
2023-06-12	PFO	2.9	238.00	PWC 1B Start up Failure GT Combustor Bypass Valve
2023-06-12	PFO	5.2	238.00	PWC 1B Start up Failure GT Combustor Bypass Valve
2023-06-12	PFO	5.2	162.00	PWC 1B Start up Failure GT Combustor Bypass Valve
2023-06-22	PMO	33.2	238.00	PWC 1A commenced the maintenance to repair 1040 Drain and IP FW Sensing
2023-06-22	PMO	33.2	162.00	PWC 1A commenced the maintenance to repair 1040 Drain and IP FW Sensing
2023-06-26	PFO	2.0	198.00	PWC-1B- Derating Force Outage-FGH Flow Control Valves.
2023-06-26	PFO	2.0	135.05	PWC-1B- Derating Force Outage-FGH Flow Control Valves.
2023-06-28	PFO	7.7	238.00	PWC-1C-BFP recirculation valve failed to operate
2023-06-28	PFO	7.7	162.00	PWC-1C-BFP recirculation valve failed to operate
2023-07-07	PFO	11.9	238.00	PWC-1C-Force Outage-IGV Actuator Oil leak
2023-07-07	PFO	11.9	162.00	PWC-1C-Force Outage-IGV Actuator Oil leak
2023-07-09	PFO	3.5	238.00	PWC-1C-FO Start up failure-IGV actuator loose connection
2023-07-09	PFO	3.5	162.00	PWC-1C-FO Start up failure-IGV actuator loose connection
2023-07-10	PMO	53.7	238.00	PWC-1C-Repair IGV Cables and Switchyard Breaker
2023-07-10	PMO	53.7	162.00	PWC-1C-Repair IGV Cables and Switchyard Breaker
2023-07-30	PFO	5.1	238.00	PWC-1B-Force Outage-Control Oil Leak in the IGV System
2023-07-30	PFO	5.1	162.00	PWC-1B-Force Outage-Control Oil Leak in the IGV System
2023-07-30	PFO	10.9	238.00	PWC-1C-Force Outage-Fuel Gas Main-A PCV Deviation.
2023-07-30	PFO	2.5	162.00	PWC-1C-Force Outage-Fuel Gas Main-A PCV Deviation.
2023-07-30	PFO	8.3	162.00	PWC-1C-Force Outage-Fuel Gas Main-A PCV Deviation.
2023-07-31	PFO	7.6	238.00	PWC-1C-Force Outage-Main A Fuel Gas PCV Position Deviation.
2023-07-31	PFO	2.1	162.00	PWC-1C-Force Outage-Main A Fuel Gas PCV Position Deviation.
2023-07-31	PFO	3.0	487.00	PWC-1ST-trip was due to a lightning strike that affected three modules
2023-07-31	PFO	3.0	162.00	PWC-1C-Force Outage-Main A Fuel Gas PCV Position Deviation.
2023-07-31	PFO	2.3	162.00	PWC-1C-Force Outage-Main A Fuel Gas PCV Position Deviation.
2023-08-01	PMO	59.6	238.00	PWC-1B-feedwater leaks and BFP recirculation tuning
2023-08-01	PMO	59.6	162.00	PWC-1B-feedwater leaks and BFP recirculation tuning
2023-08-03	PMO	29.5	238.00	PWC-1C-MOF to resolve the CT Main A Fuel Gas PCV position
2023-08-03	PMO	12.4	162.00	PWC-1C-MOF to resolve the CT Main A Fuel Gas PCV position
2023-08-04	PMO	17.1	162.00	PWC-1C-MOF to resolve the CT Main A Fuel Gas PCV position
2023-08-18	PFO	0.5	75.00	PWC-1C- Runback due to faulty CPFM sensor 3
2023-08-18	PFO	0.5	96.94	PWC-1C- Runback due to faulty CPFM sensor 3
2023-08-18	PFO	3.3	238.00	PWC-1C-CPFM elevated activity
2023-08-18	PFO	3.3	162.00	PWC-1C-CPFM elevated activity
2023-08-26	PMO	58.0	1.00	PWC-1ST-Condenser Tube Leaks
2023-08-26	PMO	58.0	1.00	PWC-1ST-Condenser Tube Leaks
2023-08-26	PMO	58.0	243.00	PWC-1ST-Condenser Tube Leaks

			55.6	238.00	PWC-1C Main Fuel Gas PCV A Position 1 Malfunctioning-CPFM Sensor
2023-08-26	PMO		55.6	162.00	PWC-1C Main Fuel Gas PCV A Position 1 Malfunctioning-CPFM Sensor
2023-09-26	PFO		2.6	238.00	PWC-1C- Force Outage-BFP trip during SU
2023-09-26	PFO		2.6	162.00	PWC-1C- Force Outage-BFP trip during SU
2023-09-26	PMO		73.2	238.00	PWC 1B - Event MOF - LP Economizer vent line leaks.
2023-09-26	PMO		73.2	162.00	PWC 1B - Event MOF - LP Economizer vent line leaks.
2023-10-02	PFO		1.4	238.00	PWC-1B-SU Failure-MP Bleed Valve Abnormal open
2023-10-02	PFO		1.4	162.00	PWC-1B-SU Failure-MP Bleed Valve Abnormal open
2023-10-22	PFO		3.0	238.00	PWC-1B-Tripped due to Tophat fuel valve deviation
2023-10-22	PFO		3.0	162.00	PWC-1B-Tripped due to Tophat fuel valve deviation

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: West County Energy Center - PWC				
			PWC-02	
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-01-16	PMO	2.3	238.00	PWC-2A- 1 and 2 Gas Yard Outage
2023-01-16	PMO	2.0	160.00	PWC-2A- 1 and 2 Gas Yard Outage
2023-01-16	PMO	1.6	238.00	PWC-2C- 1 and 2 Gas Yard Outage
2023-01-16	PMO	1.3	82.00	PWC-2C- 1 and 2 Gas Yard Outage
2023-01-16	PMO	0.2	487.00	PWC-2ST- 1 and 2 Gas Yard Outage
2023-01-16	PMO	159.1	160.00	PWC-2A- 1 and 2 Gas Yard Outage
2023-01-16	PMO	152.9	82.00	PWC-2C- 1 and 2 Gas Yard Outage
2023-01-16	FMO	152.6	1201.00	PWC-2B- 1 and 2 Gas Yard Outage
2023-01-22	PMO	9.6	238.00	PWC-2A- 1 and 2 Gas Yard Outage
2023-01-22	PMO	6.1	487.00	PWC-2ST- 1 and 2 Gas Yard Outage
2023-01-22	PMO	3.3	238.00	PWC-2B- 1 and 2 Gas Yard Outage
2023-01-23	PMO	3.4	160.00	PWC-2A- 1 and 2 Gas Yard Outage
2023-02-03	PMO	74.0	238.00	PWC-2B-Event MOF-HRSG Tube leak
2023-02-03	PMO	74.0	166.00	PWC-2B-Event MOF-HRSG Tube leak
2023-02-26	PFO	31.5	238.00	PWC-2B-OMC Force Outage- Breaker 9W437 Low SF6 Gas
2023-02-26	PFO	0.1	167.00	PWC-2B-OMC Force Outage- Breaker 9W437 Low SF6 Gas
2023-02-26	PFO	4.5	487.00	PWC-2ST-Force Outage-Condenser Pump Trip
2023-02-26	PFO	4.5	167.00	PWC-2B-OMC Force Outage- Breaker 9W437 Low SF6 Gas
2023-02-26	PFO	3.2	238.00	PWC-2A-Force Outage-Low LP Drum Level
2023-02-26	PFO	26.8	167.00	PWC-2B-OMC Force Outage- Breaker 9W437 Low SF6 Gas
2023-03-13	PMO	39.8	238.00	PWC-2C-Troubleshoot and repair MS-CRH Bypass Valve
2023-03-13	PMO	39.8	163.00	PWC-2C-Troubleshoot and repair MS-CRH Bypass Valve
2023-03-14	PMO	85.1	238.00	PWC-2A-Find and repair HRSG Tube leak
2023-03-14	PMO	38.6	163.00	PWC-2A-Find and repair HRSG Tube leak
2023-03-15	PMO	46.5	163.00	PWC-2A-Find and repair HRSG Tube leak
2023-03-19	PMO	47.1	238.00	PWC-2C-Repair LP reed line rupture
2023-03-19	PMO	47.1	163.00	PWC-2C-Repair LP reed line rupture
2023-04-29	PPO	1163.5	238.00	PWC2A-CT-MAJOR-ROTOR SWAP
2023-04-29	PPO	1141.4	162.00	PWC2A-CT-MAJOR-ROTOR SWAP
2023-06-05	PMO	97.6	238.00	PWC-2B-Repair HP DSH and LP Drum LCV
2023-06-05	PMO	97.6	162.00	PWC-2B-Repair HP DSH and LP Drum LCV
2023-06-09	PMO	80.5	238.00	PWC-2C-Repair CT Expansion Joint and LP Drum LCV
2023-06-09	PMO	80.5	162.00	PWC-2C-Repair CT Expansion Joint and LP Drum LCV
2023-06-16	PFO	0.6	487.00	PWC-2ST-Forced Outage- Main Steam valve closed inadvertently
2023-06-16	PPO	0.6	162.00	PWC2A-CT-MAJOR-ROTOR SWAP
2023-06-16	PPO	12.0	162.00	PWC2A-CT-MAJOR-ROTOR SWAP
2023-06-16	PMO	7.3	487.00	PWC-2ST-Event MOF-2AS BUS Transmission Line Switched out
2023-06-16	PPO	7.3	162.00	PWC2A-CT-MAJOR-ROTOR SWAP
2023-06-17	PPO	2.1	162.00	PWC2A-CT-MAJOR-ROTOR SWAP
2023-06-18	PPO	56.8	238.00	PWC2A-CT-MAJOR-ROTOR SWAP
2023-06-18	PPO	56.8	162.00	PWC2A-CT-MAJOR-ROTOR SWAP
2023-06-22	PFO	7.6	238.00	PWC-2B-BFP trip on low flow due to the BFP recir. valve not controlling
2023-06-22	PFO	7.6	162.00	PWC-2B-BFP trip on low flow due to the BFP recir. valve not controlling
2023-07-06	PMO	60.2	238.00	PWC 2B-Repair 2PSE-ACV-2002 Steam Leak
2023-07-06	PMO	60.2	162.00	PWC 2B-Repair 2PSE-ACV-2002 Steam Leak
2023-07-14	PMO	35.8	238.00	PWC-2C-Event MOF - Condenser tube leaks.
2023-07-14	PMO	35.8	162.00	PWC-2C-Event MOF - Condenser tube leaks.
2023-07-19	PFO	37.8	487.00	PWC-2ST-87TGSU Protection relay failed
2023-07-19	PFO	1.2	238.00	PWC-2C-87T-GSU-Protection Relay Failed
2023-07-21	PFO	3.3	238.00	PWC-2A-Tripped due to tophat fuel valve deviation

2023-07-21	PFO	9.4	238.00	PWC-2A-Tripped due to Tophat fuel valve deviation
2023-07-21	PFO	9.4	162.00	PWC-2A-Tripped due to Tophat fuel valve deviation
2023-07-22	PFO	15.9	238.00	PWC-2A-Force Outage-Tophat flow control valve position deviation
2023-07-22	PFO	15.9	162.00	PWC-2A-Force Outage-Tophat flow control valve position deviation
2023-08-02	PFO	1.5	238.00	PWC-2A-High CPFM Combustor Pressure Fluctuation Monitor Trip
2023-08-02	PFO	1.5	162.00	PWC-2A-High CPFM Combustor Pressure Fluctuation Monitor Trip
2023-08-18	PMO	50.3	238.00	PWC- 2A-Event MOF - Condenser Tube Leaks-Evap Media.
2023-08-18	PMO	51.8	1.00	PWC-2ST-Condenser Tube Leaks
2023-08-18	PMO	51.8	1.00	PWC-2ST-Condenser Tube Leaks
2023-08-18	PMO	50.3	162.00	PWC- 2A-Event MOF - Condenser Tube Leaks-Evap Media.
2023-08-18	PMO	51.8	81.00	PWC-2ST-Condenser Tube Leaks
2023-09-07	PFO	4.4	238.00	PWC-2B auto stop due to BPS
2023-09-07	PFO	4.4	162.00	PWC-2B auto stop due to BPS
2023-10-23	PMO	55.7	238.00	PWC-2A-HRSG LP Drum to SH leaks repair
2023-10-23	PMO	55.7	162.00	PWC-2A-HRSG LP Drum to SH leaks repair

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: West County Energy Center - PWC		PWC-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-01-12	PMO	37.7	241.00	PWC 3C - Event MOF - Leak repair TCA to HP drum level control valve
2023-01-12	PMO	37.7	157.00	PWC 3C - Event MOF - Leak repair TCA to HP drum level control valve
2023-01-25	PMO	273.4	241.00	PWC 3B - Event MOF - Borescope fuel oil nozzles
2023-01-25	PMO	273.4	157.00	PWC 3B - Event MOF - Borescope fuel oil nozzles
2023-02-06	PMO	44.0	241.00	PWC 3B - Event MOF - HP Steam Control Valve Repair.
2023-02-06	PMO	44.0	158.00	PWC 3B - Event MOF - HP Steam Control Valve Repair.
2023-02-12	PMO	31.3	241.00	PWC 3A - Event MOF - HP ECON Drain leak.
2023-02-12	PMO	31.3	158.00	PWC 3A - Event MOF - HP ECON Drain leak.
2023-02-13	PMO	16.7	241.00	PWC-3B commenced the maintenance to repair 3PSE-ACV-2002 Actuator
2023-02-13	PMO	5.0	158.00	PWC-3B commenced the maintenance to repair 3PSE-ACV-2002 Actuator
2023-02-14	PMO	11.6	158.00	PWC-3B commenced the maintenance to repair 3PSE-ACV-2002 Actuator
2023-02-17	PMO	48.6	241.00	PWC 3A - Event MOF - Pre-Outage Inspection-preparation
2023-02-17	PMO	48.3	158.00	PWC 3A - Event MOF - Pre-Outage Inspection-preparation
2023-02-18	PMO	46.5	241.00	PWC 3B - Event MOF - Pre-Outage Inspection-preparation
2023-02-18	PMO	46.2	79.00	PWC 3B - Event MOF - Pre-Outage Inspection-preparation
2023-02-19	PPO	0.2	484.00	PWC-3ST- Planned Outage Major Turbine Overhaul
2023-02-19	PMO	0.9	158.00	PWC 3A - Event MOF - Pre-Outage Inspection-preparation
2023-02-19	PMO	0.9	79.00	PWC 3B - Event MOF - Pre-Outage Inspection-preparation
2023-02-19	PO	0.7	1207.00	PWC-3A-Planned Outage
2023-02-20	PO	1679.0	1207.00	PWC 3B- Planned Outage
2023-05-01	PO	126.2	1207.00	PWC 3A Annual Maintenance Overhaul Extension
2023-05-01	PPO	127.3	161.00	PWC 3A Annual Maintenance Overhaul Extension
2023-05-06	PPO	53.1	241.00	PWC-3C-Planned Outage Extension
2023-05-06	PPO	1.1	484.00	PWC-3ST- Major Turbine Overhaul Extension
2023-05-06	PPO	101.5	241.00	PWC 3A Annual Maintenance Overhaul Extension
2023-05-06	PPO	100.4	161.00	PWC 3A Annual Maintenance Overhaul Extension
2023-05-10	PPO	44.6	29.00	PWC 3A Annual Maintenance Overhaul Extension
2023-05-10	PPO	44.6	173.95	PWC 3A Annual Maintenance Overhaul Extension
2023-05-13	PFO	4.4	241.00	PWC-3B-Force Outage-BFP Strainer clogged
2023-05-13	PFO	4.4	161.00	PWC-3B-Force Outage-BFP Strainer clogged
2023-05-13	PMO	31.7	241.00	PWC-3A-Event MOF-2C Cooler Piping Flange leak
2023-05-13	PMO	3.3	161.00	PWC-3A-Event MOF-2C Cooler Piping Flange leak
2023-05-14	PMO	28.4	161.00	PWC-3A-Event MOF-2C Cooler Piping Flange leak
2023-05-23	PMO	2.2	241.00	PWC-3C-Event MOF-CT Expansion Joint Replacement
2023-05-23	PMO	1.7	161.00	PWC-3C-Event MOF-CT Expansion Joint Replacement
2023-05-23	PMO	1.0	241.00	PWC-3B-Event MOF-Gland Steam repair
2023-05-23	PMO	36.0	161.00	PWC-3B-Event MOF-Gland Steam repair
2023-05-23	PMO	0.5	484.00	PWC-3ST-Event MOF-Gland Steam repair
2023-05-23	PMO	38.3	161.00	PWC-3C-Event MOF-CT Expansion Joint Replacement
2023-05-23	FMO	35.0	1207.00	PWC-3A-Event MOF-Gland Steam repair
2023-05-25	PMO	9.9	241.00	PWC-3C-Event MOF-CT Expansion Joint Replacement
2023-05-25	PMO	2.7	484.00	PWC-3ST-Event MOF-Gland Steam repair
2023-05-25	PMO	7.1	161.00	PWC-3C-Event MOF-CT Expansion Joint Replacement
2023-05-29	PFO	3.3	241.00	PWC-3B-Force outage-High IP drum level

2023-05-29	PFO		3.3	161.00	PWC-3B-Force outage-High IP drum level
2023-06-02	PFO		8.5	241.00	PWC-3B- FORCE OUTAGE-BFP RECIRC ERRADIC
2023-06-02	PFO		8.5	161.00	PWC-3B- FORCE OUTAGE-BFP RECIRC ERRADIC
2023-06-21	PFO		1.2	241.00	PWC-3B-Start Up failure on Fuel Oil-Fuel Nozzles 13-16
2023-06-21	PFO		1.2	161.00	PWC-3B-Start Up failure on Fuel Oil-Fuel Nozzles 13-16
2023-09-08	PMO		2.5	241.00	PWC-3C-Gland Steam DSH Spray Nozzles
2023-09-08	PMO		1.7	241.00	PWC-3B-Gland Steam DSH Spray Nozzles
2023-09-08	PMO		0.4	484.00	PWC-3ST-Gland Steam DSH Spray Nozzles
2023-09-08	FMO		31.0	1207.00	PWC-3A-Gland Steam DSH Spray Nozzles
2023-09-10	PMO		7.5	241.00	PWC-3C-Gland Steam DSH Spray Nozzles
2023-09-10	PMO		5.1	241.00	PWC-3B-Gland Steam DSH Spray Nozzles
2023-09-10	PMO		2.8	484.00	PWC-3ST-Gland Steam DSH Spray Nozzles
2023-09-23	PMO		47.4	241.00	PWC 3C - Event MOF - FO Main PCV B Deviation.
2023-09-23	PMO		47.4	161.00	PWC 3C - Event MOF - FO Main PCV B Deviation.
2023-10-08	PFO		0.4	241.00	PWC-3C-FO testing trip due to flame abnormal

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2023 TO: Dec-2023

PLANT/UNIT: Turkey Point - TP5		TP5-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2023-01-10	PMO	95.5	188.50	5D Event MO - Hydraulic Oil Pump Coupling Replacement
2023-01-10	PMO	95.5	148.00	5D Event MO - Hydraulic Oil Pump Coupling Replacement
2023-01-12	PMO	47.4	188.50	5C Event MO - Water Injection Purge Isolation Valves replacement
2023-01-12	PMO	47.4	1.00	5C Event MO - Water Injection Purge Isolation Valves replacement
2023-02-03	PFO	2.5	188.50	5B EFOR - Sample vacuum pump relay failure
2023-02-03	PFO	2.5	148.00	5B EFOR - Sample vacuum pump relay failure
2023-02-07	PMO	50.8	188.50	5C Event MO - LF purge valve replacement
2023-02-07	PMO	50.8	164.00	5C Event MO - LF purge valve replacement
2023-02-10	PPO	638.3	188.50	5C Planned Outage CT-HGP-TECH 2.0
2023-02-10	PPO	638.3	128.00	5C Planned Outage CT-HGP-TECH 2.0
2023-02-24	PMO	23.8	188.50	5D Event MO - Blowdown drain line leak repair
2023-02-24	PMO	23.8	152.00	5D Event MO - Blowdown drain line leak repair
2023-03-13	PPO	472.0	188.50	5A Planned Outage CT-Mini HGP
2023-03-13	PPO	472.0	128.00	5A Planned Outage CT-Mini HGP
2023-03-16	PMO	132.7	188.50	5C MO Event
2023-03-16	PMO	132.7	128.00	5C MO Event
2023-03-23	PFO	4.2	188.50	5B EFOR HP Event - Forced Point
2023-03-23	PFO	4.2	128.00	5B EFOR HP Event - Forced Point
2023-03-28	PFO	7.1	188.50	5D EFOR Event - Atomizing Air Hose leaking
2023-03-28	PFO	7.1	128.00	5D EFOR Event - Atomizing Air Hose leaking
2023-04-19	PFO	0.2	188.50	5D EFOR Event - Unit tripped during LF swap
2023-04-19	PFO	0.2	128.00	5D EFOR Event - Unit tripped during LF swap
2023-05-01	PFO	0.9	188.50	5B EFOR Event - Startup Failure AA Bypass Vlv. switch off
2023-05-01	PFO	0.9	128.00	5B EFOR Event - Startup Failure AA Bypass Vlv. switch off
2023-05-08	PFO	1.9	188.50	5C EFOR Event - HRH Sky Vent Vlv. failed to open
2023-05-08	PFO	1.9	128.00	5C EFOR Event - HRH Sky Vent Vlv. failed to open
2023-05-09	PFO	10.7	188.50	5C EFOR Event - CAN13 LF supply line leak
2023-05-09	PFO	10.7	128.00	5C EFOR Event - CAN13 LF supply line leak
2023-05-13	PMO	73.5	188.50	5A MO Event - Inspect-replace LP Drum Level Control Valve 5SGA-ACV-1310
2023-05-13	PMO	73.5	128.00	5A MO Event - Inspect-replace LP Drum Level Control Valve 5SGA-ACV-1310
2023-05-18	PPO	609.8	188.50	5D Planned Outage - PTF5D-CT-HGP-TECH 2.0
2023-05-18	PPO	609.8	128.00	5D Planned Outage - PTF5D-CT-HGP-TECH 2.0
2023-05-25	PFO	83.5	124.00	PTF5 Partial EFOR Event - 5B Circ. Pump Motor failure
2023-05-30	PPO	597.0	188.50	5B Planned Outage - PTF5B-CT-HGP-TECH 2.0
2023-05-30	PPO	597.0	128.00	5B Planned Outage - PTF5B-CT-HGP-TECH 2.0
2023-06-08	PFO	1.0	188.50	5A EFOR Event - IGV failure causing high exhaust spread temp.
2023-06-08	PFO	1.0	128.00	5A EFOR Event - IGV failure causing high exhaust spread temp.
2023-06-15	PFO	6.8	188.50	5A EFOR Event - Tripped on high exhaust temperature spread
2023-06-15	PFO	6.8	128.00	5A EFOR Event - Tripped on high exhaust temperature spread
2023-06-16	PFO	6.7	188.50	5A EFOR Event - Tripped on High Exhaust Temperature spread Second Trip
2023-06-16	PFO	6.7	128.00	5A EFOR Event - Tripped on High Exhaust Temperature spread Second Trip
2023-06-16	PFO	7.9	188.50	5A EFOR Event - Tripped on high exhaust temperature spread
2023-06-16	PFO	7.9	128.00	5A EFOR Event - Tripped on high exhaust temperature spread
2023-06-28	PMO	81.7	188.50	5D MO Event - HRH skyvent pipe repair
2023-06-28	PMO	81.7	128.00	5D MO Event - HRH skyvent pipe repair

2023-07-06	PFO	11.9	188.50	5A EFOR Event - Tripped on High Exhaust Temperature Spread
2023-07-06	PFO	11.9	128.00	5A EFOR Event - Tripped on High Exhaust Temperature Spread
2023-07-07	PMO	40.6	188.50	5B MO Task - Water Wash and Performance Test
2023-07-07	PMO	40.6	128.00	5B MO Task - Water Wash and Performance Test
2023-07-10	PFO	5.2	188.50	5B EFOR Event - Exhaust Thermocouple Failure
2023-07-10	PFO	5.2	128.00	5B EFOR Event - Exhaust Thermocouple Failure
2023-08-12	PFO	0.6	188.50	5D EFOR Event - High Exh. Spread during LF transfer
2023-08-12	PFO	0.6	128.00	5D EFOR Event - High Exh. Spread during LF transfer
2023-08-18	PFO	2.1	188.50	5D EFOR Event - Haz Gas Fault Alarm Trip HP
2023-08-18	PFO	2.1	128.00	5D EFOR Event - Haz Gas Fault Alarm Trip HP
2023-08-18	PMO	25.6	188.50	5B MO Event - Repair LF pump and WI leak
2023-08-18	PMO	25.6	128.00	5B MO Event - Repair LF pump and WI leak
2023-08-19	PMO	30.2	188.50	5D MO Event - LF supply lines inspect and cleaning
2023-09-04	PMO	38.4	188.50	5D MO Event - CT LF Distribution Vlvs. and Drains
2023-09-20	PMO	54.2	188.50	5A MO Event - LO and Hydraulic Filters Replacement
2023-09-20	PMO	54.2	128.00	5A MO Event - LO and Hydraulic Filters Replacement
2023-09-26	PMO	55.3	188.50	5C MO Event - Valve 20AA-2 troubleshooting
2023-09-26	PMO	55.3	128.00	5C MO Event - Valve 20AA-2 troubleshooting
2023-10-17	PMO	52.0	188.50	PTF MO Event - 5A CT Replace Lube Oil Pump Motor
2023-10-17	PMO	52.0	128.00	PTF MO Event - 5A CT Replace Lube Oil Pump Motor

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.