

State of Florida



Public Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD
TALLAHASSEE, FLORIDA 32399-0850

-M-E-M-O-R-A-N-D-U-M-

DATE: June 25, 2026

TO: Adam J. Teitzman, Commission Clerk, Office of Commission Clerk

FROM: Jennifer S. Crawford, Attorney Supervisor, Office of the General Counsel *JSC*

RE: Docket No. 20260045-EI - Formal complaint of Justin Gage against Duke Energy Florida, LLC for alleged violations of Commission rules, orders, and statutes governing electric utility safety standards, compliance certifications, and truthfulness in Commission filings.

Please place the attached email from Mr. Justin Gage and his supporting document in the docket file in the above referenced docket.

Thank you.

JSC
Attachment

From: [Jennifer Crawford](#)
To: [Dorothy Menasco](#)
Cc: [Danyel Sims](#)
Subject: FW: Docket NO. 20260045-EI /Justin Gage/ Additional exhibits/evidence
Date: Thursday, June 25, 2026 10:18:19 AM
Attachments: [PSC exhibits.pdf](#)
[Certificate of service Exhibits.pdf](#)

Just checking – did this get e-filed as well? If not, I'll have Danyel do a memo to file the attached information in the docket file.

From: Justin Gage <jgage76@gmail.com>
Sent: Thursday, June 25, 2026 10:11 AM
To: Adria E. Harper <AHarper@psc.state.fl.us>; Jennifer Crawford <jcrawfor@psc.state.fl.us>; Jennifer Crawford <jcrawfor@psc.state.fl.us>; Dianne.triplett@duke-energy.com; matthew.bernier@duke-energy.com; stephanie.cuello@duke-energy.com; FLRegulatoryLegal@duke-energy.com
Subject: Docket NO. 20260045-EI /Justin Gage/ Additional exhibits/evidence

CAUTION: This email originated from outside your organization. Exercise caution when opening attachments or clicking links, especially from unknown senders.

Hi

Please view/add the additional exhibits to the documents in Docket NO. 20260045-EI

--


Thanks

Justin Gage

4073016133

Exhibit 2 (closeup proper label on other BOX)

This is the proper sticker which should be on the PME-4 PER ELECTRIC CODE + DUKE ENERGY'S STANDARDS



Please note 10' clearance
* these units require the use
of a 6' Hot stick to safely
function the equipment

Exhibit
8

S&C PAD-MOUNTED GEAR

CATALOG NUMBER

65102R1-A14F14-E197

MODEL NUMBER

Manual PME-4

SERIAL NUMBER

036133

DATE OF MANUFACTURE

10/03

ED BY ONE OR MORE OF THE FOLLOWING U.S. PATENTS
4,781,530 4,637,277 4,956,572 5,803,803

PROTECTED BY S&C'S ULTRA-DUR[®] FINISH

S&C ELECTRIC COMPANY

Interval part # that
specifies exact configuration
and options for the PME-4

IS IN THIS COMPARTMENT

Exhibit

(Proper Label)
ON OTHER
DUKE BOX

Here is a pic of a DUKE
Energy Box which is walking
Distance from the BOX in violation

K112656

Proper sticker that should be
used

⚠ WARNING

 Keep Out! Hazardous voltage inside. Stay away. Warn of power lines. Duke Energy	 Call Before You Dig! Electrical cable buried below. Call 811 48 hours before digging.  Know what's below. Call before you dig.	 Maintain Clearance Energized electrical equipment. Maintain 10 ft. clearance from front and back and 3 ft. in all other sides from lines, shrubs, and structures.
---	---	---

* NOTE
the 10'
clearance
requirement

(THEY KNOW
THE CODE)

Exhibit
3

Prior to
9-4-25

Duke
Box
ID

K198787

Incorrect
Label



46"

less than
18" clearance

Hinges



Exhibit
9


Inside PME-4
Door facing Bush
* Door forced open
and standing
in Bush
45° open



Exhibit 3

Duke Tech
standing in
bushes + forcing
the door open

High
Voltage
Safety
Equipment



CERTIFICATE OF SERVICE

Docket No. 20260045-EI

I HEREBY CERTIFY that a true and correct copy of **Additional Evidence/Exhibits** has been furnished by electronic mail on this **25TH day of Junl, 2026**, to the following persons:

Florida Public Service Commission

Office of General Counsel

A. Harper / J. Crawford

2540 Shumard Oak Boulevard Tallahassee,

Florida 32399-0850

aharper@psc.state.fl.us

jcrawford@psc.state.fl.us

Duke Energy Florida, LLC

Dianne M. Triplett, Deputy General Counsel

299 1st Avenue North

St. Petersburg, Florida 33701

Dianne.triplett@duke-energy.com

Duke Energy Florida, LLC

Matthew R. Bernier, Associate General Counsel

106 East College Avenue, Suite 800 Tallahassee,

Florida 32301 matthew.bernier@duke-

energy.com

Duke Energy Florida, LLC

Stephanie A. Cuello, Senior Counsel

106 East College Avenue, Suite 800 Tallahassee,

Florida 32301 stephanie.cuello@duke-

energy.com

FLRegulatoryLegal@duke-energy.com

Respectfully submitted,

/S/ Justin Gage

Justin Gage

13114 Fox Glove Street

Winter Garden, Florida 34787

Telephone: (407) 301-6133

Email: Jgage76@gmail.com