

Cover Letter to Additional Evidence/Exhibits

Justin Gage
13114 Fox Glove St
Winter Garden Fl. 34787
jgage76@gmail.com
4073016133

6-25-26

VIA ELECTRONIC FILING

Adam J. Teitzman
Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Request to File additional evidence/exhibits Docket No. 20260045-EI

Dear Mr. Teitzman:

Please file the attached exhibits/evidence into Docket No. 20260045-EI


Respectfully submitted,

/S/ Justin Gage

Justin Gage

Exhibit 2 (closeup proper label on other Box)

This is the proper sticker which should be on the PME-4 PER ELECTRIC CODE + DUKE ENERGY'S STANDARDS



Please note 10' clearance
* these units require the use of a 6' Hot stick to safely function the Equipment

Exhibit
8

S&C PAD-MOUNTED GEAR

CATALOG NUMBER

65102R1-A14F14-E197

MODEL NUMBER

Model PME-4

SERIAL NUMBER

038133

DATE OF MANUFACTURE

10/03

PROTECTED BY ONE OR MORE OF THE FOLLOWING U.S. PATENTS
4,734,530 4,657,277 4,986,573 5,803,903

PROTECTED BY S&C'S ULTRADUR® FINISH

S&C ELECTRIC COMPANY

Internal part # that
specifies exact configuration
and options for the PME-4

FUNCTION MANUAL

THIS COMPARTMENT

Exhibit

(Proper Label)
ON OTHER
DUKE BOX

Here is a pic of a DUKE
Energy Box which is walking
Distance from the Box in violation

K112656

Proper sticker that should be
used



* NOTE
the 10'
clearance
requirement

(THEY KNOW
THE CODE)

Exhibit
3

Prior to
9-4-25

Incorrect
Label

K198787

Duke
Box
ID



46"

LESS THAN
18" clearance

Hinges

Exhibit
9

Inside PME-4
Door facing Bush
* Door forced open
and standing
in Bush
45° open



Exhibit 3

Duke Tech
standing in
bushes + forcing
the door open

High
Voltage
safety
equipment



CERTIFICATE OF SERVICE

Docket No. 20260045-EI

I HEREBY CERTIFY that a true and correct copy of **Additional Evidence/Exhibits** has been furnished by electronic mail on this **25TH day of Junl, 2026**, to the following persons:

Florida Public Service Commission

Office of General Counsel

A. Harper / J. Crawford

2540 Shumard Oak Boulevard Tallahassee,

Florida 32399-0850

aharper@psc.state.fl.us

jcrawford@psc.state.fl.us

Duke Energy Florida, LLC

Dianne M. Triplett, Deputy General Counsel

299 1st Avenue North

St. Petersburg, Florida 33701

Dianne.triplett@duke-energy.com

Duke Energy Florida, LLC

Matthew R. Bernier, Associate General Counsel

106 East College Avenue, Suite 800 Tallahassee,

Florida 32301 [matthew.bernier@duke-](mailto:matthew.bernier@duke-energy.com)

energy.com

Duke Energy Florida, LLC

Stephanie A. Cuello, Senior Counsel

106 East College Avenue, Suite 800 Tallahassee,

Florida 32301 [stephanie.cuello@duke-](mailto:stephanie.cuello@duke-energy.com)

energy.com

FLRegulatoryLegal@duke-energy.com

Respectfully submitted,

/S/ Justin Gage

Justin Gage

13114 Fox Glove Street

Winter Garden, Florida 34787

Telephone: (407) 301-6133

Email: Jgage76@gmail.com