



Stephanie A. Cuello
SENIOR COUNSEL

July 28, 2026

VIA ELECTRONIC FILING

Adam J. Teitzman, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Fuel and Purchased Power Clause with Generating Performance Incentive Factor;
Performance Data Report for June 2026; Docket No. 20260001-EI

Dear Mr. Teitzman:

Attached for electronic filing in the above-referenced Docket is Duke Energy Florida, LLC's Performance Data Report for June 2026.

Thank you for your assistance in this matter and if you have any questions, please feel free to contact me at (850) 521-1425.

Sincerely,

/s/ Stephanie A. Cuello

Stephanie A. Cuello

SAC/vr
Attachment

CERTIFICATE OF SERVICE

Docket No. 20260001-EI

I HEREBY CERTIFY that a true and correct copy of the foregoing has been furnished via electronic mail to the following this 28th day of July, 2026.

/s/ Stephanie A. Cuello

Stephanie A. Cuello

M. Thompson / Z. Bloom / S. Brownless Office of General Counsel FL Public Service Commission 2540 Shumard Oak Blvd. Tallahassee, FL 32399-0850 mthompso@psc.state.fl.us zbloom@psc.state.fl.us sbrownle@psc.state.fl.us J. Wahlen / M. Means / M. Jones Ausley McMullen Tampa Electric Company P.O. Box 391 Tallahassee, FL 32302 jwahlen@ausley.com mmeans@ausley.com mjones@ausley.com Michelle D. Napier / Jowi Baugh / Jessica Husted Florida Public Utilities Company 1635 Meathe Drive West Palm Beach, FL 33411 Michelle.Napier@chpk.com jbaugh@chpk.com jhusted@chpk.com Beth Keating Gunster, Yoakley & Stewart, P.A. Florida Public Utilities Company 215 South Monroe Street, Suite 601 Tallahassee, FL 32301 bkeating@gunster.com James W. Brew / Laura Wynn Baker / Sarah B. Newman Stone Mattheis Xenopoulos & Brew, P.C. PCS Phosphate –White Springs 1025 Thomas Jefferson Street, NW Suite E-3400 Washington, DC 20007 jbrew@smxblaw.com lwb@smxblaw.com sbn@smxblaw.com William C. Garner Law Office of William C. Garner, PLLC SACE 3425 Bannerman Road Unit 105, No. 414 Tallahassee, Florida 32312 bgarner@wcglawoffice.com	W. Trierweiler / C. Rehwinkel / O. Ponce/ A. Watrous Office of Public Counsel 111 W. Madison St., Room 812 Tallahassee, FL 32399-1400 trierweiler.walt@leg.state.fl.us rehwinkel.charles@leg.state.fl.us ponce.octavio@leg.state.fl.us watrous.austin@leg.state.fl.us Paula K. Brown Regulatory Affairs Tampa Electric Company P.O. Box 111 Tampa, FL 33601-0111 regdept@tecoenergy.com Maria Moncada Florida Power & Light Company 700 Universe Blvd. Juno Beach, FL 33408-0420 maria.moncada@fpl.com Kenneth A. Hoffman Florida Power & Light Company 134 W. Jefferson Street Tallahassee, FL 32301-1713 ken.hoffman@fpl.com Jon C. Moyle, Jr. Moyle Law Firm, P.A. FIPUG 118 North Gadsden Street Tallahassee, FL 32301 jmoyle@moylelaw.com Peter J. Mattheis / Michael K. Lavanga / Joseph R. Briscar Stone Mattheis Xenopoulos & Brew, PC NUCOR 1025 Thomas Jefferson Street, NW Suite E-3400 Washington, DC 20007 pjm@smxblaw.com mkl@smxblaw.com jrb@smxblaw.com
--	---

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2026

Bartow CC	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	Jan - Jun Period
1. EAF	85.73	97.07	79.46	84.38	86.42	99.65	0.00	0.00	0.00	0.00	0.00	0.00	88.61
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	0.0	0.0	0.0	0.0	0.0	0.0	4,343.0
3. SH	569.9	559.1	479.3	614.3	614.8	695.6	0.0	0.0	0.0	0.0	0.0	0.0	3,533.1
4. RSH	86.7	97.2	117.6	15.1	62.1	23.7	0.0	0.0	0.0	0.0	0.0	0.0	402.4
5. UH	87.4	15.7	146.1	90.6	67.0	0.7	0.0	0.0	0.0	0.0	0.0	0.0	407.5
6. POH	77.0	0.0	0.0	48.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	125.5
7. FOH	6.6	4.0	10.0	0.9	0.5	0.7	0.0	0.0	0.0	0.0	0.0	0.0	22.7
8. MOH	3.7	11.6	136.2	41.2	66.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	259.3
9. PPOH	187.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	187.9
10. LR PP (MW)	88.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	88.0
11. PFOH	20.5	28.4	82.2	241.0	0.3	26.9	0.0	0.0	0.0	0.0	0.0	0.0	399.4
12. LR PF (MW)	199.8	74.3	89.9	90.3	88.0	78.6	0.0	0.0	0.0	0.0	0.0	0.0	93.9
13. PMOH	9.1	28.4	0.0	36.8	210.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	284.8
14. LR PM (MW)	88.0	88.0	0.0	88.0	184.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	159.3
15. NSC (MW)	1,142.0	1,142.0	1,142.0	1,142.0	1,142.0	1,142.0	0.0	0.0	0.0	0.0	0.0	0.0	1,142.00
16. OPER MBTU	3,378,960	3,567,050	3,641,920	4,164,960	4,091,890	5,118,310	0	0	0	0	0	0	23,963,090
17. NET GEN (MWH)	434,531	475,639	445,104	555,231	535,048	697,108	0	0	0	0	0	0	3,142,661
18. ANOHR (BTU/KWH)	7,776.1	7,499.5	8,182.2	7,501.3	7,647.7	7,342.2	0.0	0.0	0.0	0.0	0.0	0.0	7,625.1
19. NOF %	66.76	74.49	81.33	79.15	76.20	87.75	0.00	0.00	0.00	0.00	0.00	0.00	77.89
20. NPC (MW)	1,142.0	1,142.0	1,142.0	1,142.0	1,142.0	1,142.0	0.0	0.0	0.0	0.0	0.0	0.0	1,142.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2026

Citrus County Power Block 1	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	Jan - Jun Period
1. EAF	96.73	100.00	100.00	100.00	88.81	100.00	0.00	0.00	0.00	0.00	0.00	0.00	97.52
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	0.0	0.0	0.0	0.0	0.0	0.0	4,343.0
3. SH	724.3	672.0	743.0	720.0	660.7	720.0	0.0	0.0	0.0	0.0	0.0	0.0	4,240.0
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	19.7	0.0	0.0	0.0	83.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	103.0
6. POH	0.0	0.0	0.0	0.0	83.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	83.3
7. FOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8. MOH	19.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	19.7
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13. PMOH	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	25.0
14. LR PM (MW)	152.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	152.0
15. NSC (MW)	817.0	817.0	817.0	817.0	817.0	817.0	0.0	0.0	0.0	0.0	0.0	0.0	817.00
16. OPER MBTU	3,664,370	3,587,730	4,093,790	4,035,870	3,684,830	3,951,860	0	0	0	0	0	0	23,018,450
17. NET GEN (MWH)	534,380	537,060	604,836	591,381	538,436	582,286	0	0	0	0	0	0	3,388,379
18. ANOHR (BTU/KWH)	6,857.2	6,680.3	6,768.4	6,824.5	6,843.6	6,786.8	0.0	0.0	0.0	0.0	0.0	0.0	6,793.4
19. NOF %	90.30	97.82	99.64	100.53	99.75	98.99	0.00	0.00	0.00	0.00	0.00	0.00	97.81
20. NPC (MW)	817.0	817.0	817.0	817.0	817.0	817.0	0.0	0.0	0.0	0.0	0.0	0.0	817.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2026

Citrus County Power Block 2	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	Jan - Jun Period
1. EAF	99.40	42.05	0.00	0.44	99.50	100.00	0.00	0.00	0.00	0.00	0.00	0.00	57.23
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	0.0	0.0	0.0	0.0	0.0	0.0	4,343.0
3. SH	740.5	288.7	0.0	3.2	740.5	720.0	0.0	0.0	0.0	0.0	0.0	0.0	2,492.8
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	3.5	383.3	743.0	716.8	3.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,850.2
6. POH	0.0	358.9	743.0	715.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,817.6
7. FOH	0.0	0.0	0.0	1.1	3.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.6
8. MOH	3.5	24.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	27.9
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11. PFOH	0.0	0.0	0.0	0.0	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	159.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	159.0
13. PMOH	4.6	31.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	36.2
14. LR PM (MW)	159.0	159.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	159.0
15. NSC (MW)	824.0	824.0	824.0	824.0	824.0	824.0	0.0	0.0	0.0	0.0	0.0	0.0	824.00
16. OPER MBTU	3,769,940	1,450,230	0	13,690	4,173,500	4,008,420	0	0	0	0	0	0	13,415,780
17. NET GEN (MWH)	549,673	215,280	0	447	611,957	590,837	0	0	0	0	0	0	1,968,194
18. ANOHR (BTU/KWH)	6,858.5	6,736.5	0.0	30,626.4	6,819.9	6,784.3	0.0	0.0	0.0	0.0	0.0	0.0	6,816.3
19. NOF %	90.09	90.50	0.00	17.04	100.30	99.59	0.00	0.00	0.00	0.00	0.00	0.00	95.82
20. NPC (MW)	824.0	824.0	824.0	824.0	824.0	824.0	0.0	0.0	0.0	0.0	0.0	0.0	824.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2026

Crystal River 4	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	Jan - Jun Period
1. EAF	98.63	90.85	83.13	44.59	86.49	95.61	0.00	0.00	0.00	0.00	0.00	0.00	83.24
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	0.0	0.0	0.0	0.0	0.0	0.0	4,343.0
3. SH	744.0	672.0	656.2	395.0	682.0	715.0	0.0	0.0	0.0	0.0	0.0	0.0	3,864.2
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	0.0	0.0	86.8	325.0	62.0	5.0	0.0	0.0	0.0	0.0	0.0	0.0	478.8
6. POH	0.0	0.0	0.0	325.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	325.0
7. FOH	0.0	0.0	12.3	0.0	62.0	5.0	0.0	0.0	0.0	0.0	0.0	0.0	79.3
8. MOH	0.0	0.0	74.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	74.6
9. PPOH	24.0	32.7	25.0	0.0	9.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	91.2
10. LR PP (MW)	154.6	502.0	112.0	0.0	502.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	303.6
11. PFOH	19.5	13.5	7.0	5.9	52.5	65.0	0.0	0.0	0.0	0.0	0.0	0.0	163.4
12. LR PF (MW)	75.5	408.0	572.0	572.0	431.1	246.1	0.0	0.0	0.0	0.0	0.0	0.0	324.3
13. PMOH	13.0	54.0	184.0	440.0	0.0	26.3	0.0	0.0	0.0	0.0	0.0	0.0	717.3
14. LR PM (MW)	161.0	405.0	112.0	112.0	0.0	112.0	0.0	0.0	0.0	0.0	0.0	0.0	134.9
15. NSC (MW)	712.0	712.0	712.0	712.0	712.0	712.0	0.0	0.0	0.0	0.0	0.0	0.0	712.00
16. OPER MBTU	3,096,980	2,758,710	1,951,380	1,171,090	2,752,870	3,022,610	0	0	0	0	0	0	14,753,640
17. NET GEN (MWH)	294,977	259,562	165,280	92,667	239,321	278,677	0	0	0	0	0	0	1,330,484
18. ANOHR (BTU/KWH)	10,499.1	10,628.3	11,806.5	12,637.6	11,502.8	10,846.3	0.0	0.0	0.0	0.0	0.0	0.0	11,088.9
19. NOF %	55.68	54.25	35.38	32.95	49.29	54.74	0.00	0.00	0.00	0.00	0.00	0.00	48.36
20. NPC (MW)	712.0	712.0	712.0	712.0	712.0	712.0	0.0	0.0	0.0	0.0	0.0	0.0	712.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2026

Crystal River 5	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	Jan - Jun Period
1. EAF	98.66	95.72	59.57	99.02	78.72	17.18	0.00	0.00	0.00	0.00	0.00	0.00	74.65
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	0.0	0.0	0.0	0.0	0.0	0.0	4,343.0
3. SH	744.0	672.0	421.5	720.0	620.0	133.0	0.0	0.0	0.0	0.0	0.0	0.0	3,310.5
4. RSH	0.0	0.0	41.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	41.8
5. UH	0.0	0.0	279.7	0.0	124.0	587.0	0.0	0.0	0.0	0.0	0.0	0.0	990.7
6. POH	0.0	0.0	0.0	0.0	124.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	124.0
7. FOH	0.0	0.0	17.0	0.0	0.0	150.0	0.0	0.0	0.0	0.0	0.0	0.0	167.0
8. MOH	0.0	0.0	262.7	0.0	0.0	437.0	0.0	0.0	0.0	0.0	0.0	0.0	699.7
9. PPOH	0.0	32.7	94.0	11.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	137.7
10. LR PP (MW)	0.0	500.0	89.9	453.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	216.3
11. PFOH	15.3	10.7	208.5	0.0	383.2	78.5	0.0	0.0	0.0	0.0	0.0	0.0	696.3
12. LR PF (MW)	135.6	380.8	30.0	0.0	63.6	83.9	0.0	0.0	0.0	0.0	0.0	0.0	62.3
13. PMOH	10.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10.0
14. LR PM (MW)	500.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	500.0
15. NSC (MW)	710.0	710.0	710.0	710.0	710.0	710.0	0.0	0.0	0.0	0.0	0.0	0.0	710.00
16. OPER MBTU	3,471,220	2,954,210	1,428,850	2,121,870	2,356,740	467,400	0	0	0	0	0	0	12,800,290
17. NET GEN (MWH)	345,970	289,428	132,531	194,505	232,737	45,087	0	0	0	0	0	0	1,240,258
18. ANOHR (BTU/KWH)	10,033.3	10,207.1	10,781.3	10,909.1	10,126.2	10,366.6	0.0	0.0	0.0	0.0	0.0	0.0	10,320.7
19. NOF %	65.49	60.66	44.29	38.05	52.87	47.75	0.00	0.00	0.00	0.00	0.00	0.00	52.77
20. NPC (MW)	710.0	710.0	710.0	710.0	710.0	710.0	0.0	0.0	0.0	0.0	0.0	0.0	710.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2026

Hines Power Block 2	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	Jan - Jun Period
1. EAF	34.39	35.75	64.40	99.83	67.71	0.37	0.00	0.00	0.00	0.00	0.00	0.00	50.65
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	0.0	0.0	0.0	0.0	0.0	0.0	4,343.0
3. SH	116.2	187.4	478.5	719.7	503.8	2.7	0.0	0.0	0.0	0.0	0.0	0.0	2,008.3
4. RSH	139.6	52.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	192.5
5. UH	488.1	431.7	264.5	0.3	240.2	717.3	0.0	0.0	0.0	0.0	0.0	0.0	2,142.3
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	4.2	87.1	0.0	0.3	88.0	717.3	0.0	0.0	0.0	0.0	0.0	0.0	897.0
8. MOH	484.0	344.7	264.5	0.0	152.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,245.3
9. PPOH	0.0	0.0	0.0	8.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8.0
10. LR PP (MW)	0.0	0.0	0.0	58.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	58.6
11. PFOH	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3
12. LR PF (MW)	0.0	0.0	0.0	81.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	81.0
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15. NSC (MW)	582.0	582.0	582.0	582.0	582.0	582.0	0.0	0.0	0.0	0.0	0.0	0.0	582.00
16. OPER MBTU	407,020	645,670	1,697,810	2,481,980	1,711,700	3,420	0	0	0	0	0	0	6,947,600
17. NET GEN (MWH)	51,406	92,913	227,692	338,715	239,114	358	0	0	0	0	0	0	950,198
18. ANOHR (BTU/KWH)	7,917.8	6,949.2	7,456.6	7,327.6	7,158.5	9,553.1	0.0	0.0	0.0	0.0	0.0	0.0	7,311.7
19. NOF %	76.00	85.17	81.76	80.87	81.55	23.15	0.00	0.00	0.00	0.00	0.00	0.00	81.30
20. NPC (MW)	582.0	582.0	582.0	582.0	582.0	582.0	0.0	0.0	0.0	0.0	0.0	0.0	582.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2026

Hines Power Block 3	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	Jan - Jun Period
1. EAF	100.00	100.00	39.76	0.00	81.21	98.15	0.00	0.00	0.00	0.00	0.00	0.00	69.59
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	0.0	0.0	0.0	0.0	0.0	0.0	4,343.0
3. SH	392.7	630.6	256.9	0.0	608.5	708.4	0.0	0.0	0.0	0.0	0.0	0.0	2,597.1
4. RSH	351.3	41.4	39.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	432.4
5. UH	0.0	0.0	446.4	720.0	135.5	11.6	0.0	0.0	0.0	0.0	0.0	0.0	1,313.5
6. POH	0.0	0.0	432.0	720.0	60.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,212.3
7. FOH	0.0	0.0	0.0	0.0	0.0	11.6	0.0	0.0	0.0	0.0	0.0	0.0	11.6
8. MOH	0.0	0.0	14.4	0.0	75.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	89.5
9. PPOH	0.0	0.0	0.0	0.0	25.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	25.7
10. LR PP (MW)	0.0	0.0	0.0	0.0	93.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	93.5
11. PFOH	0.0	0.0	0.0	0.0	0.0	10.7	0.0	0.0	0.0	0.0	0.0	0.0	10.7
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	88.0	0.0	0.0	0.0	0.0	0.0	0.0	88.0
13. PMOH	0.0	0.0	13.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.2
14. LR PM (MW)	0.0	0.0	51.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	51.0
15. NSC (MW)	558.0	558.0	558.0	558.0	558.0	558.0	0.0	0.0	0.0	0.0	0.0	0.0	558.00
16. OPER MBTU	1,246,360	2,024,100	647,370	0	2,041,660	2,271,670	0	0	0	0	0	0	8,231,160
17. NET GEN (MWH)	166,000	284,861	91,322	0	277,734	316,262	0	0	0	0	0	0	1,136,179
18. ANOHR (BTU/KWH)	7,508.2	7,105.6	7,088.9	0.0	7,351.1	7,182.9	0.0	0.0	0.0	0.0	0.0	0.0	7,244.6
19. NOF %	75.75	80.95	63.71	0.00	81.79	80.01	0.00	0.00	0.00	0.00	0.00	0.00	78.40
20. NPC (MW)	558.0	558.0	558.0	558.0	558.0	558.0	0.0	0.0	0.0	0.0	0.0	0.0	558.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2026

Hines Power Block 4	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	Jan - Jun Period
1. EAF	100.00	97.50	99.92	100.00	100.00	100.00	0.00	0.00	0.00	0.00	0.00	0.00	99.60
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	0.0	0.0	0.0	0.0	0.0	0.0	4,343.0
3. SH	744.0	629.6	742.4	720.0	744.0	720.0	0.0	0.0	0.0	0.0	0.0	0.0	4,300.0
4. RSH	0.0	25.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	25.7
5. UH	0.0	16.8	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	17.3
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	0.0	16.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16.8
8. MOH	0.0	0.0	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15. NSC (MW)	566.0	566.0	566.0	566.0	566.0	566.0	0.0	0.0	0.0	0.0	0.0	0.0	566.00
16. OPER MBTU	2,311,110	1,945,010	2,383,680	2,320,110	2,377,480	2,268,600	0	0	0	0	0	0	13,605,990
17. NET GEN (MWH)	323,089	274,852	342,040	330,547	330,170	314,464	0	0	0	0	0	0	1,915,162
18. ANOHR (BTU/KWH)	7,153.2	7,076.6	6,969.0	7,019.0	7,200.8	7,214.2	0.0	0.0	0.0	0.0	0.0	0.0	7,104.4
19. NOF %	76.72	77.13	81.40	81.11	78.41	77.17	0.00	0.00	0.00	0.00	0.00	0.00	78.69
20. NPC (MW)	566.0	566.0	566.0	566.0	566.0	566.0	0.0	0.0	0.0	0.0	0.0	0.0	566.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2026

Osprey CC	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	Jan - Jun Period
1. EAF	74.19	0.00	87.78	97.74	27.65	100.00	0.00	0.00	0.00	0.00	0.00	0.00	65.25
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	0.0	0.0	0.0	0.0	0.0	0.0	4,343.0
3. SH	550.9	0.0	640.6	703.7	205.7	720.0	0.0	0.0	0.0	0.0	0.0	0.0	2,821.0
4. RSH	1.1	0.0	11.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.7
5. UH	192.0	672.0	90.8	16.3	538.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,509.4
6. POH	192.0	672.0	90.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	954.8
7. FOH	0.0	0.0	0.0	16.3	538.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	554.5
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15. NSC (MW)	616.0	616.0	616.0	616.0	616.0	616.0	0.0	0.0	0.0	0.0	0.0	0.0	616.00
16. OPER MBTU	1,724,570	0	2,373,760	2,602,340	804,680	2,623,560	0	0	0	0	0	0	10,128,910
17. NET GEN (MWH)	241,783	0	325,671	369,302	107,197	365,659	0	0	0	0	0	0	1,409,612
18. ANOHR (BTU/KWH)	7,132.7	0.0	7,288.8	7,046.6	7,506.6	7,174.9	0.0	0.0	0.0	0.0	0.0	0.0	7,185.6
19. NOF %	71.25	0.00	82.53	85.19	84.60	82.44	0.00	0.00	0.00	0.00	0.00	0.00	81.12
20. NPC (MW)	616.0	616.0	616.0	616.0	616.0	616.0	0.0	0.0	0.0	0.0	0.0	0.0	616.00

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to June 2026

Bartow CC

Page 1 of 2

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4A	1/6/2026	FFO	2.83	177.50	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
BCC 4A	1/8/2026	FMO	24.00	177.50	BOROSCOPE INSPECTION
BCC 4A	1/9/2026	PO	495.65	177.50	BOROSCOPE INSPECTION
BCC 4A	2/4/2026	PFO	34.88	67.50	OTHER CO REDUCTION PROBLEMS
BCC 4A	2/6/2026	FMO	74.83	177.50	OTHER CO REDUCTION PROBLEMS
BCC 4A	4/13/2026	FFO	5.75	177.50	BLADE PATH TEMPERATURE SPREAD
BCC 4A	5/10/2026	FMO	157.28	177.50	FIRE DETECTION AND EXTINGUISHING SYSTEM
BCC 4A	6/1/2026	FFO	4.35	177.50	COOLING AND SEAL AIR SYSTEM
BCC 4B	1/26/2026	FFO	4.58	174.50	GENERATOR VOLTAGE CONTROL
BCC 4B	2/25/2026	FFO	0.18	174.50	DCS - HARDWARE PROBLEMS
BCC 4B	3/15/2026	FMO	210.97	174.50	BOROSCOPE INSPECTION
BCC 4B	5/18/2026	FMO	27.38	174.50	LUBE OIL COOLERS
BCC 4C	1/11/2026	FFO	33.52	177.50	GAS TURBINE COOLING STEAM
BCC 4C	2/14/2026	FFO	5.77	177.50	OTHER CONTROLS AND INSTRUMENTATION PROBLEMS
BCC 4C	3/4/2026	FMO	3.98	177.50	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
BCC 4C	3/17/2026	FFO	4.47	177.50	LACK OF FUEL WHERE OPERATOR IS NOT CONTROL OF DELIVERY OF FUEL
BCC 4C	3/28/2026	FFO	0.58	177.50	BLADE PATH TEMPERATURE SPREAD
BCC 4C	3/28/2026	FFO	23.63	177.50	BLADE PATH TEMPERATURE SPREAD
BCC 4C	4/6/2026	FMO	168.00	177.50	FUEL NOZZLES/VANES
BCC 4C	4/13/2026	PO	312.00	177.50	BOROSCOPE INSPECTION
BCC 4C	4/26/2026	FMO	283.37	177.50	HIGH PRESSURE BLADES/BUCKETS
BCC 4C	5/23/2026	FFO	2.17	177.50	LUBE OIL PUMPS
BCC 4D	1/9/2026	FFO	1.82	179.50	FUEL PIPING AND VALVES
BCC 4D	2/3/2026	FFO	19.88	179.50	BLADE PATH TEMPERATURE SPREAD
BCC 4D	3/17/2026	FFO	5.33	179.50	LACK OF FUEL WHERE OPERATOR IS NOT CONTROL OF DELIVERY OF FUEL
BCC 4D	3/20/2026	FMO	14.93	179.50	LUBE OIL COOLERS
BCC 4D	3/24/2026	FFO	25.23	179.50	STARTING SYSTEM (INCLUDING MOTOR)
BCC 4D	3/26/2026	FFO	4.63	179.50	FUEL PIPING AND VALVES
BCC 4D	5/20/2026	FMO	35.30	179.50	LUBE OIL COOLERS
BCC 4D	5/24/2026	FFO	0.92	179.50	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
BCC 4D	5/27/2026	FMO	21.67	179.50	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to June 2026

Bartow CC

Page 2

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4S	1/6/2026	PFO	2.83	88.00	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
BCC 4S	1/8/2026	PMO	24.00	88.00	BOROSCOPE INSPECTION
BCC 4S	1/9/2026	PFO	1.82	206.00	FUEL PIPING AND VALVES
BCC 4S	1/9/2026	PPO	495.65	88.00	BOROSCOPE INSPECTION
BCC 4S	1/10/2026	PFO	11.27	206.00	LP STARTUP BYPASS SYSTEM VALVES
BCC 4S	1/11/2026	PFO	33.52	206.00	GAS TURBINE COOLING STEAM
BCC 4S	1/26/2026	PFO	4.58	206.00	GENERATOR VOLTAGE CONTROL
BCC 4S	2/3/2026	PFO	19.88	88.00	BLADE PATH TEMPERATURE SPREAD
BCC 4S	2/4/2026	PFO	34.88	67.00	OTHER CO REDUCTION PROBLEMS
BCC 4S	2/6/2026	PMO	74.83	88.00	OTHER CO REDUCTION PROBLEMS
BCC 4S	2/14/2026	PFO	5.77	88.00	OTHER CONTROLS AND INSTRUMENTATION PROBLEMS
BCC 4S	2/25/2026	PFO	0.18	88.00	DCS - HARDWARE PROBLEMS
BCC 4S	3/10/2026	PFO	0.88	348.00	REHEAT STEAM PIPING UP TO TURBINE STOP VALVES
BCC 4S	3/10/2026	PFO	126.55	88.00	REHEAT STEAM PIPING UP TO TURBINE STOP VALVES
BCC 4S	3/16/2026	FMO	266.25	433.00	REHEAT STEAM PIPING UP TO TURBINE STOP VALVES
BCC 4S	3/28/2026	PFO	6.53	88.00	OTHER BOILER INSTRUMENTATION AND CONTROL PROBLEMS
BCC 4S	3/28/2026	PFO	704.37	88.00	BLADE PATH TEMPERATURE SPREAD
BCC 4S	3/31/2026	PFO	1.48	206.00	OTHER SWITCHYARD EQUIPMENT – EXTERNAL (OMC)
BCC 4S	4/7/2026	PFO	5.80	206.00	OTHER HP STEAM VALVES
BCC 4S	4/13/2026	PFO	5.75	206.00	BLADE PATH TEMPERATURE SPREAD
BCC 4S	4/15/2026	PFO	1.07	206.00	OTHER SWITCHYARD EQUIPMENT – EXTERNAL (OMC)
BCC 4S	4/26/2026	PMO	123.50	88.00	HIGH PRESSURE BLADES/BUCKETS
BCC 4S	5/2/2026	PMO	172.50	253.00	WATERBOX
BCC 4S	5/10/2026	PMO	151.95	253.00	WATERBOX
BCC 4S	5/18/2026	PMO	27.38	88.00	LUBE OIL COOLERS
BCC 4S	5/20/2026	PMO	35.30	88.00	LUBE OIL COOLERS
BCC 4S	5/22/2026	PMO	119.98	88.00	OTHER FEEDWATER VALVES
BCC 4S	5/24/2026	PFO	0.92	88.00	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
BCC 4S	5/27/2026	PMO	21.67	88.00	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
BCC 4S	6/1/2026	PFO	4.35	88.00	COOLING AND SEAL AIR SYSTEM
BCC 4S	6/23/2026	PFO	66.65	78.00	DRUMS AND DRUM INTERNALS

Duke Energy Florida**ACTUAL UNIT EVENT DATA - January to June 2026****Citrus County Power Block 1**

Unit	Date	Outage Type	Hours	MW Affected	Description
CITR 1A	1/23/2026	FMO	64.38	250.00	GAS TURBINE PERFORMANCE TESTING
CITR 1A	5/3/2026	PO	69.98	250.00	COOLING AND SEAL AIR SYSTEM
CITR 1B	5/3/2026	PO	110.63	250.00	BOILER INSPECTIONS – PROBLEM IDENTIFICATION/INVESTIGATION
CITR ST1	1/23/2026	PMO	64.38	152.00	GAS TURBINE PERFORMANCE TESTING
CITR ST1	5/3/2026	PO	72.20	317.00	BOILER INSPECTIONS – PROBLEM IDENTIFICATION/INVESTIGATION

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to June 2026

Citrus County Power Block 2

Unit	Date	Outage Type	Hours	MW Affected	Description
CITR 2A	1/4/2026	FMO	11.70	250.00	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEMS
CITR 2A	2/8/2026	FMO	41.77	250.00	GAS TURBINE/COMPRESSOR WASHING
CITR 2A	2/14/2026	PO	1,812.37	250.00	MAJOR OVERHAUL
CITR 2A	4/30/2026	FFO	9.83	250.00	BLADE PATH TEMPERATURE SPREAD
CITR 2A	5/20/2026	FFO	2.57	250.00	OTHER COMBUSTOR PROBLEMS
CITR 2B	2/10/2026	FMO	38.62	250.00	GAS TURBINE/COMPRESSOR WASHING
CITR 2B	2/14/2026	PO	1,820.82	250.00	MAJOR OVERHAUL
CITR ST2	1/4/2026	PMO	11.70	159.00	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEMS
CITR ST2	2/8/2026	PMO	41.77	159.00	GAS TURBINE/COMPRESSOR WASHING
CITR ST2	2/10/2026	PMO	38.62	159.00	GAS TURBINE/COMPRESSOR WASHING
CITR ST2	2/14/2026	PO	1,819.20	324.00	MAJOR OVERHAUL
CITR ST2	4/30/2026	FFO	2.25	324.00	BLADE PATH TEMPERATURE SPREAD
CITR ST2	5/20/2026	PFO	2.57	159.00	OTHER COMBUSTOR PROBLEMS

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to June 2026

Crystal River 4

Date	Outage Type	Hours	MW Affected	Description
1/12/2026	PPO	9.00	112.00	PULVERIZER MILLS
1/14/2026	PPO	12.00	112.00	PULVERIZER MILLS
1/15/2026	PFO	14.50	46.00	OTHER FEEDWATER VALVES
1/16/2026	PPO	3.00	453.00	OTHER FEEDWATER VALVES
1/24/2026	PFO	5.00	161.00	SO2 STACK EMISSIONS
1/27/2026	PMO	13.00	161.00	HEATER DRAIN PUMPS
2/10/2026	PPO	32.67	502.00	STATION SERVICE STARTUP TRANSFORMER
2/12/2026	PFO	6.00	502.00	12-15KV TRANSFORMERS
2/14/2026	PFO	0.98	502.00	BUNKER FLOW PROBLEMS
2/18/2026	PMO	54.00	405.00	FORCED DRAFT FAN MOTORS
2/23/2026	PFO	6.50	307.00	CONDENSATE/HOTWELL PUMP MOTOR
3/4/2026	PPO	25.00	112.00	PULVERIZER INSPECTION
3/12/2026	FMO	74.58	712.00	CIRCULATING WATER PIPING
3/24/2026	PMO	624.00	112.00	PULVERIZER OVERHAUL
3/25/2026	PFO	7.00	572.00	OTHER MISCELLANEOUS POLLUTION CONTROL EQUIPMENT PROBLEMS
3/28/2026	FFO	12.25	712.00	HYDRAULIC SYSTEM FILTERS
4/4/2026	PO	325.00	712.00	OTHER MISCELLANEOUS BALANCE OF PLANT PROBLEMS
4/22/2026	PFO	5.92	572.00	OTHER PIPING, DUCTING, DAMPER, AND FAN PROBLEMS
5/2/2026	PFO	1.50	502.00	OTHER HYDRAULIC SYSTEM PROBLEMS
5/2/2026	FFO	62.00	712.00	OTHER HYDRAULIC SYSTEM PROBLEMS
5/19/2026	PPO	9.50	502.00	TRANSMISSION SYSTEM PROBLEMS OTHER THAN CATASTROPHES
5/29/2026	PFO	57.50	429.00	PARTICULATE STACK EMISSIONS - FOSSIL
6/1/2026	PFO	21.00	429.00	PARTICULATE STACK EMISSIONS - FOSSIL
6/3/2026	FFO	2.75	712.00	OTHER HYDRAULIC SYSTEM PROBLEMS
6/3/2026	FFO	2.25	712.00	OTHER HYDRAULIC SYSTEM PROBLEMS
6/12/2026	PMO	3.00	112.00	PULVERIZER MILLS
6/17/2026	PMO	5.00	112.00	PULVERIZER LUBE OIL SYSTEM
6/20/2026	PMO	18.25	112.00	PULVERIZER COAL LEAK
6/28/2026	PFO	29.00	112.00	PULVERIZER FEEDERS
6/30/2026	PFO	8.50	112.00	PULVERIZER FEEDERS

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to June 2026

Crystal River 5

Date	Outage Type	Hours	MW Affected	Description
1/7/2026	PFO	4.00	110.00	PULVERIZER LUBE OIL SYSTEM
1/11/2026	PFO	3.33	110.00	PULVERIZER LUBE OIL SYSTEM
1/19/2026	PMO	10.00	500.00	FEEDWATER PUMP
1/23/2026	PFO	8.00	159.00	SO2 STACK EMISSIONS
2/9/2026	PFO	3.75	159.00	WET SCRUBBER SPRAY PUMPS AND MOTORS
2/10/2026	PPO	32.67	500.00	STATION SERVICE STARTUP TRANSFORMER
2/12/2026	PFO	6.00	500.00	12-15KV TRANSFORMERS
2/14/2026	PFO	0.98	500.00	BUNKER FLOW PROBLEMS
3/4/2026	PPO	12.00	353.00	OTHER FEEDWATER VALVES
3/6/2026	PPO	72.00	16.00	OTHER FEEDWATER VALVES
3/9/2026	FFO	17.00	710.00	OTHER HYDRAULIC SYSTEM PROBLEMS
3/10/2026	PFO	208.50	30.00	OTHER BOILER INSTRUMENTATION AND CONTROL PROBLEMS
3/11/2026	PPO	6.00	500.00	OTHER STACK OR EXHAUST EMISSIONS TESTING
3/11/2026	PPO	4.00	16.00	OTHER STACK OR EXHAUST EMISSIONS TESTING
3/19/2026	FMO	110.68	710.00	OTHER BOILER INSTRUMENTATION AND CONTROL PROBLEMS
3/23/2026	FMO	152.00	710.00	WATERWALL (FURNACE WALL)
4/18/2026	PPO	7.00	427.00	OTHER BOILER INSTRUMENTATION AND CONTROL PROBLEMS
4/22/2026	PPO	4.00	500.00	FORCED DRAFT FANS
5/7/2026	PFO	131.00	63.00	OTHER AIR SUPPLY PROBLEMS
5/13/2026	PO	124.00	710.00	OTHER AIR SUPPLY PROBLEMS
5/20/2026	PFO	112.98	63.00	AIR HEATER (REGENERATIVE)
5/20/2026	PFO	2.25	159.00	PULVERIZER FEEDERS
5/26/2026	PFO	159.00	63.00	SCR CATALYST
6/2/2026	FMO	437.00	710.00	SCR PLUGGING
6/21/2026	PFO	26.00	159.00	INDUCED DRAFT FANS
6/22/2026	FFO	150.00	710.00	INDUCED DRAFT FANS
6/29/2026	PFO	30.50	35.00	BOILER, MISCELLANEOUS

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to June 2026

Hines Power Block 2

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 2A	12/31/2025	FFO	12.00	203.00	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
HEP 2A	1/7/2026	FMO	470.00	203.00	BLOWDOWN SYSTEM PIPING
HEP 2A	1/27/2026	FMO	40.00	203.00	LP TURBINE BUCKETS OR BLADES
HEP 2A	2/6/2026	FMO	237.13	203.00	LP TURBINE BUCKETS OR BLADES
HEP 2A	2/18/2026	FFO	83.00	203.00	COMBINED CYCLE INSTRUMENTS AND CONTROLS
HEP 2A	2/22/2026	FMO	7.50	203.00	COMBINED CYCLE INSTRUMENTS AND CONTROLS
HEP 2A	2/22/2026	FMO	12.05	203.00	COMBINED CYCLE INSTRUMENTS AND CONTROLS
HEP 2A	2/25/2026	FMO	345.58	203.00	IP TURBINE DUMMY RINGS
HEP 2A	3/11/2026	FMO	20.00	203.00	OTHER TURBINE INSTRUMENT AND CONTROL PROBLEMS
HEP 2A	4/28/2026	PPO	4.00	81.00	INTAKE GRATING FOULING
HEP 2A	4/29/2026	PPO	4.00	70.00	INTAKE GRATING FOULING
HEP 2A	5/21/2026	FMO	152.18	203.00	LP TURBINE BUCKETS OR BLADES
HEP 2A	5/28/2026	FFO	808.00	203.00	LP TURBINE BUCKETS OR BLADES
HEP 2B	1/7/2026	FMO	470.00	203.00	BLOWDOWN SYSTEM PIPING
HEP 2B	2/6/2026	FMO	237.13	203.00	LP TURBINE BUCKETS OR BLADES
HEP 2B	2/18/2026	FFO	83.00	203.00	COMBINED CYCLE INSTRUMENTS AND CONTROLS
HEP 2B	2/22/2026	FMO	7.50	203.00	COMBINED CYCLE INSTRUMENTS AND CONTROLS
HEP 2B	2/22/2026	FMO	24.33	203.00	COMBINED CYCLE INSTRUMENTS AND CONTROLS
HEP 2B	2/25/2026	FMO	334.58	203.00	LP TURBINE DUMMY RINGS
HEP 2B	4/7/2026	FFO	1.00	203.00	FIRE DETECTION AND EXTINGUISHING SYSTEM
HEP 2B	4/28/2026	PPO	4.00	81.00	INTAKE GRATING FOULING
HEP 2B	4/29/2026	PPO	4.00	70.00	INTAKE GRATING FOULING
HEP 2B	5/21/2026	FMO	152.20	203.00	LP TURBINE BUCKETS OR BLADES
HEP 2B	5/28/2026	FFO	752.00	203.00	LP TURBINE BUCKETS OR BLADES
HEP 2B	6/28/2026	FFO	6.67	203.00	CONDENSER CASING OR SHELL & INTERNALS - GASKETS & SEALS
HEP 2B	6/29/2026	FFO	45.25	203.00	VIBRATION OF THE TURBINE GENERATOR UNIT
HEP ST2	1/7/2026	FMO	470.00	176.00	LP TURBINE BUCKETS OR BLADES
HEP ST2	2/6/2026	FMO	237.00	176.00	LP TURBINE BUCKETS OR BLADES
HEP ST2	2/18/2026	FFO	96.50	176.00	COMBINED CYCLE INSTRUMENTS AND CONTROLS
HEP ST2	2/22/2026	FMO	13.43	176.00	COMBINED CYCLE INSTRUMENTS AND CONTROLS
HEP ST2	2/25/2026	FMO	350.08	176.00	LP TURBINE DUMMY RINGS
HEP ST2	4/7/2026	PFO	1.00	81.00	FIRE DETECTION AND EXTINGUISHING SYSTEM
HEP ST2	4/28/2026	PPO	4.00	22.00	INTAKE GRATING FOULING
HEP ST2	4/29/2026	PPO	4.00	17.00	INTAKE GRATING FOULING
HEP ST2	5/21/2026	FMO	152.25	176.00	LP TURBINE BUCKETS OR BLADES
HEP ST2	5/28/2026	FFO	752.00	176.00	LP TURBINE BUCKETS OR BLADES
HEP ST2	6/28/2026	FFO	6.67	176.00	CONDENSER CASING OR SHELL & INTERNALS - GASKETS & SEALS
HEP ST2	6/29/2026	FFO	45.25	176.00	VIBRATION OF THE TURBINE GENERATOR UNIT

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to June 2026

Hines Power Block 3

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 3A	3/1/2026	FMO	36.00	191.00	GAS TURBINE/COMPRESSOR WASHING
HEP 3A	3/14/2026	PO	1,195.33	191.00	BALANCE OF PLANT OVERHAUL/OUTAGE
HEP 3A	5/4/2026	FMO	35.25	191.00	AUTOMATIC TURBINE CONTROL SYSTEMS - DIGITAL CONTROL AND MONITORING
HEP 3A	5/23/2026	PPO	14.27	84.00	CLOSED COOLING WATER HEAT EXCHANGERS
HEP 3A	5/24/2026	PPO	11.43	84.00	CLOSED COOLING WATER HEAT EXCHANGERS
HEP 3A	6/22/2026	FFO	34.00	191.00	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
HEP 3B	3/6/2026	FMO	6.00	191.00	GAS TURBINE/COMPRESSOR WASHING
HEP 3B	3/14/2026	PO	1,208.55	191.00	BALANCE OF PLANT OVERHAUL/OUTAGE
HEP 3B	5/3/2026	FMO	72.12	191.00	CONTRACTOR ERROR
HEP 3B	5/10/2026	FMO	78.43	191.00	FUEL PIPING AND VALVES
HEP 3B	5/23/2026	PPO	14.27	84.00	CLOSED COOLING WATER HEAT EXCHANGERS
HEP 3B	5/24/2026	PPO	11.43	84.00	CLOSED COOLING WATER HEAT EXCHANGERS
HEP ST3	3/1/2026	PMO	36.00	51.00	GAS TURBINE/COMPRESSOR WASHING
HEP ST3	3/6/2026	PMO	6.00	51.00	GAS TURBINE/COMPRESSOR WASHING
HEP ST3	3/14/2026	PO	1,234.83	176.00	BALANCE OF PLANT OVERHAUL/OUTAGE
HEP ST3	5/4/2026	FMO	36.65	176.00	AUTOMATIC TURBINE CONTROL SYSTEMS - DIGITAL CONTROL AND MONITORING
HEP ST3	5/23/2026	PPO	14.27	114.00	CLOSED COOLING WATER HEAT EXCHANGERS
HEP ST3	5/24/2026	PPO	11.43	114.00	CLOSED COOLING WATER HEAT EXCHANGERS
HEP ST3	6/22/2026	PFO	34.00	88.00	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION

Duke Energy Florida**ACTUAL UNIT EVENT DATA - January to June 2026****Hines Power Block 4**

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 4A	2/1/2026	FFO	15.88	194.00	INSTRUMENT AIR COMPRESSORS
HEP 4A	3/9/2026	FMO	1.65	194.00	OTHER EXCITER PROBLEMS
HEP 4B	2/1/2026	FFO	17.92	194.00	INSTRUMENT AIR COMPRESSORS
HEP ST4	2/1/2026	FFO	16.50	178.00	INSTRUMENT AIR COMPRESSORS

Duke Energy Florida**ACTUAL UNIT EVENT DATA - January to June 2026****Osprey CC**

Unit	Date	Outage Type	Hours	MW Affected	Description
OSP CT1	1/24/2026	PO	943.00	186.00	GENERAL UNIT INSPECTION
OSP CT1	4/30/2026	FFO	546.17	186.00	OTHER MISCELLANEOUS GENERATOR PROBLEMS
OSP CT2	1/24/2026	PO	975.55	186.00	GENERAL UNIT INSPECTION
OSP CT2	4/30/2026	FFO	551.97	186.00	OTHER MISCELLANEOUS GENERATOR PROBLEMS
OSP ST1	1/24/2026	PO	948.00	244.00	GENERAL UNIT INSPECTION
OSP ST1	4/30/2026	FFO	562.90	244.00	OTHER MISCELLANEOUS GENERATOR PROBLEMS